AMENDMENTS GROUP 101 – RESIDENTIAL CODE OF OHIO
SUMMARY of CHANGES

Ohio Administrative Code Rule Number	Paragraph/ Section	Source of Proposed Change	Reason for Proposed Change
4101:8-4-01	403.1.4.1	Petition 19-03	Brings back exceptions for frost protection
4101:8-34-01	3401.1	BBS	Adopts by reference NFPA 70 and clarifies use multi-family requirements of NFPA 70 for three family dwellings.
	3401.1 – Item #1	BBS	Relocated current modification #1 to #2. New modification #1 retains GFCI protection for 15- and 20-amp branch circuits up to 125 volts only (not 250 volts.) Follows reformatting of 210.8(A)
	3401.1 - Item #2	BBS	Renumbered exception for garage door opener from #1 to #2
	3401.1 – Item #3	BBS	Retain Ohio modification regarding GFCI protection on sump pumps and include as exception #5 under Section 210.8(A)
		BBS	Section 210.8(D) of NFPA 70 is applicable reference to section 422.5. NFPA reorganized GFCI protection for specific appliances. See NFPA 70 section 422.5 and Ohio modification 3401.1 - Item #8 below.
	3401.1 – Item #4	BBS	Follows reformatting of 210.8(F). GFCI protection not required on exterior outlets for listed hvac equipment. No sunset date.
		BBS	Section 210.12(A) is model standard language – no Ohio modifications to AFCI protection
	3401.1 – Item #5	BBS	Deleted - NFPA reorganized 210.63 and 210.64 into new section 210.63. No Ohio modifications necessary.

Ohio Administrative Code Rule Number	Paragraph/ Section	Source of Proposed Change	Reason for Proposed Change
	3401.1 – Item #5 (con't.)	BBS	Added new Item #5 to delete requirement for surge protection @ feeder supplied distribution – NFPA Section 215.18
	3401.1 – Item #6	BBS	Added new Item #6 to delete requirement for surge protection @ feeder supplied distribution – NFPA Section 225.42
	3401.1 – Item #7	BBS	Added new Item #7 to delete requirement for surge protection @ service entrance – NFPA Section 230.67
	3401.1 - Item #8	BBS	Delete sump pumps from list of specific appliances that require GFCI protetion under Section 422.5(A)
4101:8-44-01	Referenced Codes	BBS	Updates plumbing code for dwellings to OAC Chapters 4101:8-1 through 15.
	AAMA	ICC Errata	Changes date of standard 711 from "16" to "13"
	ANCE	Petition #20-11 & Daikin request	Removes ANCE organization and listed standard after that organization withdrew from standard sponsorship
	ANSI	BBS	Removes staff note from standard A108.1B
	ANSI	2021 IRC	Changes date of standard LC1/CSA 6.26 from "13" to "18"
	ASCE	ICC Errata	Changes date of standard 32 from "17" to "01"
	ASHRAE	Petition #20-11 & Daikin request	Updates standards 34 to the 2022 edition
	CSA	Petition #20-11 & Daikin request	Updates standard C22.2 No. 60335-2-40 to the 2022 edition and updates the title
	NFPA	Petition #22-01	Updates standard 70 to the 2023 edition with Ch 34 amendments
	UL	Petition #20-11 & Daikin request	Updates standard 1995 to the 2015 edition and standard 60335-2-40 to the 2022 edition and updates the title