

Ohio EPA Permit No.: 0PK00001\*ID  
Application No: OH0050016

Action Date: January 11, 2024  
Effective Date: February 1, 2024  
Expiration Date: January 31, 2029

Ohio Environmental Protection Agency  
Authorization to Discharge Under the  
National Pollutant Discharge Elimination System


In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as the "Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code Section 6111),

Scioto County Commissioners  
Wheelersburg WWTP Sewer District No. 2 WWTP

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA," to discharge from the Wheelersburg Sewer District No. 2 wastewater treatment plant, located at 2974 Hayport Road, Wheelersburg, Ohio, Scioto County, and discharging to Pine Creek in accordance with the conditions specified in Parts I, II, and III of this permit.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.



Anne M. Vogel

Anne M. Vogel  
Director

PART I, A. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and lasting until the end of the 36th month, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 – Initial

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Multiple Grab	All
00300 - Dissolved Oxygen - mg/l	-	5.0	-	-	-	-	-	1/Day	Multiple Grab	All
00530 - Total Suspended Solids - mg/l	-	-	18.0	12.0	-	81.8	54.6	3/Week	24hr Composite	All
00552 - Oil and Grease, Hexane Extr Method - mg/l	10.0	-	-	-	-	-	-	1 / 2 Weeks	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	2.50	1.50	-	11.4	6.82	3/Week	24hr Composite	Summer
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	6.0	4.0	-	27.3	18.2	3/Week	24hr Composite	Winter
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00671 - Orthophosphate, Dissolved (as P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.
01119 - Copper, Total Recoverable - ug/l	25.0	-	-	17.0	0.11	-	0.077	1/Month	24hr Composite	All
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly - Alt.
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	3/Week	Grab	Summer
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50092 - Mercury, Total (Low Level) - ng/l	-	-	-	-	-	-	-	1/Month	Grab	All
51173 - Cyanide, Free (Low-Level) - ug/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly - Alt.
61425 - Acute Toxicity, Ceriodaphnia dubia - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61426 - Chronic Toxicity, Ceriodaphnia dubia - TUc	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61427 - Acute Toxicity, Pimephales promelas - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61428 - Chronic Toxicity, Pimephales promelas - TUc	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Multiple Grab	All
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Multiple Grab	All
70300 - Residue, Total Filterable - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
80082 - CBOD 5 day - mg/l	-	-	15.0	10.0	-	68.2	45.5	3/Week	24hr Composite	All

Notes for Station Number 0PK00001001:

\* Effluent loadings based on average design flow of 1.2 MGD.

a. Mercury - See Part I, C and Part II, Item S.

b. Orthophosphate - See Part II, Item T.

- c. Free cyanide - See Part II, Item R.
- d. Biomonitoring - See Part II, Item Z.
- e. Grab sampling – See Part II, Item G.
- f. Multiple Grab sampling – see Part II, Item H.
- g. 24hr Composite sampling – See Part II, Item F.
- h. Copper – See Part II, Item V for sensitive MDL requirements.

PART I, A. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

2. During the period beginning 36 months after the effective date and lasting until the expiration date of this permit, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 – Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Multiple Grab	All
00300 - Dissolved Oxygen - mg/l	-	5.0	-	-	-	-	-	1/Day	Multiple Grab	All
00530 - Total Suspended Solids - mg/l	-	-	18.0	12.0	-	81.8	54.6	3/Week	24hr Composite	All
00552 - Oil and Grease, Hexane Extr Method - mg/l	10.0	-	-	-	-	-	-	1 / 2 Weeks	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	2.50	1.50	-	11.4	6.82	3/Week	24hr Composite	Summer
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	6.0	4.0	-	27.3	18.2	3/Week	24hr Composite	Winter
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00671 - Orthophosphate, Dissolved (as P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly - Alt.
01119 - Copper, Total Recoverable - ug/l	25.0	-	-	17.0	0.11	-	0.077	1/Month	24hr Composite	All
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly - Alt.
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	3/Week	Grab	Summer
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50092 - Mercury, Total (Low Level) - ng/l	1700	-	-	12	0.0077	-	0.000055	1/Month	Grab	All
51173 - Cyanide, Free (Low-Level) - ug/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly - Alt.
61425 - Acute Toxicity, Ceriodaphnia dubia - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61426 - Chronic Toxicity, Ceriodaphnia dubia - TUc	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61427 - Acute Toxicity, Pimephales promelas - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61428 - Chronic Toxicity, Pimephales promelas - TUc	-	-	-	-	-	-	-	1/Year	24hr Composite	September
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Multiple Grab	All
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Multiple Grab	All
70300 - Residue, Total Filterable - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
80082 - CBOD 5 day - mg/l	-	-	15.0	10.0	-	68.2	45.5	3/Week	24hr Composite	All

Notes for Station Number 0PK00001001:

\* Effluent loadings based on average design flow of 1.2 MGD.

- a. Mercury - See Part I, C and Part II, Item S.
- b. Orthophosphate - See Part II, Item T.
- c. Free cyanide - See Part II, Item R.

- d. Biomonitoring - See Part II, Item Z.
- e. Grab sampling – See Part II, Item G.
- f. Multiple Grab sampling – see Part II, Item H.
- g. 24hr Composite sampling – See Part II, Item F.
- h. Copper – See Part II, Item V for sensitive MDL requirements.

PART I, B. SSO LIMITATIONS AND MONITORING REQUIREMENTS

1. SSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittee shall monitor at Station Number 300, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - SSO Monitoring - 300 – Final

Effluent Characteristic	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	1/Month	Total	All

Notes for Station Number 0PK00001300:

- a. A sanitary sewer overflow is an overflow, spill, release, or diversion of wastewater from a sanitary sewer system. Although the above table indicates that the Measuring Frequency for Overflow Occurrence is 1/Month, the intent of that provision is to specify a reporting frequency for Overflow Occurrence, not a monitoring frequency. The monitoring requirement under this permit is that these overflows shall be monitored on each day when they discharge. Only sanitary sewer overflows that enter waters of the state, either directly or through a storm sewer or other conveyance, must be reported under this monitoring station.
- b. For the purpose of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day that enters waters of the state is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, record two occurrences for that day. If overflows from both locations continue on the following day, record two occurrences for the following day. At the end of the month, total the daily occurrences and report this number on Day 1 of the DMR. If there are no overflows during the entire month, report "zero" (0).
- c. All sanitary sewer overflows are prohibited.
- d. See Part II, Items D and E.

PART I, B. SLUDGE LIMITATIONS AND MONITORING REQUIREMENTS

2. Sludge Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittee shall monitor the treatment works' final sludge at Station Number 586, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 586 – Final

Effluent Characteristic  Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
51129 - Sludge Fee Weight - dry tons	-	-	-	-	-	-	-	1/Year	Total	December

Notes for Station Number 0PK00001586:

- a. Monitoring is required when sewage sludge is removed from the permittee's facility for disposal in a solid waste landfill. The total Sludge Fee Weight of sewage sludge disposed of in a solid waste landfill for the entire year shall be reported on the December Discharge Monitoring Report (DMR).
- b. If no sewage sludge is removed from the permittee's facility for disposal in a solid waste landfill during the year, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- c. Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.
- d. See Part II, Items N, O, P, and Q.

PART I, B. INFLUENT MONITORING REQUIREMENTS

3. Influent Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittee shall monitor the treatment works' influent wastewater at Station Number 601, and report to the Ohio EPA in accordance with the following table. Samples of influent used for determination of net values or percent removal must be taken the same day as those samples of effluent used for that determination. See Part II, OTHER REQUIREMENTS, for location of influent sampling.

Table - Influent Monitoring - 601 – Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00045 - Total Precipitation - Inches	-	-	-	-	-	-	-	1/Day	Total	All
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	3/Week	24hr Composite	All
01119 – Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
50092 - Mercury, Total (Low Level) - ng/l	-	-	-	-	-	-	-	1/Month	Grab	All
61941 - pH, Maximum - S.U.	-	-	-	-	-	-	-	1/Day	Multiple Grab	All
61942 - pH, Minimum - S.U.	-	-	-	-	-	-	-	1/Day	Multiple Grab	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	3/Week	24hr Composite	All

Notes for Station Number OPK00001601:

- a. Multiple Grab sampling – See Part II, Item H.
- b. Sampling for 601 shall coordinate same day with sampling at 001.
- c. Mercury - See Part I, C and Part II, Item S.
- d. Copper – See Part II, Item V for sensitive MDL requirements

PART I, B. UPSTREAM MONITORING REQUIREMENTS

4. Upstream Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittee shall monitor the receiving stream, upstream of the point of discharge at Station Number 801, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Upstream Monitoring - 801 – Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	-	-	-	-	-	1 / 2 Weeks	Grab	June - Aug
61432 - 48-Hr. Acute Toxicity Ceriodaphnia dubia - % Affected	-	-	-	-	-	-	-	1/Year	Grab	September
61435 - 96-Hr. Acute Toxicity Pimephales promelas-% Affected	-	-	-	-	-	-	-	1/Year	Grab	September
61438 - 7-Day Chronic Toxicity Ceriodaphnia dubia - % Affected	-	-	-	-	-	-	-	1/Year	Grab	September
61441 - 7-Day Chronic Toxicity Pimephales promelas - % Affected	-	-	-	-	-	-	-	1/Year	Grab	September

Notes for Station Number 0PK00001801:

- a. Sampling for the respective/common parameters shall occur on the same day as Outfall 001 and Monitoring Station 901.
- b. Biomonitoring - see Part II, Item Z.

Part I, B. DOWNSTREAM-NEARFIELD MONITORING REQUIREMENTS

5. Downstream-Nearfield Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date of this permit, the permittee shall monitor the receiving stream, downstream of the point of discharge, at Station Number 901, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table – Downstream-Nearfield Monitoring – 901 – Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00010 – Water Temperature – C	-	-	-	-	-	-	-	1/Month	Grab	All
00400 – pH – S.U.	-	-	-	-	-	-	-	1/Month	Grab	All
00610 – Nitrogen, Ammonia (NH3) – mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00625 – Nitrogen Kjeldahl, Total – mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00630 – Nitrite Plus Nitrate, Total – mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00665 – Phosphorus, Total (P) – mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00900 – Hardness, Total (CaCO3) – mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 – E. coli - #/100 ml	-	-	-	-	-	-	-	1 / 2 Weeks	Grab	June – Aug

Notes for Station Number 0PK00001901:

- a. Sampling for the respective/common parameters shall occur on the same day as Outfall 001 and Monitoring Station 801.

Part I, C – COMPLIANCE SCHEDULE

1. New Final Effluent Limits for Mercury

The permittee shall attain compliance with the new final effluent limits for mercury as soon as possible but not later than the dates in the following schedule:

- a. No later than 12 months after the effective date of this permit, the permittee shall submit to Ohio EPA Southeast District Office a report on the progress toward attaining compliance with the final effluent limits for mercury. At a minimum, the report shall include data from the previous twelve months and a summary of all activities completed to reduce mercury loading. (Event Code 90199)
- b. No later than 24 months after the effective date of this permit, the permittee shall submit to Ohio EPA Southeast District Office a report on the progress toward attaining compliance with the final effluent limits for mercury. At a minimum, the report shall include data from the previous twelve months and a summary of all activities completed to reduce mercury loading. Permittee may determine to submit for a mercury variance as substitute for this second report. (Event Code 90299)
- c. No later than 36 months after the effective date of this permit, the permittee shall attain compliance with the final effluent limits for mercury. The permittee shall notify Ohio EPA Southeast District Office within 14 days of attaining compliance. (Event Code 05699)

## PART II - OTHER REQUIREMENTS

### A. Operator Certification Requirements

#### 1. Classification

a. In accordance with Ohio Administrative Code 3745-7-04, the sewage treatment facility shall be classified as a Class III treatment works. The permittee shall designate one or more professional operator of record to oversee the technical operation of the treatment works with a valid certification of a class equal to or greater than the classification of the treatment works.

b. All sewerage (collection) systems that are tributary to this treatment works are Class II sewerage systems in accordance with paragraph (B)(1)(b) of rule 3745-7-04 of the Ohio Administrative Code. The permittee shall designate one or more professional operator of record to oversee the technical operation of the sewerage (collection) system with a valid certification of a class equal to or greater than the classification of the sewerage (collection) system.

#### 2. Professional Operator of Record

a. Within three days of a change in a professional operator of record, the permittee shall notify the Director of the Ohio EPA of any such change on a form acceptable to Ohio EPA. The notification can be submitted either electronically via the Ohio eBusiness Center website (<https://ebiz.epa.ohio.gov/login.html>) or hard copy. The appropriate form can be found at the following website:

<https://epa.ohio.gov/static/Portals/28/documents/opcert/Operator%20of%20Record%20Notification%20Form.pdf?ver=2018-09-11-102530-423>

b. All applications for renewal of this NPDES permit shall include an updated Operator of Record Notification form along with other necessary forms and fees to be considered a complete application.

c. The professional operator of record for a class II, III, or IV treatment works or class II sewerage system may be replaced by a backup professional operator with a certificate one classification lower than the treatment works or sewerage system for a period of up to thirty consecutive days. The use of this provision does not require notification to the agency. This provision may not be used to routinely circumvent minimum staffing requirements.

d. Upon proper justification, such as military leave or long term illness, the director may authorize the replacement of the professional operator of record for a class II, III, or IV treatment works or class II sewerage system by a backup professional operator with a certificate one classification lower than the facility for a period of greater than thirty consecutive days. Such requests shall be made in writing to the appropriate district office.

#### 3. Minimum Staffing Requirements

a. The permittee shall ensure that the treatment works professional operator of record is physically present at the facility in accordance with the minimum staffing requirements per paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code or the requirements from an approved 3745-7-04(C) minimum staffing hour reduction plan.

b. The permittee shall ensure that the collection system professional operator of record or a professional operator that is certified in the field of wastewater collection or wastewater treatment, class A operators excluded, is physically present at the collection system in accordance with the minimum staffing requirements per paragraph (C)(2) of rule 3745-7-04 of the Ohio Administrative Code.

c. If Ohio EPA approves a reduction in minimum staffing requirements based upon a facility operating plan, any change in the criteria under which the operating plan was approved (e.g., retirement of a professional operator listed in the approved staffing plan, loss of the professional operator of record, reduction in the workforce, removal or failure of automation or continuous monitoring, etc.) will require that the treatment works immediately return to the minimum staffing requirements included in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code.

#### 4. Additional Staffing Requirements

Visits to all treatment works shall be performed by the permittee, the permittee's representative, or agent five days a week and noted in the operational and maintenance records required by rule 3745-7-09 of the Administrative Code. Visits shall not be necessary when the treatment works is not in operation.

B. Description of the location of the required sampling stations are as follows:

Sampling Station	Description of Location
OPK00001001	Final effluent; Sample to be taken prior to discharge to Pine Creek (Lat: 38N 43' 06"; Long: 82W 51' 51")
OPK00001300	Reporting station for collection system sanitary sewer overflows.
OPK00001586	Sludge removed from WWTP and hauled to a sanitary landfill.
OPK00001588	Sludge removed from WWTP and hauled to another NPDES facility in an emergency.
OPK00001601	Influent monitoring station for flows entering WWTP.
OPK00001801	Upstream monitoring station on Pine Creek above mixing zone.
OPK00001901	Downstream monitoring station on Pine Creek prior to confluence with Ohio River

C. All parameters, except flow, need not be monitored on days when the plant is not normally staffed (Saturdays, Sundays, and Holidays). On those days, report "AN" on the monthly report form.

#### D. Sanitary Sewer Overflow (SSO) Reporting Requirements

A sanitary sewer overflow is an overflow, spill, release, or diversion of wastewater from a sanitary sewer system. SSOs do not include wet weather discharges from combined sewer overflows specifically listed in Part II of this NPDES permit (if any). All SSOs are prohibited.

##### 1. Reporting for SSOs That Imminently and Substantially Endanger Human Health

###### a) Immediate Notification

You must notify Ohio EPA (1-800-282-9378) and the appropriate Board of Health (i.e., city or county) within 24 hours of learning of any SSO from your sewers or from your maintenance contract areas that may imminently and substantially endanger human health. The telephone report must identify the location, estimated volume and receiving water, if any, of the overflow. An SSO that may imminently and substantially endanger human health includes dry weather overflows, major line breaks, overflow events that result in fish kills or other significant harm, overflows that expose the general public to contact with

raw sewage, and overflow events that occur in sensitive waters and high exposure areas such as protection areas for public drinking water intakes and waters where primary contact recreation occurs.

#### b) Follow-Up Written Report

Within 5 days of the time you become aware of any SSO that may imminently and substantially endanger human health, you must provide the appropriate Ohio EPA district office a written report that includes:

- (i) the estimated date and time when the overflow began and stopped or will be stopped (if known);
- (ii) the location of the SSO including an identification number or designation if one exists;
- (iii) the receiving water (if there is one);
- (iv) an estimate of the volume of the SSO (if known);
- (v) a description of the sewer system component from which the release occurred (e.g., manhole, constructed overflow pipe, crack in pipe);
- (vi) the cause or suspected cause of the overflow;
- (vii) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the overflow and a schedule of major milestones for those steps; and
- (viii) steps taken or planned to mitigate the impact(s) of the overflow and a schedule of major milestones for those steps.

An acceptable 5-day follow-up written report can be filled-in or downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance Web page at:

<https://epa.ohio.gov/divisions-and-offices/surface-water/guides-manuals/permits-program-technical-assistance>

## 2. Reporting for All SSOs, Including Those That Imminently and Substantially Endanger Human Health

### a) Discharge Monitoring Reports (DMR)

Sanitary sewer overflows that enter waters of the state, either directly or through a storm sewer or other conveyance, shall be reported on your Discharge Monitoring Reports (DMR). You must report the system-wide number of occurrences for SSOs that enter waters of the state in accordance with the requirements for station number 300. A monitoring table for this station is included in Part I, B of this NPDES permit. For the purpose of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, you should record two occurrences for that day. If overflows from both locations continue on the following day, you should record two occurrences for the following day. At the end of the month, total the daily occurrences from all locations on your system and report this number using reporting code 74062 (Overflow Occurrence, No./Month) on the 4500 form for station number 300.

### b) Annual Report

You must prepare an annual report of all SSOs in your collection system, including those that do not enter waters of the state. The annual report must be in an acceptable format (see below) and must include:

- (i) A table that lists an identification number, a location description, and the receiving water (if any) for each existing SSO. If an SSO previously included in the list has been eliminated, this shall be noted. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.

(ii) A table that lists the date that an overflow occurred, the unique ID of the overflow, the name of affected receiving waters (if any), and the estimated volume of the overflow (in millions of gallons). The annual report may summarize information regarding overflows of less than approximately 1,000 gallons.

(iii) A table that summarizes the occurrence of water in basements (WIBs) by total number and by sewershed. The report shall include a narrative analysis of WIB patterns by location, frequency and cause. Only WIBs caused by a problem in the publicly-owned collection system must be included.

Not later than March 31 of each year, you must submit one copy of the annual report for the previous calendar year. The report may be submitted electronically using the NPDES Annual Sanitary Sewer Overflow Report available through the Ohio EPA eBusiness Center, Division of Surface Water NPDES Permit Applications service. Alternatively, you may submit one hardcopy of the report to Ohio EPA Southeast District Office and one copy to: Ohio EPA; Division of Surface Water; NPDES Permit Unit; P.O. Box 1049; Columbus, OH, 43216-1049. An acceptable annual SSO report can be filled-in or downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance Web page at:

<https://epa.ohio.gov/divisions-and-offices/surface-water/guides-manuals/permits-program-technical-assistance>

You also must provide adequate notice to the public of the availability of the report. Adequate public notice would include: notices posted at the community administration building, the public library and the post office; a public notice in the newspaper; or a notice sent out with all sewer bills.

E. The permittee shall maintain in good working order and operate as efficiently as possible the "treatment works" and "sewerage system" as defined in ORC 6111.01 to achieve compliance with the terms and conditions of this permit and to prevent discharges to the waters of the state, surface of the ground, basements, homes, buildings, etc.

F. Composite samples shall be comprised of a series of grab samples collected over a 24-hour period. Such samples shall be collected at such times and locations, and in such a fashion, as to be representative of the facility's overall performance.

G. Grab samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's performance.

H. Multiple grab samples shall be comprised of at least three grab samples collected at intervals of at least three hours during the period that the plant is staffed on each day for sampling. Samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance. The critical value shall be reported.

I. The treatment works must obtain at least 85 percent removal of carbonaceous biochemical oxygen demand (five-day) and suspended solids (see Part III, Item 1).

J. If for any reason, the facility must use chlorine for disinfection, it must contact the Ohio EPA District Office, Division of Surface Water for the appropriate requirements and limitations. The permittee must state, at such time:

1. For what reason chlorine will be used for disinfection (i.e. equipment breakdown, maintenance, etc.).
2. For what length of time will it be used.

K. POTWs that accept hazardous wastes by truck, rail, or dedicated pipeline are considered to be hazardous waste treatment, storage, and disposal facilities (TSDFs) and are subject to regulation under the Resource Conservation and Recovery Act (RCRA). Under the "permit-by-rule" regulation found at 40 CFR 270.60(c), a POTW must

- 1) comply with all conditions of its NPDES permit,
- 2) obtain a RCRA ID number and comply with certain manifest and reporting requirements under RCRA,
- 3) satisfy corrective action requirements, and
- 4) meet all federal, state, and local pretreatment requirements.

L. Water quality-based permit limitations in this permit may be revised based on updated wasteload allocations or use designation rules. This permit may be modified, or revoked and reissued, to include new water quality based effluent limits or other conditions that are necessary to comply with a revised wasteload allocation, or an approved total maximum daily loads (TMDL) report as required under Section 303 (d) of the Clean Water Act.

M. Sampling for these parameters at station 0PK00001001, 0PK00001601, 0PK00001801 and 0PK00001901 shall occur the same day.

N. All disposal, use, storage, or treatment of sewage sludge by the permittee shall comply with Chapter 6111. of the Ohio Revised Code, Chapter 3745-40 of the Ohio Administrative Code and any further requirements specified in this NPDES permit, and any other actions of the Director that pertain to the disposal, use, storage, or treatment of sewage sludge by the permittee.

O. No later than March 1 of each calendar year, the permittee shall submit a report summarizing the sewage sludge disposal, use, storage, or treatment activities of the permittee during the previous calendar year. The report shall be submitted through the Ohio EPA eBusiness Center/STREAMS, Division of Surface Water NPDES Permit Applications service.

P. Each day when sewage sludge is removed from the wastewater treatment plant for use or disposal, a representative sample of sewage sludge shall be collected and analyzed for percent total solids. This value of percent total solids shall be used to calculate the total Sewage Sludge Weight (Discharge Monitoring Report code 70316) and/or total Sewage Sludge Fee Weight (Discharge Monitoring Report code 51129) removed from the treatment plant on that day. The results of the daily monitoring and the weight calculations shall be maintained on site for a minimum of five years. The test methodology used shall be from Part 2540 G of Standard Methods for the Examination of Water and Wastewater American Public Health Association, American Water Works Association, and Water Environment Federation, using the edition which is current on the issuance date of the permit. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge:  $\text{dry tons} = \text{gallons} \times 8.34 \text{ (lbs/gallon)} \times 0.0005 \text{ (tons/lb)} \times \text{decimal fraction total solids}$ .

Q. The permittee is authorized to dispose of sewage sludge by transfer to another NPDES permit holder in an emergency. Station 588 for transfer of sludge to another permit holder is included in the authorized list of station(s) in Part II, Item B of this permit, however, effluent tables are not included in Part 1.B. If this station must be used, the permittee must report the total amount of sludge taken to another facility on the permittee's Annual Sludge Report. The Discharge Monitoring Report (DMR) should not be used to report under this paragraph.

R. Monitoring for Free Cyanide (low-level)

Currently there are three approved methods for free cyanide listed in 40 CFR 136 that have a quantification level lower than any water quality-based effluent limits: ASTM D7237-10, OIA-1677-09, and ASTM D4282-02. (Note: The use of ASTM D4282-02 requires supporting documentation that it meets the requirement of a "sufficiently sensitive" test procedure as defined in 40 CFR 122.44(i)(1)(iv)). The permittee shall use one of these approved methods.

#### S. Monitoring for Mercury (low-level)

The permittee shall use either EPA Method 1631 or EPA Method 245.7 promulgated under 40 CFR 136 to comply with the effluent mercury monitoring requirements of this permit.

#### T. Monitoring for Dissolved Orthophosphate (as P)

The permittee shall monitor for dissolved orthophosphate by grab sample. The permittee shall filter the grab sample within 15 minutes of collection using a 0.45-micron filter. The filtered sample must be analyzed within 48 hours. Samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance.

#### U. Outfall Signage

The permittee shall maintain a permanent marker on the stream bank at outfall 001. The sign shall include, at a minimum, the name of the establishment to which the permit was issued, the Ohio EPA permit number, and the outfall number and a contact telephone number. The information shall be printed in letters not less than two inches in height. The sign shall be a minimum of 2 feet by 2 feet and shall be a minimum of 3 feet above ground level. The sign shall not be obstructed such that persons in boats or persons swimming on the river or someone fishing or walking along the shore cannot read the sign. Vegetation shall be periodically removed to keep the sign visible. If the outfall is normally submerged the sign shall indicate that. If the outfall is a combined sewer outfall, the sign shall indicate that untreated human sewage may be discharged from the outfall during wet weather and that harmful bacteria may be present in the water. When an existing sign is replaced or reset, the new sign shall comply with the requirements of this section.

#### V. Method Detection Limits

The permittee shall use analytical procedures approved under 40 CFR 136 with method detection limits (MDLs) less than or equal to those listed below to comply with the monitoring requirements for the following parameters:

Parameter	MDL ( $\mu\text{g/L}$ )
Copper	2

#### W. Notification to Public Water Supply Operators

1. As required by the Ohio Administrative Code 3745-33-08(F), permits for facilities designated by the director as major discharges, in the following locations, shall require the permittee to notify the public water supply operator as soon as practicable after a discharge begins that results from a spill, separate sewer overflow, bypass, upset, or combined sewer overflow that reaches waters of the state:

- a. Discharges within three thousand feet of a public water supply intake located in a lake; or
- b. Discharges within ten stream miles upstream of a public water supply intake located in a reservoir or

any other surface water of the state.

2. Public water supply operators meeting the criteria in Part II, Item W.1 above for the Wheelersburg WWTP are:

Portsmouth Water Treatment Plant  
4862 Gallia Street  
Portsmouth, OH 45662

#### X. NPDES Application Supplemental Data Submittal Requirements

a. Pursuant to Title 40 of the Code of Federal Regulations (40 CFR), Section 122.21, the permittee must sample and analyze for a list of 101 parameters, including hardness, metals, volatile organic compounds (VOCs), acid-extractable compounds, and base-neutral compounds, as part of its next NPDES permit renewal application. The permittee must provide effluent data from a minimum of three samples taken within four and one-half years prior to the date of the permit application. The complete list of parameters is contained in Table 2 of "Appendix J to Part 122 - NPDES Permit Testing Requirements for Publicly Owned Treatment Works (§122.21(j))."

b. The permittee must collect samples of effluent and analyze such samples for pollutants in accordance with analytical methods approved under 40 CFR Part 136, unless an alternative is specified in the existing NPDES permit. Except for specified pollutants (e.g. VOCs and free cyanide), 24-hour composite samples must be used. Samples must be representative of any seasonal variation in the discharge. Existing data may be used, if available, in lieu of sampling done solely for the purpose of the application.

c. The permittee shall use sufficiently sensitive analytical methods that are capable of detecting and measuring the pollutants at, or below, the respective water quality criteria or existing permit effluent limits.

d. The required analytical data shall be submitted on a form approved by the Director of Ohio EPA.

#### Y. Storm water

To comply with industrial storm water regulations, the permittee submitted a form for "No Exposure Certification" which was signed on July 5, 2022. Compliance with the industrial storm water regulations must be re-affirmed every five years. No later than July 5, 2027, the permittee must submit a new form for "No Exposure Certification" or make other provisions to comply with the industrial storm water regulations.

#### Z. Biomonitoring Program Requirements

The permittee shall continue to implement an effluent biomonitoring program to determine the toxicity of the effluent from outfall 001.

#### General Requirements

All toxicity testing conducted as required by this permit shall be done in accordance with "Reporting and Testing Guidance for Biomonitoring Required by the Ohio Environmental Protection Agency" (hereinafter, the "biomonitoring guidance"), Ohio EPA, July 1998 (or current revision). The Standard Operating Procedures (SOP) or verification of SOP submittal, as described in Section 1.B. of the

biomonitoring guidance shall be submitted no later than three months after the effective date of this permit. If the laboratory performing the testing has modified its protocols, a new SOP is required.

## Testing Requirements

### 1. Chronic Bioassays

For the duration of the permit, the permittee shall conduct chronic toxicity tests, as specified in Part I,A, using water fleas (*Ceriodaphnia dubia*) and fathead minnows (*Pimephales promelas*) on effluent samples from outfall 001. These tests shall be conducted as specified in Section 3 of the biomonitoring guidance.

### 2. Acute Bioassays

Acute endpoints, as described in Section 2.H. of the biomonitoring guidance, shall be derived from the chronic test.

### 3. Testing of Ambient Water

In conjunction with the acute and chronic toxicity tests, upstream control water shall be collected at a point outside the zone of effluent and receiving water interaction at station 0PK00001801. Testing of ambient waters shall be done in accordance with Sections 2 and 3 of the biomonitoring guidance.

### 4. Data Review

#### a. Reporting

Following completion of each bioassay requirement, the permittee shall report results of the tests in accordance with Sections 2.H.1., 2.H.2.a., 3.H.1., and 3.H.2.a. of the biomonitoring guidance, including reporting the results on the monthly DMR and submitting a copy of the complete test report to Ohio EPA, Division of Surface Water. The test report may be submitted electronically using the acute or chronic NPDES Biomonitoring Report Form available through the Ohio EPA eBusiness Center, Division of Surface Water NPDES Permit Applications service. Alternatively, the permittee may submit a hard copy of the report to Ohio EPA, Division of Surface Water, NPDES Permit Unit, P.O. Box 1049, Columbus, OH, 43216-1049.

Based on Ohio EPA's evaluation of the results, this permit may be modified to require additional biomonitoring, require a toxicity reduction evaluation, and/or contain whole effluent toxicity limits.

#### b. Definitions

TU<sub>a</sub> = Acute Toxicity Units = 100/LC50

TU<sub>c</sub> = Chronic Toxicity Units = 100/IC25

This equation for chronic toxicity units applies outside the mixing zone for warmwater, modified warmwater, exceptional warmwater, coldwater, and seasonal salmonid use designations except when the following equation is more restrictive (*Ceriodaphnia dubia* only):

TU<sub>c</sub> = Chronic Toxic Units = 100/square root of (NOEC x LOEC)

## PART III - GENERAL CONDITIONS

### 1. DEFINITIONS

"Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

"Average weekly" discharge limitation means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week. Each of the following 7-day periods is defined as a calendar week: Week 1 is Days 1 - 7 of the month; Week 2 is Days 8 - 14; Week 3 is Days 15 - 21; and Week 4 is Days 22 - 28. If the "daily discharge" on days 29, 30 or 31 exceeds the "average weekly" discharge limitation, Ohio EPA may elect to evaluate the last 7 days of the month as Week 4 instead of Days 22 - 28. Compliance with fecal coliform bacteria or *E.coli* bacteria limitations shall be determined using the geometric mean.

"Average monthly" discharge limitation means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month. Compliance with fecal coliform bacteria or *E.coli* bacteria limitations shall be determined using the geometric mean.

"85 percent removal" means the arithmetic mean of the values for effluent samples collected in a period of 30 consecutive days shall not exceed 15 percent of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.

"Absolute Limitations" Compliance with limitations having descriptions of "shall not be less than," "not greater than," "shall not exceed," "minimum," or "maximum" shall be determined from any single value for effluent samples and/or measurements collected.

"Net concentration" shall mean the difference between the concentration of a given substance in a sample taken of the discharge and the concentration of the same substances in a sample taken at the intake which supplies water to the given process. For the purpose of this definition, samples that are taken to determine the net concentration shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"Net Load" shall mean the difference between the load of a given substance as calculated from a sample taken of the discharge and the load of the same substance in a sample taken at the intake which supplies water to given process. For purposes of this definition, samples that are taken to determine the net loading shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"MGD" means million gallons per day.

"mg/l" means milligrams per liter.

"ug/l" means micrograms per liter.

"ng/l" means nanograms per liter.

"S.U." means standard pH unit.

"kg/day" means kilograms per day.

"Reporting Code" is a five digit number used by the Ohio EPA in processing reported data. The reporting code does not imply the type of analysis used nor the sampling techniques employed.

"Quarterly (1/Quarter) sampling frequency" means the sampling shall be done in the months of March, June, August, and December, unless specifically identified otherwise in the Effluent Limitations and Monitoring Requirements table.

"Yearly (1/Year) sampling frequency" means the sampling shall be done in the month of September, unless specifically identified otherwise in the effluent limitations and monitoring requirements table.

"Semi-annual (2/Year) sampling frequency" means the sampling shall be done during the months of June and December, unless specifically identified otherwise.

"Winter" shall be considered to be the period from November 1 through April 30.

"Bypass" means the intentional diversion of waste streams from any portion of the treatment facility.

"Summer" shall be considered to be the period from May 1 through October 31.

"Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

"Sewage sludge" means a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works as defined in section 6111.01 of the Revised Code. "Sewage sludge" includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes. "Sewage sludge" does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator, grit and screenings generated during preliminary treatment of domestic sewage in a treatment works, animal manure, residue generated during treatment of animal manure, or domestic septage.

"Sewage sludge weight" means the weight of sewage sludge, in dry U.S. tons, including admixtures such as liming materials or bulking agents. Monitoring frequencies for sewage sludge parameters are based on the reported sludge weight generated in a calendar year (use the most recent calendar year data when the NPDES permit is up for renewal).

"Sewage sludge fee weight" means the weight of sewage sludge, in dry U.S. tons, excluding admixtures such as liming materials or bulking agents. Annual sewage sludge fees, as per section 3745.11(Y) of the Ohio Revised Code, are based on the reported sludge fee weight for the most recent calendar year.

## 2. GENERAL EFFLUENT LIMITATION

The effluent shall, at all times, be free of substances:

- A. In amounts that will settle to form putrescent, or otherwise objectionable, sludge deposits; or that will adversely affect aquatic life or water fowl;
- B. Of an oily, greasy, or surface-active nature, and of other floating debris, in amounts that will form noticeable accumulations of scum, foam, or sheen;
- C. In amounts that will alter the natural color or odor of the receiving water to such degree as to create a nuisance;
- D. In amounts that either singly or in combination with other substances are toxic to human, animal, or aquatic life;
- E. In amounts that are conducive to the growth of aquatic weeds or algae to the extent that such growth become inimical to more desirable forms of aquatic life, or create conditions that are unsightly, or constitute a nuisance in any other fashion;
- F. In amounts that will impair designated instream or downstream water uses

## 3. FACILITY OPERATION AND QUALITY CONTROL

All wastewater treatment works shall be operated in a manner consistent with the following:

- A. At all times, the permittee shall maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee necessary to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with conditions of the permit.
- B. The permittee shall effectively monitor the operation and efficiency of treatment and control facilities and the quantity and quality of the treated discharge.
- C. Maintenance of wastewater treatment works that results in degradation of effluent quality shall be scheduled during non-critical water quality periods and shall be carried out in a manner approved by Ohio EPA as specified in the Paragraph in the PART III entitled, "UNAUTHORIZED DISCHARGES".

## 4. REPORTING

- A. Monitoring data required by this permit shall be submitted monthly on Ohio EPA 4500 Discharge Monitoring Report (DMR) forms using the electronic DMR (e-DMR) internet application. e-DMR allows permitted facilities to enter, sign, and submit DMRs on the internet. e-DMR information is found on the following web page:

<https://epa.ohio.gov/divisions-and-offices/surface-water/permitting/electronic-business-services>

- B. DMRs shall be signed by a facility's Responsible Official or a Delegated Responsible Official (i.e. a person delegated by the Responsible Official). The Responsible Official of a facility is defined as:

1. For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (a) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or (b) The manager of one or more manufacturing, production or operating facilities, provided the manager is authorized to make management decisions that govern the operation of the regulated facility including having explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

2. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or

3. In the case of a municipal, state or other public facility, by either the principal executive officer, the ranking elected official or other duly authorized employee.

For e-DMR, the person signing and submitting the DMR will need to obtain an eBusiness Center account and Personal Identification Number (PIN). Additionally, Delegated Responsible Officials must be delegated by the Responsible Official, either on-line using the eBusiness Center's delegation function, or on a paper delegation form provided by Ohio EPA. For more information on the PIN and delegation processes, please view the following web page:

<https://epa.ohio.gov/divisions-and-offices/surface-water/permitting/electronic-business-services-sub/edmr>

C. DMRs submitted using e-DMR shall be submitted to Ohio EPA by the 20th day of the month following the month-of-interest.

D. If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified in Section 5. SAMPLING AND ANALYTICAL METHODS, the results of such monitoring shall be included in the calculation and reporting of the values required in the reports specified above.

E. Analyses of pollutants not required by this permit, except as noted in the preceding paragraph, shall not be reported to the Ohio EPA, but records shall be retained as specified in Section 7. RECORDS RETENTION.

## 5. SAMPLING AND ANALYTICAL METHOD

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored flow. Test procedures for the analysis of pollutants shall conform to regulation 40 CFR 136, "Test Procedures For The Analysis of Pollutants" unless other test procedures have been specified in this permit. The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to ensure accuracy of measurements.

## 6. RECORDING OF RESULTS

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

A. The exact place and date of sampling; (time of sampling not required on EPA 4500)

- B. The person(s) who performed the sampling or measurements;
- C. The date the analyses were performed on those samples;
- D. The person(s) who performed the analyses;
- E. The analytical techniques or methods used; and
- F. The results of all analyses and measurements.

#### 7. RECORDS RETENTION

The permittee shall retain all of the following records for the wastewater treatment works for a minimum of three years except those records that pertain to sewage sludge disposal, use, storage, or treatment, which shall be kept for a minimum of five years, including:

- A. All sampling and analytical records (including internal sampling data not reported);
- B. All original recordings for any continuous monitoring instrumentation;
- C. All instrumentation, calibration and maintenance records;
- D. All plant operation and maintenance records;
- E. All reports required by this permit; and
- F. Records of all data used to complete the application for this permit for a period of at least three years, or five years for sewage sludge, from the date of the sample, measurement, report, or application.

These periods will be extended during the course of any unresolved litigation, or when requested by the Regional Administrator or the Ohio EPA. The three year period, or five year period for sewage sludge, for retention of records shall start from the date of sample, measurement, report, or application.

#### 8. AVAILABILITY OF REPORTS

Except for data determined by the Ohio EPA to be entitled to confidential status, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the appropriate district offices of the Ohio EPA. Both the Clean Water Act and Section 6111.05 Ohio Revised Code state that effluent data and receiving water quality data shall not be considered confidential.

#### 9. DUTY TO PROVIDE INFORMATION

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking, and reissuing, or terminating the permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

#### 10. RIGHT OF ENTRY

The permittee shall allow the Director or an authorized representative upon presentation of credentials and other documents as may be required by law to:

- A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit.
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
- D. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

## 11. UNAUTHORIZED DISCHARGES

A. Bypass Not Exceeding Limitations - The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 11.B and 11.C.

### B. Notice

- 1. Anticipated Bypass - If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- 2. Unanticipated Bypass - The permittee shall submit notice of an unanticipated bypass as required in paragraph 12.B (24 hour notice).

### C. Prohibition of Bypass

- 1. Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:
  - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
  - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
  - c. The permittee submitted notices as required under paragraph 11.B.
- 2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 11.C.1.

## 12. NONCOMPLIANCE NOTIFICATION

### A. Exceedance of a Daily Maximum Discharge Limit

- 1. The permittee shall report noncompliance that is the result of any violation of a daily maximum discharge limit for any of the pollutants listed by the Director in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: [sedo24hournpdes@epa.ohio.gov](mailto:sedo24hournpdes@epa.ohio.gov)  
Southwest District Office: [swdo24hournpdes@epa.ohio.gov](mailto:swdo24hournpdes@epa.ohio.gov)  
Northwest District Office: [nwdo24hournpdes@epa.ohio.gov](mailto:nwdo24hournpdes@epa.ohio.gov)  
Northeast District Office: [nedo24hournpdes@epa.ohio.gov](mailto:nedo24hournpdes@epa.ohio.gov)  
Central District Office: [cdo24hournpdes@epa.ohio.gov](mailto:cdo24hournpdes@epa.ohio.gov)  
Central Office: [co24hournpdes@epa.ohio.gov](mailto:co24hournpdes@epa.ohio.gov)

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site under the Monitoring and Reporting - Non-Compliance Notification section:

<https://epa.ohio.gov/divisions-and-offices/surface-water/permitting/individual-wastewater-discharge-permits>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330  
Southwest District Office: (800) 686-8930  
Northwest District Office: (800) 686-6930  
Northeast District Office: (800) 686-6330  
Central District Office: (800) 686-2330  
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
- b. The limit(s) that has been exceeded;
- c. The extent of the exceedance(s);
- d. The cause of the exceedance(s);
- e. The period of the exceedance(s) including exact dates and times;
- f. If uncorrected, the anticipated time the exceedance(s) is expected to continue; and,
- g. Steps taken to reduce, eliminate or prevent occurrence of the exceedance(s).

#### B. Other Permit Violations

1. The permittee shall report noncompliance that is the result of any unanticipated bypass resulting in an exceedance of any effluent limit in the permit or any upset resulting in an exceedance of any effluent limit in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.ohio.gov  
Southwest District Office: swdo24hournpdes@epa.ohio.gov  
Northwest District Office: nwdo24hournpdes@epa.ohio.gov  
Northeast District Office: nedo24hournpdes@epa.ohio.gov  
Central District Office: cdo24hournpdes@epa.ohio.gov  
Central Office: co24hournpdes@epa.ohio.gov

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site under the Monitoring and Reporting - Non-Compliance Notification section:

<https://epa.ohio.gov/divisions-and-offices/surface-water/permitting/individual-wastewater-discharge-permits>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330  
Southwest District Office: (800) 686-8930  
Northwest District Office: (800) 686-6930  
Northeast District Office: (800) 686-6330  
Central District Office: (800) 686-2330  
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
- b. The time(s) at which the discharge occurred, and was discovered;
- c. The approximate amount and the characteristics of the discharge;
- d. The stream(s) affected by the discharge;
- e. The circumstances which created the discharge;
- f. The name and telephone number of the person(s) who have knowledge of these circumstances;
- g. What remedial steps are being taken; and,
- h. The name and telephone number of the person(s) responsible for such remedial steps.

2. The permittee shall report noncompliance that is the result of any spill or discharge which may endanger human health or the environment within thirty (30) minutes of discovery by calling the 24-Hour Emergency Hotline toll-free at (800) 282-9378. The permittee shall also report the spill or discharge by e-mail or telephone within twenty-four (24) hours of discovery in accordance with B.1 above.

C. When the telephone option is used for the noncompliance reports required by A and B, the permittee shall submit to the appropriate Ohio EPA district office a confirmation letter and a completed noncompliance report within five (5) days of the discovery of the noncompliance. This follow up report is not necessary for the e-mail option which already includes a completed noncompliance report.

D. If the permittee is unable to meet any date for achieving an event, as specified in a schedule of compliance in their permit, the permittee shall submit a written report to the appropriate Ohio EPA district office within fourteen (14) days of becoming aware of such a situation. The report shall include the following:

1. The compliance event which has been or will be violated;
2. The cause of the violation;
3. The remedial action being taken;
4. The probable date by which compliance will occur; and,
5. The probability of complying with subsequent and final events as scheduled.

E. The permittee shall report all other instances of permit noncompliance not reported under paragraphs A or B of this section on their monthly DMR submission. The DMR shall contain comments that include the information listed in paragraphs A or B as appropriate.

F. If the permittee becomes aware that it failed to submit an application, or submitted incorrect information in an application or in any report to the director, it shall promptly submit such facts or information.

#### 13. RESERVED

#### 14. DUTY TO MITIGATE

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

#### 15. AUTHORIZED DISCHARGES

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than, or at a level in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit. Such violations may result in the imposition of civil and/or criminal penalties as provided for in Section 309 of the Act and Ohio Revised Code Sections 6111.09 and 6111.99.

#### 16. DISCHARGE CHANGES

The following changes must be reported to the appropriate Ohio EPA district office as soon as practicable:

A. For all treatment works, any significant change in character of the discharge which the permittee knows or has reason to believe has occurred or will occur which would constitute cause for modification or revocation and reissuance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. Notification of permit changes or anticipated noncompliance does not stay any permit condition.

B. For publicly owned treatment works:

1. Any proposed plant modification, addition, and/or expansion that will change the capacity or efficiency of the plant;
2. The addition of any new significant industrial discharge; and
3. Changes in the quantity or quality of the wastes from existing tributary industrial discharges which will result in significant new or increased discharges of pollutants.

C. For non-publicly owned treatment works, any proposed facility expansions, production increases, or process modifications, which will result in new, different, or increased discharges of pollutants.

Following this notice, modifications to the permit may be made to reflect any necessary changes in permit conditions, including any necessary effluent limitations for any pollutants not identified and limited herein. A determination will also be made as to whether a National Environmental Policy Act (NEPA) review will be required. Sections 6111.44 and 6111.45, Ohio Revised Code, require that plans for treatment works or improvements to such works be approved by the Director of the Ohio EPA prior to initiation of construction.

D. In addition to the reporting requirements under 40 CFR 122.41(l) and per 40 CFR 122.42(a), all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:

1. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit. If that discharge will exceed the highest of the "notification levels" specified in 40 CFR Sections 122.42(a)(1)(i) through 122.42(a)(1)(iv).
2. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" specified in 122.42(a)(2)(i) through 122.42(a)(2)(iv).

## 17. TOXIC POLLUTANTS

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement. Following establishment of such standards or prohibitions, the Director shall modify this permit and so notify the permittee.

## 18. PERMIT MODIFICATION OR REVOCATION

A. After notice and opportunity for a hearing, this permit may be modified or revoked, by the Ohio EPA, in whole or in part during its term for cause including, but not limited to, the following:

1. Violation of any terms or conditions of this permit;
2. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
3. Change in any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge.

B. Pursuant to rule 3745-33-04, Ohio Administrative Code, the permittee may at any time apply to the

Ohio EPA for modification of any part of this permit. The filing of a request by the permittee for a permit modification or revocation does not stay any permit condition. The application for modification should be received by the appropriate Ohio EPA district office at least ninety days before the date on which it is desired that the modification become effective. The application shall be made only on forms approved by the Ohio EPA.

#### 19. TRANSFER OF OWNERSHIP OR CONTROL

This permit may be transferred or assigned and a new owner or successor can be authorized to discharge from this facility, provided the following requirements are met:

A. The permittee shall notify the succeeding owner or successor of the existence of this permit by a letter, a copy of which shall be forwarded to the appropriate Ohio EPA district office. The copy of that letter will serve as the permittee's notice to the Director of the proposed transfer. The copy of that letter shall be received by the appropriate Ohio EPA district office sixty (60) days prior to the proposed date of transfer;

B. A written agreement containing a specific date for transfer of permit responsibility and coverage between the current and new permittee (including acknowledgement that the existing permittee is liable for violations up to that date, and that the new permittee is liable for violations from that date on) shall be submitted to the appropriate Ohio EPA district office within sixty days after receipt by the district office of the copy of the letter from the permittee to the succeeding owner;

At any time during the sixty (60) day period between notification of the proposed transfer and the effective date of the transfer, the Director may prevent the transfer if he concludes that such transfer will jeopardize compliance with the terms and conditions of the permit. If the Director does not prevent transfer, he will modify the permit to reflect the new owner.

#### 20. OIL AND HAZARDOUS SUBSTANCE LIABILITY

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

#### 21. SOLIDS DISPOSAL

Collected grit and screenings, and other solids other than sewage sludge, shall be disposed of in such a manner as to prevent entry of those wastes into waters of the state, and in accordance with all applicable laws and rules.

#### 22. CONSTRUCTION AFFECTING NAVIGABLE WATERS

This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

#### 23. CIVIL AND CRIMINAL LIABILITY

Except as exempted in the permit conditions on UNAUTHORIZED DISCHARGES or UPSETS, nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

#### 24. STATE LAWS AND REGULATIONS

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Clean Water Act.

#### 25. PROPERTY RIGHTS

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations.

#### 26. UPSET

The provisions of 40 CFR Section 122.41(n), relating to "Upset," are specifically incorporated herein by reference in their entirety. For definition of "upset," see Part III, Paragraph 1, DEFINITIONS.

#### 27. SEVERABILITY

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

#### 28. SIGNATORY REQUIREMENTS

All applications submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR 122.22.

All reports submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR Section 122.22.

#### 29. OTHER INFORMATION

A. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

B. ORC 6111.99 provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

C. ORC 6111.99 states that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

D. ORC 6111.99 provides that any person who violates Sections 6111.04, 6111.042, 6111.05, or division (A) of Section 6111.07 of the Revised Code shall be fined not more than \$25,000 or imprisoned not more than one year, or both.

### 30. NEED TO HALT OR REDUCE ACTIVITY

40 CFR 122.41(c) states that it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with conditions of this permit.

### 31. APPLICABLE FEDERAL RULES

All references to 40 CFR in this permit mean the version of 40 CFR which is effective as of the effective date of this permit.

### 32. AVAILABILITY OF PUBLIC SEWERS

Notwithstanding the issuance or non-issuance of an NPDES permit to a semi-public disposal system, whenever the sewage system of a publicly owned treatment works becomes available and accessible, the permittee operating any semi-public disposal system shall abandon the semi-public disposal system and connect it into the publicly owned treatment works.

National Pollutant Discharge Elimination System (NPDES) Permit Program

FACT SHEET

Regarding an NPDES Permit to Discharge to Waters of the State of Ohio  
for Wheelersburg Wastewater Treatment Plant (WWTP) Sewer District No. 2

Public Notice No.: 192961  
Public Notice Date: December 11, 2023  
Comment Period Ends: January 10, 2024

Ohio EPA Permit No.: OPK00001\*ID  
Application No.: OH0050016

Name and Address of Applicant:  
Scioto County Commissioners  
602 7<sup>th</sup> Street  
Portsmouth, OH 45662

Name and Address of Facility Where  
Discharge Occurs:  
Wheelersburg WWTP Sewer District No. 2  
2974 Hayport Road  
Wheelersburg, OH 45694  
Scioto County

Receiving Water: Pine Creek

Subsequent Stream Network: Ohio River

**INTRODUCTION**

Development of a Fact Sheet for NPDES permits is mandated by Title 40 of the Code of Federal Regulations (CFR), Section 124.8 and 124.56. This document fulfills the requirements established in those regulations by providing the information necessary to inform the public of actions proposed by the Ohio Environmental Protection Agency (Ohio EPA), as well as the methods by which the public can participate in the process of finalizing those actions.

This Fact Sheet is prepared in order to document the technical basis and risk management decisions that are considered in the determination of water quality based NPDES Permit effluent limitations. The technical basis for the Fact Sheet may consist of evaluations of promulgated effluent guidelines, existing effluent quality, instream biological, chemical and physical conditions, and the relative risk of alternative effluent limitations. This Fact Sheet details the discretionary decision-making process empowered to the Director by the Clean Water Act (CWA) and Ohio Water Pollution Control Law (Ohio Revised Code [ORC] 6111). Decisions to award variances to Water Quality Standards (WQS) or promulgated effluent guidelines for economic or technological reasons will also be justified in the Fact Sheet where necessary.

Antidegradation provisions in Ohio Administrative Code (OAC) Chapter 3745-1 describe the conditions under which water quality may be lowered in surface waters. No antidegradation review was necessary.

Effluent limits based on available treatment technologies are required by Section 301(b) of the CWA. Many of these have already been established by the United States Environmental Protection Agency (U.S. EPA) in the effluent guideline regulations (a.k.a. categorical regulations) for industry categories in 40 CFR Parts 405-499. Technology-based regulations for publicly-owned treatment works are listed in the Secondary Treatment Regulations (40 CFR Part 133). If regulations have not been established for a category of dischargers, the director may establish technology-based limits based on best professional judgment (BPJ).

Ohio EPA reviews the need for water-quality-based limits on a pollutant-by-pollutant basis. Wasteload allocations (WLAs) are used to develop these limits based on the pollutants that have been detected in the discharge, and the receiving water's assimilative capacity. The assimilative capacity depends on the flow in the water receiving the discharge, and the concentration of the pollutant upstream. The greater the upstream flow, and the lower the upstream concentration, the greater the assimilative capacity is. Assimilative capacity may represent dilution (as in allocations for metals), or it may also incorporate the break-down of pollutants in the receiving water (as in allocations for oxygen-demanding materials).

The need for water-quality-based limits is determined by comparing the WLA for a pollutant to a measure of the effluent quality. The measure of effluent quality is called Projected Effluent Quality (PEQ). This is a statistical measure of the average and maximum effluent values for a pollutant. As with any statistical method, the more data that exists for a given pollutant, the more likely that PEQ will match the actual observed data. If there is a small data set for a given pollutant, the highest measured value is multiplied by a statistical factor to obtain a PEQ; for example if only one sample exists, the factor is 6.2, for two samples - 3.8, for three samples - 3.0. The factors continue to decline as samples sizes increase. These factors are intended to account for effluent variability, but if the pollutant concentrations are fairly constant, these factors may make PEQ appear larger than it would be shown to be if more sample results existed.

### **SUMMARY OF PERMIT CONDITIONS**

The effluent limits and/or monitoring requirements proposed for all parameters are the same as in the current permit, except those listed below.

New effluent limits are proposed for mercury because reasonable potential exists to exceed water quality standards. A compliance schedule has been proposed to address the evaluation of a mercury variance and plant operations to comply with the proposed limits. Influent mercury monitoring is proposed.

Limits are proposed to be removed for cadmium and lead because no reasonable potential exists to exceed water quality standards. Monitoring is proposed to continue.

Annual chronic toxicity monitoring with the determination of acute endpoints is proposed for the life of the permit. This satisfies the minimum testing requirements of Ohio Administrative Code (OAC) 3754-33-07(B)(11) and will adequately characterize toxicity in the plant's effluent.

Monitoring for temperature, pH and dissolved oxygen is proposed to be removed at upstream monitoring station 801 because this data is not used for reasonable potential analyses.

Monitoring for dissolved oxygen is proposed to be removed at downstream monitoring station 901 because this data is not used for reasonable potential analyses.

Monitoring for E. coli at station 801 and 901 is proposed to change to once per two weeks for the months of June through August. The modified frequency will facilitate assessment in the receiving stream.

To ensure that data is obtained that allows Ohio EPA to make water quality-related decisions regarding copper, a special condition is proposed in Part II of the permit that provides guidance on the analytical method detection limits (MDLs) the permittee should use in analyzing for these contaminants. In addition, influent copper monitoring is proposed.

In Part II of the permit, special conditions are included that address sanitary sewer overflow (SSO) reporting; operator certification, minimum staffing and operator of record; whole effluent toxicity (WET) testing; stormwater compliance; downstream public water supply notification; supplemental effluent data; and outfall signage.

## Table of Contents

	Page
INTRODUCTION.....	1
SUMMARY OF PERMIT CONDITIONS .....	2
PROCEDURES FOR PARTICIPATION IN THE FORMULATION OF FINAL DETERMINATIONS.....	4
INFORMATION REGARDING CERTAIN WATER QUALITY BASED EFFLUENT LIMITS.....	4
LOCATION OF DISCHARGE/RECEIVING WATER USE CLASSIFICATION.....	6
FACILITY DESCRIPTION.....	6
DESCRIPTION OF EXISTING DISCHARGE .....	7
ASSESSMENT OF IMPACT ON RECEIVING WATERS .....	8
DEVELOPMENT OF WATER-QUALITY-BASED EFFLUENT LIMITS .....	9
REASONABLE POTENTIAL/EFFLUENT LIMITS/MANAGEMENT DECISIONS .....	12
OTHER REQUIREMENTS.....	14

### List of Figures

Figure 1. Location of Wheelersburg WWTP Sewer District No. 2 .....	16
Figure 2. Aerial Image of Wheelersburg WWTP Sewer District No. 2.....	16
Figure 3. Diagram of Wastewater Treatment System.....	17

### List of Tables

Table 1. Sewage Sludge Removal.....	18
Table 2. Effluent Violations for Outfall 001 .....	18
Table 3. Average Annual Effluent Flow Rates .....	18
Table 4. Effluent Characterization Using Supplemental Data from 2022 NPDES Application and Ohio EPA Sampling Data.....	19
Table 5. Effluent Characterization Using Self-Monitoring Data .....	20
Table 6. Projected Effluent Quality for Outfall 001.....	23
Table 7. Summary of Acute and Chronic Toxicity Results .....	24
Table 8. Summary of Acute Toxicity Results from Ohio EPA sampling .....	24
Table 9. Use Attainment Table .....	24
Table 10. Water Quality Criteria in the Study Area.....	25
Table 11. Instream Conditions and Discharger Flow.....	26
Table 12. Summary of Effluent Limits to Maintain Applicable Water Quality Criteria.....	28
Table 13. Parameter Assessment.....	29
Table 14. Final Effluent Limits for Outfall 001 .....	30

### List of Attachments

Attachment 1 Whole Effluent Toxicity Reasonable Potential Analysis .....	32
--	----

### List of Addendums

Addendum 1. Acronyms .....	34
----------------------------	----

## PROCEDURES FOR PARTICIPATION IN THE FORMULATION OF FINAL DETERMINATIONS

The draft action shall be issued as a final action unless the Director revises the draft after consideration of the record of a public meeting or written comments, or upon disapproval by the Administrator of the U.S. Environmental Protection Agency.

Within thirty days of the date of the Public Notice, any person may request or petition for a public meeting for presentation of evidence, statements or opinions. The purpose of the public meeting is to obtain additional evidence. Statements concerning the issues raised by the party requesting the meeting are invited. Evidence may be presented by the applicant, the state, and other parties, and following presentation of such evidence other interested persons may present testimony of facts or statements of opinion.

Requests for public meetings shall be in writing and shall state the action of the Director objected to, the questions to be considered, and the reasons the action is contested. Such requests should be emailed to [HClerk@epa.ohio.gov](mailto:HClerk@epa.ohio.gov) or mailed to:

**Legal Records Section  
Ohio Environmental Protection Agency  
P.O. Box 1049  
Columbus, Ohio 43216-1049**

Interested persons are invited to submit written comments upon the discharge permit. Comments should be submitted by email to [epa.dswcomments@epa.ohio.gov](mailto:epa.dswcomments@epa.ohio.gov) (preferred method) or delivered in person or by mail no later than 30 days after the date of this Public Notice. Deliver or mail all comments to:

**Ohio Environmental Protection Agency  
Attention: Division of Surface Water  
Permits Processing Unit  
P.O. Box 1049  
Columbus, Ohio 43216-1049**

The Ohio EPA permit number and Public Notice numbers should appear on each page of any submitted comments. All comments received no later than 30 days after the date of the Public Notice will be considered.

Citizens may conduct file reviews regarding specific companies or sites. Appointments are necessary to conduct file reviews, because requests to review files have increased dramatically in recent years. The first 250 pages copied are free. For requests to copy more than 250 pages, there is a five-cent charge for each page copied. Payment is required by check or money order, made payable to Treasurer State of Ohio.

For additional information about this fact sheet or the draft permit, contact Aaron Pennington, 740-380-5272, [aaron.pennington@epa.ohio.gov](mailto:aaron.pennington@epa.ohio.gov).

## INFORMATION REGARDING CERTAIN WATER QUALITY BASED EFFLUENT LIMITS

This draft permit may contain proposed water-quality-based effluent limits (WQBELs) for parameters that **are not** priority pollutants. (See the following link for a list of the priority pollutants: [https://epa.ohio.gov/static/Portals/35/pretreatment/Pretreatment\\_Program\\_Priority\\_Pollutant\\_Detection\\_Limits.pdf](https://epa.ohio.gov/static/Portals/35/pretreatment/Pretreatment_Program_Priority_Pollutant_Detection_Limits.pdf).) In accordance with ORC 6111.03(J)(3), the Director established these WQBELs after considering, to the extent consistent with the Federal Water Pollution Control Act, evidence relating to the technical feasibility and economic reasonableness of removing the polluting properties from those wastes and to evidence relating to conditions calculated to result from that action and their relation to benefits to the people of the state and to

accomplishment of the purposes of this chapter. This determination was made based on data and information available at the time the permit was drafted, which included the contents of the timely submitted NPDES permit renewal application, along with any and all pertinent information available to the Director.

This public notice allows the permittee to provide to the Director for consideration during this public comment period additional site-specific pertinent and factual information with respect to the technical feasibility and economic reasonableness for achieving compliance with the proposed final effluent limitations for these parameters. The permittee shall email to [epa.dswcomments@epa.ohio.gov](mailto:epa.dswcomments@epa.ohio.gov) (preferred method) or deliver or mail this information to:

**Ohio Environmental Protection Agency**  
**Attention: Division of Surface Water**  
**Permits Processing Unit**  
**P.O. Box 1049**  
**Columbus, Ohio 43216-1049**

Should the applicant need additional time to review, obtain or develop site-specific pertinent and factual information with respect to the technical feasibility and economic reasonableness of achieving compliance with these limitations, a written request for any additional time shall be sent to the above address no later than 30 days after the Public Notice Date on Page 1.

Should the applicant determine that compliance with the proposed WQBELs for parameters other than the priority pollutants is technically and/or economically unattainable, the permittee may submit an application for a variance to the applicable WQS used to develop the proposed effluent limitation in accordance with the terms and conditions set forth in OAC 3745-33-07(D). The permittee shall submit this application to the above address no later than 30 days after the Public Notice Date.

Alternately, the applicant may propose the development of site-specific WQS pursuant to OAC 3745-1-39. The permittee shall submit written notification regarding their intent to develop site specific WQS for parameters that are not priority pollutants to the above address no later than 30 days after the Public Notice Date.

## LOCATION OF DISCHARGE/RECEIVING WATER USE CLASSIFICATION

Wheelersburg WWTP discharges to Pine Creek at River Mile 1.05. Figure 1 and Figure 2 show the approximate location of the facility.

This segment of the Pine Creek is described by Hydrologic Unit Code: OH050901030205, County: Scioto, Ecoregion: Western Allegheny Plateau. The Pine Creek is designated for the following uses under Ohio's WQS (OAC 3745-1-16): Warmwater Habitat, State Resource Water, Agricultural Water Supply, Industrial Water Supply, and Primary Contact Recreation. Pine Creek discharges to Ohio River. Ohio River is designated for the following uses under Ohio's WQS (OAC 3745-1-32): Warmwater Habitat, Agricultural Water Supply, Industrial Water Supply, Bathing Waters, Public Water Supply.

Use designations define the goals and expectations of a waterbody. These goals are set for aquatic life protection, recreation use and water supply use, and are defined in the Ohio WQS (OAC 3745-1-07). The use designations for individual waterbodies are listed in rules -08 through -32 of the Ohio WQS. Once the goals are set, numeric WQS are developed to protect these uses. Different uses have different water quality criteria.

Use designations for aquatic life protection include habitats for coldwater fish and macroinvertebrates, warmwater aquatic life and waters with exceptional communities of warmwater organisms. These uses all meet the goals of the federal CWA. Ohio WQS also include aquatic life use designations for waterbodies which cannot meet the CWA goals because of human-caused conditions that cannot be remedied without causing fundamental changes to land use and widespread economic impact. The dredging and clearing of some small streams to support agricultural or urban drainage is the most common of these conditions. These streams are given Modified Warmwater or Limited Resource Water designations.

Recreation uses are defined by the depth of the waterbody and the potential for wading or swimming. Uses are defined for bathing waters, swimming/canoeing (Primary Contact Recreation) and wading only (Secondary Contact which are generally waters too shallow for swimming or canoeing).

Water supply uses are defined by the actual or potential use of the waterbody. Public Water Supply designations apply near existing water intakes so that waters are safe to drink with standard treatment. Most other waters are designated for agricultural water supply and industrial water supply.

## FACILITY DESCRIPTION

Wheelersburg WWTP was constructed in 1973 and last upgraded in 2003. In 2021, the facility replaced influent mechanical screening and a flow splitter box. The average design flow is 1.2 million gallons per day (MGD). Wheelersburg WWTP serves the Scioto County Sewer District No. 2 comprised of Wheelersburg and areas extended into Franklin Furnace. Wheelersburg WWTP has the following treatment processes (Figure 3):

- Influent pumping
- Communion
- Mechanical Screening
- Activated sludge – extended aeration (oxidation ditches)
- Secondary clarification
- Ultraviolet disinfection

Wheelersburg WWTP had piping serving as a plant bypass at the headworks that had been filled with grout and abandoned prior the last permit issuance. The newly constructed flow splitter no longer has a connection to the

former bypass pipe. The bypass is no longer in use. The sewer district has 100% separate sewers in the collection system.

Wheelersburg WWTP does not have an approved pretreatment program. Wheelersburg WWTP has one significant non-categorical user that discharges 0.12 MGD of flow.

Potable water for the sewered service area comes from a combination of sources served by Scioto Water, Inc with a groundwater supply and the City of Portsmouth with a surface water supply.

Wheelersburg WWTP utilizes the following sewage sludge treatment processes:

- Aerobic Digestion
- Mechanical Dewatering
- Sludge Drying Beds (available, but not sized to handle full volume of sludge)

Table 1 shows the last five years of sludge removed from Wheelersburg WWTP. Treated sludge is hauled for disposal at a municipal solid waste landfill.

Wheelersburg WWTP is subject to the following additional conditions: a Director's Final Findings and Orders (DFFOs) for installing new headworks without a Permit to Install. DFFOs have been resolved.

## **DESCRIPTION OF EXISTING DISCHARGE**

Table 2 presents the effluent violations for Wheelersburg WWTP during the previous five years. These violations were most likely caused by a combination of factors including reported issues of septage handling facility discharging into to the collection system, excessive receipt of septage at the WWTP, restrictions on amount of sludge quantities being set by receiving landfill, and mechanical breakdown of sludge press. These violations have been resolved by addressing the septage handling facility within the collection system, restricting septage at the WWTP, increasing the amount of sludge being hauled to the landfill and improvements to the sludge press.

Table 3 presents the average annual effluent flow rate for Wheelersburg WWTP for the previous five years. Wheelersburg WWTP estimates there is an infiltration/inflow (I/I) rate to the collection system of 0.075 MGD. Wheelersburg WWTP performs the following activities to minimize I/I: regular sewer inspections, regular sewer repairs, etc.

SSOs are reported at station 300. No SSOs were reported over the past five years.

Table 4 presents chemical specific data compiled from supplemental effluent testing data submitted as part of the NPDES renewal application. Table 4 includes a column with chemical specific data compiled from data collected by Ohio EPA.

Table 5 presents a summary of unaltered Discharge Monitoring Report (DMR). Data are presented for the period January 2018 through December 2022 and current permit limits are provided for comparison.

Table 6 summarizes the chemical specific data for outfall 001 by presenting the average and maximum PEQ values.

Table 7 summarizes the DMR reported results of acute and chronic Whole Effluent Toxicity (WET) tests of the final effluent, using the water flea (*Ceriodaphnia dubia*) and fathead minnow (*Pimephales promelas*) as test organisms.

Table 8 summarizes the acute toxicity results collected by Ohio EPA.

## ASSESSMENT OF IMPACT ON RECEIVING WATERS

Pursuant to Section 303(d) of the Clean Water Act, each state is required to develop and submit a list to US EPA of its impaired and threatened waters (e.g. stream/river segments, lakes). For each water on the list, the state identifies the pollutant(s) causing the impairment, when known. The Lick Run- Pine Creek watershed assessment unit, which includes the Pine Creek in the vicinity of Wheelersburg WWTP, is listed as impaired for aquatic life on Ohio's 303(d) list.

The attainment status of Pine Creek is reported in the Final *Ohio 2022 Integrated Water Quality Monitoring and Assessment Report*. An assessment of the impact of a permitted point source on the immediate receiving waters includes an evaluation of the available chemical/physical, biological, and habitat data which have been collected by Ohio EPA pursuant to the Five-Year Basin Approach for Monitoring and NPDES Reissuance. Other data may be used provided it was collected in accordance with Ohio EPA methods and protocols as specified by the Ohio WQS and Ohio EPA guidance documents. Other information which may be evaluated includes, but is not limited to: NPDES permittee self-monitoring data; effluent and mixing zone bioassays conducted by Ohio EPA, the permittee, or U.S. EPA.

In evaluating this data, Ohio EPA attempts to link environmental stresses and measured pollutant exposure to the health and diversity of biological communities. Stresses can include pollutant discharges (permitted and unpermitted), land use effects, and habitat modifications. Indicators of exposure to these stresses include whole effluent toxicity tests, fish tissue chemical data, and fish health biomarkers (for example, fish blood tests).

Use attainment is a term which describes the degree to which environmental indicators are either above or below criteria specified by the Ohio WQS (OAC 3745-1). Assessing use attainment status for aquatic life uses primarily relies on the Ohio EPA biological criteria (OAC 3745-1-07; Table 7-1). These criteria apply to rivers and streams outside of mixing zones. Numerical biological criteria are based on measuring several characteristics of the fish and macroinvertebrate communities; these characteristics are combined into multimetric biological indices including the Index of Biotic Integrity and modified Index of Well-Being, which indicate the response of the fish community, and the Invertebrate Community Index, which indicates the response of the macroinvertebrate community. Numerical criteria are broken down by ecoregion, use designation, and stream or river size. Ohio has five ecoregions defined by common topography, land use, potential vegetation and soil type.

Three attainment status results are possible at each sampling location -full, partial, or non-attainment. Full attainment means that all of the applicable indices meet the biocriteria. Partial attainment means that one or more of the applicable indices fails meet the biocriteria. Nonattainment means that either none of the applicable indices meet the biocriteria or one of the organism groups indicates poor or very poor performance. An aquatic life use attainment table (see Table 9) is constructed based on the sampling results and is arranged from upstream to downstream and includes the sampling locations indicated by river mile, the applicable biological indices, the use attainment status (i.e., full, partial, or non), the Qualitative Habitat Evaluation Index, and comments and observations for each sampling location.

The most recent data available for Pine Creek is from 2010-2011. Lick Run - Pine Creek is impaired due to sedimentation/siltation. However, Pine Creek was considered to be in full attainment for aquatic life in the vicinity and downstream of the Wheelersburg WWTP. This indicates that Wheelersburg WWTP is not contributing to the impairments in Pine Creek. No additional limits are recommended for Wheelersburg WWTP.

The full Integrated Report is available through the Ohio EPA, Division of Surface Water website at:

<https://epa.ohio.gov/static/Portals/35/tmdl/2022intreport/Full-2022-IR.pdf>

The most recent biological and water quality study is available through the Ohio EPA, Division of Surface Water website at:

[https://epa.ohio.gov/static/Portals/35/documents/SEORT\\_TSD\\_2010.pdf](https://epa.ohio.gov/static/Portals/35/documents/SEORT_TSD_2010.pdf)

## **DEVELOPMENT OF WATER-QUALITY-BASED EFFLUENT LIMITS**

Determining appropriate effluent concentrations is a multiple-step process in which parameters are identified as likely to be discharged by a facility, evaluated with respect to Ohio water quality criteria, and examined to determine the likelihood that the existing effluent could violate the calculated limits.

### **Parameter Selection**

Effluent data for the Wheelersburg WWTP were used to determine what parameters should undergo WLA. The parameters discharged are identified by the data available to Ohio EPA, DMR data submitted by the permittee, compliance sampling data collected by Ohio EPA, and any other data submitted by the permittee, such as priority pollutant scans required by the NPDES application or by pretreatment, or other special conditions in the NPDES permit. The sources of effluent data used in this evaluation are as follows:

Self-monitoring data (DMR)	January 2018 through December 2022
NPDES renewal application data	2022 and 2023
Ohio EPA compliance sampling data	2022

### **Statistical Outliers and Other Non-representative Data**

The data were examined and the following values were removed from the evaluation as non-representative data:

Zinc – 355 µg/l, 11/7/2019, value was nearly 3 times larger than the next highest value of 133 µg/l within a dataset of 61 results and improved the r-squared value to >0.95. The r-squared value was less than 0.95 prior to removing the outlier.

Mercury – 127 ng/l, 8/5/21, value was nearly 3 times larger than the next highest value of 38.7 ng/l within a dataset of 48 results and improved the r-squared value to >0.95. The r-squared value was less than 0.95 prior to removing the outlier.

This data is evaluated statistically, and PEQ values are calculated for each pollutant. Average PEQ (PEQ<sub>avg</sub>) values represent the 95<sup>th</sup> percentile of monthly average data, and maximum PEQ (PEQ<sub>max</sub>) values represent the 95<sup>th</sup> percentile of all data points (see Table 6). See Modeling Guidance #1 for more information on PEQ calculations, available through the Ohio EPA, Division of Surface Water website at:

<https://www.epa.ohio.gov/portals/35/guidance/model1.pdf>

The PEQ values are used according to Ohio rules to compare to applicable WQS and allowable WLA values for each pollutant evaluated. Initially, PEQ values are compared to the applicable average and maximum WQS. If both PEQ values are less than 25 percent of the applicable WQS, the pollutant does not have the reasonable potential to cause or contribute to exceedances of WQS, and no WLA is done for that parameter. If either PEQ<sub>avg</sub> or PEQ<sub>max</sub> is greater than 25 percent of the applicable WQS, a WLA is conducted to determine whether the parameter exhibits reasonable potential and needs to have a limit or if monitoring is required (see Table 10).

### **Wasteload Allocation**

For those parameters that require a WLA, the results are based on the uses assigned to the receiving waterbody in OAC 3745-1. Dischargers are allocated pollutant loadings/concentrations based on the Ohio WQS (OAC 3745-1). Most pollutants are allocated by a mass-balance method because they do not break down in the receiving water. By rule, mixing zones are not authorized for pollutants, such as mercury, which have been

designated as bioaccumulative chemicals of concern (BCCs). For BCCs, the WLA is set equal to the respective WQS value.

The methodology employed generally depends on whether the facility is considered a direct discharger to a (1) free-flowing receiving water/stream or (2) non-flowing receiving water/Lake.

For free flowing streams, WLAs for both average and maximum criteria are performed using the following general equation:

$$\text{Discharger WLA} = (\text{Downstream Flow} \times \text{WQS}) - (\text{Upstream Flow} \times \text{Background Concentration}).$$

Discharger WLAs are divided by the discharge flow so that the allocations are expressed as concentrations.

The applicable waterbody uses for this facility’s discharge and the associated stream design flows are as follows:

Aquatic life (Warmwater Habitat)		
Toxics (metals, organics, etc.)	Average	Annual 7Q10
	Maximum	Annual 1Q10
Ammonia	Average	Summer 30Q10
		Winter 30Q10
Wildlife		Annual 90Q10
Agricultural Water Supply		Harmonic mean flow
Human Health (nondrinking)		Harmonic mean flow

Allocations are developed using a percentage of stream design flow as specified in Table 11, and allocations cannot exceed the Inside Mixing Zone Maximum (IMZM) criteria.

The data used in the WLA are listed in Table 10 and Table 11. The WLA results to maintain all applicable criteria are presented in Table 12.

**Whole Effluent Toxicity Wasteload Allocation**

Whole effluent toxicity (WET) is the total toxic effect of an effluent on aquatic life measured directly with a toxicity test. Acute WET measures short term effects of the effluent while chronic WET measures longer term and potentially more subtle effects of the effluent.

WQS for WET are expressed in Ohio’s narrative “free from” WQS rule [OAC 3745-1-04(D)]. These “free froms” are translated into toxicity units (i.e. TUA and TUC) by the associated WQS Implementation Rule (OAC 3745-2-09). The translation results in a numeric value of 0.3 TUA and 1.0 TUC. WLAs can then be calculated using these values as if they were water quality criteria.

There are two separate reasonable potential procedures in Ohio - one for the Lake Erie watershed and one for the Ohio River watershed. Dischargers in the Ohio River watershed are assessed using OAC 3745-33-07(B). Dischargers in the Lake Erie watershed are assessed in accordance with the “Great Lakes Water Quality Initiative Implementation Procedures” contained in 40 CFR Part 132, Appendix F, Procedure 6.

The WLA calculations for WET are similar to those for aquatic life criteria - using the chronic toxicity unit (TUC) and 7Q10 flow for the average and the acute toxicity unit (TUA) and 1Q10 flow for the maximum. WET WLAs are based on meeting the values of 0.3 TUA and 1.0 TUC downstream of the discharge, and include any

available dilution. These values are the levels of effluent toxicity that should not cause instream toxicity during critical low-flow conditions. WLAs for acute toxicity are capped at 1.0 TUa unless the discharger demonstrates that an Area-of-Initial-Mixing (AIM) exists under OAC 3745-1-06, or that one of the factors in OAC 3745-33-07(B)(5)-(9) allows a higher TUa limit to be granted. For the purposes of establishing WET limitations, the values of 1.0 TUa and 1.0 TUc are the most restrictive limitations that can be applied in NPDES permits [OAC 3745-33-07(B)(10)].

For Wheelersburg WWTP, the WLA values for outfall 001 are 0.4 TUa and 1.43 TUc.

In accordance with OAC 3745-33-07(B)(11)(c), TUc criteria are generally applied when the available mixing zone dilution is less than twenty to one. According to the data in Table 11, the available dilution ratio for Wheelersburg WWTP to Pine Creek is approximately 1.43 to one.

$$\text{Chronic Dilution Ratio} = ([7Q10 * \% \text{ as applicable per OAC 3745-2-05}] + [\text{Outfall flow rate}]) / [\text{Outfall flow rate}] = (0.8 \text{ cfs} * 100\% + 1.86 \text{ cfs}) / 1.86 \text{ cfs} = 1.43 \text{ cfs}$$

The chronic toxicity unit (TUc) is defined as 100 divided by the estimate of the effluent concentration which causes a 25% reduction in growth or reproduction of test organisms (IC25):

$$TUc = 100/IC25$$

This equation applies outside the mixing zone for warmwater, modified warmwater, exceptional warmwater, coldwater, and seasonal salmonid use designations except when the following equation is more restrictive (Ceriodaphnia dubia only):

$$TUc = 100/\text{geometric mean of No Observed Effect Concentration and Lowest Observed Effect Concentration}$$

The acute toxicity unit (TUa) is defined as 100 divided by the concentration in water having 50% chance of causing death to aquatic life (LC50) for the most sensitive test species:

$$TUa = 100/LC50$$

This equation applies outside the mixing zone for all designated waters. Based on the above, a value of 1.0 TUa is the lowest value that can be calculated using the equation. TUa values between 0.2 and 1.0 are based on an interpolation of toxic effects where an LC50 cannot be identified.

When the acute WLA is less than 1.0 TUa, it may be defined as a ratio of the stream dilution to the effluent flow:

Acute Dilution Ratio ( <u>downstream flow to discharger flow</u> )	Allowable Effluent Toxicity ( <u>percent effects in 100% effluent</u> )
up to 2 to 1	30
greater than 2 to 1 but less than 2.7 to 1	40
2.7 to 1 to 3.3 to 1	50

$$\text{Acute Dilution Ratio} = \frac{1Q10 + [\text{WWTP flow rate}]}{[\text{WWTP flow rate}]} = \frac{[0.6] \text{ cfs} + [1.86] \text{ cfs}}{[1.86] \text{ cfs}} = [1.32]$$

The acute WLA for Wheelersburg WWTP can be expressed as 30% percent mortality in 100 percent effluent based on the dilution ratio of 1.32 to 1. If the acute dilution ratio is less than 3.3 to 1.0, and there is evidence that

effluent values between 0.3 TUA and 1.0 TUA cause or contribute to violations of WQS, the permittee may be required to investigate and remediate toxicity in this range.

## **REASONABLE POTENTIAL/EFFLUENT LIMITS/MANAGEMENT DECISIONS**

After appropriate effluent limits are calculated, the reasonable potential of the discharger to violate the WQS must be determined. Each parameter is examined and placed in a defined "group". Parameters that do not have a WQS or do not require a WLA based on the initial screening are assigned to either group 1 or 2. For the allocated parameters, the preliminary effluent limits (PEL) based on the most restrictive average and maximum WLAs are selected from Table 12. The average PEL ( $PEL_{avg}$ ) is compared to the average PEQ ( $PEQ_{avg}$ ) from Table 6, and the  $PEL_{max}$  is compared to the  $PEQ_{max}$ . Based on the calculated percentage of the allocated value [ $(PEQ_{avg} \div PEL_{avg}) \times 100$ , or  $(PEQ_{max} \div PEL_{max}) \times 100$ ], the parameters are assigned to group 3, 4, or 5. The groupings are listed in Table 13.

The final effluent limits are determined by evaluating the groupings in conjunction with other applicable rules and regulations. Table 14 presents the final effluent limits and monitoring requirements proposed for Wheelersburg WWTP outfall 001 and the basis for their recommendation. Unless otherwise indicated, the monitoring frequencies proposed in the permit are continued from the existing permit.

### **Dissolved Oxygen, Total Suspended Solids, Ammonia, 5-day Carbonaceous Biochemical Oxygen Demand**

The limits proposed for dissolved oxygen, total suspended solids, ammonia and 5-day carbonaceous biochemical oxygen demand (CBOD5) are all based on plant design criteria and existing permit limits. The TSS and CBOD5 limits are more stringent than the Secondary Treatment Standards in 40 CFR Part 133. The current ammonia limits have been evaluated using the WLA procedures and are protective of WQS for ammonia toxicity. The current dissolved oxygen limit is protective of WQS. Although the current WLA would allow slightly higher limits for ammonia, anti-backsliding provisions in the OAC prevent the imposition of less stringent limits than those in the existing permit unless specific conditions have been satisfied. In the case of the Wheelersburg WWTP, none of those conditions have been satisfied, so the existing limits are proposed to continue. The anti-backsliding provisions of OAC 3745-33-05(F) require that an anti-degradation review must be completed before an existing permit limit can be made less stringent. The rule requires other conditions to be satisfied as well.

### **Oil & Grease, pH, and *Escherichia coli***

Limits proposed for oil and grease, pH, and *Escherichia coli* are based on WQS (OAC 3745-1-35 and 37). Primary contact recreation *E. coli* standards apply to the Pine Creek.

### **Mercury and Copper**

The Ohio EPA risk assessment (Table 13) places mercury and copper in group 5. This placement, as well as the data in Table 5 and Table 6, indicates that the reasonable potential to exceed WQS exists and limits are necessary to protect water quality. For mercury, the PEQ is greater than 100 percent of the WLA and for copper the PEQ is between 75 and 100 percent of the WLA and certain conditions exist that increase the risk to the environment. Pollutants that meet these requirements must have permit limits under OAC 3745-33-07(A)(1). Copper limits are proposed to continue, while mercury limits are proposed. The daily maximum and thirty-day average loading limit for mercury and copper are based on the average daily design flow of 1.2 MGD. As the Wheelersburg WWTP may have difficulty complying with the limits for mercury and because cost effective treatment measures for reducing mercury discharge concentrations may not be available for the permittee, they may apply for a variance by submitting a mercury variance application. Ohio EPA would then review the application, and if approved, would proceed to modify the permit to incorporate variance-based mercury limits and conditions associated with the mercury variance. Wheelersburg WWTP is required to submit a mercury variance application (if needed) no later than 12 months after the effective date of the permit. If Wheelersburg

WWTP does not apply for a mercury variance and the permit is not modified, WQBELs for mercury will become effective within 36 months of the effective date. Collecting and analyzing the samples for mercury must be done using U.S. EPA Method 1631 or 245.7. Influent monitoring for copper and mercury is proposed.

### **Zinc**

The Ohio EPA risk assessment (Table 13) places zinc in group 4. This placement, as well as the data in Table 5 and Table 6, support that this parameter does not have the reasonable potential to contribute to WQS exceedances, and limits are not necessary to protect water quality. Monitoring for Group 4 pollutants (where PEQ exceeds 50 percent of the WLA) is required by OAC 3745-33-07(A)(2). Monitoring is proposed to continue at the same frequency.

### **Chromium, Lead, Nickel, Cadmium, Free Cyanide, Nitrate + Nitrite, Total Filterable Residue, and Dissolved Hexavalent Chromium**

The Ohio EPA risk assessment (Table 13) places chromium, lead, nickel, cadmium, free cyanide, nitrate + nitrite, total filterable residue and dissolved hexavalent chromium in groups 2 and 3. This placement, as well as the data in Table 5 and Table 6, support that these parameters do not have the reasonable potential to contribute to WQS exceedances, and limits are not necessary to protect water quality. Monitoring at a low frequency is proposed to document that these pollutants continue to remain at low levels. Limits for cadmium and lead are proposed to be removed but monitoring will continue at a reduced frequency.

### **Antimony, Arsenic, Barium, 1,4-Dichlorobenzene, Diethyl phthalate, Iron, Silver, Strontium, Toluene**

The Ohio EPA risk assessment (Table 13) places antimony, arsenic, barium, 1,4-Dichlorobenzene, Diethyl phthalate, iron, silver, strontium, and toluene in groups 2 and 3. This placement, as well as the data in Table 5 and Table 6, support that these parameters do not have the reasonable potential to contribute to WQS exceedances, and limits are not necessary to protect water quality. No new monitoring is proposed.

### **Flow Rate and Temperature**

Monitoring for these parameters are proposed to continue in order to evaluate the performance of the treatment plant.

### **Dissolved Orthophosphate and Total Phosphorus**

Monitoring for dissolved orthophosphate (as P) and total phosphorus is required by ORC 6111.03. This monitoring will further develop nutrient datasets that are used in stream and watershed assessments and studies. Because Ohio EPA monitoring, as well as other in-stream monitoring, for dissolved orthophosphate is taken by grab sample, grab samples are proposed for orthophosphate to maintain consistent data. The grab samples must be filtered within 15 minutes of collection using a 0.45-micron filter. The filtered sample must be analyzed within 48 hours.

### **Whole Effluent Toxicity Reasonable Potential**

Based on evaluating the WET data presented in Table 7, Table 8, Attachment 1, and other pertinent data under the provisions of OAC 3745-33-07(B), the Wheelersburg WWTP is placed in Category 4 with respect to WET. While this indicates that the plant's effluent does not currently pose a toxicity problem, annual toxicity testing is proposed consistent with the minimum monitoring requirements at OAC 3754-33-07(B)(11). Annual chronic toxicity monitoring with the determination of acute endpoints is proposed for the life of the permit. The proposed monitoring will adequately characterize toxicity in the plant's effluent.

### **Additional Monitoring Requirements**

Monitoring for temperature, pH and dissolved oxygen is proposed to be removed at upstream monitoring station 801 because this data is not used for reasonable potential analyses.

Monitoring for dissolved oxygen is proposed to be removed at downstream monitoring station 901 because this data is not used for reasonable potential analyses.

Monitoring for E. coli at station 801 and 901 is proposed to change to once per two weeks for the months of June through August. The modified frequency will facilitate assessment in the receiving stream.

Additional monitoring requirements proposed at the final effluent, influent and upstream/downstream stations are included for all facilities in Ohio and vary according to the type and size of the discharge. In addition to permit compliance, this data is used to assist in the evaluation of effluent quality and treatment plant performance and for designing plant improvements and conducting future stream studies.

### **Sludge**

Monitoring requirements proposed for the disposal of sewage sludge by the following management practices are based on OAC 3745-40: removal to sanitary landfill or transfer to another facility with an NPDES permit.

## **OTHER REQUIREMENTS**

### **Compliance Schedule**

A 36-month compliance schedule is proposed for the Wheelersburg WWTP to meet the new daily maximum and monthly average concentration and loading limits for mercury. The permittee may consider submittal of a mercury variance. Details are in Part I.C of the permit.

### **Sanitary Sewer Overflow Reporting**

Provisions for reporting SSOs are again proposed in this permit. These provisions include: the reporting of the system-wide number of SSO occurrences on monthly operating reports; telephone notification of Ohio EPA and the local health department, and 5-day follow up written reports for certain high risk SSOs; and preparation of an annual report that is submitted to Ohio EPA and made available to the public. Many of these provisions were already required under the “Noncompliance Notification”, “Records Retention”, and “Facility Operation and Quality Control” general conditions in Part III of Ohio NPDES permits.

### **Operator Certification and Operator of Record**

Operator certification requirements have been included in Part II of the permit in accordance with rules effective on August 15, 2018 (OAC 3745-7). These rules require the Wheelersburg WWTP to have a Class III wastewater treatment plant operator in charge of the sewage treatment plant operations discharging through outfall 001. These rules also require the permittee to designate one or more operator of record to oversee the technical operation of the treatment works and sewerage system.

### **Sufficiently Sensitive Method**

Part II of the permit includes a condition requiring the Wheelersburg WWTP to use laboratory analytical methods with a sufficiently sensitive MDL.

### **Method Detection Limit Reporting**

When submitting monitoring results in eDMR, the permittee must report all detected concentration values above the method detection limit (MDL), even if that value is below the quantification level, as indicated in Permit Guidance 9: *Limits below Quantification*. A detection above the MDL indicates the presence of a pollutant with strong confidence, which must be considered in reasonable potential analyses. Per OAC 3745-33-07(C)(2)(c), for the purpose of assessing compliance, any value reported below the quantification level shall be considered in compliance with an effluent limit.

### **Outfall Signage**

Part II of the permit includes requirements for the permittee to place and maintain a sign at each outfall to the Pine Creek providing information about the discharge. Signage at outfalls is required pursuant to OAC 3745-33-08(A).

### **Public Water Supply Notification**

An addition to OAC 3745-33-08 requires that permittees discharging wastewater within ten miles of a downstream public water supply intake located on the same waterway must develop and implement notification procedures in conjunction with the downstream public water supply operator in the event of a spill, separate sewer overflow, bypass or upset that reaches waters of the state. Since the Portsmouth Public Water System operates a public water supply intake ten miles downstream from the Wheelersburg WWTP, an item in Part II of the permit requires the continuation of established notification procedures.

### **NPDES Renewal Application Supplemental Effluent Data**

The permittee must submit supplemental effluent data as part of the next NPDES permit renewal application. A minimum of three samples must be tested for 101 parameters, each collected within four and one-half years of the application submission date. The complete list of parameters to be analyzed is contained in Table 2 of "Appendix J to Part 122 - NPDES Permit Testing Requirements for Publicly Owned Treatment Works (§122.21(j))." Existing effluent data may be used, if available, in lieu of sampling performed solely for the purpose of the renewal application. See Part II of the permit for details.


### **Part III**

Part III of the permit details standard conditions that include monitoring, reporting requirements, compliance responsibilities, and general requirements.

### **Stormwater Compliance**

To comply with industrial stormwater regulations, the permittee submitted a form for "No Exposure Certification" which was signed on July 5, 2022. The certification number is 0GRN00284\*BG. Compliance with the industrial stormwater regulations must be re-affirmed every five years. No later than July 5, 2027, the permittee must submit a new form for "No Exposure Certification" or make other provisions to comply with the industrial stormwater regulations.

**Figure 1. Location of Wheelersburg WWTP Sewer District No. 2**



**Figure 2. Aerial Image of Wheelersburg WWTP Sewer District No. 2**





Figure 3. Diagram of Wastewater Treatment System



**Table 1. Sewage Sludge Removal**

Year	Dry Tons Removed
2018	216
2019	102
2020	135
2021	68
2022	73

**Table 2. Effluent Violations for Outfall 001**

Parameter	2018	2019	2020	2021	2022	Total
CBOD 5-day	0	0	0	1	2	3
Copper	0	0	0	2	0	2
E. coli	1	0	0	0	0	1
Ammonia	8	7	1	53	34	103
Oil & Grease	0	0	0	0	1	1
<b>Total</b>	<b>9</b>	<b>7</b>	<b>1</b>	<b>56</b>	<b>37</b>	<b>110</b>

**Table 3. Average Annual Effluent Flow Rates**

Year	Annual Flow (MGD)		
	50th Percentile	95th Percentile	Maximum
2018	0.85	1.87	2.71
2019	0.86	1.85	2.56
2020	0.71	1.43	2.19
2021	0.77	1.48	2.18
2022	0.68	1.33	2.36

MGD = million gallons per day.

**Table 4. Effluent Characterization Using Supplemental Data from 2022 NPDES Application and Ohio EPA Sampling Data**

Parameter	Units	Permittee 7/20/22	Permittee 8/18/22 <sup>A</sup>	Ohio EPA 4/20/22	Permittee 3/1/23 <sup>B</sup>	Permittee 3/8/23 <sup>C</sup>	Permittee 4/19/23
Aluminum	µg/L	--	--	58.2	--	--	--
Antimony	µg/L	7.0 (6)	--	0.536	AA (1)	--	AA (7)
Arsenic	µg/L	AA (3)	--	0.831	AA (5)	--	AA (5)
Barium	µg/L	--	--	30.1	--	--	--
Cadmium	µg/L	AA (0.2)	--	0.0218	AA (0.2), AA (0.2)	--	AA (0.2)
Chloride	mg/L	--	--	65.6	--	--	--
Chromium	µg/L	0.6	--	0.325	AA (0.8), AA (0.8)	--	AA (0.8)
Copper	µg/L	2	--	2.75	4, 2	--	2
Hardness	mg/L	163	--	129	139	--	149
Iron	µg/L	--	--	286	--	--	--
Lead	µg/L	--	--	0.187	AA (4), AA (4)	--	AA (4)
Mercury	ng/L	--	--	--	1.9, 2.6, 1.4	--	1.4
Nickel	µg/L	1	--	2.64	1, AA (1)	--	3
Nitrate + Nitrite	mg/L	0.5	--	AA (0.0572)	1.14	--	--
Silver	µg/L	AA (0.3)	--	0.0408	AA (0.6)	--	AA (0.6)
Strontium	µg/L	--	--	140	--	--	--
Total Kjeldahl Nitrogen	mg/L	--	--	9.98	3.5	--	--
Total Filterable Residue	mg/L	--	--	868	320	--	--
Zinc	µg/L	17	--	22.9	53, 51	--	40
Free Cyanide	µg/L	AA (5)	--	4.79	0.3	--	3
Oil & Grease	mg/L	--	--	1.46	1.2, AA (0.9)	--	AA (0.9)
Diethyl phthalate	µg/L	AA (0.9)	--	1.13	AA (0.9)	--	--
1, 4-Dichlorobenzene	µg/L	--	AA (0.3)	0.949	AA (1.7)	AA (0.3)	AA (0.3)
Toluene	µg/L	--	AA (0.4)	0.671	-- <sup>C</sup>	AA (0.4)	AA (0.4)

AA = not detected (analytical method detection limit)

(--) = not tested on applicable date.

<sup>A</sup> Volatiles container had too much air on 7/20/22 sample, thus permittee collected for the volatiles on 8/18/22.

<sup>B</sup> Duplicates reported for various parameters where shown using commas. The higher/highest value from the duplicates was used to determine Preliminary Effluent Quality.

<sup>C</sup> Volatiles were re-ran 3/8/23 that were reported as sampling method error

**Table 5. Effluent Characterization Using Self-Monitoring Data**

Parameter	Season	Units	Current Permit Limits		# Obs.	Percentiles		Data Range
			30 day	Daily		50th	95th	
Outfall 001								
Water Temperature	Annual	°C	----- Monitor -----		1247	19.3	26.1	2.5-70
Dissolved Oxygen	Annual	mg/l	----- Monitor -----		1247	7.2	8.4	5-9.6
Total Suspended Solids	Annual	mg/l	12.0	18.0 <sup>a</sup>	684	2	7.85	1-22
		kg/day	54.6	81.8 <sup>a</sup>	684	6.51	29.7	0.768-75.7
Oil and Grease	Annual	mg/l	--	10	117	0	3.56	0-13.7
Ammonia (Summer)	Summer	mg/l	1.50	2.50 <sup>a</sup>	352	1.2	10	0.026-10
		kg/day	6.82	11.4 <sup>a</sup>	352	3.19	27	0.0599-73.8
Ammonia (Winter)	Winter	mg/l	4.0	6.0 <sup>a</sup>	334	0.86	6.1	0.004-10
		kg/day	18.2	27.3 <sup>a</sup>	334	2.76	25.5	0.0105-67.8
Total Kjeldahl Nitrogen	Annual	mg/l	----- Monitor -----		57	4.1	20.2	0-28.7
Nitrate + Nitrite	Annual	mg/l	----- Monitor -----		61	1.63	20.4	0-29.4
Phosphorus	Annual	mg/l	----- Monitor -----		113	1.65	5.64	0.08-7
Orthophosphate, Dissolved (as P)	Annual	mg/l	----- Monitor -----		59	1.29	4.58	0-6.63
Nickel	Annual	µg/l	----- Monitor -----		19	0	3	0-3
Zinc	Annual	µg/l	----- Monitor -----		58	58	99.3	18-355
Cadmium	Annual	µg/l	3.7	6.6	59	0	0	0-3.1
		kg/day	0.0169	0.030	59	0	0	0-0.012
Lead	Annual	µg/l	9.90	185	57	0	0	0-0
		kg/day	0.045	0.841	57	0	0	0-0
Chromium	Annual	µg/l	----- Monitor -----		18	0	2.72	0-6.8
Copper	Annual	µg/l	17.0	25.0	58	0	14	0-16
		kg/day	0.077	0.114	58	0	0.0454	0-0.12

**Table 5. Effluent Characterization Using Self-Monitoring Data**

Parameter	Season	Units	Current Permit Limits		# Obs.	Percentiles		Data Range
			30 day	Daily		50th	95th	
Hexavalent Chromium (Dissolved)	Annual	µg/l	----- Monitor -----		19	0	0.953	0-3.5
<i>E. coli</i>	Annual	#/100 ml	126	284 <sup>a</sup>	336	0	200	0-1000
Flow Rate	Annual	MGD	----- Monitor -----		1825	0.775	1.64	0.08-2.71
Mercury	Annual	ng/l	----- Monitor -----		47	2	29.9	0-127
Free Cyanide	Annual	µg/l	----- Monitor -----		17	0	0.389	0-1.8
Acute Toxicity, <i>Ceriodaphnia dubia</i>	Annual	TU <sub>a</sub>	----- Monitor -----		5	0	0	0-0
Chronic Toxicity, <i>Ceriodaphnia dubia</i>	Annual	TU <sub>c</sub>	----- Monitor -----		5	0	0	0-0
Acute Toxicity, <i>Pimephales promelas</i>	Annual	TU <sub>a</sub>	----- Monitor -----		5	0	0	0-0
Chronic Toxicity, <i>Pimephales promelas</i>	Annual	TU <sub>c</sub>	----- Monitor -----		5	0	0	0-0
pH, Maximum	Annual	S.U.	--	9.0	1247	7.6	8.1	6.9-8.7
pH, Minimum	Annual	S.U.	--	6.5	1247	7.6	8.1	6.9-8.7
Residue, Total Filterable	Annual	mg/l	----- Monitor -----		55	328	590	140-956
Carbonaceous Biochemical Oxygen Demand (5 day)	Annual	mg/l	10.0	15.0 <sup>a</sup>	638	4	11.7	1-20
		kg/day	45.5	68.2 <sup>a</sup>	638	12	40.3	1.62-101
Sanitary Sewer Overflow Station 300								
Overflow Occurrence	Annual	No./Month	----- Monitor -----		0	0	0	0-0
Sludge Station 586								
Sludge Fee Weight	Annual	Dry Tons	----- Monitor -----		5	102	200	68-216

\* = For minimum pH, 5th percentile shown in place of 50th percentile.  
\*\* = For dissolved oxygen, 5th percentile shown in place of 95th percentile.  
<sup>a</sup> = weekly average.

**Table 6. Projected Effluent Quality for Outfall 001**

<b>Parameter</b>	<b>Units</b>	<b>Number of Samples</b>	<b>Number &gt; MDL</b>	<b>PEQ Average</b>	<b>PEQ Maximum</b>
Aluminum	µg/L	1	1	263.4	360.8
Ammonia-Summer	mg/L	234	234	7.24	15.0
Ammonia-Winter	mg/L	168	168	5.84	8.00
Antimony	µg/L	4	2	13.3	18.2
Arsenic - TR	µg/L	1	1	3.76	5.15
Barium	µg/L	1	1	136.2	186.6
Cadmium - TR	µg/L	50	3	2.26	3.10
Chlorides	mg/L	1	1	296.9	406.7
Chromium - TR	µg/L	15	2	7.45	10.2
Chromium hexavalent - Dissolved	µg/L	15	2	3.83	5.25
Copper - TR	µg/L	62	23	9.43	14.87
Cyanide - free	µg/L	21	9	4.74	6.5
1,4-Dichlorobenzene	µg/L	4	1	1.80	2.47
Diethyl phthalate	µg/L	3	1	2.47	3.39
Total filterable residue	mg/L	57	57	483.4	629.2
Iron - TR	µg/L	1	1	1294.4	1773.2
Lead - TR	µg/L	1	1	0.85	1.16
Mercury - TR	ng/L	48	45	14.63	21.96
Nickel - TR	µg/L	19	9	3.07	4.2
Nitrate-N + Nitrite-N	mg/L	64	59	21.46	29.4
Oil & grease	mg/L	120	19	4.67	4.74
Silver	µg/L	1	1	0.185	0.253
Strontium	µg/L	1	1	634	868
Total Kjeldahl Nitrogen	mg/L	59	45	20.95	28.7
Toluene	µg/L	4	1	1.27	1.74
Zinc - TR	µg/L	61	61	89.6	128.0

TR = Total Recoverable

MDL = analytical method detection limit

PEQ = projected effluent quality

\* Per OAC 3745-2-04(E)(3), ammonia PEQ is based on data collected during the following months:

Summer – June through September

Winter – December through February

**Table 7. Summary of Acute and Chronic Toxicity Results**

Date	<i>Ceriodaphnia Dubia</i>		<i>Pimephales promelas</i>	
	TU <sub>a</sub>	TU <sub>c</sub>	TU <sub>a</sub>	TU <sub>c</sub>
9/1/2018	AA	AA	AA	AA
9/15/2019	AA	AA	AA	AA
9/1/2020	AA	AA	AA	AA
9/20/2021	AA	AA	AA	AA
9/1/2022	AA	AA	AA	AA

AA = non-detection; analytical method detection limit of 0.2 TU<sub>a</sub>, 1.0 TU<sub>c</sub>

TU<sub>a</sub> = acute toxicity unit

TU<sub>c</sub> = chronic toxicity unit

**Table 8. Summary of Acute Toxicity Results from Ohio EPA sampling**

Date	<i>Outfall 001</i>		<i>Upstream</i>	
	<i>Ceriodaphnia Dubia</i>	<i>Pimephales promelas</i>	<i>Ceriodaphnia Dubia</i>	<i>Pimephales promelas</i>
	TU <sub>a</sub>	TU <sub>a</sub>	% affected	% affected
4/19-20/2022	AA	0.2	10	10

AA = non-detection; analytical method detection limit of 0.2 TU<sub>a</sub>

TU<sub>a</sub> = acute toxicity unit

**Table 9. Use Attainment Table**

DSW/EAS 2012-12-17

Southeast Ohio River Tributary Watersheds 2010 & 2011

December 17, 2012

Stream	River Mile	Sampling Type	Aquatic Life Use Designation	Aquatic Life Attainment Status <sup>b</sup>	IBI	MIwb	ICI <sup>a</sup>	QHEI	Cause/Source of Impairment
Pine Creek	25.9	Wading	WWH	FULL	46	8.6	G	78.0	
Pine Creek	20.35	Wading	WWH	FULL	42 <sup>ms</sup>	9.0	42	72.3	
Pine Creek	13.36	Wading	WWH	FULL	46	8.4	52	78.8	
Pine Creek	5.05	Wading	WWH	FULL	49	9.1	48	80.5	

Attainment assessed using following index scoring:

**Biological Criteria**

<i>Western Allegheny Plateau</i>		
Index – Site Type	EWB	WWH
IBI – Headwaters	50	44
IBI – Wading	50	44
IBI – Boat	48	40
MIwb – Wading	9.4	8.4
MIwb – Boat	9.6	8.6
ICI	46	36

Data gathered from *Biological and Water Quality Study of Southeast Ohio River Tributaries (Pine, Ice, Little Scioto) 2010 & 2011*.

WWH = warmwater habitat

IBI = Index of Biotic Integrity

MIwb = Modified Index of Well-being

ICI = Invertebrate Community Index

QHEI = Qualitative Habitat Evaluation Index

**Table 10. Water Quality Criteria in the Study Area**

Parameter	Units	Outside Mixing Zone Criteria				Inside Mixing Zone Maximum
		Average			Maximum	
		Human Health	Agri-culture	Aquatic Life	Aquatic Life	
Aluminum	µg/L	--	--	--	--	--
Ammonia-Summer	mg/L	--	--	1.6	--	--
Ammonia-Winter	mg/L	--	--	5.2	--	--
Antimony	µg/L	640	--	190	900	1800
Arsenic - TR	µg/L	--	100	150	340	680
Barium	µg/L	--	--	850	3600	7600
Cadmium - TR	µg/L	--	50	3.2	6.5	14
Chlorides	mg/L	--	--	--	--	--
Chromium - TR	µg/L	--	100	110	2300	4900
Chromium hexavalent dissolved	µg/L	--	--	11	16	31
Copper - TR	µg/L	--	500	12	19	40
Cyanide - free	µg/L	400	--	12	46	92
1,4-Dichlorobenzene	µg/L	900	--	9.4	57	110
Diethyl phthalate	µg/L	600	--	220	980	2000
Total Filterable Residue	mg/L	--	--	1500	--	--
Iron - TR	µg/L	--	5000	--	--	--
Lead - TR	µg/L	--	100	9.7	180	390
Mercury - TR	ng/L	12 <sup>a</sup>	10000	910	1700	3400
Nickel - TR	µg/L	4600	200	69	620	1300
Nitrate-N + Nitrite-N	mg/L	--	100	--	--	--
Oil & grease	mg/L	--	--	--	10	--
Silver	µg/L	--	--	1.3	2.8	6.1
Strontium	µg/L	--	--	32000	82000	180000
TKN	mg/L	--	--	--	--	--
Toluene	µg/L	520	--	62	560	1100
Zinc - TR	µg/L	26000	25000	160	160	330

<sup>a</sup> = Mercury is Bioaccumulative Chemical of Concern (BCC); no mixing zone allowed after 11/15/2010, WQS must be met at end-of-pipe, unless requirements for an exception are met as listed in OAC 3745-2-05(A)(2)(e)(ii)

**Table 11. Instream Conditions and Discharger Flow**

<b>Parameter</b>	<b>Units</b>	<b>Season</b>	<b>Value</b>	<b>Basis</b>
<b><i>Stream Flows</i></b>				
1Q10	cfs	annual	0.6	Low-Flow Characteristics of Stream in Ohio through Water Year 1997 - 03216640
7Q10	cfs	annual	0.8	Low-Flow Characteristics of Stream in Ohio through Water Year 1997 - 03216640
30Q10	cfs	summer	1.1	Low-Flow Characteristics of Stream in Ohio through Water Year 1997 - 03216640
		winter	8.3	Low-Flow Characteristics of Stream in Ohio through Water Year 1997 - 03216640
Harmonic Mean	cfs	annual	10.9	Same value used in previous Factsheet from OPK00001*HD
Mixing Assumption	%	average	100	
		maximum	100	
<i>Hardness, OMZ</i>	mg/L	annual	138	Median of 20 results from 901 downstream monitoring station (2012-2023). A number of recent data results collected in 2018-2023 appeared lower than anticipated based on watershed values, thus a timeframe was expanded for a more robust dataset and assessment of a median value.
<i>Hardness, IMZ</i>	mg/L	annual	145	Average of four effluent results (2022-2023)
<i>pH</i>	S.U.	summer	7.5	Downstream Station 901; n=18, 75th percentile, (2018-2022)
		winter	7.6	Downstream Station 901; n=8, 75th percentile, (2018-2022)
<i>Temperature</i>	°C	summer	24.4	Downstream Station 901; n=18, 75th percentile, (2018-2022)
		winter	13.2	Downstream Station 901; n=8, 75th percentile, (2018-2022)
<i>Wheelersburg WWTP flow</i>	cfs MGD	annual	1.8567 1.2	Average Daily Design Flow from NPDES application Form 2A
<b><i>Background Water Quality</i></b>				
Aluminum	µg/L	annual	271	EA3 W01K07; 2022; n=1; 0<MDL; Average
Ammonia	mg/L	summer	0.08	801; 2018-2022; n=17; 0<MDL; Median
Ammonia	mg/L	winter	0.27	801; 2018-2022; n=8; 0<MDL; Average
Antimony	µg/L	annual	0	No representative data available.
Arsenic - TR	µg/L	annual	0.694	EA3 W01K07; 2022; n=1; 0<MDL; Average
Barium	µg/L	annual	40.5	EA3 W01K07; 2022; n=1; 0<MDL; Average

Cadmium - TR	µg/L	annual	0.025	EA3 W01K07; 2022; n=1; 0<MDL; Average
Chlorides	mg/L	annual	3.97	EA3 W01K07; 2022; n=1; 0<MDL; Average
Chromium - TR	µg/L	annual	0.223	EA3 W01K07; 2022; n=1; 0<MDL; Average
Chromium hexavalent dissolved	µg/L	annual	0	No representative data available.
Copper - TR	µg/L	annual	1.19	EA3 W01K07; 2022; n=1; 0<MDL; Average
Cyanide - free	µg/L	annual	0	No representative data available.
1,4-Dichlorobenzene	µg/L	annual	0	No representative data available.
Diethyl phthalate	µg/L	annual	0	No representative data available.
Total filterable residue	mg/L	annual	318	EA3 W01K07; 2022; n=1; 0<MDL; Average
Iron - TR	µg/L	annual	843	EA3 W01K07; 2022; n=1; 0<MDL; Average
Lead - TR	µg/L	annual	0.295	EA3 W01K07; 2022; n=1; 0<MDL; Average
Mercury - TR	ng/L	annual	0	No representative data available.
Nickel - TR	µg/L	annual	2.99	EA3 W01K07; 2022; n=1; 0<MDL; Average
Nitrate-N + Nitrite-N	mg/L	annual	0.42	801; 2018-2022; n=27; 6<MDL; Median
Oil & grease	mg/L	annual	0	No representative data available.
Silver	µg/L	annual	0	No representative data available.
Strontium	µg/L	annual	126	EA3 W01K07; 2022; n=1; 0<MDL; Average
TKN	mg/L	annual	0	801; 2018-2022; n=27; 21<MDL; Median

TR = Total recoverable

MDL = analytical method detection limit

n = number of samples

NPDES = National Pollutant Discharge Elimination System

Ohio EPA = Ohio Environmental Protection Agency

WWTP = wastewater treatment plant

**Table 12. Summary of Effluent Limits to Maintain Applicable Water Quality Criteria**

Parameter	Units	Outside Mixing Zone Criteria				Inside Mixing Zone Maximum <sup>A</sup>
		Average			Maximum	
		Human Health	Agri-culture	Aquatic Life	Aquatic Life	
Aluminum	µg/L	--	--	--	--	--
Ammonia-Summer	mg/L	--	--	2.5	--	--
Ammonia-Winter	mg/L	--	--	27.24	--	--
Antimony	µg/L	4397	--	272	1191	1800
Arsenic - TR	µg/L	--	683	214	450	680
Barium	µg/L	--	--	1199	4750	7600
Cadmium - TR	µg/L	--	343	4.6	8.6	14
Chlorides	mg/L	--	--	--	--	--
Chromium - TR	µg/L	--	686	157	3043	4900
Chromium hexavalent dissolved	µg/L	--	--	16	21	31
Copper - TR	µg/L	--	3428	17	25	40
Cyanide - free	µg/L	2748	--	17	61	92
1,4-Dichlorobenzene	µg/L	6184	--	13	75	110
Diethyl phthalate	µg/L	4122	--	315	1297	2000
Total filterable residue	mg/L	--	--	2009	--	--
Iron - TR	µg/L	--	29404	--	--	--
Lead - TR	µg/L	--	685	14	238	390
Mercury - TR	ng/L	12	10000	910	1700	3400
Nickel - TR	µg/L	31587	1357	97	819	1300
Nitrate-N + Nitrite-N	mg/L	--	685	--	--	--
Oil & grease	mg/L	--	--	--	13	--
Silver	µg/L	--	--	1.9	3.7	6.1
Strontium	µg/L	--	--	45734	108458	180000
TKN	mg/L	--	--	--	--	--
Toluene	µg/L	3573	--	89	741	1100
Zinc - TR	µg/L	178636	171766	229	212	330

<sup>A</sup> Allocation must not exceed the Inside Mixing Zone Maximum

<sup>B</sup> Bioaccumulative Chemical of Concern (BCC); no mixing zone allowed after 11/15/2010, WQS must be met at end-of-pipe, unless requirements for an exception are met as listed in OAC 3745-2-05(A)(2)(e)(ii).

TR = Total recoverable

**Table 13. Parameter Assessment**

*Group 1:* Due to a lack of criteria, the following parameters could not be evaluated at this time.

Aluminum Chlorides TKN

*Group 2:* PEQ < 25 percent of WQS or all data below minimum detection limit. WLA not required. No limit recommended; monitoring optional.

Antimony Arsenic - TR Barium  
 Chromium - TR 1,4-Dichlorobenzene Diethyl phthalate  
 Lead - TR Nickel - TR Nitrate-N + Nitrite-N  
 Silver Strontium Toluene

*Group 3:* PEQ<sub>max</sub> < 50 percent of maximum PEL and PEQ<sub>avg</sub> < 50 percent of average PEL. No limit recommended; monitoring optional.

Cadmium - TR Chromium hexavalent dissolved Cyanide - free  
 Total filterable residue Iron - TR Oil & grease

*Group 4:* PEQ<sub>max</sub> >= 50 percent, but < 100 percent of the maximum PEL or PEQ<sub>avg</sub> >= 50 percent, but < 100 percent of the average PEL. Monitoring is appropriate.

Zinc - TR

*Group 5:* Maximum PEQ >= 100 percent of the maximum PEL or average PEQ >= 100 percent of the average PEL, or either the average or maximum PEQ is between 75 and 100 percent of the PEL and certain conditions that increase the risk to the environment are present. Limit recommended.

Limits to Protect Numeric Water Quality Criteria

<u>Parameter</u>	<u>Units</u>	<u>Recommended Effluent Limits</u>	
		<u>Average</u>	<u>Maximum</u>
Mercury - TR	ng/L	12	1700
Copper – TR <sup>A</sup>	µg/L	17	25

<sup>A</sup> Copper becomes Group 5 due to loading test pursuant OAC 3745-2-06(B)(1)(b)

TR = total recoverable  
 PEL = preliminary effluent limit  
 PEQ = projected effluent quality  
 WLA = wasteload allocation  
 WQS = water quality standard

**Table 14. Final Effluent Limits for Outfall 001**

Parameter	Units	Concentration		Loading (kg/day) <sup>a</sup>		Basis <sup>b</sup>
		Daily Maximum	30 Day Average	Daily Maximum	30 Day Average	
Water Temperature	°C	----- Monitor -----				M <sup>c</sup>
Dissolved Oxygen	mg/L	5.0 <sup>m</sup>	--	--	--	WQS
Total suspended solids	mg/L	18 <sup>d</sup>	12	81.8 <sup>d</sup>	54.6	PD, BADCT
Oil & Grease	mg/L	10	--	--	--	WQS
Ammonia (summer)	mg/L	2.5 <sup>d</sup>	1.5	11.4 <sup>d</sup>	6.82	ABS
Ammonia (winter)	mg/L	6.0 <sup>d</sup>	4.0	27.3 <sup>d</sup>	18.2	ABS
Total Kjeldahl Nitrogen	mg/L	----- Monitor -----				M
Nitrate plus Nitrite	mg/L	----- Monitor -----				M
Phosphorus	mg/L	----- Monitor -----				PMR
Orthophosphate	mg/L	----- Monitor -----				PMR
Nickel	µg/L	----- Monitor -----				M
Zinc	µg/L	----- Monitor -----				M
Cadmium	µg/L	----- Monitor -----				M
Lead	µg/L	----- Monitor -----				M
Chromium	µg/L	----- Monitor -----				M
Copper	µg/L	25.0	17.0	0.11	0.077	RP/WLA
Dissolved Hexavalent Chromium	µg/L	----- Monitor -----				M
<i>E. coli</i>	#/100 mL	284 <sup>d</sup>	126	--	--	WQS
Flow Rate	MGD	----- Monitor -----				M <sup>c</sup>
Mercury	ng/L	1700	12	0.0077	0.000055	RP/WLA
Free Cyanide	µg/L	----- Monitor -----				M
Acute Toxicity, <i>Ceriodaphnia dubia</i>	TU <sub>a</sub>	----- Monitor -----				WET
Chronic Toxicity, <i>Ceriodaphnia dubia</i>	TU <sub>c</sub>	----- Monitor -----				WET
Acute Toxicity, <i>Pimephales promelas</i>	TU <sub>a</sub>	----- Monitor -----				WET
Chronic Toxicity, <i>Pimephales promelas</i>	TU <sub>c</sub>	----- Monitor -----				WET
Total Filterable Residue	mg/L	----- Monitor -----				M
pH, maximum	SU	9.0	--	--	--	WQS
pH, minimum	SU	6.5 <sup>m</sup>	--	--	--	WQS
CBOD5	mg/L	15 <sup>d</sup>	10	68.2 <sup>d</sup>	45.5	PD, BADCT

<sup>a</sup> Effluent loadings based on average design discharge flow of 1.2 MGD.

<sup>b</sup> Definitions:

- ABS = Antibracksliding Rule (OAC 3745-33-05(F) and 40 CFR Part 122.44(l))
- BADCT = Best Available Demonstrated Control Technology, 40 CFR Part 122.29, and OAC 3745-1-05
- CFR = Code of Federal Regulations
- M = Division of Surface Water NPDES Permit Guidance 1: Monitoring frequency requirements for Sanitary Discharges
- NPDES = National Pollutant Discharge Elimination System
- OAC = Ohio Administrative Code

PD = Plant Design (OAC 3745-33-05(E))

PMR = Phosphorus monitoring requirements (ORC 6111.03)

RP = Reasonable Potential for requiring water quality-based effluent limits and monitoring requirements in permits (OAC 3745-33-07(A))

WET = Minimum testing requirements for whole effluent toxicity [OAC 3745-33-07(B)(11)]

WLA = Wasteload Allocation procedures (OAC 3745-2)

WQS = Ohio Water Quality Standards (OAC 3745-1)

<sup>c</sup> Monitoring of flow and other indicator parameters is specified to assist in the evaluation of effluent quality and treatment plant performance.

<sup>d</sup> 7 day average limit.

<sup>m</sup> minimum limit

## Attachment 1 Whole Effluent Toxicity Reasonable Potential Analysis

Whole effluent toxicity testing produced only non-detection results for acute and chronic toxicity in *Ceriodaphnia dubia* and chronic *Pimephales promelas*, and therefore fall under Hazard Category 4. The reasonable potential analyses in Tables 3B, 3C, and 3D were only performed for *Pimephales promelas*, acute (TUa Pp).

### Hazard Category Summary

	<i>Ceriodaphnia dubia</i>		<i>Pimephales promelas</i>	
	Acute	Chronic	Acute	Chronic
Effluent Toxicity (Table A)	4	4	4	4
Near-Field Impact (Table B)	--		--	
Far-field Impact (Table C)		--		--
	4		4	

Hazard Categories: 1: Toxicity adequately documented 2: Toxicity strongly suspected 3: Toxicity possible 4: No toxicity

Table A. Effluent Toxicity

	<i>Ceriodaphnia dubia</i>		<i>Pimephales promelas</i>	
	Acute	Chronic	Acute	Chronic
WLA	--	--	0.4	--
# of tests	--	--	6	--
Maximum value	--	--	0.2	--
Percent of tests >WLA	--	--	0	--
Geometric mean replacing <MDL with 0.5XMDL	--	--	0.11	--
Average Exceedance (Geomean * Percent of tests >WLA)	--	--	0	--
Average Exceedance / WLA	--	--	0	--

<u>Attribute Evaluated</u>	<u>Hazard Category 1</u>	<u>Hazard Category 2</u>	<u>Hazard Category 3</u>	<u>Hazard Category 4</u>
Degree of Toxicity	Adequately Documented	Strongly Suspected	Possible	None
<u>(1) Minimum number of tests</u>	<u>3</u>	<u>1</u>	<u>0 or 1</u> TUa Pp	<u>0 or 1</u> TUa Pp
<u>(2) Percent of tests &gt;WLA</u>	<u>&gt;30</u>	<u>20 to 30</u>	<u>10 to 20</u>	<u>10</u> TUa Pp
<u>(3) Average Exceedance/WLA<sup>1</sup></u> <u>(Tables B and C data not available)</u>				
(a) Acute <sup>2</sup>	> 0.3	≥ 0.3	≥ 0.2	< 0.2 TUa Pp
(b) Chronic	> 0.3	≥ 0.3	≥ 0.2	< 0.2
<u>(3) Average Exceedance/WLA<sup>1</sup></u> <u>(Tables B and C data available)</u>				
(a) Acute <sup>2</sup>	> 0.5	≥ 0.3	≥ 0.3	< 0.3
(b) Chronic	>0.67	≥ 0.5	≥ 0.5	< 0.5

<u>Attribute Evaluated</u>	<u>Hazard Category 1</u>	<u>Hazard Category 2</u>	<u>Hazard Category 3</u>	<u>Hazard Category 4</u>
Degree of Toxicity	Adequately Documented	Strongly Suspected	Possible	None
(4) Maximum TU value (Tables 3B and 3C data not available)	$\geq(3xWLA)$	$\geq WLA$	$\geq WLA$	$<WLA$ TUa Pp
(4) Maximum TU value (Tables 3B and 3C data available)	$> WLA$	$\geq WLA$	$\geq 0.5xWLA$	$0.5xWLA$

Table B. Near-Field Toxicity – Table not used

<u>Attribute Evaluated</u>	<u>Hazard Category 1</u>	<u>Hazard Category 2</u>	<u>Hazard Category 3</u>	<u>Hazard Category 4</u>
Degree of Toxicity	Adequately Documented	Strongly Suspected	Possible	None
(1) Mortality within mixing zone <sup>3</sup>	$\geq 20\%$	$\leq 20\%$	$\leq 20\%$	$< 20\%$
(2) Stream community impact				
(a) implied chemically <sup>4,6</sup>	$\geq 3xIMZM$ or $>LC50$	$\geq 1.5xIMZM$ or $>LC50$	$\geq 0.75xIMZM$ or $>0.75xLC50$	$\leq 0.5xIMZM$ or $\leq 0.75xLC50$
(b) implied toxicologically <sup>4</sup>	$\geq 1.0 TUa$	$\geq 1.0 TUa$	$\geq 1.0 TUa$	$<1.0 TUa$
(c) implied biologically	Toxic	Fair/poor community	Slight impact	None

Table C. Far-Field Toxicity – Table not used

<u>Attribute Evaluated</u>	<u>Hazard Category 1</u>	<u>Hazard Category 2</u>	<u>Hazard Category 3</u>	<u>Hazard Category 4</u>
Degree of Toxicity	Adequately Documented	Strongly Suspected	Possible	None
(1) Aquatic life use impairment (Ohio EPA biological criteria)	<u>Yes</u> <sup>5</sup>	<u>Yes or partial</u> <sup>5</sup>	<u>Partial</u>	<u>None</u>
(2) Stream community impact implied toxicologically <sup>3</sup>	<u>Significant effect</u>	<u>Significant effect</u>	<u>Unknown or slight effect</u>	<u>None</u>
(3) Other indicators	<u>Stress indicated</u>	<u>Stress indicated</u>	<u>Stress indicated</u>	<u>No stress</u>

<sup>1</sup> Compare (per cent exceedances x geometric mean TU) to table factor.

<sup>2</sup> Use 0.3 x WLA for situations where AIM exists.

<sup>3</sup> Results of ambient toxicity test are not binding or required for classification as to category but, if available, will be interpreted under the weight of evidence principle giving due consideration as to sampling location and conditions.

<sup>4</sup> Based on effluent data. May not be appropriate for situations where AIM exists.

<sup>5</sup> Lack of attainment due to toxic, complex or unidentifiable type of impact.

<sup>6</sup> The LC50-based criteria are used only for pollutant parameters that do not have numeric criteria.

## **Addendum 1. Acronyms**

ABS	Anti-backsliding
BPJ	Best professional judgment
CFR	Code of Federal Regulations
CMOM	Capacity Management, Operation, and Maintenance
CONSWLA	Conservative substance wasteload allocation
CSO	Combined sewer overflow
CWA	Clean Water Act
DMR	Discharge Monitoring Report
DMT	Dissolved metal translator
IMZM	Inside mixing zone maximum
LTCP	Long-term Control Plan
MDL	Analytical method detection limit
MGD	Million gallons per day
NPDES	National Pollutant Discharge Elimination System
OAC	Ohio Administrative Code
Ohio EPA	Ohio Environmental Protection Agency
ORC	Ohio Revised Code
ORSANCO	Ohio River Valley Water Sanitation Commission
PEL	Preliminary effluent limit
PEQ	Projected effluent quality
PMP	Pollution Minimization Program
PPE	Plant performance evaluation
SSO	Sanitary sewer overflow
TMDL	Total Daily Maximum Load
TRE	Toxicity reduction evaluation
TU	Toxicity unit
U.S. EPA	United States Environmental Protection Agency
WET	Whole effluent toxicity
WLA	Wasteload allocation
WPCF	Water Pollution Control Facility
WQBEL	Water-quality-based effluent limit
WQS	Water Quality Standards
WWTP	Wastewater Treatment Plant