

National Pollutant Discharge Elimination System (NPDES) Permit Program

**FACT SHEET**

**Regarding an NPDES Permit to Discharge to Waters of the State of Ohio  
For City of Marion Water Pollution Control (WPC)**

Public Notice No.: 210315

Ohio EPA Permit No.: 2PD00011\*SD

Public Notice Date: 3/7/2025

Application No.: OH0026352

Comment Period Ends: 4/6/2025

Name and Address of Applicant:

City of Marion  
233 West Center Street  
Marion, OH 43302

Name and Address of Facility Where

Discharge Occurs:  
Marion WPC  
1810 Marion-Agosta Road  
Marion, OH 43302  
Marion County

Receiving Water: Little Scioto River

Subsequent Stream Network: Scioto River to Ohio River

**INTRODUCTION**

Development of a Fact Sheet for NPDES permits is mandated by Title 40 of the Code of Federal Regulations (CFR), Section 124.8 and 124.56. This document fulfills the requirements established in those regulations by providing the information necessary to inform the public of actions proposed by the Ohio Environmental Protection Agency (Ohio EPA), as well as the methods by which the public can participate in the process of finalizing those actions.

This Fact Sheet is prepared in order to document the technical basis and risk management decisions that are considered in the determination of water quality based NPDES Permit effluent limitations. The technical basis for the Fact Sheet may consist of evaluations of promulgated effluent guidelines, existing effluent quality, instream biological, chemical, and physical conditions, and the relative risk of alternative effluent limitations. This Fact Sheet details the discretionary decision-making process empowered to the Director by the Clean Water Act (CWA) and Ohio Water Pollution Control Law (Ohio Revised Code [ORC] 6111). Decisions to award variances to Water Quality Standards (WQS) or promulgated effluent guidelines for economic or technological reasons will also be justified in the Fact Sheet where necessary.

Antidegradation provisions in Ohio Administrative Code (OAC) Chapter 3745-1 describe the conditions under which water quality may be lowered in surface waters. No antidegradation review was necessary.

Effluent limits based on available treatment technologies are required by Section 301(b) of the CWA. Many of these have already been established by the United States Environmental Protection Agency (U.S. EPA) in the effluent guideline regulations (a.k.a. categorical regulations) for industry categories in 40 CFR Parts 405-499. Technology-based regulations for publicly-owned treatment works are listed in the Secondary Treatment Regulations (40 CFR Part 133). If regulations have not been established for a category of dischargers, the director may establish technology-based limits based on best professional judgment (BPJ).

Ohio EPA reviews the need for water-quality-based limits on a pollutant-by-pollutant basis. Wasteload allocations (WLAs) are used to develop these limits based on the pollutants that have been detected in the discharge, and the receiving water's assimilative capacity. The assimilative capacity depends on the flow in the water receiving the discharge, and the concentration of the pollutant upstream. The greater the upstream flow, and the lower the upstream concentration, the greater the assimilative capacity is. Assimilative capacity may represent dilution (as in allocations for metals), or it may also incorporate the break-down of pollutants in the receiving water (as in allocations for oxygen-demanding materials).

The need for water-quality-based limits is determined by comparing the WLA for a pollutant to a measure of the effluent quality. The measure of effluent quality is called Projected Effluent Quality (PEQ). This is a statistical measure of the average and maximum effluent values for a pollutant. As with any statistical method, the more data that exists for a given pollutant, the more likely that PEQ will match the actual observed data. If there is a small data set for a given pollutant, the highest measured value is multiplied by a statistical factor to obtain a PEQ; for example, if only one sample exists, the factor is 6.2, for two samples - 3.8, for three samples - 3.0. The factors continue to decline as sample sizes increase. These factors are intended to account for effluent variability, but if the pollutant concentrations are fairly constant, these factors may make PEQ appear larger than it would be shown to be if more sample results existed.

## **SUMMARY OF PERMIT CONDITIONS**

The effluent limits and/or monitoring requirements proposed for all parameters are the same as in the current permit, except those listed below.

New effluent limits are proposed for silver, dibenz(a,h) anthracene, and bis(2-ethylhexyl) phthalate based on the reasonable potential analysis. A compliance schedule is proposed to meet the new effluent limits.

Lower effluent limits are proposed for zinc based on the waste load allocation.

New monitoring is proposed for selenium, and bromodichloromethane based on the reasonable potential analysis.

Limits are proposed to be removed for total filterable residue and free cyanide based on the reasonable potential analysis. Monitoring is proposed to continue.

Monitoring requirements are proposed to be removed for strontium and barium because reasonable potential was not observed.

Monitoring requirements are proposed to be removed for total suspended solids and 5-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>) from the combined sewer overflow monitoring tables because this data is not needed to characterize the overflows.

Monitoring for temperature, pH, and dissolved oxygen is proposed to be removed from the 801 upstream monitoring station because this data is currently not needed.

Monitoring for nitrate & nitrite is proposed to be added at stations 801 and 901 so that nutrient data is collected for future studies.

Semi-Annual chronic toxicity monitoring with the determination of acute endpoints is proposed for the life of the permit. Increased monitoring is proposed based on the detections in July 2021 and based on the WET reasonable potential being group 3.

A schedule of compliance to implement the combined sewer overflow (CSO) long term control plan (LTCP) is proposed to be carried over from the previous permit.

In Part II of the permit, special conditions are included that address sanitary sewer overflow (SSO) reporting; operator certification, minimum staffing, and operator of record; whole effluent toxicity (WET) testing; stormwater compliance; pretreatment program requirements; and outfall signage.

## Table of Contents

|  | Page |
|--|------|
| INTRODUCTION.....  | 1    |
| SUMMARY OF PERMIT CONDITIONS.....  | 2    |
| PROCEDURES FOR PARTICIPATION IN THE FORMULATION OF FINAL DETERMINATIONS..... | 5    |
| INFORMATION REGARDING CERTAIN WATER QUALITY BASED EFFLUENT LIMITS.....       | 5    |
| LOCATION OF DISCHARGE/RECEIVING WATER USE CLASSIFICATION.....                | 7    |
| FACILITY DESCRIPTION.....  | 7    |
| DESCRIPTION OF EXISTING DISCHARGE .....                                      | 8    |
| ASSESSMENT OF IMPACT ON RECEIVING WATERS .....                               | 9    |
| DEVELOPMENT OF WATER-QUALITY-BASED EFFLUENT LIMITS .....                     | 10   |
| REASONABLE POTENTIAL/EFFLUENT LIMITS/MANAGEMENT DECISIONS .....              | 13   |
| OTHER REQUIREMENTS.....  | 15   |

## List of Figures

|  |    |
|--|----|
| Figure 1. Location of Marion WPC .....                 | 17 |
| Figure 2. Diagram of Wastewater Treatment System ..... | 18 |

## List of Tables

|   |    |
|---|----|
| Table 1. Sewage Sludge Removal.....   | 19 |
| Table 2. Effluent Violations for Outfall 001 .....                                      | 19 |
| Table 3. Average Annual Effluent Flow Rates .....                                       | 19 |
| Table 4. Sanitary Sewer Overflows Discharges.....                                       | 19 |
| Table 5. Bypass Discharges .....  | 20 |
| Table 6. Combined Sewer Overflow Discharges .....                                       | 20 |
| Table 7. Calculated Annual Total Phosphorus Loadings .....                              | 20 |
| Table 8. Effluent Characterization Using Pretreatment and Ohio EPA Data.....            | 21 |
| Table 9. Effluent Characterization Using Self-Monitoring Data .....                     | 22 |
| Table 10. Projected Effluent Quality for Outfall 001.....                               | 24 |
| Table 11. Summary of Acute and Chronic Toxicity Results .....                           | 25 |
| Table 12. Use Attainment Table .....  | 25 |
| Table 13. Water Quality Criteria in the Study Area.....                                 | 26 |
| Table 14. Instream Conditions and Discharger Flow.....                                  | 27 |
| Table 15. Summary of Effluent Limits to Maintain Applicable Water Quality Criteria..... | 29 |
| Table 16. Parameter Assessment.....   | 30 |
| Table 17. Final Effluent Limits for Outfall 001 .....                                   | 31 |

## List of Attachments

|   |    |
|---|----|
| Attachment 1. Whole Effluent Toxicity Reasonable Potential Analysis ..... | 33 |
| Attachment 2. Acronyms .....  | 35 |

## **PROCEDURES FOR PARTICIPATION IN THE FORMULATION OF FINAL DETERMINATIONS**

The draft action shall be issued as a final action unless the Director revises the draft after consideration of the record of a public meeting or written comments, or upon disapproval by the Administrator of the U.S. Environmental Protection Agency.

Within thirty days of the date of the Public Notice, any person may request or petition for a public meeting for presentation of evidence, statements, or opinions. The purpose of the public meeting is to obtain additional evidence. Statements concerning the issues raised by the party requesting the meeting are invited. Evidence may be presented by the applicant, the state, and other parties, and following presentation of such evidence other interested persons may present testimony of facts or statements of opinion.

Requests for public meetings shall be in writing and shall state the action of the Director objected to, the questions to be considered, and the reasons the action is contested. Such requests should be emailed to [HClerk@epa.ohio.gov](mailto:HClerk@epa.ohio.gov) or mailed to:

**Legal Records Section  
Ohio Environmental Protection Agency  
P.O. Box 1049  
Columbus, Ohio 43216-1049**

Interested persons are invited to submit written comments upon the discharge permit. Comments should be submitted by email to [epa.dswcomments@epa.ohio.gov](mailto:epa.dswcomments@epa.ohio.gov) (preferred method) or delivered in person or by mail no later than 30 days after the date of this Public Notice. Deliver or mail all comments to:

**Ohio Environmental Protection Agency  
Attention: Division of Surface Water  
Permits Processing Unit  
P.O. Box 1049  
Columbus, Ohio 43216-1049**

The Ohio EPA permit number and Public Notice numbers should appear on each page of any submitted comments. All comments received no later than 30 days after the date of the Public Notice will be considered.

Citizens may conduct file reviews regarding specific companies or sites. Appointments are necessary to conduct file reviews because requests to review files have increased dramatically in recent years. The first 250 pages copied are free. For requests to copy more than 250 pages, there is a five-cent charge for each page copied. Payment is required by check or money order, made payable to Treasurer State of Ohio.

For additional information about this fact sheet or the draft permit, contact Luke Heritage, [luke.heritage@epa.ohio.gov](mailto:luke.heritage@epa.ohio.gov), 419-419-3711.

## **INFORMATION REGARDING CERTAIN WATER QUALITY BASED EFFLUENT LIMITS**

This draft permit may contain proposed water-quality-based effluent limits (WQBELs) for parameters that **are not** priority pollutants. (See the following link for a list of the priority pollutants: [https://epa.ohio.gov/static/Portals/35/pretreatment/Pretreatment\\_Program\\_Priority\\_Pollutant\\_Detection\\_Limits.pdf](https://epa.ohio.gov/static/Portals/35/pretreatment/Pretreatment_Program_Priority_Pollutant_Detection_Limits.pdf).) In accordance with ORC 6111.03(J)(3), the Director established these WQBELs after considering, to the extent consistent with the Federal Water Pollution Control Act, evidence relating to the technical feasibility and economic reasonableness of removing the polluting properties from those wastes and to evidence relating to conditions calculated to result from that action and their relation to benefits to the people of the state and to

accomplishment of the purposes of this chapter. This determination was made based on data and information available at the time the permit was drafted, which included the contents of the timely submitted NPDES permit renewal application, along with any and all pertinent information available to the Director.

This public notice allows the permittee to provide to the Director for consideration during this public comment period additional site-specific pertinent and factual information with respect to the technical feasibility and economic reasonableness for achieving compliance with the proposed final effluent limitations for these parameters. The permittee shall email to [epa.dswcomments@epa.ohio.gov](mailto:epa.dswcomments@epa.ohio.gov) (preferred method) or deliver or mail this information to:

**Ohio Environmental Protection Agency  
Attention: Division of Surface Water  
Permits Processing Unit  
P.O. Box 1049  
Columbus, Ohio 43216-1049**

Should the applicant need additional time to review, obtain or develop site-specific pertinent and factual information with respect to the technical feasibility and economic reasonableness of achieving compliance with these limitations, a written request for any additional time shall be sent to the above address no later than 30 days after the Public Notice Date on Page 1.

Should the applicant determine that compliance with the proposed WQBELs for parameters other than the priority pollutants is technically and/or economically unattainable, the permittee may submit an application for a variance to the applicable WQS used to develop the proposed effluent limitation in accordance with the terms and conditions set forth in OAC 3745-33-07(D). The permittee shall submit this application to the above address no later than 30 days after the Public Notice Date.

Alternately, the applicant may propose the development of site-specific WQS pursuant to OAC 3745-1-39. The permittee shall submit written notification regarding their intent to develop site specific WQS for parameters that are not priority pollutants to the above address no later than 30 days after the Public Notice Date.

## LOCATION OF DISCHARGE/RECEIVING WATER USE CLASSIFICATION

Marion WPC discharges to Little Scioto River at River Mile 6.4. Figure 1 shows the approximate location of the facility.

This segment of the Little Scioto River is described by Ohio EPA River Code: 02-158, Hydrologic Unit Code: 05060001-03-03, County: Marion, Ecoregion: Eastern Corn Belt Plains. The Little Scioto River is designated for the following uses under Ohio's WQS (OAC 3745-1-09): Modified Warmwater Habitat, Agricultural Water Supply, Industrial Water Supply, Primary Contact Recreation.

Use designations define the goals and expectations of a waterbody. These goals are set for aquatic life protection, recreation use and water supply use, and are defined in the Ohio WQS (OAC 3745-1-07). The use designations for individual waterbodies are listed in rules -08 through -32 of the Ohio WQS. Once the goals are set, numeric WQS are developed to protect these uses. Different uses have different water quality criteria.

Use designations for aquatic life protection include habitats for coldwater fish and macroinvertebrates, warmwater aquatic life and waters with exceptional communities of warmwater organisms. These uses all meet the goals of the federal CWA. Ohio WQS also include aquatic life use designations for waterbodies which cannot meet the CWA goals because of human-caused conditions that cannot be remedied without causing fundamental changes to land use and widespread economic impact. The dredging and clearing of some small streams to support agricultural or urban drainage is the most common of these conditions. These streams are given Modified Warmwater or Limited Resource Water designations.

Recreation uses are defined by the depth of the waterbody and the potential for wading or swimming. Uses are defined for bathing waters, swimming/canoeing (Primary Contact Recreation) and wading only (Secondary Contact which are generally waters too shallow for swimming or canoeing).

Water supply uses are defined by the actual or potential use of the waterbody. Public Water Supply designations apply near existing water intakes so that waters are safe to drink with standard treatment. Most other waters are designated for agricultural water supply and industrial water supply.

## FACILITY DESCRIPTION

Marion WPC was constructed in 1924 and last upgraded in 2020. The average design flow is 10.5 million gallons per day (MGD), peak secondary treatment capacity is 42 MGD, and the peak hydraulic capacity is 51 MGD. Marion WPC serves the City of Marion, Village of Green Camp, Royal Oaks, Eagle Wood/Eagle Creek, and River Valley Trailer Park. Marion WPC has the following treatment processes (Figure 2):

- Screening
- Primary Settling
- Activated Sludge Aeration
- Secondary Clarification
- Chemical Addition
- Tertiary Clarification
- Chlorine Disinfection
- Dechlorination

The City of Marion has 50% separate sewers and 50% combined sewers in the collection system. The City's LTCP was initially submitted in August 2016, amended in January 2020, and approved by Ohio EPA on March 16, 2020. In the LTCP, the City proposed to control CSO discharges to nine events per typical year, which the City's hydraulic model projected to be equivalent to the capture of 95% of wet weather flows. The LTCP proposed a schedule to be implemented over nine phases and completed by December 31, 2044. At a cost of \$95M, the City's Financial Capability Analysis projected that the LTCP would place a "high burden" on the community. A compliance schedule with projects for the next ten years of LTCP implementation is proposed in Part I,C of the permit.

Marion WPC has one bypass, monitored as station 603. When influent flow rates exceed 42 MGD and the 5.0-MG equalization basin is full, flow is diverted after primary treatment and is directed to the chlorine contact tanks. Excess flow up to 9 MGD bypasses secondary treatment and is blended with fully treated effluent prior to monitoring at Outfall 001. The LTCP included an evaluation of feasible alternatives to eliminate bypasses at Marion WPC. Based on that assessment, the City has completed the following improvements in Phase 1 of the LTCP to increase treatment at the facility:

- Installation of a step feed system to allow an increase in existing secondary treatment capacity to 21 MGD
- Installation of the 5.0-MG storage basin to enable the capture of additional flows for secondary treatment.
- Capacity improvements to ensure that an additional 21 MGD would receive secondary treatment.

Marion WPC now has a peak secondary treatment capacity of 42 MGD, which the LTCP identified as the appropriate cut-off point at which flows should be diverted from the secondary treatment system. The remaining 9 MGD of peak flows receive at least solids and floatables removal, primary clarification, and disinfection (when necessary) for a total wet weather peak flow of 51 MGD. Given that these improvements and the remainder of the LTCP are projected to place a high financial burden on the community, it was determined to be infeasible to eliminate bypasses at Marion WPC. U.S. EPA's 1994 CSO Control Policy allows that such a feasible alternatives study in the LTCP is sufficient support for approval of a CSO-related bypass. Therefore, bypasses through station 603 are proposed to be approved as a CSO-related bypass.

The City of Marion has an approved pretreatment program. The City of Marion has 2 categorical users that discharge 0.413 MGD of flow. The City of Marion has four significant non-categorical users that discharge 0.294 MGD of flow.

Marion WPC utilizes the following sewage sludge treatment processes:

- Gravity Thickening
- Mechanical Dewatering Belt Press
- Polymer Addition

Table 1 shows the last five years of sludge removed from Marion WPC. Treated sludge is disposed of in a municipal landfill.

## **DESCRIPTION OF EXISTING DISCHARGE**

Table 2 presents the effluent violations for Marion WPC during the previous five years. The occurrence of effluent violations has decreased significantly since the completion of the Phase 1 plant improvements.

Table 3 presents the average annual effluent flow rate for Marion WPC for the previous five years. Marion WPC estimates there is an infiltration/inflow (I/I) rate to the collection system of 4 MGD Marion WPC performs the following activities to minimize I/I: Collection line replacement and repairs, grouting and implementing the CSO LTCP.

Table 4 presents the number of SSOs reported by Marion WPC for the previous five years. SSOs are reported at station 300. Projects implemented under the LTCP and additional I/I reduction efforts are anticipated to alleviate the persistent SSO and basement backup issues in the collection system.

Table 5 presents data characterizing bypass activity at Marion WPC for the previous five years. Bypasses are reported at station 603.

Table 6 presents the number of CSOs reported by Marion WPC during the previous five years. Marion WPC has three known combined sewer overflows (CSOs). In permit version 2PD00011\*QD, CSO monitoring station 005 was added for the Mt Vernon CSO. CSO 005 was deleted from previous permits because it was believed that all combined sewage was separated from the area. However, Sanitary wastewater was discovered to be present in the stormwater that discharged through the Mount Vernon Outfall. The sewer was reconnected into the combined system and the outfall designated as an active CSO.

Table 7 presents data characterizing the annual total phosphorus load from Marion WPC during the previous five years.

Table 8 presents chemical specific data compiled from data reported in annual pretreatment reported and data collected by Ohio EPA. Because this data is substantially identical to the application requirements in CFR 122.21(j), the Director has waived the requirement for submittal of supplemental effluent testing data as part of the NPDES renewal application.

Table 9 presents a summary of unaltered Discharge Monitoring Report (DMR). Data are presented for the period June 2018 through October 2023, and current permit limits are provided for comparison.

Table 10 summarizes the chemical specific data for outfall 001 by presenting the average and maximum PEQ values.

Table 11 summarizes the results of acute and chronic Whole Effluent Toxicity (WET) tests of the final effluent, using the water flea (*Ceriodaphnia dubia*) and fathead minnow (*Pimephales promelas*) as test organisms.

## **ASSESSMENT OF IMPACT ON RECEIVING WATERS**

Pursuant to Section 303(d) of the Clean Water Act, each state is required to develop and submit a list to US EPA of its impaired and threatened waters (e.g., stream/river segments, lakes). For each water on the list, the state identifies the pollutant(s) causing the impairment, when known. The City of Marion – Little Scioto River watershed assessment unit, which includes the Little Scioto River in the vicinity of Marion WPC, is listed as impaired for aquatic life and recreation on Ohio's 303(d) list.

The attainment status of the Little Scioto River is reported in the *Ohio 2024 Integrated Water Quality Monitoring and Assessment Report*. An assessment of the impact of a permitted point source on the immediate receiving waters includes an evaluation of the available chemical/physical, biological, and habitat data which have been collected by Ohio EPA pursuant to the Five-Year Basin Approach for Monitoring and NPDES Reissuance. Other data may be used provided it was collected in accordance with Ohio EPA methods and protocols as specified by the Ohio WQS and Ohio EPA guidance documents. Other information which may be evaluated includes but is not limited to: NPDES permittee self-monitoring data; effluent and mixing zone bioassays conducted by Ohio EPA, the permittee, or U.S. EPA.

In evaluating this data, Ohio EPA attempts to link environmental stresses and measured pollutant exposure to the health and diversity of biological communities. Stresses can include pollutant discharges (permitted and

unpermitted), land use effects, and habitat modifications. Indicators of exposure to these stresses include whole effluent toxicity tests, fish tissue chemical data, and fish health biomarkers (for example, fish blood tests).

Use attainment is a term which describes the degree to which environmental indicators are either above or below criteria specified by the Ohio WQS (OAC 3745-1). Assessing use attainment status for aquatic life uses primarily relies on the Ohio EPA biological criteria (OAC 3745-1-07; Table 7-1). These criteria apply to rivers and streams outside of mixing zones. Numerical biological criteria are based on measuring several characteristics of the fish and macroinvertebrate communities; these characteristics are combined into multimeric biological indices including the Index of Biotic Integrity and modified Index of Well-Being, which indicate the response of the fish community, and the Invertebrate Community Index, which indicates the response of the macroinvertebrate community. Numerical criteria are broken down by ecoregion, use designation, and stream or river size. Ohio has five ecoregions defined by common topography, land use, potential vegetation, and soil type.

Three attainment status results are possible at each sampling location -full, partial, or non-attainment. Full attainment means that all of the applicable indices meet the biocriteria. Partial attainment means that one or more of the applicable indices fails meet the biocriteria. Nonattainment means that either none of the applicable indices meet the biocriteria or one of the organism groups indicates poor or very poor performance. An aquatic life use attainment table (see Table 12) is constructed based on the sampling results and is arranged from upstream to downstream and includes the sampling locations indicated by river mile, the applicable biological indices, the use attainment status (i.e., full, partial, or non), the Qualitative Habitat Evaluation Index, and comments and observations for each sampling location.

The Little Scioto River in the vicinity of the City of Marion WPC is impaired for aquatic life and recreation due to the following: Sedimentation/Siltation, Direct Habitat Alterations, Dissolved Oxygen, Organic Enrichment, Metals, Abnormal Fish Deformities, Polycyclic Aromatic Hydrocarbon (PAHs) and Bacteria. Marion WPC is likely contributing to the impairments in Little Scioto River due to combined sewer overflow discharges and nutrient loading. Ohio EPA conducted a biological and water quality survey in the watershed in 2024 but data is not yet available.

There is historical creosote and PAH contamination in the sediment downstream of the Marion WPC discharge. A U.S. EPA funded sediment removal project is proposed in 2024. This project is the second sediment remediation project on this section of the Little Scioto River. The area for sediment removal is a 3.25 mile segment north of State Route 95 and ending at State Route 739. Contaminated sediment is proposed to be removed from the stream bed, dewatered, solidified, and hauled offsite for proper disposal. The project is projected to occur over the next three years.

The full Integrated Report is available through the Ohio EPA, Division of Surface Water website at:  
<https://epa.ohio.gov/divisions-and-offices/surface-water/reports-data/ohio-integrated-water-quality-monitoring-and-assessment-report>

The *Biological and Water Quality Study of the Upper Scioto River 2009 & 2011* is available through the Ohio EPA, Division of Surface Water website at:

<https://epa.ohio.gov/static/Portals/35/documents/UpperSciotoTSD2012.pdf>

## **DEVELOPMENT OF WATER-QUALITY-BASED EFFLUENT LIMITS**

Determining appropriate effluent concentrations is a multiple-step process in which parameters are identified as likely to be discharged by a facility, evaluated with respect to Ohio water quality criteria, and examined to determine the likelihood that the existing effluent could violate the calculated limits.

## Parameter Selection

Effluent data for the Marion WPC were used to determine what parameters should undergo WLA. The parameters discharged are identified by the data available to Ohio EPA, DMR data submitted by the permittee, compliance sampling data collected by Ohio EPA, and any other data submitted by the permittee, such as priority pollutant scans required by the NPDES application or by pretreatment, or other special conditions in the NPDES permit. The sources of effluent data used in this evaluation are as follows:

|                                   |                                |
|-----------------------------------|--------------------------------|
| Self-monitoring data (DMR)        | June 2018 through October 2023 |
| Pretreatment data                 | 2018-2022                      |
| Ohio EPA compliance sampling data | 2022                           |

## Statistical Outliers and Other Non-representative Data

The data were examined, and the following values were removed from the evaluation as non-representative data:

- Metal monitoring from 9/5/2022 was excluded, the data collected at this date appeared to occur during an upset condition.
- Zinc data prior to July 2019 was excluded, a source from an industry was removed from the influent after this date.

This data is evaluated statistically, and PEQ values are calculated for each pollutant. Average PEQ ( $PEQ_{avg}$ ) values represent the 95<sup>th</sup> percentile of monthly average data, and maximum PEQ ( $PEQ_{max}$ ) values represent the 95<sup>th</sup> percentile of all data points (see Table 10). See Modeling Guidance #1 for more information on PEQ calculations, available through the Ohio EPA, Division of Surface Water website at:

<https://www.epa.ohio.gov/portals/35/guidance/model1.pdf>

The PEQ values are used according to Ohio rules to compare to applicable WQS and allowable WLA values for each pollutant evaluated. Initially, PEQ values are compared to the applicable average and maximum WQS. If both PEQ values are less than 25 percent of the applicable WQS, the pollutant does not have the reasonable potential to cause or contribute to exceedances of WQS, and no WLA is done for that parameter. If either  $PEQ_{avg}$  or  $PEQ_{max}$  is greater than 25 percent of the applicable WQS, a WLA is conducted to determine whether the parameter exhibits reasonable potential and needs to have a limit or if monitoring is required (see Table 13).

## Wasteload Allocation

For those parameters that require a WLA, the results are based on the uses assigned to the receiving waterbody in OAC 3745-1. Dischargers are allocated pollutant loadings/concentrations based on the Ohio WQS (OAC 3745-1). Most pollutants are allocated by a mass-balance method because they do not break down in the receiving water. By rule, mixing zones are not authorized for pollutants, such as mercury, which have been designated as bioaccumulative chemicals of concern (BCCs). For BCCs, the WLA is set equal to the respective WQS value.

The methodology employed generally depends on whether the facility is considered a direct discharger to a (1) free-flowing receiving water/stream or (2) non-flowing receiving water/Lake. For free-flowing streams, WLAs for both average and maximum criteria are performed using the following general equation:

$$\text{Discharger WLA} = (\text{Downstream Flow} \times \text{WQS}) - (\text{Upstream Flow} \times \text{Background Concentration}).$$

Discharger WLAs are divided by the discharge flow so that the allocations are expressed as concentrations.

The applicable waterbody uses for this facility's discharge and the associated stream design flows are as follows:

Aquatic life (Warmwater Habitat)

|                                 |         |                    |
|---------------------------------|---------|--------------------|
| Toxics (metals, organics, etc.) | Average | Annual 7Q10        |
|                                 | Maximum | Annual 1Q10        |
| Ammonia                         | Average | Summer 30Q10       |
|                                 |         | Winter 30Q10       |
| Agricultural Water Supply       |         | Harmonic mean flow |
| Human Health (nondrinking)      |         | Harmonic mean flow |

Allocations are developed using a percentage of stream design flow as specified in Table 14, and allocations cannot exceed the Inside Mixing Zone Maximum (IMZM) criteria.

The data used in the WLA are listed in Table 13 and Table 14. The WLA results to maintain all applicable criteria are presented in Table 15.

### **Whole Effluent Toxicity Wasteload Allocation**

Whole effluent toxicity (WET) is the total toxic effect of an effluent on aquatic life measured directly with a toxicity test. Acute WET measures short term effects of the effluent while chronic WET measures longer term and potentially more subtle effects of the effluent. WQC for WET are 0.3 TUa for acute toxicity and 1.0 TUc for chronic toxicity (OAC 3745-1-44).

There are two separate reasonable potential procedures in Ohio - one for the Lake Erie watershed and one for the Ohio River watershed. Dischargers in the Ohio River watershed are assessed using OAC 3745-33-07(B). Dischargers in the Lake Erie watershed are assessed in accordance with the "Great Lakes Water Quality Initiative Implementation Procedures" contained in 40 CFR Part 132, Appendix F, Procedure 6.

The WLA calculations for WET are similar to those for aquatic life criteria - using the chronic toxicity unit (TUc) and 7Q10 flow for the average and the acute toxicity unit (TUa) and 1Q10 flow for the maximum. WET WLAs are based on meeting the values of 0.3 TUa and 1.0 TUc downstream of the discharge and include any available dilution. These values are the levels of effluent toxicity that should not cause instream toxicity during critical low-flow conditions. WLAs for acute toxicity are capped at 1.0 TUa unless the discharger demonstrates that an Area-of-Initial-Mixing (AIM) exists under OAC 3745-1-06, or that one of the factors in OAC 3745-33-07(B)(5)-(9) allows a higher TUa limit to be granted. For the purposes of establishing WET limitations, the values of 1.0 TUa and 1.0 TUc are the most restrictive limitations that can be applied in NPDES permits [OAC 3745-33-07(B)(10)].

For Marion WPC, the WLA values for outfall 001 are 0.3 TUa and 1.0 TUc.

The chronic toxicity unit (TUc) is defined as 100 divided by the estimate of the effluent concentration which causes a 25% reduction in growth or reproduction of test organisms (IC25):

$$TUc = 100/IC25$$

This equation applies outside the mixing zone for warmwater, modified warmwater, exceptional warmwater, coldwater, and seasonal salmonid use designations except when the following equation is more restrictive (Ceriodaphnia dubia only):

$TUc = 100/\text{geometric mean of No Observed Effect Concentration and Lowest Observed Effect Concentration}$

The acute toxicity unit (TUa) is defined as 100 divided by the concentration in water having 50% chance of causing death to aquatic life (LC50) for the most sensitive test species:

$$TUa = 100/LC50$$

This equation applies outside the mixing zone for all designated waters. Based on the above, a value of 1.0 TUa is the lowest value that can be calculated using the equation. TUa values between 0.2 and 1.0 are based on an interpolation of toxic effects where an LC50 cannot be identified.

When the acute WLA is less than 1.0 TUa, it may be defined as a ratio of the stream dilution to the effluent flow:

| Acute Dilution Ratio<br>(downstream flow to discharger flow) | Allowable Effluent Toxicity<br>(percent effects in 100% effluent) |
|--|---|
| up to 2 to 1   | 30  |
| greater than 2 to 1 but less than 2.7 to 1                   | 40  |
| 2.7 to 1 to 3.3 to 1   | 50  |

$$\text{Acute Dilution Ratio} = \frac{10Q_{10} + [\text{WWTP flow rate}]}{[\text{WWTP flow rate}]} = \frac{0 \text{ cfs} + 16.2 \text{ cfs}}{16.2 \text{ cfs}} = 1$$

The acute WLA for Marion WPC can be expressed as 30 percent mortality in 100 percent effluent based on the dilution ratio of 1 to 1. If the acute dilution ratio is less than 3.3 to 1.0, and there is evidence that effluent values between 0.3 TUa and 1.0 TUa cause or contribute to violations of WQS, the permittee may be required to investigate and remediate toxicity in this range.

## REASONABLE POTENTIAL/EFFLUENT LIMITS/MANAGEMENT DECISIONS

After appropriate effluent limits are calculated, the reasonable potential of the discharger to violate the WQS must be determined. Each parameter is examined and placed in a defined "group". Parameters that do not have a WQS or do not require a WLA based on the initial screening are assigned to either group 1 or 2. For the allocated parameters, the preliminary effluent limits (PEL) based on the most restrictive average and maximum WLAs are selected from Table 15. The average PEL ( $PEL_{avg}$ ) is compared to the average PEQ ( $PEQ_{avg}$ ) from Table 10, and the  $PEL_{max}$  is compared to the  $PEQ_{max}$ . Based on the calculated percentage of the allocated value [ $(PEQ_{avg} \div PEL_{avg}) \times 100$ , or  $(PEQ_{max} \div PEL_{max}) \times 100$ ], the parameters are assigned to group 3, 4, or 5. The groupings are listed in Table 16.

The final effluent limits are determined by evaluating the groupings in conjunction with other applicable rules and regulations. Table 17 presents the final effluent limits and monitoring requirements proposed for Marion WPC outfall 001 and the basis for their recommendation. Unless otherwise indicated, the monitoring frequencies proposed in the permit are continued from the existing permit.

### **Total Suspended Solids, 5-Day Carbonaceous Oxygen Demand, Dissolved Oxygen, and Ammonia**

The limits proposed for dissolved oxygen (DO), total suspended solids (TSS), 5-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>), and ammonia are all based on plant design criteria. The plant design limits were included in PTI number 03-7365 from 1993 that included upgrades to the chlorination and dechlorination treatment system. These limits are protective of WQS. The TSS and CBOD<sub>5</sub> limits are more stringent than the Secondary Treatment Standards in 40 CFR Part 133. The current ammonia limits have been evaluated using the WLA procedures and are protective of WQS for ammonia toxicity. The current dissolved oxygen limit is protective of WQS.

### **Total Residual Chlorine**

The existing daily effluent limit for total residual chlorine is proposed to continue as a plant design value which is based on protection of the inside mixing zone maximum (IMZM) and outside mixing zone maximum (OMZM) PELs. The most stringent daily maximum criterion is applied and is to be met anytime chlorine is being utilized for effluent disinfection. The limit has been evaluated using the WLA procedures and determined to be protective of WQS for chlorine toxicity.

### **Nitrite+Nitrate, and Total Kjeldahl Nitrogen**

Based on best technical judgment (BTJ), monitoring is recommended for, nitrite+nitrate, and total kjeldahl nitrogen. The Little Scioto River is listed as impaired for aquatic life usage. Nutrients and organic enrichment/dissolved oxygen are listed as causes of impairment and CSOs are listed as a source of impairment. The purpose of the monitoring is to maintain a nutrient data set for use in any future TMDL studies.

### **Oil and Grease, pH, and *Escherichia coli***

Limits proposed for oil and grease, pH, and *Escherichia coli* are based on WQS (OAC 3745-1-35 and 37). Primary contact recreation *E. coli* standards apply to the Little Scioto River.

### **Bis(2-ethylhexyl) phthalate, Dibenz(a,h) anthracene, Silver, and Zinc**

The Ohio EPA risk assessment (Table 16) places bis(2-ethylhexyl) phthalate, dibenz(a,h) anthracene, silver, and zinc in group 5. This placement, as well as the data in Table 9 and Table 10, indicates that the reasonable potential to exceed WQS exists and limits are necessary to protect water quality. For these parameters, the PEQ is greater than 100 percent of the WLA or the PEQ is between 75 and 100 percent of the WLA and certain conditions exist that increase the risk to the environment. Pollutants that meet this requirement must have permit limits under OAC 3745-33-07(A)(1). A compliance schedule is proposed to meet the effluent limits for bis(2-ethylhexyl) phthalate, dibenz(a,h) anthracene, and silver. A compliance schedule is not proposed for Zinc, based on the evaluation of EDMR data it is believed that the lower Zinc limits will be able to be met.

### **Bromodichloromethane, Total Filterable Residue, and Selenium**

The Ohio EPA risk assessment (Table 16) places bromodichloromethane, total filterable residue, and selenium in group 4. This placement, as well as the data in Table 9 and Table 10, support that these parameters do not have the reasonable potential to contribute to WQS exceedances, and limits are not necessary to protect water quality. Monitoring for Group 4 pollutants (where PEQ exceeds 50 percent of the WLA) is required by OAC 3745-33-07(A)(2). Limits for total filterable residue are proposed to be removed but monitoring will continue.

### **Cadmium, Chromium, Dissolved Hexavalent Chromium, Copper, Free Cyanide, Lead, Mercury, and Nickel**

The Ohio EPA risk assessment (Table 16) places cadmium, chromium, dissolved hexavalent chromium, copper, free cyanide, lead, mercury and nickel in groups 2 and 3. This placement, as well as the data in Table 9 and Table 10, support that these parameters do not have the reasonable potential to contribute to WQS exceedances, and limits are not necessary to protect water quality. Monitoring is proposed to document that these pollutants continue to remain at low levels. Limits for free cyanide are proposed to be removed but monitoring will continue.

### **Antimony, Arsenic, Barium, Chloroform, Dibromochloromethane, 1,4-Dichlorobenzene, Methyl ethyl ketone, Molybdenum, Strontium, Toluene, Methylene Chloride, and 1,3,5 Trimethylbenzene.**

The Ohio EPA risk assessment (Table 16) places antimony, arsenic, barium, chloroform, dibromochloromethane, 1,4-dichlorobenzene, methyl ethyl ketone, molybdenum, strontium, toluene, methylene chloride, and 1,3,5 trimethylbenzene in groups 2 and 3. This placement, as well as the data in Table 9 and Table 10, support that these parameters do not have the reasonable potential to contribute to WQS exceedances, and limits are not necessary to protect water quality. No new monitoring is proposed. Monitoring for barium and strontium are proposed to be removed. Data for these parameters will be available for future reasonable potential analyses through pretreatment program monitoring.

### **Temperature and Flow Rate**

Monitoring for these parameters is proposed to continue to evaluate the performance of the treatment plant.

### **Dissolved Orthophosphate and Total Phosphorus**

Monitoring for dissolved orthophosphate (as P) and total phosphorus is required by ORC 6111.03. This monitoring will further develop nutrient datasets that are used in stream and watershed assessments and studies. Because Ohio EPA monitoring, as well as other in-stream monitoring, for dissolved orthophosphate is taken by grab sample, grab samples are proposed for orthophosphate to maintain consistent data. The grab samples must be filtered within 15 minutes of collection using a 0.45-micron filter. The filtered sample must be analyzed within 48 hours.

### **Bis(2-ethylhexyl) phthalate, Bromodichloromethane, and Dibenz(a,h) anthracene**

Bis(2-ethylhexyl) phthalate, bromodichloromethane, dibenz(a,h) anthracene are carcinogens, which require the evaluation of the additive effect of these pollutants. OAC 3745-33-07(A)(8) states that a pollutant may be removed from the consideration of additivity if the PEL for the pollutant is less than the quantification level for that pollutant. For bis(2-ethylhexyl) phthalate and dibenz(a,h) anthracene, the average PELs are less than the respective quantification levels, so these parameters removed from additivity consideration. As a result, there is no additive effect and carcinogenic additivity is not proposed for inclusion in the permit.

### **Whole Effluent Toxicity Reasonable Potential**

Based on evaluating the WET data presented in Table 11 and Attachment 1, and other pertinent data under the provisions of OAC 3745-33-07(B), the Marion WPC is placed in Category 3 with respect to WET. No limits are proposed, but increased testing is proposed for the duration of the permit.

### **Additional Monitoring Requirements**

Monitoring for temperature, pH, and dissolved oxygen is proposed to be removed from the 801 upstream monitoring station because this data is currently not needed for the reasonable potential analysis. Monitoring for nitrate & nitrite is proposed to be added at stations 801 and 901 so that nutrient data is collected for future studies.

Monitoring requirements are proposed to be removed for total suspended solids and 5-day carbonaceous biochemical oxygen demand (CBOD<sub>5</sub>) from the combined sewer overflow monitoring tables because this data is not needed to characterize the overflows.

Additional monitoring requirements proposed at the final effluent, influent and upstream/downstream stations are included for all facilities in Ohio and vary according to the type and size of the discharge. In addition to permit compliance, this data is used to assist in the evaluation of effluent quality and treatment plant performance and for designing plant improvements and conducting future stream studies.

### **Sludge**

Limits and monitoring requirements proposed for the disposal of sewage sludge by the following management practices are based on OAC 3745-40: land application, removal to sanitary landfill or transfer to another facility with an NPDES permit.

## **OTHER REQUIREMENTS**

### **Compliance Schedule**

**Pretreatment Local Limits Review** - A 6-month compliance schedule is proposed for the City to submit a technical justification for either revising its local industrial user limits or retaining its existing local limits. If revisions to local limits are required, the City must also submit a pretreatment program modification request. Details are in Part I.C of the permit.

**Effluent limits** – A 36 month compliance schedule is proposed to meet the final effluent limits for. Details are in Part I.C of the permit

**Combined Sewer Overflow LTCP** – The schedule to implement the phases of the LTCP will be carried over in this permit. Details are in Part I.C of the permit.

### **Sanitary Sewer Overflow Reporting**

Provisions for reporting SSOs are again proposed in this permit. These provisions include: the reporting of the system-wide number of SSO occurrences on monthly operating reports; telephone notification of Ohio EPA and the local health department, and 5-day follow up written reports for certain high risk SSOs; and preparation of an annual report that is submitted to Ohio EPA and made available to the public. Many of these provisions were already required under the “Noncompliance Notification”, “Records Retention”, and “Facility Operation and Quality Control” general conditions in Part III of Ohio NPDES permits.

### **Operator Certification and Operator of Record**

Operator certification requirements have been included in Part II of the permit in accordance with rules effective on August 15, 2018 (OAC 3745-7). These rules require the Marion WPC to have a Class IV wastewater treatment plant operator in charge of the sewage treatment plant operations discharging through outfall 001. These rules also require the permittee to designate one or more operator of record to oversee the technical operation of the treatment works and sewerage system.

### **Method Detection Limit Reporting**

When submitting monitoring results in eDMR, the permittee must report all detected concentration values above the method detection limit (MDL), even if that value is below the quantification level. A detection above the MDL indicates the presence of a pollutant with strong confidence, which must be considered in reasonable potential analyses. Per OAC 3745-33-07(C)(2)(c), for the purpose of assessing compliance, any value reported below the quantification level shall be considered in compliance with an effluent limit.

### **Outfall Signage**

Part II of the permit includes requirements for the permittee to place and maintain a sign at each outfall to the Little Scioto River providing information about the discharge. Signage at outfalls is required pursuant to OAC 3745-33-08(A).

## **Part III**

Part III of the permit details standard conditions that include monitoring, reporting requirements, compliance responsibilities, and general requirements.


### **Stormwater Compliance**

To comply with industrial stormwater regulations, the permittee requested coverage under the industrial stormwater general permit. Permit 2GR00549\*GG became effective on 9/1/2022. No later than 90 days after the effective date of the renewed general permit, the permittee must request renewed coverage under the industrial storm water general permit or make other provisions to comply with the industrial storm water regulations.

Figure 1. Location of Marion WPC



**Figure 2. Diagram of Wastewater Treatment System**



**Table 1. Sewage Sludge Removal**

| Year | Dry Tons Removed |
|------|------------------|
| 2018 | 2700             |
| 2019 | 1730             |
| 2020 | 1790             |
| 2021 | 1540             |
| 2022 | 1590             |
| 2023 | 1628             |

**Table 2. Effluent Violations for Outfall 001**

| PARAMETER                | 2018 <sup>a</sup> | 2019      | 2020      | 2021      | 2022     | 2023 <sup>b</sup> | Total      |
|--------------------------|-------------------|-----------|-----------|-----------|----------|-------------------|------------|
| Chlorine, Total Residual | 0                 | 0         | 0         | 17        | 7        | 2                 | 26         |
| Dissolved Oxygen         | 11                | 40        | 23        | 12        | 0        | 1                 | 87         |
| E. coli                  | 2                 | 1         | 4         | 0         | 0        | 0                 | 7          |
| Nitrogen, Ammonia (NH3)  | 0                 | 1         | 0         | 1         | 0        | 0                 | 2          |
| Total Suspended Solids   | 0                 | 3         | 0         | 1         | 1        | 0                 | 5          |
| Zinc                     | 0                 | 5         | 0         | 0         | 0        | 0                 | 5          |
| pH, Minimum              | 0                 | 0         | 1         | 33        | 0        | 0                 | 34         |
| <b>Total</b>             | <b>13</b>         | <b>50</b> | <b>28</b> | <b>64</b> | <b>8</b> | <b>3</b>          | <b>166</b> |

<sup>a</sup> = data set begins on 6/1/18<sup>b</sup> = data set ends on 10/31/23**Table 3. Average Annual Effluent Flow Rates**

| Flow Rate (Million Gallons per Day) |       |         |        |                 |         |
|-------------------------------------|-------|---------|--------|-----------------|---------|
| Year                                | # obs | Average | Median | 95th Percentile | Maximum |
| 2018 <sup>a</sup>                   | 214   | 9.0     | 7.4    | 17.3            | 27.9    |
| 2019                                | 360   | 10.4    | 8.6    | 23.9            | 28.8    |
| 2020                                | 366   | 9.9     | 9.0    | 19.5            | 27.2    |
| 2021                                | 365   | 9.3     | 7.5    | 20.0            | 36.0    |
| 2022                                | 365   | 8.9     | 7.0    | 20.3            | 34.4    |
| 2023 <sup>b</sup>                   | 304   | 8.0     | 6.4    | 19.6            | 33.4    |

<sup>a</sup> = data set begins on 6/1/18<sup>b</sup> = data set ends on 10/31/23**Table 4. Sanitary Sewer Overflow Discharges**

| Year              | Number of SSOs |
|-------------------|----------------|
| 2018 <sup>a</sup> | 6              |
| 2019              | 13             |
| 2020              | 25             |
| 2021              | 12             |
| 2022              | 11             |
| 2023 <sup>b</sup> | 0              |

<sup>a</sup> = data set begins on 6/1/18<sup>b</sup> = data set ends on 10/31/23

**Table 5. Bypass Discharges**

| Outfall | Year              | Days with bypass flow | Annual Bypass Volume (MG) | Median Bypass Volume (MG) | Median TSS (mg/L) | Median CBOD (mg/L) |
|---------|-------------------|-----------------------|---------------------------|---------------------------|-------------------|--------------------|
| 603     | 2018 <sup>a</sup> | 9                     | 24                        | 2                         | 52                | 33                 |
| 603     | 2019              | 32                    | 88                        | 1                         | 56                | 37                 |
| 603     | 2020              | 18                    | 61                        | 2                         | 73                | 51                 |
| 603     | 2021              | 25                    | 102                       | 4                         | 112               | 38                 |
| 603     | 2022              | 5                     | 13                        | 3                         | 55                | 35                 |
| 603     | 2023 <sup>b</sup> | 2                     | 0.2                       | 0.1                       | 56                | 37                 |

<sup>a</sup> = data set begins on 6/1/18<sup>b</sup> = data set ends on 10/31/23**Table 6. Combined Sewer Overflow Discharges**

| Station No. | Occurrences       |      |      |      |      |                   | Volume (MG)       |       |       |       |       |                   |
|-------------|-------------------|------|------|------|------|-------------------|-------------------|-------|-------|-------|-------|-------------------|
|             | 2018 <sup>a</sup> | 2019 | 2020 | 2021 | 2022 | 2023 <sup>b</sup> | 2018 <sup>a</sup> | 2019  | 2020  | 2021  | 2022  | 2023 <sup>b</sup> |
| 003         | 25                | 45   | 46   | 42   | 41   | 33                | 9.8               | 81.1  | 103.4 | 143.4 | 211.8 | 6.8               |
| 004         | 28                | 46   | 46   | 55   | 46   | 41                | 58.9              | 117.2 | 103.6 | 101.3 | 263.7 | 36.5              |
| 005         | --                | --   | --   | 3    | 22   | 13                | --                | --    | --    | 0.09  | 7.2   | 4.1               |

<sup>a</sup> = data set begins on 6/1/18<sup>b</sup> = data set ends on 10/31/23**Table 7. Calculated Annual Total Phosphorus Loadings**

| Year              | Median Phosphorus (mg/L) | Median Flow (MGD) | Median Loading (kg/day) |
|-------------------|--------------------------|-------------------|-------------------------|
| 2018 <sup>a</sup> | 1.79                     | 7.4               | 50                      |
| 2019              | 1.72                     | 8.6               | 56                      |
| 2020              | 1.52                     | 9.0               | 52                      |
| 2021              | 2.22                     | 7.5               | 63                      |
| 2022              | 2.10                     | 7.0               | 56                      |
| 2023 <sup>b</sup> | 2.61                     | 6.4               | 63                      |

<sup>a</sup> = data set begins on 6/1/18<sup>b</sup> = data set ends on 10/31/23

MGD = million gallons per day

**Table 8. Effluent Characterization Using Pretreatment and Ohio EPA Data**

| Parameter                          | Ohio EPA   | Ohio EPA   | PT        | PT       | PT        | PT        | PT        |
|------------------------------------|------------|------------|-----------|----------|-----------|-----------|-----------|
|                                    | 3/28/2023  | 5/16/2023  | 7/26/2018 | 5/9/2019 | 6/22/2020 | 7/21/2021 | 7/13/2022 |
| Antimony                           | 0.74       | 0.808      | AA (5)    | AA (5)   | 2         | AA (5)    | AA (5)    |
| Arsenic                            | 1.53       | 1.87       | AA (5)    | AA (5)   | 1         | AA (5)    | AA (5)    |
| Cadmium                            | 0.043      | 0.0325     | AA (3)    | AA (3)   | AA (0.1)  | AA (3)    | AA (3)    |
| Chromium                           | 0.875      | 1.34       | AA (7)    | AA (7)   | 2         | AA (7)    | AA (7)    |
| Copper                             | 2.83       | 3.3        | AA (8)    | AA (8)   | 4         | AA (8)    | AA (8)    |
| Lead                               | 0.307      | 0.269      | AA (10)   | AA (10)  | AA (0.1)  | AA (10)   | AA (10)   |
| Nickel                             | 8.3        | 9.69       | 20        | 11       | 10        | 17        | 15        |
| Selenium                           | 1.59       | 0.778      | AA (4)    | AA (4)   | 1         | AA (4)    | AA (4)    |
| Silver                             | 0.06       | AA (0.01)  | AA (5)    | AA (5)   | AA (0.4)  | AA (5)    | AA (5)    |
| Strontium                          | 1620       | 3100       | NT        | NT       | NT        | NT        | NT        |
| Zinc                               | 36.1       | 48.5       | 345       | 315      | 83        | 77        | 71        |
| Nitrate + Nitrite (mg/L)           | 9.36       | 14.5       | NT        | NT       | NT        | NT        | NT        |
| Molybdenum                         | NT         | NT         | AA (20)   | AA (20)  | 20        | AA (20)   | AA (20)   |
| Chloroform                         | 0.683      | 3.88       | AA (5)    | AA (5)   | 0.7       | AA (5)    | AA (5)    |
| Acetone                            | AA (0.545) | 2.51       | NT        | NT       | NT        | NT        | NT        |
| Butylbenzene, tert-                | 0.448      | AA (0.207) | NT        | NT       | NT        | NT        | NT        |
| Chlorodibromomethane               | AA (0.15)  | 0.74       | AA (5)    | AA (5)   | AA (0.4)  | AA (5)    | AA (5)    |
| Dibenzo[a,h]anthracene             | AA (1.77)  | 1.93       | AA (10)   | AA (10)  | AA (1.37) | AA (10)   | AA (10)   |
| Dichlorobenzene, 1,4-              | 0.536      | AA (0.277) | AA (5)    | AA (5)   | AA (0.5)  | AA (5)    | AA (5)    |
| Dichlorobromomethane               | 0.589      | 1.78       | AA (5)    | AA (5)   | AA (0.4)  | AA (5)    | AA (5)    |
| Methyl ethyl ketone                | AA (0.511) | 0.647      | NT        | NT       | NT        | NT        | NT        |
| Methyl tertiary butyl ether (MTBE) | 0.939      | AA (0.644) | NT        | NT       | NT        | NT        | NT        |
| Methylene chloride                 | 0.608      | AA (0.303) | AA (10)   | AA (10)  | AA (0.6)  | AA (10)   | AA (10)   |
| Toluene                            | 2.6        | 0.63       | AA (5)    | AA (5)   | AA (0.4)  | AA (5)    | AA (5)    |
| Trihalomethanes (unspecified mix)  | 1.27       | 6.41       | NT        | NT       | NT        | NT        | NT        |
| Trimethylbenzene, 1,3,5-           | 0.443      | AA (0.182) | NT        | NT       | NT        | NT        | NT        |
| Bis (2-ethylhexyl) Phthalate       | AA (1.71)  | AA (1.79)  | AA (5)    | AA (5)   | AA (1.1)  | AA (5)    | AA (5)    |

Units in  $\mu\text{g/L}$ , unless otherwise noted

PT = pretreatment

AA = not-detected (analytical method detection limit)

**Table 9. Effluent Characterization Using Self-Monitoring Data**

| <b>Parameter</b>               | <b>Unit</b> | <b>Current Limits</b> |                  | <b># Obs</b> | <b>Percentiles</b> |             | <b>Data Range</b> |
|--------------------------------|-------------|-----------------------|------------------|--------------|--------------------|-------------|-------------------|
|                                |             | <b>30 Day</b>         | <b>Daily</b>     |              | <b>50th</b>        | <b>95th</b> |                   |
| Water Temperature              | °C          | Monitoring Only       |                  | 1963         | 18.7               | 27.6        | 9.4 - 30          |
| Dissolved Oxygen               | mg/L        | --                    | 5.0 <sup>m</sup> | 1935         | 7.4                | 5.1*        | 0 - 11.4          |
| Total Suspended Solids         | kg/day      | 477                   | 715 <sup>w</sup> | 1256         | 84.6               | 430         | 0 - 3590          |
| Total Suspended Solids         | mg/L        | 12                    | 18 <sup>w</sup>  | 1261         | 2.8                | 8           | 0 - 61            |
| Oil and Grease                 | mg/L        | --                    | 10               | 152          | --                 | --          | < 5               |
| Nitrogen, Ammonia - Summer     | kg/day      | 40                    | 60 <sup>w</sup>  | 673          | 2.78               | 51.2        | 0 - 224           |
| Nitrogen, Ammonia - Summer     | mg/L        | 1.0                   | 1.5 <sup>w</sup> | 678          | .11                | 1.47        | 0 - 4.44          |
| Nitrogen, Ammonia - Winter     | kg/day      | 100                   | 159 <sup>w</sup> | 574          | 2.78               | 62.1        | 0 - 416           |
| Nitrogen, Ammonia - Winter     | mg/L        | 2.5                   | 4.0 <sup>w</sup> | 574          | .0718              | 1.18        | 0 - 9.14          |
| Nitrogen Kjeldahl, Total       | mg/L        | Monitoring Only       |                  | 66           | 1.7                | 4.24        | 0 - 7.4           |
| Nitrite Plus Nitrate, Total    | mg/L        | Monitoring Only       |                  | 65           | 9.16               | 15.2        | 3.4 - 22.8        |
| Phosphorus, Total              | mg/L        | Monitoring Only       |                  | 229          | 1.95               | 4.22        | .0626 - 6.08      |
| Orthophosphate, Dissolved      | mg/L        | Monitoring Only       |                  | 66           | 1.81               | 4.87        | .079 - 35.8       |
| Barium, TR                     | µg/L        | Monitoring Only       |                  | 63           | 30.2               | 40.8        | 15.9 - 43         |
| Nickel, TR                     | µg/L        | Monitoring Only       |                  | 63           | 9                  | 18.9        | 0 - 42.1          |
| Silver, TR                     | µg/L        | Monitoring Only       |                  | 63           | < 1                | < 1         | 0 - 1.72          |
| Strontium, TR                  | µg/L        | Monitoring Only       |                  | 63           | 2270               | 3700        | 1000 - 4260       |
| Zinc, TR - All                 | kg/day      | --                    | 12               | 58           | 1.98               | 10.7        | .32 - 18.3        |
| Zinc, TR - All                 | µg/L        | --                    | 300              | 59           | 66                 | 234         | 16.6 - 418        |
| Zinc, TR - Quarterly           | µg/L        | Monitoring Only       |                  | 4            | 322                | 375         | 206 - 378         |
| Cadmium, TR                    | µg/L        | Monitoring Only       |                  | 63           | < 2                | < 2         | 0 - 42.8          |
| Lead, TR                       | µg/L        | Monitoring Only       |                  | 63           | < 2                | 1.65        | 0 - 38.5          |
| Chromium, TR                   | µg/L        | Monitoring Only       |                  | 63           | < 5                | < 5         | 0 - 37.7          |
| Copper, TR                     | µg/L        | Monitoring Only       |                  | 63           | < 5                | 6.01        | 0 - 48.1          |
| Chromium, Dissolved Hexavalent | µg/L        | Monitoring Only       |                  | 59           | --                 | --          | < 4               |
| E. coli                        | #/100 mL    | 126                   | 284 <sup>w</sup> | 1061         | 26                 | 816         | 0 - 2420          |
| Bis(2-ethylhexyl) Phthalate    | µg/L        | Monitoring Only       |                  | 65           | < 5                | < 5         | 0 - 4.9           |
| Flow Rate                      | MGD         | Monitoring Only       |                  | 1974         | 7.68               | 20.2        | 2.38 - 36         |
| Chlorine, Total Residual       | mg/L        | --                    | 0.019            | 1073         | < .01              | < .01       | 0 - 1.47          |
| Mercury, Total                 | kg/day      | 0.0005                | 0.012            | 11           | .00002             | .0000823    | 0 - .0000866      |

| Parameter                             | Unit   | Current Limits  |                  | # Obs | Percentiles |       | Data Range   |
|---------------------------------------|--------|-----------------|------------------|-------|-------------|-------|--------------|
|                                       |        | 30 Day          | Daily            |       | 50th        | 95th  |              |
| Mercury, Total - 2018-2019            | ng/L   | 12              | 300              | 11    | .609        | 1.17  | 0 - 1.5      |
| Mercury, Total - 2019-2023            | ng/L   | Monitoring Only |                  | 55    | .765        | 1.76  | 0 - 2.68     |
| Cyanide, Free (Low-Level) - All       | kg/day | 0.48            | 1.84             | 55    | < .0647     | .0975 | 0 - .368     |
| Cyanide, Free (Low-Level) - All       | µg/L   | 12              | 46               | 55    | < 3         | 5.21  | 0 - 10       |
| Cyanide, Free (Low-Level) - Quarterly | µg/L   | Monitoring Only |                  | 4     | --          | --    | < 3          |
| Acute Toxicity, Ceriodaphnia dubia    | TUa    | Monitoring Only |                  | 5     | --          | --    | < .2         |
| Chronic Toxicity, Ceriodaphnia dubia  | TUc    | Monitoring Only |                  | 5     | < 1         | 1.84  | 0 - 2.3      |
| Acute Toxicity, Pimephales promelas   | TUa    | Monitoring Only |                  | 6     | < .2        | 1.03  | 0 - 1.3      |
| Chronic Toxicity, Pimephales promelas | TUc    | Monitoring Only |                  | 6     | < 1         | 1.35  | 0 - 1.8      |
| pH, Maximum                           | S.U.   | --              | 9.0              | 1876  | 7.58        | 8.02  | 6.56 - 8.89  |
| pH, Minimum                           | S.U.   | --              | 6.5 <sup>m</sup> | 1876  | 7.35        | 6.88* | 6.08 - 8.71  |
| Residue, Total Filterable             | kg/day | 59700           | --               | 152   | 20000       | 42500 | 4910 - 70800 |
| Residue, Total Filterable             | mg/L   | 1500            | --               | 152   | 650         | 879   | 230 - 1400   |
| CBOD 5 day                            | kg/day | 398             | 596 <sup>w</sup> | 1110  | 55.9        | 208   | 0 - 2180     |
| CBOD 5 day                            | mg/L   | 10              | 15 <sup>w</sup>  | 1115  | 2           | 4     | 0 - 27       |

\* = For minimum pH, 5th percentile shown in place of 50th percentile.

\*\* = For dissolved oxygen, 5th percentile shown in place of 95th percentile.

<sup>a</sup> = weekly average.

<sup>m</sup> = minimum limit

**Table 10. Projected Effluent Quality for Outfall 001**

| Parameter                               | Units | Number of Samples | Number > MDL | PEQ Average | PEQ Maximum |
|---|-------|-------------------|--------------|-------------|-------------|
| Ammonia (Summer)                        | mg/L  | 471               | 441          | 0.85        | 1.8         |
| Ammonia (Winter)                        | mg/L  | 296               | 257          | 0.7         | 1.5         |
| Antimony                                | µg/L  | 3                 | 3            | 4.38        | 6           |
| Arsenic - TR                            | µg/L  | 3                 | 3            | 4.10        | 5.61        |
| Barium                                  | µg/L  | 63                | 63           | 38.6        | 47.9        |
| Bis(2-ethylhexyl) phthalate             | µg/L  | 68                | 1            | 3.65        | 5           |
| Bromodichloromethane                    | µg/L  | 3                 | 2            | 3.90        | 5.34        |
| tert-Butylbenzene                       | µg/L  | 2                 | 1            | 1.24        | 1.70        |
| Cadmium - TR                            | µg/L  | 2                 | 2            | 0.12        | 0.16        |
| Chloroform<br>(Trichloromethane)        | µg/L  | 7                 | 3            | 7.3         | 10          |
| Chromium - TR                           | µg/L  | 65                | 3            | 3.65        | 5           |
| Hexavalent Chromium<br>(Dissolved)      | µg/L  | 59                | 0            | --          | --          |
| Copper - TR                             | µg/L  | 69                | 13           | 4.6         | 7.2         |
| Cyanide, Free                           | µg/L  | 59                | 5            | 2           | 7.4         |
| Dibenz(a,h)anthracene                   | µg/L  | 3                 | 1            | 4.22        | 5.79        |
| Dibromochloromethane                    | µg/L  | 3                 | 1            | 1.62        | 2.22        |
| 1,4-Dichlorobenzene                     | µg/L  | 3                 | 1            | 1.17        | 1.61        |
| Total Filterable Residue                | mg/L  | 152               | 152          | 793         | 940         |
| Lead - TR                               | µg/L  | 59                | 5            | 2.20        | 3.01        |
| Mercury                                 | ng/L  | 66                | 53           | 1.4         | 2.1         |
| Methyl ethyl ketone                     | µg/L  | 2                 | 1            | 1.79        | 2.46        |
| Molybdenum                              | µg/L  | 5                 | 1            | 33.6        | 46          |
| Nickel - TR                             | µg/L  | 69                | 50           | 15.5        | 21.7        |
| Nitrate-N + Nitrite-N                   | mg/L  | 67                | 67           | 14.3        | 19.4        |
| Selenium - TR                           | µg/L  | 3                 | 3            | 3.48        | 4.77        |
| Silver                                  | µg/L  | 50                | 4            | 1.25        | 1.72        |
| Strontium                               | µg/L  | 65                | 65           | 3184        | 4098        |
| Toluene                                 | µg/L  | 3                 | 2            | 5.69        | 7.8         |
| Zinc - TR                               | µg/L  | 62                | 62           | 148         | 224         |
| Methylene chloride<br>(Dichloromethane) | µg/L  | 3                 | 1            | 1.33        | 1.82        |
| 1,3,5-Trimethylbenzene                  | µg/L  | 2                 | 1            | 1.23        | 1.68        |
| Chlorine, Total Residual                | mg/L  | 1073              | 30           | 0.54        | 0.74        |

MDL = analytical method detection limit

PEQ = projected effluent quality

\* Per OAC 3745-2-04(E)(3), ammonia PEQ is based on data collected during the following months:

Summer – June through September

Winter – December through February

**Table 11. Summary of Acute and Chronic Toxicity Results**

| <b>Date</b> | <i>Ceriodaphnia dubia</i>     |                                 | <i>Pimephales promelas</i>    |                                 |
|-------------|-------------------------------|---------------------------------|-------------------------------|---------------------------------|
|             | <b>Acute (TU<sub>a</sub>)</b> | <b>Chronic (TU<sub>c</sub>)</b> | <b>Acute (TU<sub>a</sub>)</b> | <b>Chronic (TU<sub>c</sub>)</b> |
| 7/1/2018    | AA (0.2)                      | AA (1.0)                        | AA (0.2)                      | AA (1.0)                        |
| 7/1/2019    | AA (0.2)                      | AA (1.0)                        | AA (0.2)                      | AA (1.0)                        |
| 7/1/2020    | AA (0.2)                      | AA (1.0)                        | AA (0.2)                      | AA (1.0)                        |
| 7/1/2021    | AA (0.2)                      | 2.3                             | 1.3                           | 1.8                             |
| 7/26/2022   | AA (0.2)                      | AA (1.0)                        | AA (0.2)                      | AA (1.0)                        |
| 7/25/2023   | AE ()                         | AE ()                           | .2                            | AA (1.0)                        |
| 8/28/2023   | AA (0.2)                      | AA (1.0)                        | --                            | --                              |

AA = non-detection; analytical method detection limit of 0.2 TU<sub>a</sub>, 1.0 TU<sub>c</sub>

AE = test not valid

TU<sub>a</sub> = acute toxicity unitTU<sub>c</sub> = chronic toxicity unit**Table 12. Use Attainment Table**

| <b>Location</b>  | <b>RM</b> | <b>Use</b> | <b>Status</b> | <b>Cause</b>  | <b>Source</b>          |
|--|-----------|------------|---------------|---|------------------------|
| Little Scioto River at Marion, upstream of Marion WPC, downstream of Rockswale Ditch | 6.50      | MWH-C      | PARTIAL       | Organic Enrichment/ dissolved oxygen<br>Habitat alterations | CSOs<br>Channelization |
| Little Scioto River at landfill, Township Road 97-A                                  | 6.24      | MWH-C      | PARTIAL       | Organic Enrichment/ dissolved oxygen<br>Habitat alterations | CSOs<br>Channelization |
| Little Scioto River at Green Camp, at Owens-Green Camp Road                          | 0.39      | MWH-C      | NON           | Sediment contamination, chronic ammonia                     | CSOs<br>Creosote       |

Data gathered from Table 2, *Biological and Water Quality Study of the Upper Scioto River 2009 & 2011*

MWH-C = Modified warmwater habitat (channelized)

**Table 13. Water Quality Criteria in the Study Area**

| Parameter                            | Units | Outside Mixing Zone Criteria |              |              | Maximum Aquatic Life | Inside Mixing Zone Maximum |  |  |
|--------------------------------------|-------|------------------------------|--------------|--------------|----------------------|----------------------------|--|--|
|                                      |       | Average                      |              | Human Health |                      |                            |  |  |
|                                      |       | Agri-culture                 | Aquatic Life |              |                      |                            |  |  |
| Ammonia (Summer)                     | mg/L  | --                           | --           | 2.7          | --                   | --                         |  |  |
| Ammonia (Winter)                     | mg/L  | --                           | --           | 4.8          | --                   | --                         |  |  |
| Antimony                             | µg/L  | 640                          | --           | 190          | 900                  | 1800                       |  |  |
| Arsenic - TR                         | µg/L  | --                           | 100          | 150          | 340                  | 680                        |  |  |
| Barium                               | µg/L  | --                           | --           | 1500         | 6300                 | 13000                      |  |  |
| Bis(2-ethylhexyl)phthalate           | µg/L  | 3.7 <sup>c</sup>             | --           | 8.4          | 1100                 | 2100                       |  |  |
| Bromodichloromethane                 | µg/L  | 5.6 <sup>c</sup>             | --           | --           | --                   | --                         |  |  |
| tert-Butylbenzene                    | µg/L  | --                           | --           | --           | --                   | --                         |  |  |
| Cadmium - TR                         | µg/L  | --                           | 50           | 5.2          | 13                   | 27                         |  |  |
| Chloroform (Trichloromethane)        | µg/L  | 20000 <sup>c</sup>           | --           | 140          | 1300                 | 2600                       |  |  |
| Chromium - TR                        | µg/L  | --                           | 100          | 190          | 3900                 | 7900                       |  |  |
| Hexavalent Chromium (Dissolved)      | µg/L  | --                           | --           | 11           | 16                   | 31                         |  |  |
| Copper - TR                          | µg/L  | --                           | 500          | 21           | 34                   | 69                         |  |  |
| Cyanide, Free                        | µg/L  | 400                          | --           | 12           | 46                   | 92                         |  |  |
| Dibenz(a,h)anthracene                | µg/L  | 0.0013 <sup>c</sup>          | --           | --           | --                   | --                         |  |  |
| Dibromochloromethane                 | µg/L  | 210 <sup>c</sup>             | --           | --           | --                   | --                         |  |  |
| 1,4-Dichlorobenzene                  | µg/L  | 900                          | --           | 9.4          | 57                   | 110                        |  |  |
| Total Filterable Residue             | mg/L  | --                           | --           | 1500         | --                   | --                         |  |  |
| Lead - TR                            | µg/L  | --                           | 100          | 22           | 410                  | 830                        |  |  |
| Mercury                              | ng/L  | 12                           | 10000        | 910          | 1700                 | 3400                       |  |  |
| Methyl ethyl ketone                  | µg/L  | --                           | --           | 22000        | 200000               | 400000                     |  |  |
| Molybdenum                           | µg/L  | --                           | --           | 20000        | 190000               | 370000                     |  |  |
| Nickel - TR                          | µg/L  | 4600                         | 200          | 120          | 1100                 | 2100                       |  |  |
| Nitrate-N + Nitrite-N                | mg/L  | --                           | 100          | --           | --                   | --                         |  |  |
| Selenium - TR                        | µg/L  | 4200                         | 50           | 5            | 62                   | 120                        |  |  |
| Silver                               | µg/L  | --                           | --           | 1.3          | 8.3                  | 17                         |  |  |
| Strontium                            | µg/L  | --                           | --           | 72000        | 190000               | 380000                     |  |  |
| Toluene                              | µg/L  | 520                          | --           | 62           | 560                  | 1100                       |  |  |
| Zinc - TR                            | µg/L  | 26000                        | 25000        | 270          | 270                  | 540                        |  |  |
| Methylene chloride (Dichloromethane) | µg/L  | 10000 <sup>c</sup>           | --           | 1900         | 11000                | 22000                      |  |  |
| 1,3,5-Trimethylbenzene               | µg/L  | 950                          | --           | 26           | 230                  | 460                        |  |  |
| Chlorine, Total Residual             | mg/L  | --                           | --           | 0.011        | 0.019                | 0.038                      |  |  |

<sup>c</sup> carcinogen

**Table 14. Instream Conditions and Discharger Flow**

| Parameter                          | Units | Season  | Value  | Basis                                     |
|------------------------------------|-------|---------|--------|---|
| <i>Stream Flows</i>                |       |         |        |   |
| 1Q10                               | cfs   | annual  | 0      | USGS station 03218000 1938-1971           |
| 7Q10                               | cfs   | annual  | 0      | USGS station 03218000 1938-1971           |
| 30Q10                              | cfs   | summer  | 0      | USGS station 03218000 1938-1971           |
|                                    |       | winter  | 0.12   | USGS station 03218000 1938-1971           |
| 90Q10                              | cfs   | annual  | 0      | USGS station 03218000 1938-1971           |
| Harmonic Mean                      | cfs   | annual  | 1.66   | USGS station 03218000 1938-1971           |
| Mixing Assumption                  | %     | average | 100    |   |
|                                    |       | maximum | 100    |   |
| <i>Hardness, OMZ</i>               |       |         |        |   |
| Hardness, OMZ                      | mg/L  | annual  | 260    | 901 Station 50th percentile n=66          |
| <i>Hardness, IMZ</i>               |       |         |        |   |
| Hardness, IMZ                      | mg/L  | annual  | 260    | 901 Station 50th percentile n=66          |
| pH                                 | S.U.  | summer  | 7.7    | 901 station 75th percentile n=38          |
|                                    |       | winter  | 7.8    | 901 station 75th percentile n=21          |
| Temperature                        | °C    | summer  | 22.5   | 901 station 75th percentile n=38          |
|                                    |       | winter  | 8.7    | 901 station 75th percentile n=21          |
| Marion WPC flow                    | cfs   | annual  | 16.246 | NPDES Application Form 2A                 |
| <i>Background Water Quality</i>    |       |         |        |   |
| Ammonia (Summer)                   | mg/L  |         | 0.109  | EDMR; 2018-2023; n=39; 0<MDL; 801 Station |
| Ammonia (Winter)                   | mg/L  |         | 0.132  | EDMR; 2018-2023; n=20; 0<MDL; 801 Station |
| Antimony                           | µg/L  |         | 0      | No representative data available.         |
| Arsenic - TR                       | µg/L  |         | 1.57   | OEPA; 2023; n=1; 0<MDL; Station 610750    |
| Barium                             | µg/L  |         | 57     | OEPA; 2023; n=1; 0<MDL; Station 610750    |
| Bis(2-ethylhexyl)phthalate         | µg/L  |         | 0      | No representative data available.         |
| Bromodichloromethane               | µg/L  |         | 0      | No representative data available.         |
| tert-Butylbenzene                  | µg/L  |         | 0      | No representative data available.         |
| Cadmium - TR                       | µg/L  |         | 0.0938 | OEPA; 2023; n=1; 0<MDL; Station 610750    |
| Chloroform<br>(Trichloromethane)   | µg/L  |         | 0      | No representative data available.         |
| Chromium - TR                      | µg/L  |         | 2.9    | OEPA; 2023; n=1; 0<MDL; Station 610750    |
| Hexavalent Chromium<br>(Dissolved) | µg/L  |         | 0      | No representative data available.         |
| Copper - TR                        | µg/L  |         | 4.49   | OEPA; 2023; n=1; 0<MDL; Station 610750    |
| Cyanide, Free                      | µg/L  |         | 0      | No representative data available.         |
| Dibenz(a,h)anthracene              | µg/L  |         | 0      | No representative data available.         |
| Dibromochloromethane               | µg/L  |         | 0      | No representative data available.         |
| 1,4-Dichlorobenzene                | µg/L  |         | 0      | No representative data available.         |
| Total Filterable Residue           | mg/L  |         | 0      | No representative data available.         |
| Lead - TR                          | µg/L  |         | 2.85   | OEPA; 2023; n=1; 0<MDL; Station 610750    |
| Mercury                            | ng/L  |         | 0      | No representative data available.         |
| Methyl ethyl ketone                | µg/L  |         | 0      | No representative data available.         |

| Parameter                               | Units | Season | Value | Basis                                  |
|---|-------|--------|-------|--|
| Molybdenum                              | µg/L  |        | 0     | No representative data available.      |
| Nickel - TR                             | µg/L  |        | 5.24  | OEPA; 2023; n=1; 0<MDL; Station 610750 |
| Nitrate-N + Nitrite-N                   | mg/L  |        | 0     | No representative data available.      |
| Selenium - TR                           | µg/L  |        | 0.716 | OEPA; 2023; n=1; 0<MDL; Station 610750 |
| Silver                                  | µg/L  |        | 0     | No representative data available.      |
| Strontium                               | µg/L  |        | 448   | OEPA; 2023; n=1; 0<MDL; Station 610750 |
| Toluene                                 | µg/L  |        | 0     | No representative data available.      |
| Zinc - TR                               | µg/L  |        | 17.9  | OEPA; 2023; n=1; 0<MDL; Station 610750 |
| Methylene chloride<br>(Dichloromethane) | µg/L  |        | 0     | No representative data available.      |
| 1,3,5-Trimethylbenzene                  | µg/L  |        | 0     | No representative data available.      |
| Chlorine, Total Residual                | mg/L  |        | ?     | No representative data available.      |

MDL = analytical method detection limit

n = number of samples

OEPA = Ohio Environmental Protection Agency

**Table 15. Summary of Effluent Limits to Maintain Applicable Water Quality Criteria**

| Parameter                            | Units | Outside Mixing Zone Criteria |              |              | Maximum Aquatic Life | Inside Mixing Zone Maximum |  |  |
|--------------------------------------|-------|------------------------------|--------------|--------------|----------------------|----------------------------|--|--|
|                                      |       | Average                      |              | Human Health |                      |                            |  |  |
|                                      |       | Agri-culture                 | Aquatic Life |              |                      |                            |  |  |
| Ammonia (Summer)                     | mg/L  | --                           | --           | 2.7          | --                   | --                         |  |  |
| Ammonia (Winter)                     | mg/L  | --                           | --           | 4.83         | --                   | --                         |  |  |
| Antimony                             | µg/L  | 705                          | --           | 190          | 900                  | 1800                       |  |  |
| Arsenic - TR                         | µg/L  | --                           | 110          | 150          | 340                  | 680                        |  |  |
| Barium                               | µg/L  | --                           | --           | 1500         | 6300                 | 13000                      |  |  |
| Bis(2-ethylhexyl)phthalate           | µg/L  | 4.1 <sup>c</sup>             | --           | 8.4          | 1100                 | 2100                       |  |  |
| Bromodichloromethane                 | µg/L  | 6.2 <sup>c</sup>             | --           | --           | --                   | --                         |  |  |
| tert-Butylbenzene                    | µg/L  | --                           | --           | --           | --                   | --                         |  |  |
| Cadmium - TR                         | µg/L  | --                           | 55           | 5.2          | 13                   | 27                         |  |  |
| Chloroform (Trichloromethane)        | µg/L  | 22044 <sup>c</sup>           | --           | 140          | 1300                 | 2600                       |  |  |
| Chromium - TR                        | µg/L  | --                           | 110          | 190          | 3900                 | 7900                       |  |  |
| Hexavalent Chromium (Dissolved)      | µg/L  | --                           | --           | 11           | 16                   | 31                         |  |  |
| Copper - TR                          | µg/L  | --                           | 551          | 21           | 34                   | 69                         |  |  |
| Cyanide, Free                        | µg/L  | 441                          | --           | 12           | 46                   | 92                         |  |  |
| Dibenz(a,h)anthracene                | µg/L  | 0.0014 <sup>c</sup>          | --           | --           | --                   | --                         |  |  |
| Dibromochloromethane                 | µg/L  | 231                          | --           | --           | --                   | --                         |  |  |
| 1,4-Dichlorobenzene                  | µg/L  | 992                          | --           | 9.4          | 57                   | 110                        |  |  |
| Total Filterable Residue             | mg/L  | --                           | --           | 1500         | --                   | --                         |  |  |
| Lead - TR                            | µg/L  | --                           | 110          | 22           | 410                  | 830                        |  |  |
| Mercury <sup>B</sup>                 | ng/L  | 12                           | 10000        | 910          | 1700                 | 3400                       |  |  |
| Methyl ethyl ketone                  | µg/L  | --                           | --           | 22000        | 200000               | 400000                     |  |  |
| Molybdenum                           | µg/L  | --                           | --           | 20000        | 190000               | 370000                     |  |  |
| Nickel - TR                          | µg/L  | 5069                         | 220          | 120          | 1100                 | 2100                       |  |  |
| Nitrate-N + Nitrite-N                | mg/L  | --                           | 110          | --           | --                   | --                         |  |  |
| Selenium - TR                        | µg/L  | 4629                         | 55           | 5            | 62                   | 120                        |  |  |
| Silver                               | µg/L  | --                           | --           | 1.3          | 8.3                  | 17                         |  |  |
| Strontium                            | µg/L  | --                           | --           | 72000        | 190000               | 380000                     |  |  |
| Toluene                              | µg/L  | 573                          | --           | 62           | 560                  | 1100                       |  |  |
| Zinc - TR                            | µg/L  | 28655                        | 27553        | 270          | 270                  | 540                        |  |  |
| Methylene chloride (Dichloromethane) | µg/L  | 11022 <sup>c</sup>           | --           | 1900         | 11000                | 22000                      |  |  |
| 1,3,5-Trimethylbenzene               | µg/L  | 1047                         | --           | 26           | 230                  | 460                        |  |  |
| Chlorine, Total Residual             | mg/L  | --                           | --           | 0.011        | 0.019                | 0.038                      |  |  |

<sup>B</sup> Bioaccumulative Chemical of Concern (BCC); no mixing zone allowed after 11/15/2010, WQS must be met at end-of-pipe, unless requirements for an exception are met as listed in OAC 3745-2-05(A)(2)(e)(ii)

<sup>c</sup> carcinogen

**Table 16. Parameter Assessment**

Group 1: Due to a lack of criteria, the following parameters could not be evaluated at this time.

tert-Butylbenzene

Group 2: PEQ < 25 percent of WQS or all data below minimum detection limit.

WLA not required. No limit recommended; monitoring optional.

|                                 |                       |                        |
|---------------------------------|-----------------------|------------------------|
| Antimony                        | Arsenic - TR          | Barium                 |
| Cadmium - TR                    | Chloroform            |                        |
| Hexavalent Chromium (Dissolved) | (Trichloromethane)    | Chromium - TR          |
| Dibromochloromethane            | Copper - TR           | Cyanide, Free          |
| Mercury                         | 1,4-Dichlorobenzene   | Lead - TR              |
| Nickel - TR                     | Methyl ethyl ketone   | Molybdenum             |
| Toluene                         | Nitrate-N + Nitrite-N | Strontium              |
|                                 | Methylene chloride    | 1,3,5-Trimethylbenzene |
|                                 | (Dichloromethane)     |                        |

Group 3: PEQ<sub>max</sub> < 50 percent of maximum PEL and PEQ<sub>avg</sub> < 50 percent of average PEL.

No limit recommended; monitoring optional.

*No Parameters in this group*

Group 4: PEQ<sub>max</sub> >= 50 percent, but < 100 percent of the maximum PEL or PEQ<sub>avg</sub> >= 50 percent, but < 100 percent of the average PEL. Monitoring is appropriate.

Bromodichloromethane      Total Filterable Residue      Selenium - TR

Group 5: Maximum PEQ >= 100 percent of the maximum PEL or average PEQ >= 100 percent of the average PEL, or either the average or maximum PEQ is between 75 and 100 percent of the PEL and certain conditions that increase the risk to the environment are present. Limit recommended.

Limits to Protect Numeric Water Quality Criteria

| Parameter                   | Units | Recommended Effluent Limits |         |
|-----------------------------|-------|-----------------------------|---------|
|                             |       | Average                     | Maximum |
| Bis(2-ethylhexyl) phthalate | µg/L  | 4.1                         | 1100    |
| Dibenz(a,h)anthracene       | µg/L  | 0.0014                      | --      |
| Silver                      | µg/L  | 1.3                         | 8.3     |
| Zinc - TR                   | µg/L  | 270                         | 270     |
| Chlorine, Total Residual    | mg/L  | 0.011                       | 0.019   |

PEL = preliminary effluent limit

PEQ = projected effluent quality

WLA = wasteload allocation

WQS = water quality standard

**Table 17. Final Effluent Limits for Outfall 001**

| Parameter                                       | Units    | Concentration    |                | Loading (kg/day) <sup>a</sup> |                | Basis <sup>b</sup> |
|---|----------|------------------|----------------|-------------------------------|----------------|--------------------|
|   |          | Daily Maximum    | 30 Day Average | Daily Maximum                 | 30 Day Average |                    |
| Water Temperature                               | °C       | --               | Monitor        | --                            | --             | M <sup>c</sup>     |
| Dissolved Oxygen                                | mg/L     | 5.0 <sup>m</sup> | --             | --                            | --             | WQS                |
| TSS   | mg/L     | 18 <sup>d</sup>  | 12             | 715 <sup>d</sup>              | 477            | PD                 |
| Oil & Grease                                    | mg/L     | 10               | --             | --                            | --             | WQS                |
| Ammonia (summer)                                | mg/L     | 1.5 <sup>d</sup> | 1.0            | 60 <sup>d</sup>               | 40             | PD                 |
| Ammonia (winter)                                | mg/L     | 4.0 <sup>d</sup> | 2.5            | 159 <sup>d</sup>              | 100            | PD                 |
| Total Kjeldahl Nitrogen                         | mg/L     | --               | Monitor        | --                            | --             | M                  |
| Nitrate plus Nitrite                            | mg/L     | --               | Monitor        | --                            | --             | M                  |
| Phosphorus                                      | mg/L     | --               | Monitor        | --                            | --             | PMR                |
| Orthophosphate                                  | mg/L     | --               | Monitor        | --                            | --             | PMR                |
| Selenium  | µg/L     | --               | Monitor        | --                            | --             | RP                 |
| Nickel  | µg/L     | --               | Monitor        | --                            | --             | M                  |
| Silver  | µg/L     | 8.3              | 1.3            | 0.33                          | 0.052          | RP                 |
| Zinc  | µg/L     | 270              | --             | 11                            | --             | RP                 |
| Cadmium   | µg/L     | --               | Monitor        | --                            | --             | M                  |
| Lead  | µg/L     | --               | Monitor        | --                            | --             | M                  |
| Chromium  | µg/L     | --               | Monitor        | --                            | --             | M                  |
| Copper  | µg/L     | --               | Monitor        | --                            | --             | M                  |
| Dissolved Hexavalent Chromium                   | µg/L     | --               | Monitor        | --                            | --             | M                  |
| <i>E. coli</i>                                  | #/100 mL | 284 <sup>d</sup> | 126            | --                            | --             | WQS                |
| Bromodichloromethane                            | µg/L     | --               | Monitor        | --                            | --             | RP                 |
| Dibenzo (A,H) Anthracene                        | µg/L     | --               | 0.0014         | --                            | 0.000056       | RP                 |
| Bis(2-ethylhexyl) Phthalate                     | µg/L     | 1100             | 4.1            | 44                            | 0.164          | RP                 |
| Flow Rate                                       | MGD      | --               | Monitor        | --                            | --             | M <sup>c</sup>     |
| Chlorine  | mg/L     | 0.019            | --             | --                            | --             | PD/WLA             |
| Mercury   | ng/L     | --               | Monitor        | --                            | --             | M                  |
| Free Cyanide                                    | µg/L     | --               | Monitor        | --                            | --             | M                  |
| Acute Toxicity,<br><i>Ceriodaphnia dubia</i>    | TUa      | --               | Monitor        | --                            | --             | WET                |
| Chronic Toxicity,<br><i>Ceriodaphnia dubia</i>  | TUC      | --               | Monitor        | --                            | --             | WET                |
| Acute Toxicity,<br><i>Pimephales promelas</i>   | TUa      | --               | Monitor        | --                            | --             | WET                |
| Chronic Toxicity,<br><i>Pimephales promelas</i> | TUC      | --               | Monitor        | --                            | --             | WET                |
| Total Filterable Residue                        | mg/L     | --               | Monitor        | --                            | --             | RP                 |
| pH, maximum                                     | SU       | 9.0              | --             | --                            | --             | WQS                |
| pH, minimum                                     | SU       | 6.5 <sup>m</sup> | --             | --                            | --             | WQS                |
| CBOD5   | mg/L     | 15 <sup>d</sup>  | 10             | 596 <sup>d</sup>              | 398            | PD                 |

<sup>a</sup> Effluent loadings based on average design discharge flow of 10.5 MGD.

<sup>b</sup> Definitions:

M = Division of Surface Water NPDES Permit Guidance 1: Monitoring frequency requirements for Sanitary Discharges

PD = Plant Design (OAC 3745-33-05(E))

PMR = Phosphorus monitoring requirements (ORC 6111.03)

RP = Reasonable Potential for requiring water quality-based effluent limits and monitoring requirements in permits (OAC 3745-33-07(A))

WLA = Wasteload Allocation procedures (OAC 3745-2)

WQS = Ohio Water Quality Standards (OAC 3745-1)

WET = Minimum testing requirements for whole effluent toxicity [OAC 3745-33-07(B)(11)]

WQS = Ohio Water Quality Standards (OAC 3745-1)

<sup>c</sup> Monitoring of flow and other indicator parameters is specified to assist in the evaluation of effluent quality and treatment plant performance.

<sup>d</sup> 7 day average limit.

<sup>m</sup> minimum limit

## Attachment 1. Whole Effluent Toxicity Reasonable Potential Analysis

Whole effluent toxicity testing produced only non-detection results for acute toxicity in *Ceriodaphnia dubia*, and therefore it falls under Hazard Category 4. The reasonable potential analyses in Tables 3B, 3C, and 3D were only performed for chronic *Ceriodaphnia dubia* (TUC CD) and *Pimephales promelas* acute (TUA PP) and chronic toxicity (TUC PP).

### Hazard Category Summary

|                             | <i>Ceriodaphnia dubia</i> |         | <i>Pimephales promelas</i> |         |
|-----------------------------|---------------------------|---------|----------------------------|---------|
|                             | Acute                     | Chronic | Acute                      | Chronic |
| Effluent Toxicity (Table A) | 4                         | 3       | 4                          | 3       |
| Near-Field Impact (Table B) | 4                         |         | 3                          |         |
| Far-field Impact (Table C)  |                           | 3       |                            | 4       |
|                             |                           | 3       |                            | 3       |

Hazard Categories:  
 1: Toxicity adequately documented  
 2: Toxicity strongly suspected  
 3: Toxicity possible  
 4: No toxicity

Table A. Effluent Toxicity

|   | <i>Ceriodaphnia dubia</i> |         | <i>Pimephales promelas</i> |         |
|---|---------------------------|---------|----------------------------|---------|
|   | Acute                     | Chronic | Acute                      | Chronic |
| WLA   | 0.3                       | 1.0     | 0.3                        | 1.0     |
| # of tests  | 6                         | 6       | 6                          | 6       |
| Maximum value   | AA                        | 2.3     | 1.3                        | 1.8     |
| Percent of tests >WLA                                   | --                        | 17      | 17                         | 17      |
| Geometric mean  | --                        | 1.2     | 0.27                       | 1.1     |
| Average Exceedance<br>(Geomean * Percent of tests >WLA) | --                        | 0.20    | 0.05                       | 0.19    |
| Average Exceedance / WLA                                | --                        | 0.2     | 0.17                       | 0.19    |

| Attribute Evaluated  | Hazard Category 1                  | Hazard Category 2  | Hazard Category 3                     | Hazard Category 4             |
|--|------------------------------------|--------------------|---------------------------------------|-------------------------------|
| Degree of Toxicity   | Adequately Documented              | Strongly Suspected | Possible                              | None                          |
| (1) Minimum number of tests  | 3<br><br>TUC Cd<br>TUA, TUC Pp     | 1                  | 0 or 1                                | 0 or 1                        |
| (2) Percent of tests >WLA  | >30                                | 20 to 30           | 10 to 20<br><br>TUC Cd<br>TUA, TUC Pp | 10                            |
| (3) Average Exceedance/WLA <sup>1</sup><br>(Tables B and C data available) |                                    |                    |                                       |                               |
| (a) Acute <sup>2</sup>   | > 0.5                              | ≥ 0.3              | ≥ 0.3                                 | < 0.3<br><br>TUA PP           |
| (b) Chronic  | >0.67                              | ≥ 0.5              | ≥ 0.5                                 | < 0.5<br><br>TUC Pp<br>TUC Cd |
| (4) Maximum TU value<br>(Tables 3B and 3C data available)                  | > WLA<br><br>TUC Cd<br>TUA, TUC Pp | ≥ WLA              | ≥ 0.5xWLA                             | < 0.5xWLA                     |

Table B. Near-Field Toxicity

| Attribute Evaluated                           | Hazard Category 1                                 | Hazard Category 2                                   | Hazard Category 3  | Hazard Category 4   |
|---|---|---|--|---|
| Degree of Toxicity                            | Adequately Documented                             | Strongly Suspected                                  | Possible   | None  |
| (1) Mortality within mixing zone <sup>3</sup> | $\geq 20\%$                                       | $\leq 20\%$   | $\leq 20\%$  | $< 20\%$  |
| (2) Stream community impact                   |   |   |  |   |
| (a) implied chemically <sup>4, 6</sup>        | $\geq 3 \times \text{IMZM}$ or<br>$> \text{LC50}$ | $\geq 1.5 \times \text{IMZM}$ or<br>$> \text{LC50}$ | $\geq 0.75 \times \text{IMZM}$ or<br>$> 0.75 \times \text{LC50}$ | $\leq 0.5 \times \text{IMZM}$ or<br>$\leq 0.75 \times \text{LC50}$<br><b>TUa Pp</b> |
| (b) implied toxicologically <sup>4</sup>      | $\geq 1.0 \text{ TUa}$                            | $\geq 1.0 \text{ TUa}$                              | $\geq 1.0 \text{ TUa}$<br><b>TUa Pp</b>                          | $< 1.0 \text{ TUa}$   |
| (c) implied biologically                      | Toxic   | Fair/poor community                                 | Slight impact  | None<br><b>TUa Pp</b>   |

Table C. Far-Field Toxicity

| Attribute Evaluated  | Hazard Category 1     | Hazard Category 2           | Hazard Category 3        | Hazard Category 4                      |
|--|-----------------------|-----------------------------|--------------------------|--|
| Degree of Toxicity   | Adequately Documented | Strongly Suspected          | Possible                 | None                                   |
| (1) Aquatic life use impairment (Ohio EPA biological criteria)   | Yes <sup>5</sup>      | Yes or partial <sup>5</sup> | Partial                  | None<br><b>TUc Cd,<br/>TUc Pp</b>      |
| (2) Stream community impact implied toxicologically <sup>3</sup> | Significant effect    | Significant effect          | Unknown or slight effect | None<br><b>TUc Cd,<br/>TUc Pp</b>      |
| (3) Other indicators   | Stress indicated      | Stress indicated            | Stress indicated         | No stress<br><b>TUc Cd,<br/>TUc Pp</b> |

<sup>1</sup> Compare (per cent exceedances x geometric mean TU) to table factor.

<sup>2</sup> Use 0.3 x WLA for situations where AIM exists.

<sup>3</sup> Results of ambient toxicity test are not binding or required for classification as to category but, if available, will be interpreted under the weight of evidence principle giving due consideration as to sampling location and conditions.

<sup>4</sup> Based on effluent data. May not be appropriate for situations where AIM exists.

<sup>5</sup> Lack of attainment due to toxic, complex or unidentifiable type of impact.

<sup>6</sup> The LC50-based criteria are used only for pollutant parameters that do not have numeric criteria.

## Attachment 2. Acronyms

|          |   |
|----------|---|
| ABS      | Anti-backsliding                                |
| BPJ      | Best professional judgment                      |
| CFR      | Code of Federal Regulations                     |
| CMOM     | Capacity Management, Operation, and Maintenance |
| CONSWLA  | Conservative substance wasteload allocation     |
| CSO      | Combined sewer overflow                         |
| CWA      | Clean Water Act                                 |
| DMR      | Discharge Monitoring Report                     |
| DMT      | Dissolved metal translator                      |
| IMZM     | Inside mixing zone maximum                      |
| LTCP     | Long-term Control Plan                          |
| MDL      | Analytical method detection limit               |
| MGD      | Million gallons per day                         |
| NPDES    | National Pollutant Discharge Elimination System |
| OAC      | Ohio Administrative Code                        |
| Ohio EPA | Ohio Environmental Protection Agency            |
| ORC      | Ohio Revised Code                               |
| ORSANCO  | Ohio River Valley Water Sanitation Commission   |
| PEL      | Preliminary effluent limit                      |
| PEQ      | Projected effluent quality                      |
| PMP      | Pollution Minimization Program                  |
| PPE      | Plant performance evaluation                    |
| SSO      | Sanitary sewer overflow                         |
| TMDL     | Total Daily Maximum Load                        |
| TRE      | Toxicity reduction evaluation                   |
| TU       | Toxicity unit                                   |
| U.S. EPA | United States Environmental Protection Agency   |
| WET      | Whole effluent toxicity                         |
| WLA      | Wasteload allocation                            |
| WPCF     | Water Pollution Control Facility                |
| WQBEL    | Water-quality-based effluent limit              |
| WQS      | Water Quality Standards                         |
| WWTP     | Wastewater Treatment Plant                      |