# Ohio Environmental Protection Agency Modification of National Pollutant Discharge Elimination System (NPDES) Permit

Action Date: September 1, 2022

Existing Permit No.: 2PD00026\*TD

Effective Date: November 1, 2022

Application No.: OH0021415

Entity Name: City of St. Marys WWTP

Facility Location: 410 Defiance Road, St. Marys, Ohio, 45885

In accordance with Rule 3745-33-04 (D) of the Ohio Administrative Code (formerly Ohio EPA Regulation EP-31-06), the above referenced NPDES Permit is hereby modified as follows:

## Revision

- 1) Part I,C Item B revisions to the compliance schedule for addressing untreated bypass discharges at the WWTP.
- 2) Part I,C Item E a separate compliance schedule for SSO elimination was added

Attached is the modified NPDES permit.

All terms and conditions of the existing permit not recommended for modification by this document will remain in effect. Any modified term or condition contained in this modification shall supersede, on the date this modification is effective, the existing respective term or condition of the permit.

When the modification is effective, the Ohio EPA permit number will be changed to 2PD00026\*UD. The application number will remain OH0021415.

Laurie A. Stevenson

Lamie a Stevenson

Director

Application No. OH0021415

Modification Action Date: September 1, 2022

Modification Effective Date: November 1, 2022

Expiration Date: April 30, 2023

Ohio Environmental Protection Agency Authorization to Discharge Under the National Pollutant Discharge Elimination System

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as the "Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code Section 6111),

City of St. Marys

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA," to discharge from the City of St. Marys wastewater treatment works located at 410 Defiance Road, St. Marys, Ohio, Auglaize County and discharging to the St. Marys River in accordance with the conditions specified in Parts I, II, and III of this permit.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

Laurie A. Stevenson

Lami a Stevenson

Director

Total Pages: 47

# Part I, A. INITIAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date and lasting until October 31, 2022, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 - Initial

Effluent Characteristic			Dischar	ge Limitati	<u>ons</u>			Mon	itoring Requires	<u>nents</u>
		centration Sp	ecified Ur	nits	Lo	oading* kg	g/day			
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Maximum	All
									Indicating	
									Thermometer	
00300 - Dissolved Oxygen - mg/l	-	6.0	-	-	-	-	-	1/Day	Multiple	All
			•			400			Grab	
00530 - Total Suspended Solids -	-	-	36	24	-	409	273	3/Week	24hr	All
mg/l	10.0							105 1	Composite	. 11
00552 - Oil and Grease, Hexane Extr	10.0	-	-	-	-	-	-	1/Month	Grab	All
Method - mg/l			2.0	1.2		22.0	140	2/11/	2.41	
00610 - Nitrogen, Ammonia (NH3) -	-	-	2.0	1.3	-	22.8	14.8	3/Week	24hr	Summer
mg/l			7.1	4.7		00.7	52.4	2/33/ 1	Composite	177.
00610 - Nitrogen, Ammonia (NH3) -	-	-	7.1	4.7	-	80.7	53.4	3/Week	24hr	Winter
mg/l								1 /N / 41.	Composite	A 11
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00630 - Nitrite Plus Nitrate, Total -							_	1/Month	24hr	All
mg/l	-	-	-	-	-	_	-	1/Monun	Composite	All
00665 - Phosphorus, Total (P) - mg/l		_	1.5	1.0		17.1	11.4	1/Week	24hr	All
00003 - Phosphorus, Total (P) - hig/1	_	_	1.5	1.0	-	1/.1	11.4	17 W CCK	Composite	AII
00671 - Orthophosphate, Dissolved	_	_	_	_	_	_	-	1/Month	Grab	All
(as P) - mg/l	_	_				_	_	1/1VIOITIII	Glao	7 111
00981 - Selenium, Total	_	_	_	_	_	_	_	1/Quarter	24hr	Quarterly
Recoverable - ug/l								17 Quarter	Composite	Quarterry
01074 - Nickel, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l									Composite	
01094 - Zinc, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l									Composite	

										2PD00026*I
01113 - Cadmium, Total	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
Recoverable - ug/l									Composite	
01114 - Lead, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l									Composite	
01118 - Chromium, Total	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
Recoverable - ug/l									Composite	
01119 - Copper, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l									Composite	
01220 - Chromium, Dissolved	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
Hexavalent - ug/l										
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	3/Week	Grab	Summer
39100 - Bis(2-ethylhexyl) Phthalate	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly
- ug/l										
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50092 - Mercury, Total (Low Level)	1700	-	-	5.1	0.0194	-	0.000058	1/Month	Grab	All
- ng/l										
51173 - Cyanide, Free (Low-Level)	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
- ug/l										
61425 - Acute Toxicity,	-	-	-	-	-	-	-	2/Year	24hr	June and
Ceriodaphnia dubia - TUa									Composite	Aug
61426 - Chronic Toxicity,	-	-	-	-	-	-	-	2/Year	24hr	June and
Ceriodaphnia dubia - TUc									Composite	Aug
61427 - Acute Toxicity, Pimephales	-	-	-	-	-	-	-	1/Year	24hr	June
promelas - TUa									Composite	
61428 - Chronic Toxicity,	-	-	-	-	-	-	-	1/Year	24hr	June
Pimephales promelas - TUc									Composite	
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Multiple	All
									Grab	
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Multiple	All
									Grab	
70300 - Residue, Total Filterable -	-	-	-	-	-	-	-	1/Month	24hr	All
mg/l									Composite	
80082 - CBOD 5 day - mg/l	-	-	15	10	-	171	114	3/Week	24hr	Summer
									Composite	
80082 - CBOD 5 day - mg/l	-	-	31.6	20	-	359	228	3/Week	24hr	Winter
									Composite	

Notes for station 2PD00026001:
- Effluent loadings based on average design flow of 3.0 MGD.

- a. Operator Certification Requirements See Part II, Item A.
- b. Composite Samples See Part II, Item F.
- c. Grab Samples See Part II, Item G.
- d. Multiple Grab Samples See Part II, Item H.
- e. Nickel, Zinc, Cadmium, Lead, Total Chromium, Selenium & Copper See Part II, Item L.
- f. Dissolved Hexavalent Chromium See Part II, Item M.
- g. Mercury See Part II, Item M, S, U, V, and W.
- h. Pretreatment Program Requirements See Part II, Item T.
- i. Whole effluent toxicity See Compliance Schedule, Item A and Part II, Items X and Y.
- j. Bis (2-ethylhexyl) phthalate See Part II, Items L and AA.
- k. Orthophosphate Monitoring See Part II, Item Z

# Part I, A. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

2. During the period beginning November 1, 2022 and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 2PD00026001. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Final Outfall - 001 - Final

Effluent Characteristic			Dischar	ge Limitati	<u>ons</u>			Mon	itoring Requires	ments_
	Cone	centration Sp	ecified Ur	nits	Lo	oading* kg	g/day			
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Maximum	All
									Indicating	
									Thermometer	
00300 - Dissolved Oxygen - mg/l	-	6.0	-	-	-	-	-	1/Day	Multiple	All
									Grab	
00530 - Total Suspended Solids -	-	-	36	24	-	409	273	3/Week	24hr	All
mg/l									Composite	
00552 - Oil and Grease, Hexane Extr	10.0	-	-	-	-	-	-	1/Month	Grab	All
Method - mg/l										
00610 - Nitrogen, Ammonia (NH3) -	-	-	2.0	1.3	-	22.8	14.8	3/Week	24hr	Summer
mg/l									Composite	
00610 - Nitrogen, Ammonia (NH3) -	-	-	7.1	4.7	-	80.7	53.4	3/Week	24hr	Winter
mg/l									Composite	
00625 - Nitrogen Kjeldahl, Total -	-	-	-	-	-	-	-	1/Month	24hr	All
mg/l									Composite	
00630 - Nitrite Plus Nitrate, Total -	-	-	-	-	-	-	-	1/Month	24hr	All
mg/l									Composite	
00665 - Phosphorus, Total (P) - mg/l	-	-	1.5	1.0	-	17.1	11.4	1/Week	24hr	All
									Composite	
00671 - Orthophosphate, Dissolved	-	-	-	-	-	-	-	1/Month	Grab	All
(as P) - mg/l										
00981 - Selenium, Total	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
Recoverable - ug/l									Composite	
01074 - Nickel, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l									Composite	
01094 - Zinc, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l									Composite	

										2PD00026*
01113 - Cadmium, Total	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
Recoverable - ug/l								`	Composite	
01114 - Lead, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l								-	Composite	
01118 - Chromium, Total	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
Recoverable - ug/l									Composite	
01119 - Copper, Total Recoverable -	-	-	-	-	-	-	-	1/Quarter	24hr	Quarterly
ug/l									Composite	
01220 - Chromium, Dissolved	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
Hexavalent - ug/l										
31648 - E. coli - #/100 ml	-	-	284	126	-	-	-	3/Week	Grab	Summer
39100 - Bis(2-ethylhexyl) Phthalate	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly
- ug/l										
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50092 - Mercury, Total (Low Level)	1700	-	-	5.1	0.0194	-	0.000058	1/Month	Grab	All
- ng/l										
51173 - Cyanide, Free (Low-Level)	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
- ug/l										
61425 - Acute Toxicity,	1.0	-	-	-	-	-	-	2/Year	24hr	June and
Ceriodaphnia dubia - TUa									Composite	Aug
61426 - Chronic Toxicity,	-	-	-	1.11	-	-	-	2/Year	24hr	June and
Ceriodaphnia dubia - TUc									Composite	Aug
61427 - Acute Toxicity, Pimephales	-	-	-	-	-	-	-	1/Year	24hr	June
promelas - TUa									Composite	
61428 - Chronic Toxicity,	-	-	-	-	-	-	-	1/Year	24hr	June
Pimephales promelas - TUc									Composite	
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Multiple	All
									Grab	
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Multiple	All
									Grab	
70300 - Residue, Total Filterable -	-	-	-	-	-	-	-	1/Month	24hr	All
mg/l									Composite	
80082 - CBOD 5 day - mg/l	-	-	15	10	-	171	114	3/Week	24hr	Summer
							1		Composite	
80082 - CBOD 5 day - mg/l	-	-	31.6	20	-	359	228	3/Week	24hr	Winter
									Composite	

Notes for station 2PD00026001:
- Effluent loadings based on average design flow of 3.0 MGD.

- a. Operator Certification Requirements See Part II, Item A.
- b. Composite Samples See Part II, Item F.
- c. Grab Samples See Part II, Item G.
- d. Multiple Grab Samples See Part II, Item H.
- e. Nickel, Zinc, Cadmium, Lead, Total Chromium, Selenium & Copper See Part II, Item L.
- f. Dissolved Hexavalent Chromium See Part II, Item M.
- g. Mercury See Part II, Item M, S, U, V, and W.
- h. Pretreatment Program Requirements See Part II, Item T.
- i. Whole effluent toxicity See Compliance Schedule, Item A and Part II, Items X and Y.
- j. Bis (2-ethylhexyl) phthalate See Part II, Items L and AA.
- k.Orthophosphate Monitoring See Part II, Item Z

## Part I, B. - BYPASS MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. Bypass Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment plant's bypass when discharging, at Station Number 2PD00026009, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Bypass Monitoring - 009 - Final

Effluent Characteristic	Discharge I	<u>Limitations</u>						Monitoring	Requiremen	<u>its</u>
	Concentrati	on Specified	Units		Loadin	g* kg/day				
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
00051 - Bypass Occurrence -	-	-	-	-	-	-	-	When	24hr	All
No./Day								Disch.	Total	
00052 - Bypass Total Hours Per Day	-	-	-	-	-	-	-	When	24hr	All
- Hrs/Day								Disch.	Total	
00530 - Total Suspended Solids -	-	-	-	-	-	-	-	When	Grab	All
mg/l								Disch.		
51428 - Bypass Volume - MGAL	-	-	-	-	-	-	-	When	24hr	All
• •								Disch.	Total	
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	When	Grab	All
								Disch.		

Notes for Station Number 2PD00026009:

- a. Data for 24 hour total flow, bypass occurrence, and bypass duration may be estimated if a measuring device is not available.
- b. A Discharge Monitoring Report (DMR) for this station must be submitted every month.
- c. Monitoring and sampling shall be conducted and reported on each day that there is a discharge through this station.
- d. If there are no discharges during the entire month, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- e. Bypass Occurrence: If a discharge from this station occurs intermittently during a day, starting and stopping several times, report "1" for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence: Report "1" on the first day of the discharge.
- f. Discharge through this station is prohibited. The Director may take enforcement action for violations of this prohibition unless the three conditions specified at 40 CFR 122.41(m) and in Part III, Item 11.C.1 of this permit are met.

## Part I, B. - SSO MONITORING EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

2. SSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 2PD00026300, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - SSO Monitoring - 300 - Final

Effluent Characteristic	Discharge I	Limitations						Monitoring	Requiremen	<u>its</u>
	Concentrati	on Specified	Units		Loadin	g* kg/day				
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
				-				Frequency	Type	Months
74062 - Overflow Occurrence -	-	-	-	-	-	-	-	1/Month	Total	All
No./Month										

Notes for Station Number 2PD00026300:

- a. A sanitary sewer overflow is an overflow, spill, release, or diversion of wastewater from a sanitary sewer system. Although the above table indicates that the Measuring Frequency for Overflow Occurrence is 1/Month, the intent of that provision is to specify a reporting frequency for Overflow Occurrence, not a monitoring frequency. The monitoring requirement under this permit is that these overflows shall be monitored on each day when they discharge. Only sanitary sewer overflows that enter waters of the state, either directly or through a storm sewer or other conveyance, must be reported under this monitoring station.
- b. For the purpose of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day that enters waters of the state is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, record two occurrences for that day. If overflows from both locations continue on the following day, record two occurrences for the following day. At the end of the month, total the daily occurrences and report this number on Day 1 of the DMR. If there are no overflows during the entire month, report "zero" (0).
- c. All sanitary sewer overflows are prohibited.
- d. See Part II, Items D and E.

# Part I, B. - SLUDGE MONITORING REQUIREMENTS

3. Sludge Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' final sludge at Station Number 2PD00026581, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 581 - Final

Effluent Characteristic			Discharg	ge Limitatio	<u>ons</u>			Monitoring	Requirement	<u>s</u>
	Cone	centration Sp	ecified U	nits	Lo	oading* kg	g/day			
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
00611 - Ammonia (NH3) In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00627 - Nitrogen Kjeldahl, Total In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00668 - Phosphorus, Total In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00938 - Potassium In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01003 - Arsenic, Total In Sludge - mg/kg	75	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01028 - Cadmium, Total In Sludge - mg/kg	85	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01043 - Copper, Total In Sludge - mg/kg	4300	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01052 - Lead, Total In Sludge - mg/kg	840	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01068 - Nickel, Total In Sludge - mg/kg	420	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01093 - Zinc, Total In Sludge - mg/kg	7500	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01148 - Selenium, Total In Sludge - mg/kg	100	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
51129 - Sludge Fee Weight - dry tons	-	-	-	-	-	-	-	1/Quarter	Total	Quarterly - Alt.
51131 - Fecal Coliform in Sludge - CFU/gram	2000000	-	-	-	-	-	-	1/Quarter	Multiple Grab	Quarterly - Alt.

70316 - Sludge Weight - Dry Tons	-	-	-	-	-	-	-	1/Quarter	Total	Quarterly -
										Alt.
71921 - Mercury, Total In Sludge -	57	-	-	-	-	-	-	1/Quarter	Composite	Quarterly -
mg/kg										Alt.
78465 - Molybdenum In Sludge -	75	-	-	-	-	-	-	1/Quarter	Composite	Quarterly -
mg/kg								-		Alt.

#### Notes for Station Number 2PD00026581:

- a. Monitoring is required when sewage sludge is removed from the permittee's facility for application to the land. The monitoring data shall be reported on the March, June, September, and December Discharge Monitoring Report (DMR). The monitoring data can be collected at any time during the reporting period.
- b. Metal analysis must be completed during each reporting period whether or not sewage sludge is removed from the facility and applied to the land. Alternatively, the number of composite samples collected and reported prior to the next land application event shall be increased to account for the reporting period(s) in which land application did not occur. If all accumulated sewage sludge has been removed and hauled to a landfill, incinerated or transferred to another NPDES permit holder, then the metal analysis is not required.
- c. If no sewage sludge is removed from the facility during the reporting period, enter the results for the metal analysis on the DMR and enter "0" for sludge weight and sludge fee weight.
- d. If no sewage sludge is removed from the facility during the reporting period and no metal analysis is completed during the reporting period, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- e. If metal analysis has not been completed previously during each reporting period: when sewage sludge is removed from the facility all metal analysis results shall be reported on the applicable DMR by entering the separate results on different days within the DMR. For example, if no sewage sludge has been removed from the facility for a full calendar year, and quarterly monitoring is required by the permit, then five (four from the previous year and one for the current monitoring period) separate composite samples of the sewage sludge are required to be collected and analyzed for metals prior to removal from the facility. The first sample result may be entered on the first day of the DMR, the second result on the second day of the DMR, and so on. A note may then be added to indicate the actual day(s) when the samples were collected.
- f. It is recommended that composite samples of the sewage sludge be collected and analyzed close enough to the time of land application to be reflective of the sludge's current quality, but not so close that the results of the analysis are not available prior to land applying the sludge.
- g. The permittee shall maintain the appropriate records on site to verify that the requirements of Pathogen Reduction and Vector Attraction Reduction have been met.
- h. Units of mg/kg are on a dry weight basis.
- i. Sludge weight is a calculated total for each reporting period. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge: dry tons= gallons x 8.34 (lbs/gallon) x 0.0005 (tons/lb) x decimal fraction total solids.

- j. Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.
- k. To sample for fecal coliform, the treatment plant should collect and analyze a grab sample every other day over a two week period for a total of seven grab samples when practical. Each of the grab samples shall be analyzed independently to determine the CFU/g of fecal coliform in the individual sample. The geometric mean of those seven results shall be reported on the DMR. Each fecal coliform sample must be delivered to the analytical lab within six hours after the sample has been collected, in accordance with the requirements for Part 9221 E. or part 9222 D., "Standard Methods for the Examination of Water and Wastewater". This process must be completed prior to sewage sludge being removed from the treatment facility.

1. See Part II, Items O, P, Q, and R.

# Part I, B. - SLUDGE MONITORING REQUIREMENTS

4. Sludge Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' final sludge at Station Number 2PD00026586, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 586 - Final

Effluent Characteristic	Discharge I	Limitations						Monitoring	Requiremen	<u>its</u>
	Concentrati	on Specified	Units		Loadin	g* kg/day				
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
51129 - Sludge Fee Weight - dry tons	-	-	-	-	-	-	-	1/Year	Total	December

Notes for Station Number 2PD00026586:

- a. Monitoring is required when sewage sludge is removed from the permittee's facility for disposal in a mixed solid waste landfill. The total Sludge Fee Weight of sewage sludge disposed of in a mixed solid waste landfill for the entire year shall be reported on the December Discharge Monitoring Report (DMR).
- b. If no sewage sludge is removed from the Permittee's facility for disposal in a solid waste landfill during the year, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- c. Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.
- d. See Part II, Items O, Q, and R.

## Part I, B. - SLUDGE MONITORING REQUIREMENTS

5. Sludge Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' final sludge at Station Number 2PD00026588, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 588 - Final

Effluent Characteristic			Discharg	ge Limitatio	<u>ons</u>			Monitoring Requirements				
	Cone	centration Sp	ecified Ur	nits	Lo	oading* kg	g/day					
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	_	1 0	Monitoring		
								Frequency	Type	Months		
80991 - Sludge Volume, Gallons - Gals	-	-	-	-	1	ı	-	1/Year	Total	December		

Notes for Station Number 2PD00026588:

- a. Monitoring is required when sewage sludge is removed from the permittee's facility for transfer to another NPDES permit holder. The total sludge weight or sludge volume transferred to another NPDES permit holder for the entire year shall be reported on the December Discharge Monitoring Report (DMR).
- b. If no sewage sludge is removed from the Permittee's facility for transfer to another NPDES permit holder during the year, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- c. Sludge weight is a calculated total for the year. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge: dry tons = gallons x 8.34 (lbs/gallon) x 0.0005 (tons/lb) x decimal fraction total solids.
- d. See Part II, Items O, Q, and R.

# Part I, B. - INFLUENT MONITORING REQUIREMENTS

6. Influent Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' influent wastewater at Station Number 2PD00026601, and report to the Ohio EPA in accordance with the following table. Samples of influent used for determination of net values or percent removal must be taken the same day as those samples of effluent used for that determination. See Part II, OTHER REQUIREMENTS, for location of influent sampling.

Table - Influent Monitoring - 601 - Final

Effluent Characteristic			Discharg	ge Limitatio	ons			Moni	toring Require	ements
	Conc	centration Sp	ecified Ur	nits	Lo	oading* kg	g/day			
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
00400 - pH - S.U.	-	-	-	-	-	-	-	1/Day	Grab	All
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	3/Week	24hr Composite	All
00720 - Cyanide, Total - mg/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
00981 - Selenium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
39100 - Bis(2-ethylhexyl) Phthalate - ug/l	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly
50092 - Mercury, Total (Low Level) - ng/l	-	-	-	-	-	-	-	1/Month	Grab	All

80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	3/Week	24hr	All
									Composite	

Notes for Station Number 2PD00026601:

- a. Bis (2-ethylhexyl) phthalate See Compliance Schedule, Item D and Part II, Items L and AA.
- b. Nickel, Zinc, Cadmium, Lead, Total Chromium, Selenium, Molybdenum, Arsenic, & Copper See Part II, Item L. c. Dissolved Hexavalent Chromium See Part II, Item N.
- d. Mercury See Part II, Items N, S, U, V, and W.

# Part I, B. - UPSTREAM MONITORING REQUIREMENTS

7. Upstream Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the receiving stream, upstream of the point of discharge at Station Number 2PD00026801, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Upstream Monitoring - 801 - Final

Effluent Characteristic	<u>Discharge Limitations</u>						Monitoring Requirements			
	Cond	Concentration Specified Units Loading* kg/day				g/day				
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Month	Grab	All
00300 - Dissolved Oxygen - mg/l	-	-	-	-	-	1	-	1/Month	Grab	All
00400 - pH - S.U.	-	-	-	-	-	ı	-	1/Month	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
31648 - E. coli - #/100 ml	-	-	-	-	-	-	-	1/Month	Grab	Summer
61432 - 48-Hr. Acute Toxicity Ceriodaphnia dubia - % Affected	-	-	-	-	-	-	-	2/Year	Grab	June and Aug
61435 - 96-Hr. Acute Toxicity Pimephales promela - % Affected	-	-	-	-	-	-	-	1/Year	Grab	June
61438 - 7-Day Chronic Toxicity Ceriodaphnia dubia - % Affected	-	-	-	-	-	-	-	2/Year	Grab	June and Aug
61441 - 7-Day Chronic Toxicity Pimephales promelas - % Affected	-	-	-	-	-	-	-	1/Year	Grab	June

Notes for Station Number 2PD00026801:

a. See Part II, Item L.

b. Biomonitoring Program Requirements - See Part II, Item X.

# Part I, B. DOWNSTREAM-NEARFIELD MONITORING REQUIREMENTS

8. Downstream-Nearfield Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the receiving stream, downstream of the point of discharge, at Station Number 901, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Downstream-Nearfield Monitoring - 901 - Final

Effluent Characteristic	<u>Discharge Limitations</u>						Monitoring Requirements			
	Concentration Specified Units			Loading* kg/day						
Parameter	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Measuring	Sampling	Monitoring
								Frequency	Type	Months
00010 - Water Temperature - C	-	1	ı	-	-	-	-	1/Month	Grab	All
00300 - Dissolved Oxygen - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00400 - pH - S.U.	-	-	-	-	-	-	-	1/Month	Grab	All
00610 - Nitrogen, Ammonia (NH3) -	-	-	-	-	-	-	-	1/Month	Grab	All
mg/l										
00625 - Nitrogen Kjeldahl, Total -	-	-	-	-	-	-	-	1/Month	Grab	All
mg/l										
00630 - Nitrite Plus Nitrate, Total -	-	-	-	-	-	-	-	1/Month	Grab	All
mg/l										
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00900 - Hardness, Total (CaCO3) -	-	-	-	-	-	-	-	1/Month	Grab	All
mg/l										
31648 - E. coli - #/100 ml	-	-	1	-	-	-	-	1/Month	Grab	Summer

## Part I, C - Schedule of Compliance

A. Plant Performance Evaluation (COMPLETE)

B. Bypass: No Feasible Alternatives Analysis and Schedule

The St. Mary's WWTP includes a bypass which re-routes a portion of wastewater flow when the influent flow rate exceeds 9.0 MGD. Bypassed flow is screened at the headworks but does not receive the following treatment: grit removal, oxidation ditch, secondary clarification, and disinfection. From the headworks, bypass flows are diverted to the equalization basin, which discharges directly to the St. Marys River through outfall 009 when full.

The permittee shall undertake the following actions as soon as possible but not later than the dates in the following schedule:

- 1. No later than August 1, 2023, the permittee shall submit an annual report describing the progress made toward construction of the improvements to the solids treatment and handling processes. The progress report shall be submitted to Ohio EPA NWDO.
- 2. As soon as possible but no later than January 1, 2024, the permittee shall complete construction of the improvements to the solids treatment and handling processes. The permittee shall provide written notice to Ohio EPA NWDO within 7 days of construction completion.
- 3. As soon as practicable after the completion of the solids treatment projects, the permittee shall initiate draw-down of mixed liquor suspended solids (MLSS) concentrations for decommissioning of the Cannibal system and optimization of peak capacity operations of the treatment systems. The permittee shall provide written notice to Ohio EPA NWDO within 7 days of initiation of the decommissioning process.
- 4. As soon as practicable but no later than July 1, 2024, the permittee shall complete decommissioning of the Cannibal process and optimization of the peak flow operations of the treatment and storage systems. The permittee shall provide written notice to Ohio EPA NWDO within 7 days of completion of peak flow operation optimization. Upon achieving optimized peak flow operations, the permittee shall initiate a post-construction compliance monitoring period.
- 5. No later than July 1, 2024, the permittee shall submit an annual report describing the progress made toward decommissioning of the Cannibal system, optimization of the treatment and storage systems, and draw-down of MLSS concentrations in the oxidation ditch. The progress report shall be submitted to Ohio EPA NWDO.
- 6. As soon as possible but no later than July 1, 2025, the permittee shall conclude the post-construction compliance monitoring period. The permittee shall provide written notice to Ohio EPA NWDO within 7 days of the end of the monitoring period.
- 7. As soon as possible but no later than January 1, 2026, the permittee shall submit to Ohio EPA NWDO for acceptance, a final report with an evaluation of the hydraulic capacity of the permitted facility following decommissioning of the Cannibal system and characterization of bypass activity during the post-construction compliance monitoring period.

- 8. If the evaluation determines that bypasses at Outfall 009 continue to occur, the report shall include a No Feasible Alternatives (NFA) analysis to eliminate the bypass. At a minimum, the NFA shall include assessments of:
- a. Inflow/infiltration reduction within the collection system;
- b. Additional wastewater storage and flow equalization;
- c. Additional secondary treatment capacity;
- d. Costs associated with the respective alternatives;
- e. A proposed schedule for implementation of any recommended improvements in the collection system and/or the treatment plant.
- 9. Within 30 days of notification of review and acceptance by Ohio EPA, the permittee shall submit an NPDES permit modification application to incorporate the implementation schedule recommended by final report and initiate implementation of the recommendations of the report, including any revisions necessary to address Ohio EPA comments.
- 10. This Schedule of Compliance includes items that extend beyond the expiration date of this NPDES permit modification, 2PD00026\*UD. The requirements of Schedule of Compliance will be included in permit number 2PD00026 when it is renewed.
- C. Evaluation for Reducing Discharge of Phosphorus (COMPLETE)
- D. Municipal Pretreatment Schedule (COMPLETE)
- E. SSO Elimination

The permittee shall evaluate alternatives and recommend improvements to eliminate sanitary sewer overflows (SSOs) in the collection system as soon as possible, but no later than the dates in the following schedule:

- 1. The permittee shall submit annual reports describing the progress made toward elimination of the SSOs. The report shall describe activities completed during the previous twelve months and indicate any activities projected to be implemented in the next twelve months. Annual reports shall be submitted in accordance with the following schedule:
- a. No later than August 1, 2023
- b. No later than July 1, 2024.
- c. No later than July 1, 2025.
- 2. As soon as possible but no later than January 1, 2026, the permittee shall submit to Ohio EPA for acceptance a final SSO Elimination Report. At a minimum, the report shall include a comprehensive evaluation of alternatives to eliminate SSOs and an implementation schedule to complete recommended improvements.
- 3. Within 30 days of notification of review and acceptance by Ohio EPA, the permittee shall submit an NPDES permit modification application to incorporate the implementation schedule recommended by the final report and initiate implementation of the recommendations of the final report, including any revisions necessary to address Ohio EPA comments.
- 4. This Schedule of Compliance includes items that extend beyond the expiration date of this NPDES

permit modification, 2PD00026\*UD. The Schedule of Compliance requirements will be included in permit number 2PD00026 when it is renewed.

## Part II, Other Requirements

## A. Operator Certification Requirements

#### 1. Classification

- a. In accordance with Ohio Administrative Code 3745-7-04, the sewage treatment facility at this facility shall be classified as a Class III facility.
- b. All sewerage (collection) systems that are tributary to this treatment works are Class II sewerage systems in accordance with paragraph (B)(1)(a) of rule 3745-7-04 of the Ohio Administrative Code.

## 2. Operator of Record

- a. The permittee shall designate one or more operator of record to oversee the technical operation of the treatment works and sewerage (collection) system in accordance with paragraph (A)(2) of rule 3745-7-02 of the Ohio Administrative Code.
- b. Each operator of record shall have a valid certification of a class equal to or greater than the classification of the treatment works as defined in Part II, Item A.1 of this NPDES permit.
- c. Within three days of a change in an operator of record, the permittee shall notify the Director of the Ohio EPA of any such change on a form acceptable to Ohio EPA. The appropriate form can be found at the following website:

 $http://www.epa.ohio.gov/portals/28/Documents/opcert/Operator\_of\_Record\_Notification\_Form.pdf$ 

- d. Within 60 days of the effective date of this permit, the permittee shall notify the Director of Ohio EPA of the operators of record on a form acceptable to Ohio EPA.
- e. The operator of record for a class II, III, or IV treatment works or class II sewerage system may be replaced by a backup operator with a certificate one classification lower than the treatment works or sewerage system for a period of up to thirty consecutive days. The use of this provision does not require notification to the agency.
- f. Upon proper justification, such as military leave or long term illness, the director may authorize the replacement of the operator of record for a class II, III, or IV treatment works or class II sewerage system by a backup operator with a certificate one classification lower than the facility for a period of greater than thirty consecutive days. Such requests shall be made in writing to the appropriate district office.

#### 3. Minimum Staffing Requirements

- a. The permittee shall ensure that the treatment works operator of record is physically present at the facility in accordance with the minimum staffing requirements per paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code or the requirements from an approved 3745-7-04(C) minimum staffing hour reduction plan.
- b. Sewerage (collection) system Operators of Record are not required to meet minimum staffing requirements in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code.
- c. If Ohio EPA approves a reduction in minimum staffing requirements based upon a facility operating plan, any change in the criteria under which the operating plan was approved (such as enforcement status, history of noncompliance, or provisions included in the plan) will require that the treatment works

immediately return to the minimum staffing requirements included in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code.

B. Description of the location of the required sampling stations are as follows:

Sampling Station	Description of Location
	<del></del>
2PD00026001	Final effluent (Lat: 40 N 33' 04"; Long: 84 W 23' 35")
2PD00026009	Bypass to St. Marys River from Equalization Basin
2PD00026300	System-wide sanitary sewer overflow occurrences
2PD00026581	Sewage sludge removed for land application
2PD00026586	Sewage sludge removed disposal in a landfill
2PD00026588	Sewage sludge transferred to another NPDES permit holder
2PD00026601	Influent monitoring
2PD00026801	Upstream monitoring
2PD00026901	Downstream monitoring
	8

C. All parameters, except flow, need not be monitored on days when the plant is not normally staffed (Saturdays, Sundays, and Holidays). On those days, report "AN" on the monthly report form.

D. Sanitary Sewer Overflow (SSO) Reporting Requirements

A sanitary sewer overflow is an overflow, spill, release, or diversion of wastewater from a sanitary sewer system. SSOs do not include wet weather discharges from combined sewer overflows specifically listed in Part II of this NPDES permit (if any). All SSOs are prohibited.

- 1. Reporting for SSOs That Imminently and Substantially Endanger Human Health
- a) Immediate Notification

You must notify Ohio EPA (1-800-282-9378) and the appropriate Board of Health (i.e., city or county) within 24 hours of learning of any SSO from your sewers or from your maintenance contract areas that may imminently and substantially endanger human health. The telephone report must identify the location, estimated volume and receiving water, if any, of the overflow. An SSO that may imminently and substantially endanger human health includes dry weather overflows, major line breaks, overflow events that result in fish kills or other significant harm, overflows that expose the general public to contact with raw sewage, and overflow events that occur in sensitive waters and high exposure areas such as protection areas for public drinking water intakes and waters where primary contact recreation occurs.

#### b) Follow-Up Written Report

Within 5 days of the time you become aware of any SSO that may imminently and substantially endanger human health, you must provide the appropriate Ohio EPA district office a written report that includes:

- (i) the estimated date and time when the overflow began and stopped or will be stopped (if known);
- (ii) the location of the SSO including an identification number or designation if one exists;
- (iii) the receiving water (if there is one);
- (iv) an estimate of the volume of the SSO (if known);
- (v) a description of the sewer system component from which the release occurred (e.g., manhole, constructed overflow pipe, crack in pipe);

- (vi) the cause or suspected cause of the overflow;
- (vii) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the overflow and a schedule of major milestones for those steps; and
- (viii) steps taken or planned to mitigate the impact(s) of the overflow and a schedule of major milestones for those steps.

An acceptable 5-day follow-up written report can be filled-in or downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance Web page at epa.ohio.gov/divisions-and-offices/surface-water/guides-manuals/permits-program-technical-assistance

2. Reporting for All SSOs, Including Those That Imminently and Substantially Endanger Human Health

## a) Monthly Operating Reports

Sanitary sewer overflows that enter waters of the state, either directly or through a storm sewer or other conveyance, shall be reported on your monthly operating reports. You must report the system-wide number of occurrences for SSOs that enter waters of the state in accordance with the requirements for station number 300. A monitoring table for this station is included in Part I, B of this NPDES permit. For the purpose of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, you should record two occurrences for that day. If overflows from both locations continue on the following day, you should record two occurrences for the following day. At the end of the month, total the daily occurrences from all locations on your system and report this number using reporting code 74062 (Overflow Occurrence, No./Month) on the 4500 form for station number 300.

#### b) Annual Report

You must prepare an annual report of all SSOs in your collection system, including those that do not enter waters of the state. The annual report must be in an acceptable format (see below) and must include:

- (i) A table that lists an identification number, a location description, and the receiving water (if any) for each existing SSO. If an SSO previously included in the list has been eliminated, this shall be noted. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.
- (ii) A table that lists the date that an overflow occurred, the unique ID of the overflow, the name of affected receiving waters (if any), and the estimated volume of the overflow (in millions of gallons). The annual report may summarize information regarding overflows of less than approximately 1,000 gallons.
- (iii) A table that summarizes the occurrence of water in basements (WIBs) by total number and by sewershed. The report shall include a narrative analysis of WIB patterns by location, frequency and cause. Only WIBs caused by a problem in the publicly-owned collection system must be included. Not later than March 31 of each year, you must submit one copy of the annual report for the previous calendar year to the appropriate Ohio EPA district office and one copy to: Ohio EPA; Division of Surface Water; NPDES Permit Unit; P.O. Box 1049; Columbus, OH 43216-1049. You also must provide adequate notice to the public of the availability of the report.

Systems serving fewer than 10,000 people are not required to prepare an annual report if all monthly operating reports for the preceding calendar year show no discharge from overflows.

An acceptable annual SSO report can be filled-in or downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance Web page at epa.ohio.gov/divisions-and-offices/surface-water/guides-manuals/permits-program-technical-assistance

- E. The permittee shall maintain in good working order and operate as efficiently as possible the "treatment works" and "sewerage system" as defined in ORC 6111.01 to achieve compliance with the terms and conditions of this permit and to prevent discharges to the waters of the state, surface of the ground, basements, homes, buildings, etc.
- F. Composite samples shall be comprised of a series of grab samples collected over a 24-hour period and proportionate in volume to the sewage flow rate at the time of sampling. Such samples shall be collected at such times and locations, and in such a fashion, as to be representative of the facility's overall performance.
- G. Grab samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's performance.
- H. Multiple grab samples shall be comprised of at least three grab samples collected at intervals of at least three hours during the period that the plant is staffed on each day for sampling. Samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance. The critical value shall be reported.
- I. The treatment works must obtain at least 85 percent removal of carbonaceous biochemical oxygen demand (five-day) and suspended solids (see Part III, Item 1).
- J. POTWs that accept hazardous wastes by truck, rail, or dedicated pipeline are considered to be hazardous waste treatment, storage, and disposal facilities (TSDFs) and are subject to regulation under the Resource Conservation and Recovery Act (RCRA). Under the "permit-by-rule" regulation found at 40 CFR 270.60(c), a POTW must:
- 1) comply with all conditions of its NPDES permit,
- 2) obtain a RCRA ID number and comply with certain manifest and reporting requirements under RCRA,
- 3) satisfy corrective action requirements, and
- 4) meet all federal, state, and local pretreatment requirements.
- K. Water quality based permit limitations in this permit may be revised based on updated wasteload allocations or use designation rules. This permit may be modified, or revoked and reissued, to include new water quality based effluent limits or other conditions that are necessary to comply with a revised wasteload allocation, or an approved total maximum daily loads (TMDL) report as required under Section 303 (d) of the Clean Water Act.
- L. Sampling for the respective parameters at station 2PD00026001, 2PD00026601, 2PD00026601 and 2PD00026901 shall occur the same day.
- M. Sampling at station 2PD00026001 for the respective parameters shall occur one detention time (the time it takes for a volume of water to travel through the treatment plant) after sampling at station 2PD00026601 for the same parameters on the same day.
- N. Sampling at station 2PD00026601 for the respective parameters shall occur one detention time (the time it takes for a volume of water to travel through the treatment plant) prior to sampling at station 2PD00026001 for the same parameters on the same day.

- O. All disposal, use, storage, or treatment of sewage sludge by the Permittee shall comply with Chapter 6111. of the Ohio Revised Code, Chapter 3745-40 of the Ohio Administrative Code, any further requirements specified in this NPDES permit, and any other actions of the Director that pertain to the disposal, use, storage, or treatment of sewage sludge by the Permittee.
- P. Sewage sludge composite samples shall consist of a minimum of six grab samples collected at such times and locations, and in such fashion, as to be representative of the facility's sewage sludge.
- Q. No later than March 1 of each calendar year, the Permittee shall submit a report summarizing the sewage sludge disposal, use, storage, or treatment activities of the Permittee during the previous calendar year. The report shall be submitted through the Ohio EPA eBusiness Center, Division of Surface Water NPDES Permit Applications service.
- R. Each day when sewage sludge is removed from the wastewater treatment plant for use or disposal, a representative sample of sewage sludge shall be collected and analyzed for percent total solids. This value of percent total solids shall be used to calculate the total Sewage Sludge Weight (Discharge Monitoring Report code 70316) and/or total Sewage Sludge Fee Weight (Discharge Monitoring Report code 51129) removed from the treatment plant on that day. The results of the daily monitoring, and the weight calculations, shall be maintained on site for a minimum of five years. The test methodology used shall be from Part 2540 G of Standard Methods for the Examination of Water and Wastewater American Public Health Association, American Water Works Association, and Water Environment Federation, the edition which is current when this permit becomes effective. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge: dry tons = gallons x 8.34 (lbs/gallon) x 0.0005 (tons/lb) x decimal fraction total solids.
- S. The permittee shall use EPA Method 1631 promulgated under 40 CFR 136 to comply with the influent and effluent mercury monitoring requirements of this permit.

## T. Pretreatment Program Requirements

The permittee's pretreatment program initially approved on September 20, 2011 and all subsequent modifications approved before the effective date of this permit, shall be an enforceable term and condition of this permit.

To ensure that the approved program is implemented in accordance with 40 CFR 403, Chapter 3745-3 of Ohio Administrative Code and Chapter 6111 of the Ohio Revised Code, the permittee shall comply with the following conditions:

#### 1. Legal Authority

The permittee shall adopt and maintain legal authority which enables it to fully implement and enforce all aspects of its approved pretreatment program including the identification and characterization of industrial sources, issuance of control documents, compliance monitoring and reporting, and enforcement.

The permittee shall establish agreements with all contributing jurisdictions, as necessary, to enable the permittee to fulfill its requirements with respect to industrial users discharging to its system.

#### 2. Funding

The permittee shall have sufficient resources and qualified personnel to fully implement all aspects of its

approved pretreatment program.

## 3. Industrial User Inventory

The permittee shall identify all industrial users subject to pretreatment standards and requirements and characterize the nature and volume of pollutants in their wastewater. Dischargers determined to be Significant Industrial Users according to OAC 3745-3-01(FF) must be notified of applicable pretreatment standards and requirements within 30 days of making such a determination. This inventory shall be updated at a frequency to ensure proper identification and characterization of industrial users.

# 4. Slug Load Control Plans for Significant Industrial Users

The permittee shall evaluate the need for a plan, device or structure to control a potential slug discharge at least once during the term of each significant industrial user's control mechanism. Existing significant industrial users shall be evaluated within one year of the effective date of this permit if the users have never been evaluated. New industrial users identified as significant industrial users shall be evaluated within one year of being identified as a significant industrial user.

#### 5. Local Limits

The permittee shall develop and enforce technically based local limits to prevent the introduction of pollutants into the POTW which will interfere with the operation of the POTW, pass through the treatment works, be incompatible with the treatment works, or limit wastewater or sludge use options.

The permittee shall use the following waste load allocation values when evaluating local limits for the following pollutants for which a final effluent limit has not been established:

Arsenic 166.0 ug/l
Cadmium 6.4 ug/l
Chromium, hexavalent 12.0 ug/l
Chromium, total 150 ug/l
Copper 26.0 ug/l
Free Cyanide 5.8 ug/l
Lead 29.0 ug/l
Molybdenum 14,987 ug/l
Nickel 144.0 ug/l
Selenium 5.5 ug/l
Silver 1.4 ug/l
Zinc 330.0 ug/l

For the purpose of periodically reevaluating local limits, the permittee shall implement and maintain a sampling program to characterize pollutant contribution to the POTW from industrial and residential sources and to determine pollutant removal efficiencies through the POTW. The permittee shall continue to review and develop local limits as necessary.

#### 6. Control Mechanisms

The permittee shall issue control mechanisms to all industries determined to be Significant Industrial Users as define in OAC 3745-3-01(FF). Control mechanisms must meet at least the minimum requirements of OAC-3745-3-03(C)(1)(c).

#### 7. Industrial Compliance Monitoring

The permittee shall sample and inspect industrial users in accordance with the approved program or approved modifications, including inspection and sampling of all significant industrial users at least annually. Sample collection, preservation and analysis must be performed in accordance with procedures in 40 CFR 136 and with sufficient care to produce evidence admissible in judicial enforcement proceedings.

The permittee shall also require, receive, and review self-monitoring and other industrial user reports when necessary to determine compliance with pretreatment standards and requirements. If the permittee performs sampling and analysis in lieu of an industrial user's self-monitoring, the permittee shall perform repeat sampling and analysis within 30 days of becoming aware of a permit violation, unless the permittee notifies the user of the violation and requires the user to perform the repeat analysis and reporting.

#### 8. POTW Priority Pollutant Monitoring

The permittee shall annually monitor priority pollutants, as defined by U.S. EPA, in the POTW's influent, effluent and sludge. Sample collection, preservation, and analysis shall be performed using U.S. EPA approved methods.

a. A sample of the influent and the effluent shall be collected when industrial discharges are occurring at normal to maximum levels. Sampling of the influent shall be done prior to any recycle streams and sampling of the effluent shall be after disinfection. Both samples shall be collected on the same day or, alternately, the effluent sample may be collected following the influent sample by approximately the retention time of the POTW.

Sampling of sludge shall be representative of sludge removed to final disposal. A minimum of one grab

sample shall be taken during actual sludge removal and disposal unless the POTW uses more than one disposal option. If multiple disposal options are used, the POTW shall collect a composite of grab samples from all disposal practices which are proportional to the annual flows to each type of disposal.

b. A reasonable attempt shall be made to identify and quantify additional constituents (excluding priority pollutants and unsubstituted aliphatic compounds) at each sample location. Identification of additional peaks more than ten times higher than the adjacent background noise on the total ion plots (reconstructed gas chromatograms) shall be attempted through the use of U.S. EPA/NIH computerized library of mass spectra, with visual confirmation by an experienced analyst. Quantification may be based on an order of magnitude estimate compared with an internal standard.

The results of these samples must be submitted on Ohio EPA Form 4221 with the permittee's annual pretreatment report. Samples may be collected at any time during the 12 months preceding the due date of the annual report and may be used to fulfill other NPDES monitoring requirements where applicable.

#### 9. Enforcement

The permittee shall investigate all instances of noncompliance with pretreatment standards and requirements and take timely, appropriate, and effective enforcement action to resolve the noncompliance in accordance with the permittee's approved enforcement response plan.

On or prior to March 15th of each year, the permittee shall publish, in a newspaper of general circulation that provides meaningful public notice within the jurisdiction served by the permittee, a list of industrial users which, during the previous 12 months, have been in Significant Noncompliance [OAC 3745-3-03(C)(2)(h)] with applicable pretreatment standards or requirements.

## 10. Reporting

All reports required under this section shall be submitted either through Ohio EPA's eBusiness Center or by mail. The Ohio EPA eBusiness Center can be found in the link: https://ebiz.epa.ohio.gov/login.html If submitting hardcopies by mail, reports shall be sent to the following address in duplicate:

Ohio Environmental Protection Agency Division of Surface Water Pretreatment Unit P.O. Box 1049 Columbus, OH 43216-1049

#### a. Quarterly Industrial User Violation Report

On or prior to the 15th day of February, May, August, and November, the permittee shall report the industrial users that are in violation of applicable pretreatment standards during the previous quarter. The report shall be prepared in accordance with guidance provided by Ohio EPA and shall include a description of all industrial user violations and corrective actions taken to resolve the violations.

#### b. Annual Pretreatment Report

On or prior to March 15th of each year, the permittee shall submit an annual report on the effectiveness of the pretreatment program. The report shall be prepared in accordance with guidance provided by Ohio EPA and shall include, but not be limited to: a discussion of program effectiveness; and industrial user inventory; a description of the permittee's monitoring program; a description of any pass through or

interference incidents; a copy of the annual publication of industries in Significant Noncompliance; and, priority pollutant monitoring results.

## 11. Record Keeping

All records of pretreatment activities including, but not limited to, industrial inventory data, monitoring results, enforcement actions, and reports submitted by industrial users must be maintained for a minimum of three (3) years. This period of retention shall be extended during the course of any unresolved litigation. Records must be made available to Ohio EPA and U.S. EPA upon request.

## 12. Program Modifications

Any proposed modifications of the approved pretreatment program must be submitted to Ohio EPA for review, on forms available from Ohio EPA and consistent with guidance provided by Ohio EPA. If the modification is deemed to be substantial, prior approval must be obtained before implementation; otherwise, the modification is considered to be effective 45 days after the date of application. Substantial program modifications include, among other things, changes to the POTW's legal authority, industrial user control mechanisms, local limits, confidentiality procedures, or monitoring frequencies.

## U. General Mercury Variance

The permittee is granted a renewal of the general mercury variance under the provisions of Rule 3745-33-07(D)(8) of the Ohio Administrative Code. The City of St. Marys has demonstrated that the facility is currently unable to comply with the monthly average water quality-based effluent limit of 1.3 ng/l without construction of expensive end-of-pipe controls more stringent than those required by sections 301(b) and 306 of the Clean Water Act. The City of St. Marys is currently able to achieve an annual average mercury concentration of 12 ng/l. For general mercury variance purposes, the annual average mercury effluent concentration is defined as the average of the most recent 12 months of effluent data.

One of the conditions of the general mercury variance is that the permittee make reasonable progress towards attaining the water quality-based effluent limits for mercury (1.b, below). To accomplish this, the permittee is required to continue implementing a pollutant minimization program (PMP) for mercury. The elements of a PMP include: a control strategy to locate, identify and, where cost-effective, reduce levels of mercury that contribute to discharge levels; periodic monitoring of sources and the treatment system; and annual reporting of results.

The plan of study that was part of the permittee's 2007 application for coverage under the general mercury variance included items associated with developing a control strategy and initial implementation of a PMP. By implementing the plan of study and meeting other conditions of its NPDES permit, the permittee has been taking actions consistent with a PMP for mercury. Condition 1.d below, requires the permittee to continue implementing a PMP for mercury.

- 1. As conditions of this variance, the permittee shall meet the following requirements:
- a. The permittee shall comply with the effluent limitations for mercury at outfall 2PD00026001 given in Part I, A. of this permit.
- b. The permittee shall make reasonable progress towards attaining the monthly average water quality-based effluent limit for mercury by complying with the general mercury variance conditions included in this NPDES permit.

- c. The permittee shall use EPA Method 1631 to comply with the influent and effluent mercury monitoring requirements of this permit.
- d. The permittee shall continue implementing a PMP for mercury consistent with the plan of study included in the permittee's mercury variance application submitted on March 14, 2011 and any other relevant information submitted by the permittee, including the following activities, all of which will be implemented annually:
- i. conduct industrial site visits in conjunction with the industrial pretreatment program;
- ii. conduct site visits of additional potential sources;
- iii. distribute available guidance;
- iv. encourage implementation of appropriate strategies for reduction, elimination, and prevention;
- v. evaluate sewer system monitoring and records;
- vi. conduct additional monitoring if warranted;
- vii. develop a public education program; and
- viii. distribute information annually with City utility bills.
- e. The permittee shall assess the impact of the mercury variance on public health, safety, and welfare by, as a minimum, monitoring for mercury in the facility's influent and effluent as required by this NPDES permit.
- f. The permittee shall maintain an annual average mercury effluent concentration equal to or less than 12 ng/l.
- g. On or prior to March 1st of each year, the permittee shall submit two copies of an annual PMP report to Ohio EPA, Division of Surface Water, P.O. Box 1049, Columbus, OH, 43216-1049. The annual PMP report shall include:
- i. All minimization program monitoring results for the year;
- ii. A list of potential sources of mercury;
- iii. A summary of all actions taken to meet the effluent limits for mercury; and
- iv. Any updates of the control strategy, including actions planned to reduce the levels of mercury in the treatment plants final effluent.
- h. Upon completion of the actions identified in the plan of study as required in Part II, Item U.1.d. of this permit or upon submittal of the permittee's NPDES permit renewal application, whichever comes first, the permittee shall submit to Ohio EPA's Northwest District Office a certification stating that all permit conditions imposed to implement the plan of study and the PMP have been satisfied and whether compliance with the monthly average water quality based effluent limit for mercury has been achieved and can be maintained. This certification shall be accompanied by the following:
- i. All available mercury influent and effluent data for the most recent 12-month period.
- ii. Data documenting all known significant sources of mercury and the steps that have been taken to reduce or eliminate those sources; and
- iii. A determination of the lowest mercury concentration that currently available data indicate can be reliably achieved through implementation of the PMP.
- 2. Exceedance of the annual average limit of 12 ng/l.
- a. If at any time after the effective date of this permit, the permittee's annual average mercury effluent concentration exceeds 12 ng/l, the permittee shall:

- i. Notify Ohio EPA's Northwest District Office not later than 30 days from the date of the exceedance.
- ii. Submit an individual variance application, if a variance is desired, not later than 6 months from the date of the exceedance; or
- iii. Request a permit modification not later than 6 months from the date of the exceedance for a compliance schedule to attain compliance with the water quality-based effluent limits for mercury. b. If the permittee complies with either 2.a.ii or 2.a.iii, above, the general mercury variance conditions included in this NPDES permit will remain in effect until the date that the Director acts on the individual variance application or the date that the permit modification becomes effective.
- c. If the permittee does not comply with either 2.a.ii or 2.a.iii, above, a monthly water-quality based effluent limit for mercury of 1.3 ng/l shall apply at outfall 2PD00026001 beginning 6 months from the date of the exceedance.
- 3. The requirements of Part II, Item U.2 shall not apply if the permittee demonstrates to the satisfaction of the Director that the mercury concentration in the permittee's effluent exceeds 12 ng/l due primarily to the presence of mercury in the permittee's intake water.
- V. Permit Reopener for Mercury Variance Revisions

Ohio EPA may reopen and modify this permit at any time based upon Ohio EPA water quality standard revisions to the mercury variance granted in Part II, Item U of this permit.

W. Renewal of Mercury Variance

For renewal of the mercury variance authorized in this permit, the permittee shall include the following information with the submittal of the subsequent NPDES permit renewal application:

- 1. the certification described under Part II, Item U.1.h., and all information required under Part II, Item U.1.h.i. through Part II, Item U.1.h.ii;
- 2. a status report on the progress being made implementing the pollutant minimization program (PMP). This information may be included in the annual PMP report required under Part II, Item U.1.g;
- 3. a listing of the strategies and/or programs in the PMP which will be continued under the next renewal of this permit; and
- 4. a statement requesting the renewal of the mercury variance.
- X. Biomonitoring Program Requirements

The permittee shall continue implementing an effluent biomonitoring program to determine the toxicity of the effluent from outfall 2PD00026001.General Requirements

All toxicity testing conducted as required by this permit shall be done in accordance with "Reporting and Testing Guidance for Biomonitoring Required by the Ohio Environmental Protection Agency" (hereinafter, the "biomonitoring guidance"), Ohio EPA, July 1998 (or current revision). The Standard Operating Procedures (SOP) or verification of SOP submittal, as described in Section 1.B. of the biomonitoring guidance shall be submitted no later than three months after the effective date of this permit. If the laboratory performing the testing has modified its protocols, a new SOP is required.

#### **Testing Requirements**

#### 1. Chronic Bioassays

For a period of two years, the permittee shall conduct quarterly chronic toxicity tests using Ceriodaphnia dubia and annual (June) chronic toxicity tests using fathead minnows (Pimephales promelas) on effluent samples from outfall 2PD00026001. Thereafter, semi-annual testing shall be performed. These tests shall be conducted as specified in Section 3 of the biomonitoring guidance.

### 2. Acute Bioassays

For a period of two years, the permittee shall conduct quarterly definitive acute toxicity tests using Ceriodaphnia dubia and annual (June) acute toxicity tests using fathead minnows (Pimephales promelas) on effluent samples from outfall 2PD00026001. Thereafter, semi-annual testing shall be performed. These tests shall be conducted as specified in Section 2 of the biomonitoring guidance. Acute toxicity tests need not be performed for months in which chronic toxicity tests are conducted. Acute endpoints, as described in Section 2.H. of the biomonitoring guidance, shall be derived from the chronic test.

#### 3. Testing of Ambient Water

In conjunction with the acute and chronic toxicity tests, upstream control water shall be collected at a point outside the zone of effluent and receiving water interaction at station 2PD00026801. Testing of ambient waters shall be done in accordance with Sections 2 and 3 of the biomonitoring guidance.

#### 4. Data Review

#### a. Reporting

Following completion of each bioassay requirement, the permittee shall report results of the tests in accordance with Sections 2.H.1., 2.H.2.a., 3.H.1., and 3.H.2.a. of the biomonitoring guidance. Based on Ohio EPA's evaluation of the results, this permit may be modified to require additional biomonitoring, require a toxicity reduction evaluation, and/or contain whole effluent toxicity limits.

#### b. Definitions

TUa = Acute Toxicity Units = 100/LC50

TUc = Chronic Toxicity Units = 100/IC25

This equation for chronic toxicity units applies outside the mixing zone for warmwater, modified warmwater, exceptional warmwater, coldwater, and seasonal salmonid use designations except when the following equation is more restrictive (Ceriodaphnia dubia only):

TUc = Chronic Toxic Units = 100/square root of (NOEC x LOEC)

### Y. Toxicity Reopener

This permit may be modified to remove the limits for whole effluent toxicity at station 2PD00026001 and the schedule of compliance for toxicity limits. A request for such a modification shall be based on the results of at least eight definitive chronic toxicity tests conducted by the permittee over a period of two years. These tests shall be done in a manner consistent with the "General Requirements" and "Testing

Requirements" included in Part II, Item X of this NPDES permit. The results of these tests shall be evaluated using 40 CFR Part 132, Appendix F, Procedure 6 and OAC 3745-33-07(B)(1). To support a modification, the evaluation should show that there is no reasonable potential for the St. Marys wastewater plant discharge to cause or contribute to a violation of the criteria for whole effluent toxicity.

### Z. Monitoring for Dissolved Orthophosphate (as P)

Beginning on the effective date of this permit, the permittee shall begin monitoring for dissolved orthophosphate by grab sample. The permittee shall filter the grab sample within 15 minutes of collection using a 0.45-micron filter. The filtered sample must be analyzed within 48 hours. Samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance.

#### AA. Monitoring for Bis(2-ethylhexyl) Phthalate

Composite samples for Bis(2-ethylhexyl) phthalate shall be comprised of at least three grab samples proportionate in volume to the sewage flow rate at the time of sampling and collected at intervals of at least 30 minutes, but not more than 2 hours, during an 8 hour period that the plant is staffed for sampling. The samples shall be collected in glass to eliminate the potential for contamination from plastic containers; and they shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance.

BB. The permittee shall use analytical procedures approved under 40 CFR 136 with MDLs (method detection levels) less than or equal to those listed below to comply with the monitoring requirements for the following parameters:

Parameter	MDL (ug/l)
Cadmium	1.9
Chromium, Total	47
Chromium, Dissolved Hexavalent	4.0
Copper	7.7
Lead	8.0
Nickel	44
Zinc	99
Selenium	1.0
Bis(2-ethylhexyl) Phthalate	10

## CC. Outfall Signage

The permittee shall maintain a permanent marker on the stream bank at each outfall that is regulated under this NPDES permit. If a marker does not currently exist, the permittee shall install one within 4 months of the effective date of this permit. This includes final outfalls, bypasses, and combined sewer overflows. The marker shall consist at a minimum of the name of the establishment to which the permit was issued, the Ohio EPA permit number, and the outfall number and a contact telephone number. The information shall be printed in letters not less than two inches in height. The marker shall be a minimum of 2 feet by 2 feet and shall be a minimum of 3 feet above ground level. The sign shall not be obstructed such that persons in boats or persons swimming on the river or someone fishing or walking along the shore cannot read the sign. Vegetation shall be periodically removed to keep the sign visible. If the outfall is normally submerged the sign shall indicate that. If the outfall is a combined sewer outfall, the sign shall indicate that untreated human sewage may be discharged from the outfall during wet weather and that harmful bacteria may be present in the water. When an existing marker is replaced or reset, the new marker shall comply with the requirements of this section.

#### PART III - GENERAL CONDITIONS

#### 1. DEFINITIONS

"Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

"Average weekly" discharge limitation means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week. Each of the following 7-day periods is defined as a calendar week: Week 1 is Days 1 - 7 of the month; Week 2 is Days 8 - 14; Week 3 is Days 15 - 21; and Week 4 is Days 22 - 28. If the "daily discharge" on days 29, 30 or 31 exceeds the "average weekly" discharge limitation, Ohio EPA may elect to evaluate the last 7 days of the month as Week 4 instead of Days 22 - 28. Compliance with fecal coliform bacteria or E coli bacteria limitations shall be determined using the geometric mean.

"85 percent removal" means the arithmetic mean of the values for effluent samples collected in a period of 30 consecutive days shall not exceed 15 percent of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.

"Absolute Limitations" Compliance with limitations having descriptions of "shall not be less than," "nor greater than," "shall not exceed," "minimum," or "maximum" shall be determined from any single value for effluent samples and/or measurements collected.

"Net concentration" shall mean the difference between the concentration of a given substance in a sample taken of the discharge and the concentration of the same substances in a sample taken at the intake which supplies water to the given process. For the purpose of this definition, samples that are taken to determine the net concentration shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"Net Load" shall mean the difference between the load of a given substance as calculated from a sample taken of the discharge and the load of the same substance in a sample taken at the intake which supplies water to given process. For purposes of this definition, samples that are taken to determine the net loading shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"MGD" means million gallons per day.

"mg/l" means milligrams per liter.

"ug/l" means micrograms per liter.

"ng/l" means nanograms per liter.

"S.U." means standard pH unit.

"kg/day" means kilograms per day.

"Reporting Code" is a five-digit number used by the Ohio EPA in processing reported data. The reporting code does not imply the type of analysis used nor the sampling techniques employed. "Quarterly (1/Quarter) sampling frequency" means the sampling shall be done in the months of March, June, August, and December, unless specifically identified otherwise in the Effluent Limitations and Monitoring Requirements table.

"Yearly (1/Year) sampling frequency" means the sampling shall be done in the month of September, unless specifically identified otherwise in the effluent limitations and monitoring requirements table.

"Semi-annual (2/Year) sampling frequency" means the sampling shall be done during the months of June and December, unless specifically identified otherwise.

"Winter" shall be considered to be the period from November 1 through April 30.

"Bypass" means the intentional diversion of waste streams from any portion of the treatment facility.

"Summer" shall be considered to be the period from May 1 through October 31.

"Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

"Sewage sludge" means a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works as defined in section 6111.01 of the Revised Code. "Sewage sludge" includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes. "Sewage sludge" does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator, grit and screenings generated during preliminary treatment of domestic sewage in a treatment works, animal manure, residue generated during treatment of animal manure, or domestic septage.

"Sewage sludge weight" means the weight of sewage sludge, in dry U.S. tons, including admixtures such as liming materials or bulking agents. Monitoring frequencies for sewage sludge parameters are based on the reported sludge weight generated in a calendar year (use the most recent calendar year data when the NPDES permit is up for renewal).

"Sewage sludge fee weight" means the weight of sewage sludge, in dry U.S. tons, excluding admixtures such as liming materials or bulking agents. Annual sewage sludge fees, as per section 3745.11(Y) of the Ohio Revised Code, are based on the reported sludge fee weight for the most recent calendar year.

#### 2. GENERAL EFFLUENT LIMITATION

The effluent shall, at all times, be free of substances:

A. In amounts that will settle to form putrescent, or otherwise objectionable, sludge deposits; or that will adversely affect aquatic life or waterfowl;

- B. Of an oily, greasy, or surface-active nature, and of other floating debris, in amounts that will form noticeable accumulations of scum, foam, or sheen;
- C. In amounts that will alter the natural color or odor of the receiving water to such degree as to create a nuisance;
- D. In amounts that either singly or in combination with other substances are toxic to human, animal, or aquatic life;
- E. In amounts that are conducive to the growth of aquatic weeks or algae to the extent that such growth become inimical to more desirable forms of aquatic life, or create conditions that are unsightly, or constitute a nuisance in any other fashion;
- F. In amounts that will impair designated instream or downstream water uses

# 3. FACILITY OPERATION AND QUALITY CONTROL

All wastewater treatment works shall be operated in a manner consistent with the following:

- A. At all times, the permittee shall maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee necessary to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with conditions of the permit.
- B. The permittee shall effectively monitor the operation and efficiency of treatment and control facilities and the quantity and quality of the treated discharge.
- C. Maintenance of wastewater treatment works that results in degradation of effluent quality shall be scheduled during non-critical water quality periods and shall be carried out in a manner approved by Ohio EPA as specified in the Paragraph in the PART III entitled, "UNAUTHORIZED DISCHARGES".

#### 4. REPORTING

A. Monitoring data required by this permit shall be submitted monthly on Ohio EPA 4500 Discharge Monitoring Report (DMR) forms using the electronic DMR (e-DMR) internet application. e-DMR allows permitted facilities to enter, sign, and submit DMRs on the internet. e-DMR information is found on the following web page:

https://epa.ohio.gov/divisions-and-offices/surface-water/permitting/electronic-business-services

- B. DMRs shall be signed by a facility's Responsible Official or a Delegated Responsible Official (i.e. a person delegated by the Responsible Official). The Responsible Official of a facility is defined as:
- 1. For a corporation: by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (a) a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or (b) The manager of one or more manufacturing, production or operating facilities, provided the manager is authorized to make management decisions that govern the operation of the regulated facility including having explicit or implicit duty of making major capital investment

recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

- 2. For a partnership or sole proprietorship: by a general partner or the proprietor, respectively; or
- 3. In the case of a municipal, state or other public facility, by either the principal executive officer, the ranking elected official or other duly authorized employee.

For e-DMR, the person signing and submitting the DMR will need to obtain an eBusiness Center account and Personal Identification Number (PIN). Additionally, Delegated Responsible Officials must be delegated by the Responsible Official, either on-line using the eBusiness Center's delegation function, or on a paper delegation form provided by Ohio EPA. For more information on the PIN and delegation processes, please view the following web page:

https://epa.ohio.gov/divisions-and-offices/surface-water/guides-manuals/edmr-pin-information-and-application

- C. DMRs submitted using e-DMR shall be submitted to Ohio EPA by the 20th day of the month following the month-of-interest.
- D. If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified in Section 5. SAMPLING AND ANALYTICAL METHODS, the results of such monitoring shall be included in the calculation and reporting of the values required in the reports specified above.
- E. Analyses of pollutants not required by this permit, except as noted in the preceding paragraph, shall not be reported to the Ohio EPA, but records shall be retained as specified in Section 7. RECORDS RETENTION.

#### 5. SAMPLING AND ANALYTICAL METHOD

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored flow. Test procedures for the analysis of pollutants shall conform to regulation 40 CFR 136, "Test Procedures For The Analysis of Pollutants" unless other test procedures have been specified in this permit. The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to ensure accuracy of measurements.

## 6. RECORDING OF RESULTS

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- A. The exact place and date of sampling; (time of sampling not required on EPA 4500)
- B. The person(s) who performed the sampling or measurements;
- C. The date the analyses were performed on those samples;

- D. The person(s) who performed the analyses;
- E. The analytical techniques or methods used; and
- F. The results of all analyses and measurements.

#### 7. RECORDS RETENTION

The permittee shall retain all of the following records for the wastewater treatment works for a minimum of three years except those records that pertain to sewage sludge disposal, use, storage, or treatment, which shall be kept for a minimum of five years, including:

- A. All sampling and analytical records (including internal sampling data not reported);
- B. All original recordings for any continuous monitoring instrumentation;
- C. All instrumentation, calibration and maintenance records;
- D. All plant operation and maintenance records;
- E. All reports required by this permit; and
- F. Records of all data used to complete the application for this permit for a period of at least three years, or five years for sewage sludge, from the date of the sample, measurement, report, or application.

These periods will be extended during the course of any unresolved litigation, or when requested by the Regional Administrator or the Ohio EPA. The three year period, or five year period for sewage sludge, for retention of records shall start from the date of sample, measurement, report, or application.

## 8. AVAILABILITY OF REPORTS

Except for data determined by the Ohio EPA to be entitled to confidential status, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the appropriate district offices of the Ohio EPA. Both the Clean Water Act and Section 6111.05 Ohio Revised Code state that effluent data and receiving water quality data shall not be considered confidential.

## 9. DUTY TO PROVIDE INFORMATION

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking, and reissuing, or terminating the permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

#### 10. RIGHT OF ENTRY

The permittee shall allow the Director or an authorized representative upon presentation of credentials and other documents as may be required by law to:

A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.

- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit.
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
- D. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

#### 11. UNAUTHORIZED DISCHARGES

A. Bypass Not Exceeding Limitations - The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 11.B and 11.C.

#### B. Notice

- 1. Anticipated Bypass If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible, at least ten days before the date of the bypass.
- 2. Unanticipated Bypass The permittee shall submit notice of an unanticipated bypass as required in paragraph 12.B (24 hour notice).
- C. Prohibition of Bypass
- 1. Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:
- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
- c. The permittee submitted notices as required under paragraph 11.B.
- 2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 11.C.1.

#### 12. NONCOMPLIANCE NOTIFICATION

- A. Exceedance of a Daily Maximum Discharge Limit
- 1. The permittee shall report noncompliance that is the result of any violation of a daily maximum discharge limit for any of the pollutants listed by the Director in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.ohio.gov Southwest District Office: swdo24hournpdes@epa.ohio.gov Northwest District Office: nwdo24hournpdes@epa.ohio.gov Northeast District Office: nedo24hournpdes@epa.ohio.gov Central District Office: cdo24hournpdes@epa.ohio.gov

Central Office: co24hournpdes@epa.ohio.gov

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site under the Monitoring and Reporting - Non-Compliance Notification section:

https://epa.ohio.gov/divisions-and-offices/surface-water/permitting/individual-wastewater-discharge-permits

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330 Southwest District Office: (800) 686-8930 Northwest District Office: (800) 686-6930 Northeast District Office: (800) 686-6330 Central District Office: (800) 686-2330

Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
- b. The limit(s) that has been exceeded;
- c. The extent of the exceedance(s);
- d. The cause of the exceedance(s);
- e. The period of the exceedance(s) including exact dates and times;
- f. If uncorrected, the anticipated time the exceedance(s) is expected to continue; and,
- g. Steps taken to reduce, eliminate or prevent occurrence of the exceedance(s).

#### B. Other Permit Violations

1. The permittee shall report noncompliance that is the result of any unanticipated bypass resulting in an exceedance of any effluent limit in the permit or any upset resulting in an exceedance of any effluent limit in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.ohio.gov Southwest District Office: swdo24hournpdes@epa.ohio.gov Northwest District Office: nwdo24hournpdes@epa.ohio.gov Northeast District Office: nedo24hournpdes@epa.ohio.gov Central District Office: cdo24hournpdes@epa.ohio.gov

Central Office: co24hournpdes@epa.ohio.gov

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site under the Monitoring and Reporting - Non-Compliance Notification section:

https://epa.ohio.gov/divisions-and-offices/surface-water/permitting/individual-wastewater-discharge-permits

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330 Southwest District Office: (800) 686-8930 Northwest District Office: (800) 686-6930 Northeast District Office: (800) 686-6330 Central District Office: (800) 686-2330

Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
- b. The time(s) at which the discharge occurred, and was discovered;
- c. The approximate amount and the characteristics of the discharge;
- d. The stream(s) affected by the discharge;
- e. The circumstances which created the discharge;
- f. The name and telephone number of the person(s) who have knowledge of these circumstances;
- g. What remedial steps are being taken; and,
- h. The name and telephone number of the person(s) responsible for such remedial steps.
- 2. The permittee shall report noncompliance that is the result of any spill or discharge which may endanger human health or the environment within thirty (30) minutes of discovery by calling the 24-Hour Emergency Hotline toll-free at (800) 282-9378. The permittee shall also report the spill or discharge by email or telephone within twenty-four (24) hours of discovery in accordance with B.1 above.
- C. When the telephone option is used for the noncompliance reports required by A and B, the permittee shall submit to the appropriate Ohio EPA district office a confirmation letter and a completed noncompliance report within five (5) days of the discovery of the noncompliance. This follow up report is not necessary for the e-mail option which already includes a completed noncompliance report.
- D. If the permittee is unable to meet any date for achieving an event, as specified in a schedule of compliance in their permit, the permittee shall submit a written report to the appropriate Ohio EPA district office within fourteen (14) days of becoming aware of such a situation. The report shall include the following:
- 1. The compliance event which has been or will be violated;
- 2. The cause of the violation:
- 3. The remedial action being taken;
- 4. The probable date by which compliance will occur; and,
- 5. The probability of complying with subsequent and final events as scheduled.

- E. The permittee shall report all other instances of permit noncompliance not reported under paragraphs A or B of this section on their monthly DMR submission. The DMR shall contain comments that include the information listed in paragraphs A or B as appropriate.
- F. If the permittee becomes aware that it failed to submit an application or submitted incorrect information in an application or in any report to the director, it shall promptly submit such facts or information.

#### 13. RESERVED

#### 14. DUTY TO MITIGATE

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

#### 15. AUTHORIZED DISCHARGES

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than, or at a level in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit. Such violations may result in the imposition of civil and/or criminal penalties as provided for in Section 309 of the Act and Ohio Revised Code Sections 6111.09 and 6111.99.

#### 16. DISCHARGE CHANGES

The following changes must be reported to the appropriate Ohio EPA district office as soon as practicable:

A. For all treatment works, any significant change in character of the discharge which the permittee knows or has reason to believe has occurred or will occur which would constitute cause for modification or revocation and reissuance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. Notification of permit changes or anticipated noncompliance does not stay any permit condition.

- B. For publicly owned treatment works:
- 1. Any proposed plant modification, addition, and/or expansion that will change the capacity or efficiency of the plant;
- 2. The addition of any new significant industrial discharge; and
- 3. Changes in the quantity or quality of the wastes from existing tributary industrial discharges which will result in significant new or increased discharges of pollutants.
- C. For non-publicly owned treatment works, any proposed facility expansions, production increases, or process modifications, which will result in new, different, or increased discharges of pollutants.

Following this notice, modifications to the permit may be made to reflect any necessary changes in permit conditions, including any necessary effluent limitations for any pollutants not identified and limited herein. A determination will also be made as to whether a National Environmental Policy Act (NEPA) review will be required. Sections 6111.44 and 6111.45, Ohio Revised Code, require that plans for

treatment works or improvements to such works be approved by the Director of the Ohio EPA prior to initiation of construction.

- D. In addition to the reporting requirements under 40 CFR 122.41(l) and per 40 CFR 122.42(a), all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:
- 1. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit. If that discharge will exceed the highest of the "notification levels" specified in 40 CFR Sections 122.42(a)(1)(i) through 122.42(a)(1)(iv).
- 2. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" specified in 122.42(a)(2)(i) through 122.42(a)(2)(iv).

#### 17. TOXIC POLLUTANTS

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement. Following establishment of such standards or prohibitions, the Director shall modify this permit and so notify the permittee.

#### 18. PERMIT MODIFICATION OR REVOCATION

- A. After notice and opportunity for a hearing, this permit may be modified or revoked, by the Ohio EPA, in whole or in part during its term for cause including, but not limited to, the following:
- 1. Violation of any terms or conditions of this permit;
- 2. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
- 3. Change in any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge.
- B. Pursuant to rule 3745-33-04, Ohio Administrative Code, the permittee may at any time apply to the Ohio EPA for modification of any part of this permit. The filing of a request by the permittee for a permit modification or revocation does not stay any permit condition. The application for modification should be received by the appropriate Ohio EPA district office at least ninety days before the date on which it is desired that the modification become effective. The application shall be made only on forms approved by the Ohio EPA.

### 19. TRANSFER OF OWNERSHIP OR CONTROL

This permit may be transferred or assigned, and a new owner or successor can be authorized to discharge from this facility, provided the following requirements are met: A. The permittee shall notify the succeeding owner or successor of the existence of this permit by a letter, a copy of which shall be forwarded to the appropriate Ohio EPA district office. The copy of that letter will serve as the permittee's notice to the Director of the proposed transfer. The copy of that letter shall be received by the appropriate Ohio EPA district office sixty (60) days prior to the proposed date of transfer;

B. A written agreement containing a specific date for transfer of permit responsibility and coverage between the current and new permittee (including acknowledgement that the existing permittee is liable for violations up to that date, and that the new permittee is liable for violations from that date on) shall be submitted to the appropriate Ohio EPA district office within sixty days after receipt by the district office of the copy of the letter from the permittee to the succeeding owner;

At any time during the sixty (60) day period between notification of the proposed transfer and the effective date of the transfer, the Director may prevent the transfer if he concludes that such transfer will jeopardize compliance with the terms and conditions of the permit. If the Director does not prevent transfer, he will modify the permit to reflect the new owner.

#### 20. OIL AND HAZARDOUS SUBSTANCE LIABILITY

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

#### 21. SOLIDS DISPOSAL

Collected grit and screenings, and other solids other than sewage sludge, shall be disposed of in such a manner as to prevent entry of those wastes into waters of the state, and in accordance with all applicable laws and rules.

#### 22. CONSTRUCTION AFFECTING NAVIGABLE WATERS

This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

### 23. CIVIL AND CRIMINAL LIABILITY

Except as exempted in the permit conditions on UNAUTHORIZED DISCHARGES or UPSETS, nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

# 24. STATE LAWS AND REGULATIONS

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Clean Water Act.

## 25. PROPERTY RIGHTS

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations.

26. UPSET

The provisions of 40 CFR Section 122.41(n), relating to "Upset," are specifically incorporated herein by reference in their entirety. For definition of "upset," see Part III, Paragraph 1, DEFINITIONS. 27. SEVERABILITY

The provisions of this permit are severable, and if any provision of this permit, or the application of any

provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

28. SIGNATORY REQUIREMENTS

All applications submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR 122.22.

All reports submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR Section 122.22.

#### 29. OTHER INFORMATION

A. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

B. ORC 6111.99 provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

C. ORC 6111.99 states that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

D. ORC 6111.99 provides that any person who violates Sections 6111.04, 6111.042, 6111.05, or division (A) of Section 6111.07 of the Revised Code shall be fined not more than \$25,000 or imprisoned not more than one year, or both.

## 30. NEED TO HALT OR REDUCE ACTIVITY

40 CFR 122.41(c) states that it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with conditions of this permit.

#### 31. APPLICABLE FEDERAL RULES

All references to 40 CFR in this permit mean the version of 40 CFR which is effective as of the effective date of this permit.

## 32. AVAILABILITY OF PUBLIC SEWERS

Notwithstanding the issuance or non-issuance of an NPDES permit to a semi-public disposal system, whenever the sewage system of a publicly owned treatment works becomes available and accessible, the permittee operating any semi-public disposal system shall abandon the semi-public disposal system and connect it into the publicly owned treatment works.

## National Pollutant Discharge Elimination System (NPDES) Permit Program

## FACT SHEET

Regarding a Modification of an NPDES Permit to Discharge to Waters of the State of Ohio for the City of St. Marys Wastewater Treatment Plant (WWTP)

Public Notice No.: 159801 OEPA Permit No.: 2PD00026\*UD Public Notice Date: September 8, 2022 Application No.: OH0021415

Comment Period Ends: October 22, 2022

Name and Address of Facility Where

Name and Address of Applicant: Discharge Occurs:

City of St. Marys City of St. Marys Wastewater Treatment Plant 101 East Spring Street 410 Defiance Road

410 Defiance Road St. Marys, Ohio 45885 Auglaize County

Receiving Water: St. Marys River

St. Marys, Ohio 45885

Subsequent Stream Network: Maumee River to Lake Erie

#### Introduction

Development of a Fact Sheet for NPDES permits is mandated by Title 40 of the Code of Federal Regulations, Section 124.8 and 124.56. This document fulfills the requirements established in those regulations by providing the information necessary to inform the public of actions proposed by the Ohio Environmental Protection Agency, as well as the methods by which the public can participate in the process of finalizing those actions.

This Fact Sheet is prepared in order to document the technical basis and risk management decisions that are considered in the determination of water quality based NPDES Permit effluent limitations. The technical basis for the Fact Sheet may consist of evaluations of promulgated effluent guidelines, existing effluent quality, instream biological, chemical and physical conditions, and the relative risk of alternative effluent limitations. This Fact Sheet details the discretionary decision-making process empowered to the Director by the Clean Water Act and Ohio Water Pollution Control Law (ORC 6111). Decisions to award variances to Water Quality Standards or promulgated effluent guidelines for economic or technological reasons will also be justified in the Fact Sheet where necessary.

No antidegradation review was necessary.

### <u>Procedures for Participation in the Formulation of Final Determinations</u>

The proposed modification is tentative but shall become final on the effective date unless (1) an adjudication hearing is requested, (2) the Director withdraws and revises the proposed modification after consideration of the record of a public meeting or written comments, or (3) upon disapproval by the Administrator of the U.S. Environmental Protection Agency.

Within forty-five (45) days of <u>publication</u> of this notice, any person may submit written comments, a statement as to why the proposed modification should be changed, a request for a public meeting on the proposed modification

and/or a request for notice of further actions concerning the modification. All communications timely received will be considered in the final formulation of the modification. If significant public interest is shown a public meeting will be held prior to finalization of the modification.

Within thirty (30) days of the <u>issuance</u> of the proposed modification any officer of an agency of the state or of a political subdivision, acting in his representative capacity or any person aggrieved or adversely affected by issuance of it may request an adjudication hearing by submitting a written objection in accordance with Ohio Revised Code Section 3745.07. Since all other conditions of the permit remain in effect, a hearing may not be requested on any issues other than the proposed modification. If an adjudication hearing is requested, the existing NPDES permit will remain in effect until the hearing is resolved. Following the finalization of the modification by the Director, any person who was a party to an adjudication hearing may appeal to the Environmental Review Appeals Commission.

Requests for public meetings shall be in writing and shall state the action of the Director objected to, the questions to be considered, and the reasons the action is contested. Such requests should be addressed to:

Legal Records Section
Ohio Environmental Protection Agency
Lazarus Government Center
P.O. Box 1049
Columbus, Ohio 43216-1049

Interested persons are invited to submit written comments upon the proposed modification. Comments should be submitted in person or by mail no later than 30 days after the date of this Public Notice. Deliver or mail all comments to:

Ohio Environmental Protection Agency Attention: Division of Surface Water Permits and Compliance Section Lazarus Government Center P.O. Box 1049 Columbus, Ohio 43216-1049

The OEPA permit number and Public Notice numbers should appear on each page of any submitted comments. All comments received no later than 30 days after the date of the Public Notice will be considered.

Citizens may conduct file reviews regarding specific companies or sites. Appointments are necessary to conduct file reviews, because requests to review files have increased dramatically in recent years. The first 250 pages copied are free. For requests to copy more than 250 pages, there is a five-cent charge for each page copied. Payment is required by check or money order, made payable to Treasurer State of Ohio.

## Location of Discharge/Receiving Water Use Classification

The City of St. Marys WWTP discharges to the St. Marys River at River Mile 98.6 in Auglaize County. Figure 1 shows the approximate location of the facility.

This segment of the St. Marys River is described by Ohio EPA River Code: 04-500, Hydrologic Unit Code: 04100004-01-06, County: Auglaize, Ecoregion: Eastern Corn Belt Plains (ECBP). The St. Marys River is designated for the following uses under Ohio's WQS (OAC 3745-1-07): Warmwater Habitat (WWH), Agricultural Water Supply (AWS), Industrial Water Supply (IWS), Primary Contact Recreation (PCR) The St. Marys River combines with the St. Joseph River to form the Maumee River in Indiana.

Use designations define the goals and expectations of a waterbody. These goals are set for aquatic life protection, recreation use and water supply use, and are defined in the Ohio WQS (OAC 3745-1-07). The use designations for individual waterbodies are listed in rules -08 through -32 of the Ohio WQS. Once the goals are set, numeric WQS are developed to protect these uses. Different uses have different water quality criteria.

Use designations for aquatic life protection include habitats for coldwater fish and macroinvertebrates, warmwater aquatic life and waters with exceptional communities of warmwater organisms. These uses all meet the goals of the federal CWA. Ohio WQS also include aquatic life use designations for waterbodies which cannot meet the CWA goals because of human-caused conditions that cannot be remedied without causing fundamental changes to land use and widespread economic impact. The dredging and clearing of some small streams to support agricultural or urban drainage is the most common of these conditions. These streams are given Modified Warmwater or Limited Resource Water designations.

Recreation uses are defined by the depth of the waterbody and the potential for wading or swimming. Uses are defined for bathing waters, swimming/canoeing (Primary Contact Recreation) and wading only (Secondary Contact which are generally waters too shallow for swimming or canoeing). Water supply uses are defined by the actual or potential use of the waterbody. Public Water Supply designations apply near existing water intakes so that waters are safe to drink with standard treatment. Most other waters are designated for agricultural water supply and industrial water supply.

## **Facility Description**

The City of St. Marys Wastewater Treatment Plant was last upgraded in 2009. The average design flow is 3.0 million gallons per day (MGD) and the peak hydraulic capacity is 9.0 MGD. The City of St. Marys Wastewater Treatment Plant serves a population of 9,421 in the City of St. Marys and 3,254 in St. Marys Township for a total of 12,675 customers. The City of St. Marys Wastewater Treatment Plant has the following treatment processes which are shown in Figure 2:

- Influent fine screening;
- Vortex Grit Removal;
- Orbital Oxidation Ditch;
- Ferrous Chloride addition for phosphorus removal;
- Two peripheral feed secondary clarifiers; and
- Ultraviolet disinfection

The treatment plant includes a 2.7 million-gallon equalization basin (EQ basin). Wastewater is diverted to the EQ basin at the headworks of the plant when the influent flow exceeds 9.0 MGD. Flow is screened prior to being diverted to the EQ basins. When the EQ basin becomes full, wastewater is bypassed directly to the St. Marys River through outfall 009. When the precipitation event has ended, the wastewater from the EQ basin is routed back to the headworks of the plant to receive full treatment. The City of St. Marys collection system has 100% separated sanitary sewers.

The City of St. Marys is subject to the following additional conditions: Ohio EPA Director's Final Findings and Orders issued to the City in September 2003 requiring the elimination of five (5) SSO's and the bypass from the EQ Basin.

## **Basis of the Modification**

Part I,C, Item B of NPDES permit 2PD00026\*TD included a compliance schedule requirement to submit a comprehensive analysis of feasible alternatives to eliminate the WWTP bypass and SSOs in the collection system. The permittee's recommended alternative is to abandon the current WWTP operational mode, referred to as the Cannibal system. The Cannibal system requires the facility to maintain a very high mixed liquor suspended solids (MLSS) concentration and results in a less-than-typical amount of sludge that must be wasted from the facility. However, to prevent the high MLSS from washing out in the effluent, the facility must avoid high flow rates. This operational limitation on the peak hydraulic capacity of the WWTP induces the discharge of untreated bypasses to the receiving stream during wet weather events. Before the permittee can abandon the Cannibal operational mode, the facility's sludge treatment and handling processes must be expanded to the accommodate the increased volume of wasted sludge.

The permittee has submitted a permit modification application to incorporate a revised compliance schedule to expand sludge treatment systems, abandon the Cannibal System, and monitor the facility's hydraulic capacity and reassess bypass activity after the changes are implemented. If the assessment determines that bypasses at Outfall 009 continue to occur, the report shall include a No Feasible Alternatives (NFA) analysis and propose additional controls to eliminate the bypass.

Additionally, the compliance schedule has been revised to separate the NFA requirement for the WWTP bypass and the requirement to eliminate SSOs in the collection system.

Figure 1. Approximate location of St. Marys WWTP.




Figure 1. Diagram of Wastewater Treatment System

