

Re: Columbiana County, Middleton Township  
Application No. 3MP00052\*AM  
Land Application Management Plan Permit for Lambs House, Inc.  
Plans Received: March 14, 2018

Issue Date: July 25, 2018  
Effective Date: September 1, 2018  
Expiration Date: August 31, 2023

Lambs House, Inc.  
Box 24  
Rogers, OH 44455

Ladies and Gentlemen:

The Ohio Environmental Protection Agency (Ohio EPA) has reviewed the land application management plan submitted pursuant to Ohio Revised Code Chapter (ORC) 6111.44 and Ohio Administrative Code Chapter (OAC) 3745-42-13. The plan is approved subject to the condition of compliance with all applicable laws, rules, regulations and all the conditions below and in Part I, Part II and Part III of this permit.

The entity shall perform the proposed land application in strict accordance with the conditions in this permit and with the method of operation outlined in the land application management plan submitted to the Ohio Environmental Protection Agency. Approval of the land application management plan does not constitute assurance that the proposed operation will be in compliance with all Ohio laws and regulations.

This permit is not an authorization for a discharging land application system. Pursuant to OAC 3745-42-13 and OAC 3745-42-02, a discharging land application system requires a National Pollutant Discharge Elimination System (NPDES) permit to discharge and a permit to install, in accordance with ORC 6111. The applicant shall apply for an NPDES permit 180 days prior to operating a discharging land application system and a permit to install prior to installing the land application system.

Any unauthorized discharges to waters of the state must be reported to Ohio EPA (toll free) by calling 1-800-282-9378 within 2 hours of discovery. The director shall be notified in writing within seven days of any person discovering noncompliance with a land application management plan or an NPDES permit.

This applicant is required to submit a revised land applicaiton management plan application, if the Director of the Ohio EPA deems it necessary.

The director may add, delete, or change any conditions to a land application management plan permit to protect human health or the environment.

Any expansion of the operation or modification of the treatment works or the expansion or modification of any land application area must be approved by the Ohio EPA.

The director of the Ohio Environmental Protection Agency, or his authorized representative(s), may enter upon the premises of the land application system during its construction or its operation at any reasonable time for the purpose of making inspections, conducting tests, examining records, or reports pertaining to the installation, modification, or operation of the land application system.

Issuance of this permit does not relieve you of the duty of complying with all applicable federal, state, and local laws, ordinances, and regulations.

This permit shall expire at midnight on the expiration date shown above. In order to receive authorization to continue to land apply beyond the date of expiration, you shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel", which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission  
77 South High Street, 17th Floor  
Columbus, Ohio 43215

Sincerely,



---

Anne M. Vogel  
Director

cc: Northeast District Office  
Columbiana County Health Department  
Betsy VanWormer, DSW, CO

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from outfall 3MP00052601. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Internal Monitoring Station - 601 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months		
Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly	
00056 - Flow Rate - GPD	-	-	-	-	-	-	-	1/Day	24hr Total Estimate	All
00300 - Dissolved Oxygen - mg/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
00400 - pH - S.U.	9.0	6.0	-	-	-	-	-	1/Quarter	Grab	Quarterly
00530 - Total Suspended Solids - mg/l	-	-	18	12	-	-	-	1/Quarter	Grab	Quarterly
00552 - Oil and Grease, Hexane Extr Method - mg/l	10	-	-	-	-	-	-	1/Year	Grab	Yearly
00640 - Nitrogen, Inorganic, Total - mg/l	-	-	-	10	-	-	-	1/Quarter	Grab	Quarterly
01350 - Turbidity, Severity - Units	-	-	-	-	-	-	-	1/Week	Estimate	All
31648 - E. coli - #/100 ml	126	-	-	-	-	-	-	1/Quarter	Grab	Summer - Qtrly
50060 - Chlorine, Total Residual - mg/l	10	1	-	-	-	-	-	1/Quarter	Grab	Summer - Qtrly
80082 - CBOD 5 day - mg/l	-	-	15	10	-	-	-	1/Quarter	Grab	Quarterly

Notes for station 3MP00052601:

\* Effluent loadings based on average design flow of 0.00605 MGD.

a. Sampling shall be performed when discharging.

b. Effluent samples shall be collected after wastewater treatment and prior to discharging into the storage pond.

c. Rainfall amount shall be measured for any rain event when sewage is applied.

d. Sewage shall only be land applied at times set forth in the approved land application management plan that will minimize human exposure to the application of treated sewage.

e. Noncompliance notification - See Part III, Item 12.

f. Chlorine - See Part II, Item H.

g. Turbidity - See Part II, Item K.

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from outfall 3MP00052603. See Part II, OTHER REQUIREMENTS, for locations of effluent sampling.

Table - Internal Monitoring Station - 603 - Final

<u>Effluent Characteristic</u>  Parameter	<u>Discharge Limitations</u>							<u>Monitoring Requirements</u>		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00045 - Total Precipitation - Inches	-	-	-	-	-	-	-	1/Day	24hr Total	All
31648 - E. coli - #/100 ml	-	-	-	-	-	-	-	When Disch.	Grab	All
50042 - Area Sprayed, Acres - Acres	-	-	-	-	-	-	-	When Disch.	Total Estimate	All
50045 - Application Rate-Wastewater, Spray - inches/day	-	-	-	-	-	-	-	When Disch.	Total	All

Notes for station 3MP00052603:

Part I, B. - SLUDGE MONITORING REQUIREMENTS

1. Sludge Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' final sludge at Station Number 3MP00052588, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 588 - Final

Effluent Characteristic  Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day		Measuring Frequency	Sampling Type	Monitoring Months			
Maximum	Minimum	Weekly	Monthly	Daily				Weekly	Monthly	
80991 - Sludge Volume, Gallons - Gals	-	-	-	-	-	-	-	1/Year	Total	December

NOTES for Station Number 3MP00052588:

- a. Monitoring is required when sewage sludge is removed from the permittee's facility for transfer to another NPDES permit holder. The total sludge volume transferred to another NPDES permit holder for the entire year shall be reported on the December Discharge Monitoring Report (DMR).
- b. If no sewage sludge is removed from the Permittee's facility for transfer to another NPDES permit holder during the year, select the "No Discharge" check box on the data entry form and PIN the eDMR.
- c. See Part II, Items I & J.

## Part II, OTHER REQUIREMENTS

### A. General Land Application Requirements

1. New Day Recovery LLC. and their designated Operator of Record shall be responsible for proper operation and maintenance of the treated sewage land application system.
2. This permit applies to land application of treated sewage from the New Day Recovery LLC. treatment works, that has been designed to treat an average daily flow of 6,050 gallons per day (gpd).
3. Any person land applying treated sewage shall confirm that the treated sewage, prior to its storage, is in accordance with this land application management plan and is at least a Class B as defined in paragraph OAC 3745-42-13 (K).
4. Treated sewage shall be land applied so as to minimize direct human contact, and the potential for creating aerosols and mist.
5. Signs shall be installed at the entrance to each land application area, to inform the public that the land is used for land application of treated sewage. "No Trespassing" signs shall be posted at regularly spaced intervals and along all entrances to the fields. Each sign shall include notification that:
  - (i) All above ground sewage distribution pipes contain "Non-potable Water that is Not Suitable for Human Consumption"; and
  - (ii) If applicable, all nozzles distribute "Non-potable Water that is Not Suitable for Human Consumption".
6. The Ohio EPA shall be notified at least six months prior to the expiration date of any land application contract. Notification shall be sent to the Division of Surface Water, at the appropriate Ohio EPA district office.
7. Records shall be kept in accordance with the approved land application management plan and OAC 3745-42-13(O).
8. Any new site proposed for land application shall be approved by the Director of Ohio EPA prior to the land application of treated sewage. A revised land application management plan, including the information specified in paragraphs (F), (M) and (N) of OAC 3745-42-13 for the new site, shall be submitted to the appropriate Ohio EPA district office, and a new LAMP approval received before the new site is used for land application of treated sewage.

## B. Operator Certification Requirements

### 1. Classification

a. In accordance with OAC 3745-7-04, the treatment works at this facility shall be classified as a Class A facility.

### 2. Operator of Record

a. The permittee shall designate one or more operator of record to oversee the technical operation of the treatment works and sewerage (collection) system in accordance with paragraph (A)(2) of rule 3745-7-02 of the Ohio Administrative Code.

b. Each operator of record shall have a valid certification of a class equal to or greater than the classification of the treatment works as defined in Part II, Item A.1 of this NPDES permit.

c. Within three days of a change in an operator of record, the permittee shall notify the Director of the Ohio EPA of any such change on a form acceptable to Ohio EPA. The appropriate form can be found at the following website:

[http://epa.ohio.gov/Portals/28/documents/opcert/Operator\\_of\\_Record\\_Notification\\_Form.pdf](http://epa.ohio.gov/Portals/28/documents/opcert/Operator_of_Record_Notification_Form.pdf)

d. Within 60 days of the effective date of this permit, the permittee shall notify the Director of Ohio EPA of the operators of record on a form acceptable to Ohio EPA.

### 3. Minimum Staffing Requirements

a. The permittee shall ensure that the treatment works operator of record is physically present at the facility in accordance with the minimum staffing requirements per paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code or the requirements from an approved 3745-7-04(C) minimum staffing hour reduction plan.

C. Description of the location of the required sampling stations are as follows:

Sampling Station	Description of Location
------------------	-------------------------

---

3MP00050601	WWTP discharge prior to storage pond (Lat: 40N 45 ' 30 " ; Long: 80W 34' 00")
3MP00052603	Treated wastewater at the spray irrigation field
3MP00052588	Sludge hauled to another permitted NPDES facility

D. All parameters, except flow, need not be monitored on days when the plant is not normally staffed (Saturdays, Sundays, and Holidays). On those days, report "AN" on the monthly report form.

E. Grab samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's performance.

F. Water quality based permit limitations in this permit may be revised based on updated wasteload allocations or use designation rules. This permit may be modified, or revoked and reissued, to include new water quality based effluent limits or other conditions that are necessary to comply with a revised wasteload allocation, or an approved total maximum daily loads (TMDL) report as required under Section 303 (d) of the Clean Water Act.

G. The permittee shall abandon the treatment system and connect any influent flows to the the publically-owned treatment works whenever the sewage system of a publically-owned treatment works becomes available and accessible.

#### H. REPORTING:

All analytical results, even those below the OEPA QL (listed below), shall be reported. Analytical results are to be reported as follows:

1. Results above the QL: Report the analytical result for the parameter of concern.
2. Results above the MDL, but below the QL: Report the analytical result, even though it is below the QL.
3. Results below the MDL: Analytical results below the method detection limit shall be reported as "below detection" using the reporting code "AA".

The following table of quantification levels will be used to determine compliance with NPDES permit limits:

Parameter PQL ML

Chlorine, tot. res. 0.050 mg/l--

This permit may be modified, or, alternatively, revoked and reissued, to include more stringent effluent limits or conditions if information generated as a result of the conditions of this permit indicate the presence of these pollutants in the discharge at levels above the water quality based effluent limit (WQBEL).

I. All disposal, use, storage, or treatment of sewage sludge by the Permittee shall comply with Chapter 6111. of the Ohio Revised Code, Chapter 3745-40 of the Ohio Administrative Code, any further requirements specified in this NPDES permit, and any other actions of the Director that pertain to the disposal, use, storage, or treatment of sewage sludge by the Permittee.

J. No later than March 1 of each calendar year, the Permittee shall submit a report summarizing the sewage sludge disposal, use, storage, or treatment activities of the Permittee during the previous calendar year. The report shall be submitted through the Ohio EPA eBusiness Center, Division of Surface Water NPDES Permit Applications service.

K. If Severity Units are required for Turbidity, Odor, or Color, use the following table to determine the value between 0 and 4 that is reported.

REPORTED VALUE*	SEVERITY DESCRIPTION	TURBIDITY	ODOR	COLOR
0	None	Clear	None	Colorless
1	Mild			
2	Moderate	Light Solids	Musty	Grey
3	Serious			
4	Extreme	Heavy Solids	Septic	Black

\* Interpolate between the descriptive phrases.

L. The permittee shall never allow or cause the spray irrigation to enter any Waters of the State of Ohio.



RECEIVED

MAR 14 2018

Central District Office  
 Ohio EPA

**Plan Approval**

Treated Sewage Land Application Management Plan

**FOR AGENCY USE ONLY**

Application Number:	Date Received: / /
District office: Please check which applies: <input checked="" type="checkbox"/> Design flow less than 10,000 gpd <input type="checkbox"/> Design flow greater than or equal to 10,000 gpd	District office: Please check which applies: <input checked="" type="checkbox"/> Land application rate less than or equal to 12 inches/acre/year <input type="checkbox"/> Land Application rate greater than 12 inches/acre/year
District office: please check which applies: The land application system is: <input type="checkbox"/> A discharging land application system; or <input checked="" type="checkbox"/> A non-discharging land application system.	District office: please indicate recommended term of plan approval (based on compliance record): <input checked="" type="checkbox"/> 5 years <input type="checkbox"/> 10 years

**General Information**

Applicant:	New Day Recovery, LLC.	
Project Name:	New Day Recovery Middleton Facility	
County (ies) that Project is Located in:	Middletown Township	Treatment Works
	Columbiana County	Land Application Area
Source(s) of Treated Sewage:	Drug Rehabilitation Facility	(Treatment Works name)
Operator Certification Class required for the WWTP (check one): <input checked="" type="checkbox"/> A <input type="checkbox"/> I <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/> IV (See Rule 3745-7 of the Ohio Administrative Code for Operator Certification Requirements)		
How many hours per week is the operator present at the Treatment Works? <u>1.0</u> hours/week		
Check appropriate response: <input checked="" type="checkbox"/> Initial management plan application <input type="checkbox"/> Renewal management plan application <input type="checkbox"/> Transfer Application		
Is a NPDES permit required for this project? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No    If yes, state NPDES permit number: <u>former 3PR00361</u>		
<b>If this is a management plan application for a system installed prior to July 1, 2007, skip to Item V.</b>		
<i>(Note: If no NPDES permit is required, this form shall be submitted with a PTI/Plan Approval Application Form A and plan approval fee; if a NPDES permit is required, this form shall be submitted with the NPDES permit application form and NPDES permit application fee – no separate plan approval fee is required. Refer to Rule 3745-42-13 (E) of the Administrative Code for NPDES permit requirements for land application systems).</i>		
Is Applicant for the Land Application Management Plan the Operator/Owner of the Treatment Plant? <input type="checkbox"/> Yes <input type="checkbox"/> No If not, please explain and state who is responsible for monitoring the treatment plant effluent quality:		

At a minimum, the following items shall be included in the land application management plan required by Rule 3745-42-13 of the Administrative Code. Any additional unique features must be described on separate pages and attached to this plan.

**A. Treatment and Storage Information**

Average Daily Design Flow to the Treatment Works: \_\_\_\_\_ gpd

Average Actual Flow to the treatment works (if existing treatment works): \_\_\_\_\_ gpd

Sewage Treatment Class That Will be Attained:

Class A     Class B

Class C (only an option for Land Application Systems with a design flow less than 10,000 gpd)

*Attach a sheet indicating the effluent limits and minimum monitoring frequencies that must be followed in accordance with table (K)(1) of Rule 3745-42-13 of the Administrative Code.*

**B. Describe the method or methods used for the storage and land application of treated sewage (including detailed information about the distribution system):**

**C. Describe the experience of the operator of the land application system in operating a land application system, and state how many hours per week the operator will be working at the land application system location:**

**D. Describe the additional storage volume provided for the treated sewage that will be available for times when land application is not practical or allowable (indicate units):**

**E. Describe the minimum freeboard to be provided in the storage facility (ies) (refer to Table H-3 of Rule 3745-42-13 of the Administrative Code for minimum freeboard requirement, and the design plans – enter most stringent) and how it will be measured and maintained:**

**F. Equipment calibration & maintenance schedule (add more rows as needed):**

Type of Equipment	Frequency of Calibration	Frequency of Maintenance

**Land Application/Irrigation Management**

**G. Indicate how much treated sewage will be land applied (check all that apply) in inches per acre for each month (if zero, enter zero) for each land application area. Attach an additional sheet for each land application area.**

Land application area location: \_\_\_\_\_ (Include County)

January     February     March     April     May     June  
 July     August     September     October     November     December

Hours of the Day that land application may occur. (Please check a.m. or p.m.)

From \_\_\_\_\_  a.m.  p.m. To \_\_\_\_\_  a.m.  p.m.

Total Annual Application Rate for the land application area is:

less than or equal to 12 inches/acre/year     greater than 12 inches/acre/year

**H. Please provide justification supporting the determination of the land application rate(s) and the total acres required and available for land application, in accordance with paragraphs (E) and (F) of Rule 3745-42-13 of the Administrative Code:**

**I. Please describe the appropriate weather conditions required for the land application of treated sewage and how they will be determined:**

**J. Check which land application restrictions are applicable and will be followed (if any of these will not be followed, attach a separate sheet explaining how the requirements of Rule 3745-42-13 of the Administrative Code will be met):**

No land application during precipitation events	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Allowed per NPDES Permit
No land application on frozen or snow covered ground	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Allowed per NPDES Permit
No spray irrigation when instantaneous wind speeds exceed 20 miles per hour	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Will not be followed
No land application within 10-year floodplain	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Will not be followed
No land application in wetlands	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Will not be followed
No land application where the land application contract is expired or void	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Will not be followed
No land application when the ground is saturated at or near the surface	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Will not be followed
Land application will only occur where there is at least 12 inches between final grade and bedrock, sand or gravel lenses, compacted glacial till, and/or normal ground water elevation.	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Will not be followed
No land application within the emergency management zone of a public water system using surface water or within 1,500 of any drinking water intake, whichever is greater unless the treated sewage meets the water quality standards established for the public water supply use designation under Chapter 3745-1 of the Administrative Code.	<input type="checkbox"/> Will be followed	<input type="checkbox"/> Will not be followed

**K. Isolation Distances for Land Application Areas – please indicate the setbacks that will be provided in accordance with rule 3745-42-13(J):**

Siting Criteria	Minimum Isolation Distance Provided (feet)*
Private potable water source not owned by the person land applying sewage	_____
Private potable water source owned by the person land applying sewage	_____
UIC Class V Injection Well	_____
Sinkhole or Karst Feature	_____
Property line	_____
Human crops that may be eaten raw	_____

**L. Please explain how the additional siting criteria for Land Application of Class A Treated Sewage will be met per paragraph (J)(2) of Rule 3745-42-13 of the Administrative Code:**  N/A

**M. Please explain how the additional siting criteria for Land Application of Class B Treated Sewage will be met per paragraph (J)(3) of Rule 3745-42-13 of the Administrative Code:**  N/A

**N. Will Class C treated sewage be land applied in accordance with paragraph (J)(4) of Rule 3745-42-13 of the Administrative Code?**  Yes  No

*\* Refer to Paragraph (C), Table J-1 and Paragraphs (J)(2) to (J)(4) of Rule 3745-42-13 of the Administrative Code for minimum required isolation distances for land application areas.*

**O. Describe how treated sewage will be land applied so as to minimize direct human contact, and the potential for creating aerosols and mist:**

**P. Describe or list any other practices that will be used to minimize pollutant discharges or nuisances:**

**Q. Will ground water monitoring exemptions for the storage facility or land application site(s) apply?  
If so, please list which one(s):**

**If not, describe who is responsible for the ground water monitoring program and indicate when the program was approved by Ohio EPA (see paragraph (L) of Rule 3745-42-13 of the Administrative Code for ground water monitoring requirements):**

**R. Describe how operation and maintenance records for the land application system will be kept in accordance with Rule 3745-42-13 of the Administrative Code:**

**S. A record keeping form showing how and where land application records will be kept shall be attached. Records shall be kept in accordance with paragraph (O) of Rule 3745-42-13 of the Administrative Code.**

Ohio EPA's Land Application Record Form or  Our Own Land Application Record Form is attached.

**T. Will the land application system serve two or more homes or treat 10,000 gpd or greater and not be operated by a public entity?**

Yes  No

*If yes, then the additional information listed in Paragraph (D)(6)(f) of Rule 3745-42-13 of the Administrative Code must be attached with the initial land application management plan.*

**U. A map locating each land application site shall be attached. Each site shall be labeled "Restricted access site" or "Un-restricted access site". The map(s) shall show the following items and are considered part of this plan:**

- All present and known proposed occupied buildings within 300 feet of the land application area.
- All present and known proposed non occupied buildings within 300 feet of the land application area.
- Developments and Public access areas within 300 feet of the land application area.
- All public sewerage system(s) and their planning area(s) within 1,000 feet of the land application area.
- All drinking water supply intakes or emergency management zones within 1,000 feet of the land application area.
- Location of signs required in accordance with rule 3745-42-13(E)(1).

**V. Land Application Systems installed prior to the effective date of Rule 3745-42-13 of the Administrative Code**

*This section references land application systems that have been installed/in operation prior to July 1, 2007.*

Please check which applies:

No treated sewage shall be land applied within the emergency management zone of a public water system using surface water or within one thousand five hundred feet of any drinking water intake, whichever is greater unless the treated sewage meets the water quality standards established for the public water supply use designation under Chapter 3745-1 of the Administrative Code.       Will be followed       Will not be followed.

*The following items shall be attached for existing land application systems:*

- Effluent pollutant sampling and monitoring records for the past five years.
- Flow monitoring records for the past five years.
- A description of how the land application of treated sewage is managed including application rates, setbacks, and the practices that are used to comply with paragraph (E)(1) of Rule 3745-42-13 of the Administrative Code.


**Miscellaneous Information:**

*The following items shall be included with this land application management plan:*

- Two copies of the Permit-to-Install/Plan Approval Application Form A or the NPDES Permit Application.
- Two copies of the site and soil evaluation required in accordance with rule 3745-42-13(N).  
(For renewal applications, this is only needed if additional or different areas will be used for land application)
- One copy of the effluent pollutant sampling and flow monitoring records for the last five years. (Renewal Applications Only)
- Four copies of this management plan and any attachments.
- Fee check payable to "Treasurer, State of Ohio."

The following additional information is included with this form:

Copies of PTI 02-16998 approved on September 24, 2003



**Signature: The foregoing data is a true statement of facts pertaining to this proposed land application management plan.**

Date: 3/6/2018 Signed:

Plan prepared by: New Day Recovery, LLC