Project Manual

Project Number: DAS-OIT223

Project Name: Butler Guyed Tower Replacement

Prepared for: MARCS

Ohio Facilities Construction Commission


Prepared by: Engineer of Record

Verdantas, LLC

James G Roberts, PE 1555 W Main Street Newark, OH 43055

Project Manager: Amanda Spencer

Date: September 21st, 2023



Document 00 01 10 - Table of Contents (General Contracting Project)

State of Ohio Standard Requirements for Public Facility Construction

PROCUREMENT AND CONTRACTING REQUIREMENTS GROUP

Division 00 – Procurement and Contracting Requirements

Introductory Information

00 01 10.....Table of Contents

Procurement Requirements

00 21 13Instructions to Bidde	
00 Z1 15Ilistructions to Didde	rs
00 41 13Bid Form	
00 43 13Bid Security Form	
00 45 13Bidder's Qualificatio	n
00 45 39EDGE Affidavit	

Contracting Requirements

COII	tracting K	equirements
00 52	2 00	.Agreement Form
00 52	2 14	.Subcontract Form (OAC 153:1-03-02)
00 6	1 13	.Performance and Payment Bond Form
00 7	1 00	.Contracting Definitions
00 72	2 13	.General Conditions
00 73	3 43	. Wage Rate Requirements

SPECIFICATIONS GROUP

GENERAL REQUIREMENTS SUBGROUP

Division 01 - General Requirements

01 10 00	.Project Description
01 20 00	.Bid Items
01 30 00	.Geotechnical Report
01 40 00	.Tower Preliminary Design
01 50 00	.COAX Cable Specifications
01 60 00	.FAA Lighting Specifications

END OF DOCUMENT

Document 00 10 00 - Solicitation (General Contracting / Electronic Bid) State of Ohio Standard Requirements for Public Facility Construction

Electronic bids will be received by:

OFCC https://bidexpress.com

for the following Project:

DAS-OIT223 Butler Guyed Tower Replacement 6469 Garber Road Belleville, Ohio 44813

in accordance with the Contract Documents prepared by:

Verdantas 1555 W Main Street Newark, OH 43055 740-344-5451 (office) 740-224-0600 (desk)Amanda E Spencer aspencer@verdantas.com

In compliance with Section 153.08 of the Ohio Revised Code and Section 153:1-8-01 of the Ohio Administrative Code, Bids for this Project are being received, opened, and published through electronic means using the State's electronic bidding service.

To access this Project through the electronic bidding service, you must first register at https://bidexpress.com by clicking on the "REGISTER FOR FREE" button and following the instructions. In order to bid, you must create and enable a digital ID within the service. This process requires the submission of notarized paperwork and may take up to five business days to complete. There are no fees to register, create and enable a digital ID, or to download bid documents. There is a small expense on a monthly or per bid basis to submit a bid. The electronic bidding service offers customer support that may be reached at 888.352.2439 or via email at support@bidexpress.com.

Bidders may submit requests for consideration of a proposed Substitution for a specified product, equipment, or service to the Architect/Engineer ("A/E") no later than 10 days prior to the bid opening. Additional products, equipment, and services may be accepted as approved Substitutions only by written Addendum.

From time to time, the Commission issues new editions of the "State of Ohio Standard Requirements for Public Facility Construction" and may issue interim changes. Bidders must submit Bids that comply with the version of the Standard Requirements included in the Contract Documents.

Prevailing Wage rates and Equal Employment Opportunity requirements are applicable to this Project.

This Project is subject to the State of Ohio's Encouraging Diversity, Growth, and Equity ("EDGE") Business Development Program. A Bidder is required to submit with its Bid and with its Bidder's Qualifications form, certain information about the certified EDGE Business Enterprise(s) participating on the Project with the Bidder. Refer to **Section 6.1.10** of the **Instructions to Bidders**.

The EDGE Participation Goal for the Project is 5.0 percent.

The percentage is determined by the contracted value of goods, services, materials, and labor that are provided by EDGE-certified business(es). The participation is calculated on the total amount of each awarded contract. For more information about EDGE, contact the Business Certification Compliance Manager at Stacy.Cornett@development.ohio.gov, or at 77 South High Street, 28th Floor, Columbus, Ohio 43215; or by telephone at (614) 728-0088.

The Bidder may be subject to a Pre-Award Affirmative Action Compliance Review in accordance with Section 123:2-5-01 of the Ohio Administrative Code including a review of the Bidder's employment records and an on-site review.

The Bidder must indicate on the electronic Bid Form, the locations where its services will be performed in the spaces provided or by attachment in accordance with the requirements of Executive Order 2019-12D related to providing services only within the United States and the requirements of Executive Order 2022-02D prohibiting purchases from or investment in any Russian institution or company. Failure to do so may cause the Bid to be rejected as non-responsive.

DOMESTIC STEEL USE REQUIREMENTS AS SPECIFIED IN OHIO REVISED CODE SECTION 153.011 APPLY TO THIS PROJECT. COPIES OF OHIO REVISED CODE SECTION 153.011 CAN BE OBTAINED FROM ANY OF THE OFFICES OF THE OHIO FACILITIES CONSTRUCTION COMMISSION.

Bidders are encouraged to be enrolled in and to be in good standing in a Drug-Free Safety Program ("DFSP") approved by the Ohio Bureau of Workers' Compensation ("OBWC") prior to submitting a Bid and provide, on the Electronic Bid Form with its Bid, certain information relative to their enrollment in such a program; and, if awarded a Contract, shall comply with other DFSP criteria described in **Section 1.6** of the **General Conditions**.

Electronic bids will be received for:

Trade Estimate
General Contract \$848,000.00

until October 25th, 2023, at 2:00 p.m., when all Bids will be electronically opened. Bid tabulations will be posted no later than 5:00 p.m. on the day Bids are opened.

All Bidders are strongly encouraged to attend the Pre-Bid Meeting on October 10th, 2023, at 12:30 p.m. until approximately 1:30 p.m., at the following location: Throughway 25 Carey, Wyandot County, Ohio (project site).

The Contractor is responsible for scheduling the Project, coordinating the Subcontractors, and providing other services identified in the Contract Documents.

The Contract Documents may be downloaded as electronic PDF files from the State's electronic bidding service at https://bidexpress.com at no charge.

END OF DOCUMENT

Document 00 21 13 - Instructions to Bidders (General Contracting / Electronic Bid) State of Ohio Standard Requirements for Public Facility Construction

TABLE OF CONTENTS

ARTICLE 1 - GENERAL INSTRUCTIONS	1
ARTICLE 2 - BIDDING PROCEDURES	1
ARTICLE 3 - BID OPENING AND EVALUATION	5
ARTICLE 4 - WITHDRAWAL OF BID	8
ARTICLE 5 - BID GUARANTY AND BOND	9
ARTICLE 6 - CONTRACT AWARD AND EXECUTION	10
KEYWORD INDEX	12

ARTICLE 1 - GENERAL INSTRUCTIONS

1.1 Applicable Law and Forum

1.1.1 The rights of any Bidder or any party to a subsequent Contract shall be governed by the laws of the state of Ohio and only Ohio courts shall have jurisdiction over any action or proceeding related to the Bid or any subsequent Contract. The Bidder irrevocably consents to such jurisdiction.

1.2 Project Scheduling and Coordination

- **1.2.1** When the Contract Documents refer to a period of time by a number of days, it excludes the first day and includes the last day of the period. If the last day of the period falls on a Saturday, Sunday, or a legal holiday, that day shall be omitted and the period shall end on the next day which is not a Saturday, Sunday, or legal holiday.
- **1.2.2** The time for completion of the Project indicated on the electronic **Bid Form** is the time for Substantial Completion of all Work applicable to the Bidder.
- **1.2.3** The State may assign all or any portion of its interest in a Contract with one or more of the successful Bidders to another successful Bidder as an agreed condition for an award of the Contract for the respective Bid. The assignment may include, without limitation, the duty to schedule, coordinate, and administer the Contract.
- **1.2.4** The Contractor is responsible for scheduling the Project, coordinating the Subcontractors, and providing other services identified in the Contract Documents.
- **1.2.5** By submitting its Bid, the Bidder indicates its understanding that the Contract Sum, based on its Bid and as amended by Change Orders, includes all costs that the Contracting Authority owes the Bidder.

1.3 Written Notice

- **1.3.1** Notice under the Contract Documents shall be validly given if:
 - **1.3.1.1** delivered personally to a member of the organization for whom the notice is intended;
 - 1.3.1.2 delivered, or sent by registered or certified mail, to the last known business address of the organization; or
 - **1.3.1.3** sent by facsimile, email, or web-based project management software, provided the original signed document is delivered within 3 business days after the date of the electronic transmission.
- **1.3.2** Notices provided to one Project Participant from another shall be simultaneously copied to the prospective Bidders, the Owner, the Contracting Authority, and the A/E.

1.4 Use of the State's Electronic Bidding Software

- **1.4.1** The Bidder shall use the State's Electronic Bidding Software to submit its Bid for this Project. Paper Bids will not be accepted.
- **1.4.2** Bidders, Subcontractors, and Material Suppliers may download the Contract Documents as PDF files from the State's Electronic Bidding Software at no charge by registering and associating with a company at https://bidexpress.com.
- **1.4.3** Bidders are encouraged to create and obtain approval of their Digital ID well in advance of the bid deadline. Approval may take up to seven business days.

- **1.4.4** Bidders are also encouraged to click the "Select for Bidding" link on the electronic **Bid Form** to be listed on the electronic Plan Holder's list and submit payment to receive notifications regarding Addenda and other announcements.
- 1.4.5 Subcontractors and Material Suppliers may view the electronic Plan Holder's list to determine potential Bidders.
- **1.4.6** Bidders, Subcontractors, and Material Suppliers are encouraged to attend a contractor webinar or contact the vendor's help desk through the means identified at https://bidexpress.com to increase their knowledge of using the State's Electronic Bidding Software.

ARTICLE 2 - BIDDING PROCEDURES

2.1 Examination of Contract Documents and the Site

- **2.1.1** Before submitting a Bid, the Bidder shall examine all Contract Documents, including, but not limited to, the Drawings, Specifications, and Addenda for all divisions of Work for the Project, noting in particular all requirements that may affect its Work in any way.
- **2.1.2** The Bidder's failure to become acquainted with the extent and nature of Work required to complete any portion of the Work in conformity with the requirements of the Contract Documents, shall not be a basis for additional compensation.
- **2.1.3** Before submitting a Bid, the Bidder should not only examine and evaluate the Site and related Project conditions where the Work will be performed, but shall also consider when the Work will be performed including, but not limited to, the following:
 - **2.1.3.1** the condition, layout, and nature of the Site and surrounding area;
 - 2.1.3.2 the availability and cost of labor;
 - **2.1.3.3** the availability and cost of materials, supplies, and equipment;
 - 2.1.3.4 the cost of temporary utilities required in the Bid;
 - 2.1.3.5 the cost of any permit or license required by a local or regional authority having jurisdiction over the Project;
 - **2.1.3.6** the usual weather conditions of the Project location;
 - **2.1.3.7** conditions bearing upon transportation, disposal, handling, and storage of equipment, materials, and waste; and
 - **2.1.3.8** subsurface and concealed physical conditions and related information provided in the Contract Documents.

2.2 Pre-Bid Meeting

- **2.2.1** The Bidder is encouraged to attend the pre-bid meeting, where the A/E, the Contracting Authority, and the Owner will receive questions regarding the Contract Documents. If not given in **Document 00 10 00 Solicitation**, the A/E shall issue notice of the time and place of any pre-bid meeting to each registered Plan Holder.
- **2.2.2** The A/E shall prepare minutes of the pre-bid meeting for the Project record. If questions raised by the prospective Bidders require changes to, or clarifications of, the Contract Documents, the A/E shall issue the changes by written Addendum, along with a list of pre-bid meeting attendees.
- **2.2.3** Additional compensation shall not be based upon the Bidder's failure to attend the pre-bid meeting, which results in the Bidder's incomplete knowledge and familiarity of the Project requirements.

2.3 Request for Interpretation

- **2.3.1** If the Bidder finds any perceived ambiguity, conflict, error, omission, or discrepancy within the Contract Documents, including the Drawings, Specifications, and Addenda, or between any of the Contract Documents and Applicable Law, the Bidder shall submit a written Request for Interpretation ("RFI") to the A/E for an interpretation or clarification.
 - **2.3.1.1** The Bidder is responsible for prompt delivery of the RFI.
 - **2.3.1.2** The A/E shall respond to RFIs received more than 7 days before the bid opening.
- **2.3.2** The A/E shall issue Addenda in response to RFIs that modify or clarify the Contract Documents. Any Addenda issued within 72 hours before any bid opening (excluding Saturdays, Sundays, and legal holidays) shall extend the bid opening date by 7 days pursuant to **Section 3.3.1**.

- **2.3.2.1** The Addenda may be delivered via the State's State's Electronic Bidding Software, facsimile or e-mail, posted to a web or FTP site, or otherwise furnished to each registered Plan Holder.
- **2.3.3** Any interpretation or clarification of the Contract Documents made by any Person other than the A/E, in any manner other than a written Addendum, shall not be binding, and the Bidder shall not rely upon the interpretation or clarification.
- **2.3.4** The successful Bidder shall not be compensated for a claim alleging insufficient data, incomplete, ambiguous, conflicting, or erroneous Contract Documents or proposed Contract Documents, or assumed conditions regarding the nature, extent, or character of the Work, if the Bidder did not submit a related RFI prior to the bid opening.

2.4 Basis of Design and Acceptable Components

- **2.4.1** The Contract Documents may list components produced by specific manufacturers to denote kind, quality, or performance requirements.
- **2.4.2** The component listed first is the Basis of Design Component.
- **2.4.3** Other listed components are Acceptable Components.
 - **2.4.3.1** If the Bidder includes an Acceptable Component in its Bid, the Bidder is responsible for the costs of coordination and modification required.

2.5 Substitutions Prior to Bid Opening

- **2.5.1** If the Bidder proposes to use an article, device, material, equipment, form of construction, fixture, or item other than the Basis of Design or Acceptable Components named in the Specifications, the Bidder shall certify that the proposed item is equal in quality and all aspects of performance and appearance, to the item specified.
 - **2.5.1.1** If approval of a Substitution requires changes to the Contract Documents or affects the work of other trades, the Bidder is responsible for the additional costs, including, but not limited to, changes to the design by the A/E.
- **2.5.2** The Bidder shall submit its request for Substitution to the A/E no later than 10 days prior to the bid opening, which must include:
 - **2.5.2.1** the name and complete description of the proposed Substitution, including Drawings, performance and test data, and other information necessary for a complete evaluation; and
 - **2.5.2.2** a statement setting forth any changes that the Proposed Substitution will require in the Contract Documents or the Project.
- **2.5.3** If the A/E approves the Proposed Substitution, the A/E shall issue an Addendum.
- **2.5.4** If the A/E does not approve the Proposed Substitution, the A/E shall inform the Bidder of its decision, which is final. The A/E may reject a proposed Substitution because the Bidder failed to provide sufficient information to enable the A/E to completely evaluate the Proposed Substitution without causing a delay in the bid deadline.
- **2.5.5** Proposed Substitutions received by the A/E less than 10 days prior to the bid deadline shall not be considered.

2.6 Electronic Bid Form

- **2.6.1** Each Bid shall be submitted on the electronic **Bid Form** through the State's Electronic Bidding Software.
 - **2.6.1.1** All sections of the electronic **Bid Form**, including a completed "Bidder Affirmation and Disclosure" section acknowledging that the Bidder affirms, understands, and will abide by the requirements of Executive Order 2019-12D related to providing services only within the United States and Executive Order 2022-02D prohibiting purchases from or investment in any Russian institution or company, and a completed "Commitment to Participate in the EDGE Business Assistance Program" page, shall be submitted with the Bid. Failure to do so may cause the Bid to be rejected as non-responsive.
 - .1 If the names, locations, and service locations of Subcontractors are not known at the time of the Bid deadline, the Bidder must provide the information requested with its **Subcontractor and Material Supplier Declaration**.
 - **2.6.1.2** Unless the Bidder withdraws the Bid as provided in **Article 4**, the Bidder is required to comply with all requirements of the Contract Documents, regardless of whether the Bidder had actual knowledge of the requirements and regardless of any statement or omission made by the Bidder that might indicate a contrary intention.

- **2.6.2** The Bidder shall fill in all relevant spaces on the electronic **Bid Form**. The State's Electronic Bidding Software will identify any incomplete required fields.
- **2.6.3** If the Bidder is a corporation, partnership, or sole proprietorship, an officer, partner or principal of the Bidder shall enter the legal name of the Bidder in the space provided on the electronic **Bid Form**. If the Bidder is a joint venture, an officer, partner or principal, as applicable, of each member of the joint venture shall enter the legal name of the applicable member in the space provided.

2.7 Allowances

2.7.1 If Allowances are provided on the electronic **Bid Form**, the amount of each Allowance shall be included in the Base Bid amount. Allowances shall be used solely for the purpose of determining the adjustment to the Contract Sum for the difference between the amount of the Allowance and the actual cost of the related Work provided. Allowances shall not include the Contractor's Fee.

2.8 Unit Prices

- **2.8.1** If Unit Prices are requested on the electronic **Bid Form**, the amount of the scheduled quantities shall be included in the Base Bid amount. Unit prices shall be used solely for the purpose of determining the adjustment to the Contract Sum for the difference between the estimated quantities on the electronic **Bid Form** and the actual quantities provided.
- **2.8.2** Unit Prices shall include all materials, equipment, labor, delivery, installation, and any other cost or expense, in connection with, or incidental to, the performance of that portion of the Work. Unit Prices shall not include the Contractor's Fee on account of the associated Unit Price Work. The Bidder shall submit Unit Prices for all items listed.

2.9 Alternates

- **2.9.1** If an Alternate is listed on the electronic **Bid Form**, the Bidder shall fill in the applicable space with a positive or negative bid amount as applicable. The Contracting Authority reserves the right to accept or reject any or all bid amounts for Alternates, in whole or in part, and in any order.
 - **2.9.1.1** If no change in the bid amount is required, indicate "\$0."
 - **2.9.1.2** Failure to make an entry on any Alternate shall cause the Bid to be rejected as non-responsive if that Alternate is selected.
 - **2.9.1.3** Failure to indicate a negative number will indicate the Bidder's intent to increase the Base Bid by the amount entered in the applicable space.
 - **2.9.1.4** If an Alternate is not selected, an entry as listed in **Section 2.9.1.2** on that Alternate shall not, by itself, render a Bid non-responsive.

2.10 Submittals with Electronic Bid Form

- **2.10.1** The Contracting Authority shall reject a Bid as non-responsive if the Bidder fails to submit the following with the Bid:
 - **2.10.1.1** An electronic facsimile of the Bid Guaranty as provided in **Article 5**, meeting the requirements of Ohio Revised Code ("ORC") Sections 153.54 and 153.571.
 - **2.10.1.2** The original unaltered Bid Guaranty shall be delivered to the Contracting Authority within 3 business days after the public bid opening as provided in Ohio Administrative Code ("OAC") Section 153:1-8-01(H).
- **2.10.2** If the apparent low Bidder does not submit a valid Power of Attorney of the agent signing for the Surety with its Bid, the Contracting Authority shall direct the apparent low Bidder to deliver a valid and appropriate Power of Attorney to the Contracting Authority within a period determined by the Contracting Authority. The Contracting Authority shall not enter into a Contract without a valid Power of Attorney.
- **2.10.3** The Bidder is encouraged to submit background information with its Bid using the **Bidder's Qualifications** form and including, but not limited to, the information listed in this **Section 2.10**. If the apparent low Bidder does not submit the **Bidder's Qualifications** form and related information attached to the electronic **Bid Form**, the Bidder shall provide it upon request in accordance with **Section 3.5.4**, including, but not limited to:
 - **2.10.3.1** the overall experience of the Bidder, including number of years in business under present and former business names;
 - **2.10.3.2** a complete listing of all the Bidder's ongoing construction projects and a listing of construction projects which are similar in cost and type to the Project completed by the Bidder in the last 5 years. Include information of

the scope of work and value of each contract, a description of Encouraging Diversity Growth and Equity ("EDGE") participation and performance, and a project name/contact Person/address/phone number for the owner and the architect or engineer for each project;

- **2.10.3.3** a Certificate of Compliance with Affirmative Action Programs, issued pursuant to ORC Section 9.47, by the Equal Opportunity Coordinator of the Department of Administrative Services;
- **2.10.3.4** a complete listing of Affirmative Action and EDGE program violations in the last 5 years;
- **2.10.3.5** a complete listing of Prevailing Wage, EPA, OSHA, or other regulatory entity issues or violations in the last 5 years;
- **2.10.3.6** a complete listing of judgments, claims, arbitration proceedings or suits pending or outstanding in the last 5 years;
- **2.10.3.7** a complete listing of Drug-Free Workplace Program and Drug-Free Safety Program ("DFSP") violations in the last 5 years;
- **2.10.3.8** upon request of the Contracting Authority, the apparent low Bidder shall submit the following information, which is not a public record under ORC Section 149.43; and shall remain confidential, except under proper order of a court:
 - .1 an annual financial statement prepared within the 12 months prior to the bid opening by an independent licensed accounting firm; and the name, address, contact Person, and phone number of the bank normally used by the Bidder for its primary banking; or
 - .2 a financial report generated within 30 days prior to the bid opening from Standard and Poor, Dun and Bradstreet or a similar company acceptable to the Contracting Authority documenting the financial condition of the Bidder; and the name, address, contact Person, and phone number of the bank normally used by the Bidder for its primary banking.
- 2.10.3.9 a description of the Bidder's relevant facilities and major equipment, whether leased or owned;
- **2.10.3.10** a description of the management experience of the Bidder's project manager(s) and superintendent(s) and a comprehensive resume for each;
- **2.10.3.11** a description of the EDGE-certified Business Enterprises the Bidder proposes as Subcontractors for this Project by attaching a fully completed **EDGE Affidavit** form for each EDGE-certified Business Enterprise;
- **2.10.3.12** to support a Bond, a current and signed Certificate of Compliance issued by the Ohio Department of Insurance, showing the Surety is licensed to do business as a surety in Ohio;
- 2.10.3.13 a current Ohio Workers' Compensation Certificate;
- **2.10.3.14** if the Bidder is a foreign corporation not incorporated under the laws of Ohio, a Certificate of Good Standing from the Ohio Secretary of State; or, if the Bidder is a foreign person or partnership, evidence that the Bidder filed, with the Ohio Secretary of State, a Power of Attorney designating the Ohio Secretary of State as the Bidder's agent for the purpose of accepting service of summons in any action brought under ORC Section 153.05 or under ORC Sections 4123.01 to 4123.94, inclusive;
- **2.10.3.15** evidence that the Bidder is enrolled in, and in good standing in, a DFSP approved by the Ohio Bureau of Workers' Compensation ("OBWC"); and
- **2.10.3.16** any other data or information which the A/E may request concerning the responsibility of the Bidder, including a complete list of major Subcontractors with an estimated contract value of \$200,000 or more, which the Bidder proposes to employ on the Project.

2.11 Changes in the Bid Amount

2.11.1 Any change to a previously submitted Bid shall be resubmitted through the State's Electronic Bidding Software prior to the deadline for submission of Bids.

ARTICLE 3 - BID OPENING AND EVALUATION

3.1 Delivery of Bid

- **3.1.1** The Bidder shall submit its Bid to the Contracting Authority prior to the time of the bid deadline.
- **3.1.2** Bids that are submitted after the time of the bid deadline shall not be considered.

3.2 Bid Opening

- **3.2.1** Electronic Bids shall be received until the time stated when all Bids shall be electronically opened and the Bid tabulation made public by posting on the State's Electronic Bidding Software.
- **3.2.2** The posting of Bid tabulations is for informational purposes only and is not to be construed as an acceptance or rejection of any Bid submitted.
- **3.2.3** The contents of the electronic **Bid Form** and its attachments are public records and shall be available for inspection, upon request, at any time after the bid deadline, except for any information that is not defined as a public record under Ohio law.

3.3 Bid Deadline Extension

- **3.3.1** If an Addendum is issued within 72 hours prior to the published time for the bid deadline, excluding Saturdays, Sundays and legal holidays, the bid deadline shall be extended 7 days. If the Contracting Authority approves, the bid deadline may be extended for more than 7 days, and consideration for additional advertising may be recommended.
- **3.3.2** As part of issuing any Addendum earlier than 72 hours prior to the published time for the bid deadline, excluding Saturdays, Sundays and legal holidays, only the Contracting Authority may approve a revised bid deadline or additional advertising.

3.4 Bid Evaluation Criteria

- **3.4.1** The Contracting Authority reserves the right to accept or reject any or all Bids, in whole or in part, and reserves the right to award the Contract to any remaining Bidder the Contracting Authority determines, in its sole discretion, to have submitted the lowest responsive and responsible Bid.
- **3.4.2** The Contracting Authority reserves the right to accept or reject any or all Alternates. Alternates may be accepted or rejected in any order.
- **3.4.3** If any Bidder has engaged in collusive bidding, the Contracting Authority shall reject that Bidder's Bid as non-responsible for the Contract. A collusive bidder may also be debarred from future State Contracts.
- **3.4.4** The Contracting Authority reserves the right to waive, or to allow any Bidder a reasonable opportunity to cure a minor irregularity or technical deficiency in a Bid, provided the irregularity or deficiency does not affect the bid amount, or otherwise give the Bidder a competitive advantage. Noncompliance with any material requirements of the Contract Documents shall cause a Bid to be rejected as non-responsive.
- **3.4.5** If, in the opinion of the Owner, the award of the Contract to the lowest Bidder is not in the best interest of the State, with the written consent of the Contracting Authority, the Owner may accept, in its discretion, another Bid so opened, or the Contracting Authority may reject all Bids and advertise for other Bids. The advertisement shall be for the period, in the form, and in the publications directed by the Contracting Authority.

3.5 Bid Evaluation Procedure

- **3.5.1** The Contract shall be awarded to the lowest responsive and responsible Bidder as determined in the discretion of the Contracting Authority, or all Bids may be rejected in accordance with Applicable Law.
 - **3.5.1.1** In determining which Bid is the lowest, the Contracting Authority shall consider the Base Bid and the bid amounts for any Alternate, or Alternates, which the Owner decides, in its sole discretion, to accept.
 - **3.5.1.2** The total of the bid amounts for the accepted Alternate(s) shall be added to, or deducted from, the Base Bid, as applicable, for determining the lowest Bidder.
 - **3.5.1.3** If two Bidders submit the same bid amount and both are determined to be responsive and responsible, the Contracting Authority may select one Bidder by the flip of a coin, which shall be conducted in the presence of both Bidders and shall be final.
 - .1 If one of the Bidders refuses to participate in, or fails to be present at, the flip of a coin, the remaining Bidder shall be selected.
- **3.5.2** A Bidder for a Contract shall be considered responsive if the Bidder's Bid responds to the Contract Documents in all material respects and contains no irregularities or deviations from the Contract Documents that would affect the amount of the Bid or otherwise give the Bidder a competitive advantage.
 - **3.5.2.1** A Bid shall be rejected as non-responsive if the Bid contains a Bid Guaranty executed by a Surety not licensed in Ohio or a Bid Guaranty that is otherwise determined to be insufficient by the Contracting Authority.

- **3.5.2.2** The Bidder may be subject to a Pre-Award Affirmative Action Compliance Review pursuant to OAC Section 123:2-5-01 including a review of the Bidder's employment records and an on-site review.
 - .1 The Bidder must submit the information requested no later than 10 days after receipt of the request. Failure to timely respond to this request for records may result in the Bidder being found non-responsive.
- 3.5.2.3 If the lowest Bidder is non-responsive, the Bidder shall be notified according to Section 3.6.
- **3.5.3** In determining whether a Bidder is responsible, factors to be considered include, without limitation:
 - **3.5.3.1** preferences required by law, where applicable;
 - **3.5.3.2** the experience of the Bidder;
 - **3.5.3.3** the financial condition of the Bidder:
 - **3.5.3.4** the conduct and performance of the Bidder on previous Contracts, including compliance with Equal Employment Opportunity in the Construction Industry Administrative Rules, OSHA and Prevailing Wage laws, and demonstration of good faith effort to participate in the EDGE Business Development program, or actual participation in the EDGE Business Development program, or both, as indicated in the ORC and the Ohio Administrative Code;
 - **3.5.3.5** the facilities of the Bidder;
 - **3.5.3.6** the management skills of the Bidder, including the capability of the Bidder to construct and manage the entire Project, including but not limited to the plumbing, fire protection, heating, ventilating and air conditioning, and electrical branches or classes of the Work; and
 - **3.5.3.7** the Bidder's ability to execute the Contract properly, including past performance of the Bidder and the Subcontractors that the Bidder proposes to use on the Project.
- **3.5.4** The A/E shall obtain from the lowest responsive Bidder any information the Contracting Authority determines appropriate to consideration of factors showing responsibility. If the lowest responsive Bidder is responsible, the Contract shall be awarded to that Bidder, unless all Bids are rejected. The Bidder shall provide all requested information within 3 days of a request from the A/E, or a longer period, if the Contracting Authority consents in writing.
- **3.5.5** If the lowest responsive Bidder is not responsible, the Contracting Authority shall evaluate the next lowest Bidder according to the procedures set forth in this **Section 3.5** until the Contract is awarded, all Bids are rejected, or all responsive Bidders are determined to be not responsible.

3.6 Rejection of Bid

3.6.1 If the lowest Bidder is not responsive or responsible, the Contracting Authority shall reject the Bid and notify the Bidder in writing by Certified Mail of the finding and the reasons for the finding.

3.6.2 Ten Percent Rule.

- **3.6.2.1** If the lowest responsive and responsible Bid for the Contract, including the Base Bid and accepted Alternates if any, exceeds an amount 10 percent greater than the published Estimated Construction Cost for the Contract, the Contracting Authority shall reject all Bids.
- **3.6.3** A Bidder notified in accordance with **Section 3.6.1** may object to its rejection by filing a written protest, which must be received by the Contracting Authority within 5 days of the notification provided pursuant to **Section 3.6.1**.
- **3.6.4** Upon receipt of a timely protest, the Contracting Authority shall meet with the protesting Bidder to hear its objections. ORC Chapter 119 administrative hearing requirements are not applicable to the bid protest meeting.
 - **3.6.4.1** No Contract award shall become final until after the Contracting Authority has met with all Bidders who have timely filed protests and the award of the Contract is affirmed by the Contracting Authority.
 - **3.6.4.2** If all protests are rejected, the Contract shall be awarded to the lowest responsive and responsible Bidder, or all Bids shall be rejected.

3.7 Notice of Intent to Award

- **3.7.1** The Contracting Authority shall notify the apparent successful Bidder that upon satisfactory compliance with all conditions precedent for execution of the Contract, within the time specified, the Bidder shall be awarded the Contract.
- **3.7.2** The Contracting Authority reserves the right to rescind any Notice of Intent to Award if the Contracting Authority determines it issued the Notice of Intent to Award in error, or if the conditions precedent for execution of Contract set forth in **Article 6** are not met.

ARTICLE 4 - WITHDRAWAL OF BID

4.1 Withdrawal prior to Bid Opening

4.1.1 A Bidder may withdraw a Bid after submitting the Bid through the State's Electronic Bidding Software, provided the Bidder submits its request through the State's Electronic Bidding Software prior to the bid deadline.

4.2 Withdrawal after Bid Opening

- **4.2.1** The Bid shall remain valid and open for acceptance for a period of 60 days after the bid opening; provided, however, a Bidder may withdraw a Bid from consideration after the bid opening if the bid amount was substantially lower than the amounts of other Bids, providing the Bid was submitted in good faith, and the reason for the bid amount being substantially lower was a clerical mistake, as opposed to a judgment mistake, and was actually due to an unintentional and substantial arithmetic error or an unintentional omission of a substantial quantity of Work, labor, or material made directly in the compilation of the bid amount.
 - **4.2.1.1** Notice of a request to withdraw a Bid shall be made in writing filed with the Contracting Authority within 2 business days after the bid opening. The Contracting Authority reserves the right to request the Bidder to submit evidence substantiating the Bidder's request to withdraw the Bid.
 - **4.2.1.2** No Bid may be withdrawn under **Section 4.2.1** which would result in awarding a Contract involving the same item on another Bid to the same Bidder.
- **4.2.2** If a Bidder withdraws its Bid under **Section 4.2.1**, the Contracting Authority may award the Contract to the next lowest responsive and responsible Bidder, or reject all Bids and advertise for other Bids. In the event the Contracting Authority advertises for other Bids, the withdrawing Bidder shall pay the costs, in connection with the re-bidding, of printing new Contract Documents, required advertising, and printing and mailing of notices to prospective Bidders, if the Contracting Authority finds that these costs would not have been incurred but for the withdrawal.
- **4.2.3** A Bidder may withdraw the Bidder's Bid at any time after the 60-day period described in **Section 4.2.1** by giving written notice to the Contracting Authority.

4.3 Refusal to Accept Withdrawal

- **4.3.1** If the Contracting Authority contests the right of a Bidder to withdraw a Bid pursuant to **Section 4.2.1**, a hearing shall be held within 10 days after the bid opening and the Contracting Authority shall issue an order allowing or denying the claim of this right within 5 days after the hearing is concluded. The Contracting Authority shall give the withdrawing Bidder timely notice of the time and place of the hearing.
 - **4.3.1.1** The Contracting Authority shall make a stenographic record of all testimony, other evidence, and rulings on the admissibility of evidence presented at the hearing. The Bidder shall pay the costs of the hearing.
 - **4.3.1.2** Pursuant to ORC Section 119.12, the Bidder may appeal the order of the Contracting Authority required by **Section 4.3.1**.

4.4 Refusal to Perform

4.4.1 In the event the Contracting Authority denies the request for withdrawal and the Bidder refuses to perform the Contract, the Contracting Authority may reject all Bids or award the Contract to the next lowest responsive and responsible Bidder.

4.5 Effect of Withdrawal

4.5.1 A Bidder, who is permitted to withdraw a Bid under **Section 4.2.1**, shall not supply material or labor to, or perform a subcontract or other work for, the Person to whom the Contract is awarded; or otherwise benefit, directly or indirectly, from the performance of the Project for which the withdrawn Bid was submitted; without the Contracting Authority's prior written consent.

ARTICLE 5 - BID GUARANTY AND BOND

5.1 Bid Guaranty

- **5.1.1** The Bidder shall submit a Bid Guaranty with the Bidder's Bid, payable to the Contracting Authority, in the form of either:
 - **5.1.1.1** the signed **Document 00 43 13 Bid Security Form** contained in the Contract Documents for the amount of the Base Bid plus all additive Alternates; or
 - **5.1.1.2** a certified check, cashier's check, or letter of credit, for 10 percent of the Base Bid, plus all additive Alternates a letter of credit shall expressly provide that it is revocable only by the Contracting Authority.
- **5.1.2** The Bid Guaranty shall be in form and substance satisfactory to the Contracting Authority and shall serve as an assurance that upon acceptance of the Bid, the Bidder shall comply with all conditions precedent for Contract execution, within the time specified by the Contracting Authority.
- **5.1.3** If the blank line on the **Bid Security Form** is not filled in, the penal sum shall be the full amount of the Base Bid plus all additive Alternates. If the blank line is filled in, the amount shall not be less than the full amount of the Base Bid plus all additive Alternates, stated in dollars and cents. A percentage is not acceptable. In the event the blank line is filled in for an amount less than the full amount of the Base Bid plus all additive alternates, the Bid shall be rejected as non-responsive.
- **5.1.4** An authorized agent must sign the **Bid Security Form**, and the Bidder shall provide a Power of Attorney from the Surety. A Surety authorized by the Ohio Department of Insurance to transact business in Ohio must issue the **Bid Security Form**.
- **5.1.5** The requirements of ORC Section 3901.86 may be applicable requiring an Ohio resident agent countersign the **Bid Security Form**. The Bidder shall determine the applicability of this provision.
- **5.1.6** Bid Guaranties in the form of a certified check, cashier's check, or letter of credit shall be returned to unsuccessful Bidders 60 days after the bid opening. Bid Guaranties in the form of a certified check, cashier's check, or letter of credit shall be returned to the successful Bidder upon providing **Document 00 61 13 Performance and Payment Bond Form** from a Surety satisfactory to the Contracting Authority.

5.2 Forfeiture of Bid Guaranty

- **5.2.1** If for any reason, other than as authorized by **Section 4.2.1** or **Section 5.3**, the Bidder fails to execute the Agreement, and the Contracting Authority awards the Contract to another Bidder, which the Contracting Authority determines is the lowest responsive and responsible Bidder:
 - **5.2.1.1** The Bidder who failed to execute the Agreement is liable to the State for the difference between its Bid and the Bid of the next lowest responsive and responsible Bidder, or for a penal sum not to exceed ten percent of the bid amount, whichever is less.
- **5.2.2** If the Contracting Authority then awards a Contract to another Bidder, which the Contracting Authority determines is the lowest responsive and responsible Bidder and that Bidder fails or refuses to execute the Agreement:
 - **5.2.2.1** The liability of the lowest responsive and responsible Bidder shall be the difference between the bid amount of the lowest responsive and responsible Bidder and another Bidder which the Contracting Authority determines is the lowest responsive and responsible Bidder, except as provided in **Section 5.3**, but not in excess of the liability specified in **Section 4.2.2**.
 - **5.2.2.2** The liability on account of an award to the lowest responsive and responsible Bidder beyond the third lowest responsive and responsible Bidder shall be determined in like manner.
- **5.2.3** If the Contracting Authority does not award the Contract to another Bidder under **Section 5.2.2**, but submits the Project for re-bidding:
 - **5.2.3.1** The Bidder failing or refusing to execute the Agreement is liable to the State for a penal sum not to exceed 10 percent of the Bidder's bid amount or the costs in connection with the resubmission of printing new Contract Documents, required advertising, and printing and mailing notices to prospective Bidders, whichever is less, except as provided in **Section 5.3**.

5.3 Exception to Forfeiture

- **5.3.1** A Bidder for a Contract with the State costing less than \$500,000 may withdraw its Bid from consideration if its Bid for another Contract with the State for less than \$500,000 has already been accepted if:
 - **5.3.1.1** the Bidder certifies in good faith that the total amount of its current contracts is less than \$500,000; and
 - **5.3.1.2** the Bidder's Surety certifies in good faith that the Bidder is unable to perform the subsequent Contract because such performance would exceed the Bidder's bonding capacity.
- **5.3.2** If a Bid is withdrawn pursuant to **Section 5.3.1**:
 - **5.3.2.1** the Contracting Authority may award the Contract to another Bidder which the Contracting Authority determines is the lowest responsive and responsible Bidder or reject all Bids and submit the Project for re-bidding; and
 - **5.3.2.2** neither the withdrawing Bidder nor the Bidder's Surety shall be liable for the difference between the Bidder's Bid and that of the next lowest responsive and responsible Bidder for a penal sum, or for the costs of printing new Contract Documents, required advertising, and printing and mailing notices to prospective Bidders.

5.4 Bond

- **5.4.1** Prior to signing the Agreement, the Bidder shall provide the Bond required by law in form and substance satisfactory to the Contracting Authority, and from a Surety licensed to do business in the state of Ohio and satisfactory to the Contracting Authority.
 - **5.4.1.1** If the Bidder provided **Document 00 43 13 Bid Security Form**, described in **Section 5.1.1.1**, as its Bid Guaranty then that form shall be the Bond.
 - **5.4.1.2** If the Bidder provided another form of Bid Guaranty, described in **Section 5.1.1.2**, then **Document 00 61 13 Performance and Payment Bond Form**, described in **Section 5.1.6**, shall be the Bond.
 - **5.4.1.3** The Bidder shall not be required to provide both forms described above.
- **5.4.2** The Bond must be in the full amount of the Contract to indemnify the State against all direct and consequential damages suffered by failure of the Contractor to perform according to the provisions of the Contract and in accordance with the Plans, Specifications, details, and bills of material therefore and pay all lawful claims of Subcontractors, Material Suppliers, and laborers for labor performed or materials furnished in performing and completing the Contract.

ARTICLE 6 - CONTRACT AWARD AND EXECUTION

6.1 Conditions Precedent for Execution of Contract

- **6.1.1** The successful Bidder must submit the items in this **Section 6.1** to the Contracting Authority before executing the Agreement.
- **6.1.2** Bond, and to support the Bond, a Certificate of Compliance issued by the Ohio Department of Insurance, showing the Surety is licensed to do business in the state of Ohio.
- **6.1.3** Ohio Workers' Compensation Certificate
- **6.1.4** Certificate of Compliance with Affirmative Action Programs, issued by the Equal Opportunity Coordinator. The form must be submitted through the Ohio Business Gateway: http://business.ohio.gov/efiling/.
- **6.1.5** Certificate of Insurance (ACORD form is acceptable) and copy of additional insured or loss payee endorsement. The Contracting Authority reserves the right to request and receive a certified copy of the Contractor's insurance policies.
- **6.1.6** If a Bidder is a foreign corporation (e.g., not incorporated under the laws of Ohio) it must submit a Certificate of Good Standing from the Ohio Secretary of State showing the right of the Bidder to do business in the state of Ohio.
- **6.1.7** If a Bidder is an individual or partnership, nonresident of the State, it must submit a Power of Attorney designating the Ohio Secretary of State as the Bidder's agent for accepting service of summons in any action brought under ORC Section 153.05 or under ORC Sections 4123.01 to 4123.94, inclusive.
- **6.1.8** Evidence that the Bidder is enrolled in, and in good standing in, a DFSP approved by the OBWC.

6.1.9 Required Notice of Unresolved Findings for Recovery.

6.1.9.1 By submitting its Bid, the Bidder warrants that it is not subject to an unresolved findings for recovery under ORC Section 9.24. ORC Section 9.24 prohibits the State from awarding a Contract to any Bidder against whom the Auditor of State has issued a finding for recovery if the finding for recovery is unresolved at the time of award. If the Contract is awarded to a Bidder subject to an unresolved finding for recovery under ORC Section 9.24, the Contract is void on its face and the Contractor shall immediately repay to the Owner any funds paid under the Contract.

6.1.10 EDGE Program – Supporting Documentation Required.

- **6.1.10.1** The Bidder shall provide evidence acceptable to the Contracting Authority of the Bidder's participation in the EDGE Program by contracting with EDGE-certified Business Enterprise(s) for the Project by submitting a fully completed EDGE Affidavit for each EDGE-certified Business Enterprise, by requesting a waiver or partial waiver of the advertised EDGE Program participation goal for the Project on the Bidder's company letterhead including full documentation of the Bidder's good faith effort to contract with EDGE-certified Business Enterprise(s) for this Project, or both.
- **6.1.11** If the Bidder is a joint venture, it must submit the executed agreement between the joint venturers describing the division of services/work and percentage of contract for each company, and a Power of Attorney which authorizes one or more individuals to bind the joint venture and each individual joint venturer to Contract Modifications.

6.2 Non-compliance with Conditions Precedent

- **6.2.1** The award of the Contract and execution of the Agreement require the Contractor to comply with:
 - **6.2.1.1** all conditions precedent for execution of the Contract within 10 days of the date of the Notice of Intent to Award; and
 - **6.2.1.2** the **Bidder's Qualifications** form, including a fully completed **EDGE Affidavit** for each EDGE-certified Business Enterprise, not previously provided within 3 business days of receiving the Contracting Authority's request.
- **6.2.2** Non-compliance with the conditions precedent for execution of the Contract as stated in **Section 6.1** within the timelines stated in **Section 6.2.1** following the date of the Notice of Intent to Award shall be sufficient cause to permit the Contracting Authority to cancel the Notice of Intent to Award, for the Bidder's lack of responsibility and award the Contract to another Bidder, which the Contracting Authority determines is the lowest responsive and responsible Bidder; or the Contracting Authority may re-bid the Work at its sole discretion.
- **6.2.3** The Contracting Authority may extend the time for complying with the conditions precedent for execution of the Contract for good cause. The extension is not a waiver of the conditions precedent for execution of the Contract.

6.3 Time Limits

- **6.3.1** The Contracting Authority's failure to award the Contract and execute the Agreement-within 60 days of the bid opening invalidates the entire bid process and all Bids submitted, unless the time is extended by written consent of the apparent lowest responsive and responsible Bidder and the Contracting Authority.
 - **6.3.1.1** If the Contracting Authority awards the Contract within 60 days of the bid opening, increases in material, labor, and subcontract costs shall be borne by the Bidder.
 - **6.3.1.2** If failure to execute the Contract within 60 days of the bid opening is due to matters for which the State is solely responsible, the Contractor is entitled to a Change Order authorizing payment of verifiable increased costs in materials, labor, or subcontracts. This increase shall not exceed the difference in price between the successful Bidder and the price of the next lowest responsive and responsible Bidder.
 - **6.3.1.3** If failure to execute the Contract within 60 days of the bid opening is due to matters for which the Contractor is responsible, the Contracting Authority shall not grant a request for increased costs.

6.4 Notice to Proceed

- **6.4.1** The Contracting Authority shall issue a Notice to Proceed to the Contractor, which establishes the date for commencement and the calendar days allocated for Substantial Completion of all Work. Within 10 days of the date of the Notice to Proceed, or other period as mutually agreed by the Contractor and the Contracting Authority, the Contractor shall furnish the following submittals to the A/E:
 - **6.4.1.1** Schedule of Values;

- **6.4.1.2** preliminary schedule of Shop Drawings and other Submittals;
- **6.4.1.3 Subcontractor and Material Supplier Declaration** form, with completed "Bidder Affirmation and Disclosure" forms acknowledging that the Contractor affirms, understands, and will abide by the requirements of Executive Order 2019-12D and Executive Order 2022-02D for Subcontractors that were not identified in the electronic **Bid Form**;
- **6.4.1.4** qualifications of proposed project manager(s) and superintendent(s) and a comprehensive resume of each; and
- **6.4.1.5** evidence that an authorization agreement for automatic deposit of state warrants has been submitted to Ohio Shared Services using the electronic funds transfer form provided on the Internet at http://supplier.ohio.gov.

6.5 Prevailing Wage Rates

- **6.5.1** The Bidder shall base its Bid upon the prevailing rates of wages as ascertained by the Ohio Department of Commerce, Wage and Hour Bureau for the Project as provided in ORC Sections 4115.03 through 4115.14. Refer to **Document 00 73 43 Wage Rate Requirements** for related information and the Project's prevailing rates of wages with an appropriate ratio of registered apprentices.
- **6.5.2** The Bidder shall not be entitled to an increase in the Contract Sum on account of an increase in prevailing wage rates, except as otherwise provided by Applicable Law. The Bidder is responsible for compliance of its Subcontractors with prevailing wage requirements.
- **6.5.3** Within 10 days of the date of the Notice to Proceed, the Contractor shall provide the Contracting Authority's Prevailing Wage Coordinator with a schedule of dates during the term of the Contract when the Contractor shall pay wages to its employees for the Project.

KEYWORD INDEX

Α

Acceptable Components, 3 Addenda, 2, 3 Addendum, 2, 3, 6 Affirmative Action, 5, 6, 10 Agreement, 9, 10, 11 Allowances, 4 Alternate, 4, 6, 7 Applicable Law, 2, 6, 12 award of the Contract, 1, 6, 7, 11

В

Base Bid, 4, 6, 7, 9
Basis of Design Component, 3
Bid, 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12
Bid Form, 1, 2, 3, 4, 6
Bid Guaranty, 4, 6, 9, 10
Bidder, 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12
Bond, 5, 10

C

Change Order, 1, 11 Contract, 1, 4, 6, 7, 8, 9, 10, 11, 12 Contract Documents, 1, 2, 3, 6, 8, 9, 10 Contract Sum, 1, 4

D

Drawings, 2, 3 Drug-Free Safety Program ("DFSP"), 5, 10

E

Encouraging Diversity Growth and Equity ("EDGE"), 3, 4, 5, 7, 11
Equal Employment Opportunity, 7
Equal Opportunity Coordinator, 5, 10
Estimated Construction Cost, 7

ī

insurance, 10

J

joint venture, 4, 11

N

Notice of Intent to Award, 7, 11 Notice to Proceed, 11, 12

O

Ohio Bureau of Workers' Compensation ("OBWC"), 5, 10

Ohio Department of Commerce, 12 Ohio Department of Insurance, 5, 9, 10 Ohio Secretary of State, 5, 10

P

Plan Holder, 2, 3 Prevailing Wage Rates, 12

R

Request for Interpretation, 2

S

Schedule of Values, 11 Shop Drawings, 12 Specifications, 2, 3, 10 State, 1, 6, 9, 10, 11 State's Electronic Bidding Software, 1, 2, 3, 5, 8 Subcontractor, 1, 2, 3, 5, 7, 10, 12 Substantial Completion, 1, 11 Substitutions, 3 Surety, 4, 5, 6, 9, 10

Т

Ten Percent Rule, 7

U

Unit Price, 4 unresolved findings for recovery, 11

W

Wage and Hour Bureau, 12

END OF DOCUMENT

Document 00 41 13 - Bid Form (General Contract / Electronic Bid)

State of Ohio Standard Requirements for Public Facility Construction

THIS SAMPLE BID FORM IS PROVIDED WITH THE PROJECT MANUAL AS A PLACEHOLDER ONLY – SUBMIT YOUR BID USING THE ELECTRONIC BID FORM ON HTTPS://BIDEXPRESS.COM

■ General Info	Alt Total:	Bid Total:
Deadline October 25 th , 2023 at 2:00pm	Description Butler Guyed Tower Replacement: This construction of a new 500' self-supporti	
Advertised September 29 th , 2023 and October 6 th & 13 th , 2023	site. The contractor shall be responsible to connect the new tower to the existing demolition of the existing tower after the	g shelter as well as the
Number DAS-OIT224	constructed.	
Business Name OFCC		

■ Procurement Documents
«insert Public Bid Advertisement file name» → Public Bid Advertisement
«insert Solicitation file name» → Notice to Bidders
«insert Project Manual file name» → Procurement & Contracting Requirements and Specifications
«insert Drawings file name» → Plans, elevations, sections, details, and schedules
«4» Attachments

Addenda		
letion of all Work is 180 consecu	utive days from the Notice to Pro	oceed.
Date Addendum #2 Received	Date Addendum #3 Received	Date Addendum #4 Received
	ddenda Date Addendum	letion of all Work is 180 consecutive days from the Notice to Produced Date Addendum

Base Bid Instructions

Enter the amount of the Base Bid for ALL LABOR AND MATERIALS to complete the scope of Work. Include the amount of each Allowance (if applicable) and the subtotal of each Unit Price Extension (if applicable) in the Base Bid amount. Failure to include Allowance or Unit Price Extensions in the Base Bid is the responsibility of the Bidder and will not be sufficient reason for adjustment of the Bid amount after the Bid deadline. Do not include Alternates (if applicable) in the Base Bid amount.

■ Base Bid	(General Contract)		
Item	Description	Base Bid Amount*	Extension
Base Bid	All Labor and Materials (include Allowances and Unit Price Extensions above)		
1 Item		Total:	

_	Riddor	Affirmation	and	Disclosur	r۵
	Diadei	Allimation	anu	DISCIOSU	ıe

The Bidder acknowledges that by submitting its Bid, the Bidder has read and understands the applicable Executive Orders regarding the prohibitions of performance of offshore services, locating State data offshore in any way, or purchasing from Russian institutions or companies. If awarded a Contract, the Bidder will become the Contractor and affirms that both the Contractor and its Subcontractors shall perform no services requested under this Contract outside of the United States.

The Bidder shall provide the locations where services under this Contract will be performed in the spaces provided below or by attachment. Failure to provide this information as part of its Bid may cause the Bidder to be deemed non-responsive and no further consideration will be given to its Bid. If the Bidder will not be using Subcontractors, indicate "Not Applicable" in the appropriate spaces.

1. Principal business location of Contractor: Contractor Address*	City, State, and Zip*
Name / Principal business location of Subcontractor(s), if known at tire Subcontractor Name*	Address, City, State, and Zip*
2. Location(s) where services will be performed by Contractor (Projection Name*	Address, City, State, and Zip*
Name(s) / Location(s) where services will be performed by Subcontra Subcontractor Name	Address, City, State, and Zip
3. Location(s) where State data will be located by Contractor: Address*	City, State, and Zip*
Location(s) where State data will be located by Subcontractor(s), if kn Subcontractor Name	Address, City, State, and Zip

Bidder also affirms, understands and agrees that the Contractor and its Subcontractors are under a duty to disclose to the State any change or shift in location of services performed by the Contractor or its Subcontractors before, during and after execution of any Contract with the State. Bidder agrees it shall so notify the State immediately of any such change or shift in location of its services. The State has the right to immediately terminate the contract, unless a duly signed waiver from the State has been attained by the Contractor to perform the services outside the United States.

On behalf of the Bidder, I acknowledge that I am duly authorized to execute this electronic Bid Form including this Bidder Affirmation and Disclosure form and have read and understand that this form is a part of any Contract that Bidder may enter into with the State and is incorporated therein.

EDGE Program Commitment to Participate

Option A

The Bidder commits to meet or exceed the advertised EDGE Participation Goal of the Contract award amount, calculated as a portion of the Base Bid plus all accepted Alternates, by using EDGE-certified Business(es).

The Bidder agrees that if selected for consideration of the Contract, it shall provide (if not provided with the Bidder's Bid) to the Contracting Authority, at the location required and within 3 business days after receiving notice from the Contracting Authority, its fully completed Bidder's Qualification Form, including an EDGE Affidavit form for each EDGE-certified Business proposed for use by the Bidder if awarded the Contract for this Project.

Option B (indicate percentage of participation below)

The Bidder declares that it does not meet the advertised EDGE Participation Goal percentage, but, if awarded the Contract for this Project, commits to provide the percentage of the Contract award amount, indicated above, calculated as a portion of the Base Bid plus all accepted Alternates, by using EDGE-certified Business(es).

The Bidder acknowledges it understands the requirement for it to provide and agrees to provide to the Contracting Authority, if selected for consideration of the Contract, within 3 business days after notice from the Contracting Authority, a detailed Demonstration of Good Faith form describing its efforts undertaken prior to submitting its Bid to meet the advertised EDGE Participation Goal percentage for the Contract for this Project.

The Bidder commits to provide to the Contracting Authority at the location required, and within 3 days after receiving notice from the Contracting Authority, its fully completed Bidder's Qualifications Form, including an EDGE Affidavit form for each EDGE-certified Business proposed for use by the Bidder if awarded the Contract for this Project.

Option C

The Bidder declares that the Bidder is an EDGE-certified Business and that if awarded this Contract, the EDGE Participation percentage will be 100 percent of the Contract award amount.

Sei	ect	EDGE	: optio	n above [*]	

C٢		\sim	•	

If option B selected, enter percentage

Certifications (State Prevailing Wages)

- 1. The Bidder has read and understands the proposed Contract Documents and agrees to comply with all requirements of the proposed Contract Documents, regardless of whether the Bidder has actual knowledge of the requirements and regardless of any statement or omission made by the Bidder, which might indicate a contrary intention.
- 2. The Bidder represents that the Bid is based upon the Basis of Design and Acceptable Components specified by the proposed Contract Documents.
- 3. The Bidder has visited the Site, become familiar with local conditions, and has correlated personal observations about the requirements of the proposed Contract Documents. The Bidder has no outstanding questions regarding the interpretation or clarification of the proposed Contract Documents.
- 4. The Bidder understands that the execution of the Project will require sequential, coordinated, and interrelated operations, which may involve interference, disruption, hindrance, or delay in the progress of the Bidder's Work. The Bidder agrees that the Contract Sum, as amended from time to time, shall cover all amounts due from the State resulting from interference, disruption, hindrance, or delay that is not caused by the State or its agents and employees. The Bidder agrees that any such interference, disruption, hindrance, or delay is within the contemplation of the Bidder and the State and that the Contractor's sole remedy from the State for any such interference, disruption, hindrance, or delay shall be an extension of time in accordance with the proposed Contract Documents.

- 5. During the performance of the Contract, the Bidder agrees to comply with Ohio Administrative Code ("OAC") Chapters 123:2-3 through 123:2-9 and agrees to incorporate the monthly reporting provisions of OAC Section 123:2-9-01 into all subcontracts on the Project, regardless of tier. The Bidder understands the State's Equal Opportunity Coordinator or the Contracting Authority may conduct pre-award and post-award compliance reviews to determine if the Bidder maintains nondiscriminatory employment practices, maintains an affirmative action program, and is exerting good faith efforts to accomplish the goals of the affirmative action program. For a full statement of the rules regarding Equal Employment Opportunity in the Construction Industry, see OAC Chapters 123:2-1 through 123:2-9.
- 6. The Bidder and each Person submitting a Bid on behalf of the Bidder certifies, and in the case of a Bid by a joint venture each member thereof certifies as to such member's entity, under penalty of perjury, that to the best of the undersigned's knowledge and belief: (a) the Base Bid, any Unit Prices, and any Alternate bid in the Bid have been arrived at independently without collusion, consultation, communication or agreement, for the purpose of restricting competition as to any matter relating to such Base Bid, Unit Prices or Alternate bid with any other Bidder; (b) unless otherwise required by law, the Base Bid, any Unit Prices and any Alternate bid in the Bid have not been knowingly disclosed by the Bidder and shall not knowingly be disclosed by the Bidder prior to the bid opening, directly or indirectly, to any other Bidder who would have any interest in the Base Bid, Unit Prices, or Alternate bid; (c) no attempt has been made or shall be made by the Bidder to induce any other Person to submit or not to submit a Bid for the purpose of restricting competition.
- 7. The Bidder shall execute the Agreement with the Contracting Authority, if a Contract is awarded on the basis of this Bid, and if the Bidder does not execute the Agreement for any reason, other than as authorized by law, the Bidder and the Bidder's Surety are liable to the State as provided in Article 5 of the Instructions to Bidders.
- 8. The Bidder certifies that the upon the award of a Contract, as the Contractor it shall make a good faith effort to ensure that all of the Contractor's employees, while working on the Site, shall not purchase, transfer, use, or possess illegal drugs or alcohol or abuse prescription drugs in any way.
- 9. The Bidder acknowledges that it read all of the Instructions to Bidders, and in particular, Section 2.10 Submittals With Bid Form, and by submitting its Bid certifies that it has read the Instructions to Bidders and it understands and agrees to the terms and conditions stated in them
- 10. The Bidder agrees to furnish any information requested by the Contracting Authority or the Architect/Engineer to evaluate the responsibility of the Bidder.
- 11. The Bidder agrees to furnish the submittals required by Section 6.1 of the Instructions to Bidders for execution of the Agreement within 10 days of the date of the Notice of Intent to Award.
- 12. When the Bidder is a corporation, partnership or sole proprietorship, an officer, partner or principal of the Bidder, as applicable, shall enter the legal name of the Bidder and the name of the officer, partner or principal of the Bidder (in lieu of signing the Bid Form) in the data fields provided.
- 13. When the Bidder is a joint venture, an officer, partner or principal, as applicable, of each member of the joint venture shall enter the legal name of the applicable member and the name of the officer, partner or principal (in lieu of signing the Bid Form) in the data fields provided.
- 14. The Bidder understands that the Contract is subject to all the provisions, duties, obligations, remedies and penalties of Ohio Revised Code Chapter 4115 and that the Bidder shall pay any wage increase in the locality during the term of the Contract.
- 15. The Bidder represents that the individual that is submitting and digitally signing the electronic Bid is legally authorized to do so.
- 16. Bidder acknowledges that by the act of submitting an electronic Bid that it is digitally signing the actual Bid, which shall serve as the Bidder's authorization for the further consideration and activity in the bidding and contract process.

The Ridder hereh	ly acknowledges that the above representation	is in this Bid are material and not mere recitals.
THE DIGGET HELED	v acknowledges that the above representation	is ili tilis bid ale iliateriai alid fiot filere recitais.

Procurement Forms

Document 00 43 13 - Bid Security Form

→ Upload below and provide original document within 3 days

Document 00 45 13 - Bidder's Qualifications

→ Upload below or provide within 3 days of request

Document 00 45 39 - EDGE Affidavit

→ Upload below or provide within 3 days of request

3 Attachments

M160-00 41 13.EB 2022-MAR Page 4 of 6

Instructions for Providing Bid Submittals

Submission of Electronic Facsimile of Bid Guaranty with Electronic Bid

The Bidder SHALL UPLOAD and ATTACH TO ITS BID an ELECTRONIC FACSIMILE (scanned PDF document) OF ITS BID GUARANTY, payable to the Contracting Authority, in the form of either: (1) the signed and sealed Document 00 43 13 - "Bid Security Form" contained in the Contract Documents (and provided for the Bidder's convenience in the block above) for the amount of the Base Bid plus all additive Alternates; or (2) a certified check, cashier's check, or letter of credit, for 10 percent of the Base Bid, plus all additive Alternates – a letter of credit shall expressly provide that it is revocable only by the Contracting Authority. Refer to Sections 2.10.1.1 and 5.1 of Document 00 21 13 - "Instructions to Bidders."

Submission of Original Bid Guaranty

In addition to the Electronic Facsimile above, the Bidder SHALL DELIVER ITS ORIGINAL UNALTERED BID GUARANTY to the Project Coordinator at the address identified below WITHIN 3 BUSINESS DAYS AFTER THE BID DEADLINE as provided in Ohio Administrative Code Section 153:1-8-01(H). THIS REQUIREMENT APPLIES TO ALL BIDDERS. Refer to Section 2.10.1.2 of the Instructions to Bidders.

Holly Watson Project Coordinator OFCC 30 West Spring Street, 4th Floor Columbus, Ohio 43215

Non-responsive Bid for Failure to Submit Bid Guaranty

Each Bidder MUST SUBMIT BOTH THE ELECTRONIC FACSIMILE AND THE ORIGINAL UNALTERED BID GUARANTY as described above. The Contracting Authority SHALL REJECT A BID AS NON-RESPONSIVE if the Bidder fails to submit BOTH elements of the Bid Guaranty. The checkboxes below are to identify that you have uploaded the other form of Bid Guaranty. DO NOT CHECK ALL BOXES. Refer to Section 2.10.1 of the Instructions to Bidders.

Submission of Bidder's Qualifications and EDGE Affidavit

The Bidder is encouraged to submit background information with its Bid using Document 00 45 13 - "Bidder's Qualifications" and Document 00 45 39 - "EDGE Affidavit" with the EDGE-certified Business(es) the Bidder proposes to use on the Project (forms provided for the Bidder's convenience in the block above). If the Bidder does not submit the Bidder's Qualifications form and/or the EDGE Affidavit form and related information attached to the electronic Bid Form, the Bidder shall provide it within 3 days of request. Refer to Sections 2.10.3 and 3.5.4 of the Instructions to Bidders.

■ Required Bid Guaranty Upload		
Name	File*	
Document 00 43 13 - Bid Security Form → Upload a scan of the fully executed Bid Security Form AND submit the original document to the Contracting Authority within 3 days of the bid deadline	Select file no file selected I am NOT enclosing this document because the omission terms have been met. (Bidder submitted a Cashier's check below)	
Power of Attorney → Upload a scan of the fully executed Power of Attorney AND submit the original document to the Contracting Authority within 3 days of the bid deadline	Select file no file selected I am NOT enclosing this document because the omission terms have been met. (Bidder submitted a Cashier's check below OR included with the Bid Security Form above)	
Cashier's Check for 10% of the Bid → Upload a scan of the Cashier's Check AND submit the original check to the Contracting Authority within 3 days of the bid deadline	Select file no file selected I am NOT enclosing this document because the omission terms have been met. (Bidder submitted the Bid Security Form AND Power of Attorney above)	
3 Required Documents		

Name	File*
Document 00 45 13 - Bidder's Qualifications → Upload fully completed form and attachments	I am NOT enclosing this document because the omission terms have been met. (Must be submitted to the Contracting Authority within 3 days of request)
Document 00 45 39 - EDGE Affidavit → Upload a completed form for each EDGE business	I am NOT enclosing this document because the omission terms have been met. (Must be submitted to the Contracting Authority within 3 days of request)
2 Required Documents	

■ Bidder Signatory Information		
Bidder Signatory		
Name of Bidder's Authorized Signatory:*	Title of Authorized Signatory:*	
All Bidders complete all information in this form. Duplicate and complete the block below for each Joint Venturer:		
Bidder Information		
Business Name:*		
Business Mailing Address, City, State, Zip:*		
Telephone Number:* Facsimile Number:	Email Address:*	
Federal Tax ID Number:*	State of Incorporation (if applicable):	
Contact person for Contract processing:*	Date enrolled in an OBWC-approved DFSP (month/date/year):	
President or Chief Executive Officer's Name:*	President or Chief Executive Officer's Title:*	

END OF DOCUMENT

Document 00 43 13 - Bid Security Form

State of Ohio Standard Requirements for Public Facility Construction

(Form of combined Bid Guaranty and Bond prescribed by Ohio Revised Code Section 153.571)

KNOW ALL PERSONS BY	THESE PRESENTS, that we, the undersigned	
		_, as Principal,
and		as Sureties,
are hereby held and firmly bound unto)	
as (Obligee(s), in the penal sum of the dollar amount of the Bid submitted	by the Principal
to the Obligee on	(date) to undertake the Project known as:	
Project Number: _		
Project Name: _		
Contract Description	n:(e.g., General Contractor/Trades, Plumbing, HVAC, Electrical)	

THE CONDITION OF THE ABOVE OBLIGATION IS SUCH, that whereas the above-named Principal has submitted a Bid for the above referenced Project;

NOW, THEREFORE, if the Obligee accepts the Bid of the Principal, and the Principal fails to enter into a proper contract in accordance with the Bid, Plans, Specifications, details, and bills of material; and in the event the Principal pays to the Obligee the difference, not to exceed ten percent of the penal sum hereof between the amount specified in the Bid and such larger amount for which the Obligee may in good faith contract with the Bidder determined by the Obligee to be the next lowest responsive and responsible to perform the Work covered by the Bid; or in the event the Obligee does not award the Contract to such next lowest responsive and responsible Bidder and resubmits the Project for bidding, the Principal pays to the Obligee the difference not to exceed ten percent of the penal sum hereof between the amount specified in the Bid, or the costs, in connection with the resubmission, of printing new Contract Documents, required advertising and printing and mailing notices to prospective Bidders, whichever is less, then this obligation shall be null and void, otherwise to remain in full force and effect. If the Obligee accepts the Bid of the Principal, and the Principal, within 10 days after the awarding of the Contract, enters into a proper contract and executes the Agreement Form in accordance with the Contract Documents, including without limitation the Bid, Plans, Specifications, details, and bills of material, which said Contract is made a part of this Bond the same as though set forth herein; and

NOW ALSO, IF THE SAID Principal shall well and faithfully perform each and every condition of such Contract; and indemnify the Obligee against all damage suffered by failure to perform such Contract according to the provisions thereof and in accordance with the Contract Documents, including without limitation Plans, Specifications, details, and bills of material therefore; and shall pay all lawful claims of Subcontractors, Material Suppliers and laborers for labor performed and materials furnished in the carrying forward, performing or completing of said Contract; we, agreeing and assenting that this undertaking shall be for the benefit of any Subcontractor, Material Suppliers or laborer having a just claim, as well as for the Obligee herein; then this obligation shall be void; otherwise the same shall remain in full force and effect; it being expressly understood and agreed that the liability of the Surety for any and all claims hereunder shall in no event exceed the penal amount of this obligation as herein stated.

Document 00 43 13 Bid Security Form

THE SAID Surety hereby stipulates and agrees that no modifications, omissions or additions, in or to the terms of said Contract, the Work thereunder or the Contract Documents, including without limitation the Plans and Specifications, therefore, shall in any way affect the obligations of said Surety on its bond, and it does hereby waive notice of any such modifications, omissions or additions in or to the terms of the Contract, the Work, or the Contract Documents, including without limitation the Plans and Specifications.

SIGNED AND SEALED this	day of ,
PRINCIPAL:	SURETY:
Signature	Signature
By:Name	By:Attorney-in-Fact
Name	Attorney-in-Fact
Title	
SURETY INFORMATION:	SURETY AGENT'S INFORMATION:
Name	Name
Address 1	Address 1
Address 2	Address 2
City State Zip	City State Zip
Telephone	Telephone
 Email	 Email

END OF DOCUMENT

M140-00 43 13 2020-OCT Page 2 of 2

Document 00 45 13 - Bidder's Qualifications

State of Ohio Standard Requirements for Public Facility Construction

	Project Number:	
	Project Name:	
1.	Company Name:	
	Physical Address:	Street, Building, Unit
		City, State, Zip
	Mailing Address (if different):	P.O. Box
		City, State, Zip
	Telephone Number (w/ Area Code):	()
	Fax Number (w/ Area Code):	()
	Email address:	

2. Overall Experience. Indicate Bidder's overall experience performing the trades bid, including the years in business performing the trade under <u>present and former</u> business names.

- 3. Financial. The apparent low Bidder shall submit, upon request of the Contracting Authority, either:
 - a) An annual financial statement prepared within the 12 months prior to the bid opening by an independent licensed accounting firm; and the name, address, contact person and phone number of the bank normally used by the Bidder for its primary banking; or,
 - b) A financial report generated within 30 days prior to the bid opening from Standard and Poor, Dun and Bradstreet or a similar company acceptable to the Contracting Authority documenting the financial condition of the Bidder; and the name, address, contact person and phone number of the bank normally used by the Bidder for its primary banking;

This information is not a public record under Ohio Revised Code Section 149.43; and shall remain confidential, except under proper order of a court.

Document 00 45 13 Bidder's Qualications

4.	. Facilities & Equipment. Indicate Bidder's relevant facilities and major equipment (leased or owned).	
5.	Ongoing & Relevant Projects. List all ongoing projects and projects completed in the last 5 years, which are similar in cost and type to the Project. Include scope of Work, Contract value, a description of EDGE participation and performance, and project name/contact person/address/phone number for each owner and the architect or engineer for each project.	
6.	Regulatory / Contractual. Indicate all occurrences of the following in the last 5 years (indicate if none). For verification, attach documentation, and/or provide sufficient and appropriate detail information such as: project name, owner, contact person and phone number, amount of contract, etc. a) State or federal Prevailing Wage violations or judgments	
	a) State of federal Flevailing wage violations of judgments	
	b) Affirmative Action and EDGE program violations (Attach Certificate of Compliance with Affirmative Action Programs, issued pursuant to Ohio Revised Code Section 9.47)	
	c) Contract abandonment, contract termination, as either a prime- or sub-contractor, or Surety takeover	
	d) Debarment by state, federal, or local jurisdictions	

M140-00 45 13 2014 Edition (2014-JUN) Page 2 of 3

Document 00 45 13 Bidder's Qualications

	e) EPA/OSHA violations			
	f) Liquidated damages and Statutory Delay F	Forfeiture assessed		
	g) Drug-Free Safety Program and Drug Free Y	Workplace Program violati	ons	
7.	Management. Identify individuals assigned to this	Project.		
	Principal	Years with firm	Total Exp	
	Project Manager	Years with firm	Total Exp	
	Field Superintendent	Years with firm	Total Exp	
8.	EDGE Participation. Identify EDGE-certified Bus for this Project. <u>Attach a fully completed Document Enterprise</u> .	siness Enterprises proposed t 00 45 39 - "EDGE Affida	as Subcontractors and Material vit" for each EDGE-certified Bu	Suppliers siness
9.	Certification. I hereby certify that the information is and referenced information, is factual and complete		ifications form, including all atta	achments
	Company Name			
	Authorized Official (please print or type)			
	Signature of Authorized Official	Date		

END OF DOCUMENT

Document 00 45 39 - EDGE Affidavit

State of Ohio Standard Requirements for Public Facility Construction

EDGE PARTICIPATION

Certified Statement of Intent to Contract and Perform Bidder or Proposer: Submit one fully completed form for each EDGE-certified Business

	Project:		
	Project Name:		
A.	Bidder or Proposer's Company Name:		
	Mark all that apply:		
	Multi-Prime Contract General Contract	CM at Risk Contract Design-Build Con	ıtract
В.	EDGE-certified Business information (for contract	at ANY tier)	
	Mark all that apply:		
	Subcontractor Material Supplier	Professional Services Goods & Services	S
ED	GE Business Name:		
ED	CF Codification Number	E mill	
		E-mail: Phone:	
Inse	ert detailed description of materials, labor, services, sup	plies, etc. (may use industry codes – continue on separate pag	ge):
C.	portion of the contract described above related to its signing below, the EDGE-certified Business certifies provide the portion of the contract described above related to its signing below, the EDGE-certified Business certifies provide the portion of the contract described above related to its signing below, the EDGE-certified Business certifies provide the portion of the contract described above related to its signing below, the EDGE-certified Business certifies provide the portion of the contract described above related to its signing below, the EDGE-certified Business certifies provide the portion of the contract described above related to its signing below, the EDGE-certified Business certifies provide the portion of the contract described above related to its signing below.	at it intends to contract with the EDGE-certified Business for Contract for this Project and for the estimated cost shown below that it intends to contract with the Bidder or Proposer and intellated to the Contract for this Project for the estimated cost of	ow. By tends to
		and /100 dollars (\$).
	In the event the named Bidder or Proposer is NO	T awarded a Contract, this Statement shall be null and void.	
	EDGE-certified Business	Bidder or Proposer	
	Authorized Signature	Authorized Signature	_
	Name and Title	Name and Title	_
	Date Signed	Date Signed	_

END OF DOCUMENT

Document 00 52 00 - Agreement Form

State of Ohio Standard Requirements for Public Facility Construction

This Agreement is made as of the date set forth below between the State of Ohio, acting by and through the Contracting Authority, and the Contractor in connection with the Project.

Project Number: DAS-OIT223

Project Name: Butler Guyed Tower Replacement

Site Address: 6469 Garber Road

Belleville, OH 44813 Richland County

Owner: MARCS

Owner's Representative: Dick Miller

Address: 4200 Surface Road Columbus, OH 43215

Contracting Authority: Ohio Facilities Construction Commission

Project Manager: John DeBruhl

Address: 30 West Spring Street, 4th Floor

Columbus, OH 43215

Contractor: «insert name»

Contractor's Principal Contact: «insert name»

Address: «insert street address»
«insert city, state zip code»

Architect/Engineer ("A/E"): Verdantas

A/E's Principal Contact: Amanda E Spencer

Address: 1555 W Main Street Newark, OH 43055

ARTICLE 1 - SCOPE OF WORK; EDGE COMMITMENT

- 1.1 The Contractor shall perform and provide all of the Work described in the Contract.
- **1.2** The project delivery method for this Project shall be General Contracting.
- **1.3** The Contractor shall contract with EDGE-certified Business(es) for not less than 5.0 percent of the Contract Sum.

ARTICLE 2 - COMPENSATION

2.1 The Owner shall pay the Contractor the Contract Sum for the Contractor's proper, timely, and complete performance of the Contract. The Contract Sum is \$\(\sigma\) insert amount, subject to Modifications as provided in the Contract Documents. The Contract Sum is comprised of the following:

2.1.1 Base Bid:\$ «Insert Base Bid Amount»

ARTICLE 3 - CONTRACT TIMES

3.1 The Contract Times are the periods established in the following table for the achievement of the associated Milestones:

Construction Stage Milestone(s) to which Liquidated Damages apply	Contract Time	Projected Date (as of the date of this Agreement)
Substantial Completion of all Work	«180» days	05/27/2024

3.1.1 The projected dates listed under "Projected Date (as of the date of this Agreement)" are provided only for convenient reference during consideration of the Agreement. The durations listed under "Contract Time" define the Contract Times and take precedence over the projected dates.

ARTICLE 4 - KEY PERSONNEL

- **4.1** The Contractor's key personnel for the Project are:
 - 4.1.1 «insert name», Project Manager;
 - 4.1.2 «insert name», Lead Scheduling Engineer;
 - 4.1.3 «insert name», General Superintendent.
- **4.2** The Contractor's key personnel are authorized to act on the Contractor's behalf with respect to the Project and all matters concerning the Project.

ARTICLE 5 - GENERAL PROVISIONS

5.1 Effectiveness.

- **5.1.1** It is expressly understood by the Contractor that none of the rights, duties, and obligations described in the Contract Documents shall be valid and enforceable unless the Director of the Office of Budget and Management first certifies that there is a balance in the Owner's appropriation not already encumbered to pay existing obligations and until all relevant statutory provisions of the Ohio Revised Code, including ORC Section 126.07, have been complied with, and until such time as all necessary funds are available or encumbered and, when required, such expenditure of such funds is approved by the State Controlling Board, or other applicable approving body.
- **5.1.2** In addition, if federal funds are to be used to pay fees and expenses under this Agreement, none of the rights, duties, and obligations contained in this Agreement shall be binding on any party until the Owner gives the Contractor written notice that such funds are available from the Owner's funding source.
- **5.1.3** Subject to **Section 5.1.1**, the Contract shall become binding and effective upon execution by the Contracting Authority, Owner, Contractor, and Ohio Attorney General.
 - **5.1.3.1** If the Contractor is a joint venture, **(1)** each individual joint venturer shall **(a)** sign the Agreement in its own name and **(b)** be a party to the Contract, and **(2)** the Contract and the Performance and Payment Bond shall be binding on and apply to all joint venturers jointly and severally.
 - **5.1.3.2** If the Contractor is a limited liability company, which the Contracting Authority reasonably believes to be a special purpose or similar entity, the Contracting Authority may in its discretion require the limited liability company and each member of the limited liability company to (1) sign the Agreement in its own name and (2) be a party to the Contract. In that case, the Contract and the Performance and Payment Bond shall be binding on and apply to the limited liability company and to all of its members jointly and severally.
- **5.1.4** This Agreement may be executed in several counterparts, each of which shall constitute a complete original Agreement, which may be introduced in evidence or used for any other purpose without production of any other counterparts.

5.2 Representations.

- **5.2.1** The Contractor represents and warrants that it is not subject to an unresolved finding for recovery under ORC Section 9.24. If this representation and warranty is found to be false, the Contract is void, and the Contractor shall immediately repay to the Owner any funds paid under this Contract.
- **5.2.2** The Contractor hereby certifies that neither the Contractor nor any of the Contractor's partners, officers, directors, shareholders nor the spouses of any such person have made contributions in excess of the limitations specified in ORC Section 3517.13.
- **5.2.3** The Contractor, by signature on this Agreement, certifies that it is currently in compliance with, and will continue to adhere to, the requirements of Ohio ethics laws and conflict of interest laws and will take no action inconsistent with those laws.
- **5.2.4** The Contractor affirms to have read and understands Executive Order 2019-12D and shall abide by those requirements in the performance of this Contract. Notwithstanding any other terms of this Contract, the State reserves the right to recover any funds paid for services the Contractor performs outside of the United States for which it did not receive a waiver. The State does not waive any other rights and remedies provided the State in this Contract.
- **5.2.5** The Contractor affirms to have read and understands Executive Order 2022-02D regarding the prohibition of purchases from or investment in a Russian institution or company and shall abide by those requirements in the

performance of this Contract. Notwithstanding any other terms of this Contract, the State reserves the right to recover any funds paid to the Contractor for purchases or investments in a Russian institution or company in violation of this paragraph. The provisions of this paragraph will expire when the applicable Executive Order is no longer effective.

5.2.6 During the performance of this Contract, if the Contractor changes the location(s) disclosed on the **Affirmation and Disclosure Form** (a page in its **Bid Form**), the Contractor must complete and submit a revised **Affirmation and Disclosure Form**.

5.2.7 Pursuant to ORC Section 9.76(B), the Contractor warrants that it is not boycotting any jurisdiction with whom the State of Ohio can enjoy open trade, including Israel, and will not do so during the term of this Contract.

ARTICLE 6 - Enumeration of Documents

6.1 The Contract Documents constitute the substance of the Contract, and include this Agreement, Drawings, Specifications, Addenda if any, Contracting Definitions, General Conditions, Supplementary Conditions if any, Bid Form, Wage Rate Requirements, Bid Guaranty and Contract Bond or Performance and Payment Bond, and Change Orders if any.

SIGNATURES

IN WITNESS WHEREOF, the parties hereto have executed this Agreement as of the date set forth below:

«INSERT CONTRACTOR'S NAME»

STATE OF OHIO

Signature	Signature
Printed Name	Printed Name
OWNER'S CONCURRENCE by MARCS	OHIO ATTORNEY GENERAL Approval as to Form
Signature	Signature
Printed Name	Printed Name
Title	Title
	Date

M140-00 52 00 2022-MAR Page 3 of 4

DAS-OIT223	Butler Guyed Tower Replace	men
		_
		_
		_
		_
		_
		_
		<u> </u>
		_

END OF DOCUMENT

Document 00 52 14 - State of Ohio Subcontract Form State of Ohio Standard Requirements for Public Facility Construction

This Agreement is made as of the date set forth below between the Contractor and the Subcontractor in connection with the Project.

Project Number: DAS-OIT223

Project Name: Butler Guyed Tower Replacement

Site Address: 6469 Garber Road Belleville, OH 44813

Richland County

Contractor: «insert name»

Contractor's Principal Contact: «insert name»

Address: «insert street address»
«insert city, state zip code»

Subcontractor: «insert name»

Subcontractor's Principal Contact: «insert name»

Address: «insert street address»
«insert city, state zip code»

Public Authority: Ohio Facilities Construction Commission (OFCC)

Public Authority Contact: John DeBruhl

Address: 30 W Spring Street, 4th Floor

Columbus, OH 43215

ARTICLE 1 - NATURE OF SUBCONTRACT

1.1 The Subcontractor shall perform the entire Subcontract Work as specified in Exhibit «N» and described in the Contract Documents for the Project.

ARTICLE 2 - COMPENSATION

2.1 The Contractor agrees to pay for the performance of this Subcontract, subject to additions and deductions as provided in the Contract Documents, the Subcontract Sum of <u>«insert Subcontract Sum»</u>, comprised of the following:

«insert Subcontract Sum component»	\$«insert amount»
«insert Subcontract Sum component»	\$«insert amount»
«insert Subcontract Sum component»	\$«insert amount»
«insert Subcontract Sum component»	\$«insert amount»

ARTICLE 3 - TIME OF PERFORMANCE

3.1 Time is of the essence. The Subcontractor shall diligently prosecute and complete all Subcontract Work in accordance with the construction progress schedule agreed between the parties.

ARTICLE 4 - CONTRACT DOCUMENTS

- **4.1** To the extent that the contract between the Public Authority and the Contractor applies to the Subcontract Work:
 - **4.1.1** The Contractor and the Subcontractor agree to be mutually bound by the terms of the Contract Documents;
 - **4.1.2** The Contractor assumes toward the Subcontractor the rights, remedies, obligations, and responsibilities that the Public Authority has and assumes toward the Contractor;

- **4.1.3** The Subcontractor assumes toward the Contractor the rights, remedies, obligations, and responsibilities that the Contractor assumes toward the Public Authority; and
- **4.1.4** The Subcontractor agrees to perform its portion of the Work in accordance with the Contract Documents.
- **4.2** The Subcontract and any modifications, amendments, or alterations thereto shall be governed, construed, and enforced by and under the laws of the State of Ohio.
- **4.3** If any term or provision of the Subcontract, or the application thereof to any Person or circumstance, is finally determined, to be invalid or unenforceable by a court of competent jurisdiction, the remainder of the Subcontract or the application of such term or provision to other Persons or circumstances, shall not be affected thereby, and each term and provision of the Subcontract shall be valid and enforced to the fullest extent permitted by law.
- **4.4** The Subcontract shall be binding on the Contractor and Subcontractor, their successors and assigns, in respect to all respective covenants and obligations contained in the Contract Documents, but the Subcontractor may not assign the Subcontract without the prior written consent of the Contractor and the Public Authority.

ARTICLE 5 - EFFECTIVENESS

- **5.1** The Subcontract shall become binding and effective upon execution by the Contractor.
- **5.2** This Subcontract has been executed in several counterparts, each of which shall constitute a complete original Subcontract, which may be introduced in evidence or used for any other purpose without production of any other counterparts.
- **5.3** Any signatory may deliver a copy of its counterpart signature page to this Subcontract via fax or e-mail. Each signatory shall be entitled to rely upon a signature of any other signatory delivered in such a manner as if such signature were an original.

ARTICLE 6 - REPRESENTATIONS

- **6.1** Contingent Assignment. The Contractor's contingent assignment of this Subcontract to the Public Authority, as provided in the Contract, is effective after termination of the Contractor by the Public Authority and the Public Authority's acceptance of the assignment in writing to the Subcontractor. The Subcontractor consents to the assignment and shall be bound at the same price and terms as in the Subcontract to the Public Authority. Unless the Public Authority takes assignment of the Subcontract, the Subcontractor will not have any contractual rights against the Public Authority.
- **6.2** <u>Intended Third-Party Beneficiary</u>. The Public Authority is an intended third party beneficiary of the Subcontract, entitled to enforce any rights thereunder for its benefit.
- **6.3** <u>Insurance</u>. The Subcontractor shall maintain insurance in accordance with the Contract Documents. Exhibit «N» sets forth the minimum limits of liability for the insurance required in the Contract Documents.
- **6.4** Right to Audit. The Subcontractor agrees that the Public Authority or any agents designated by the Public Authority have access to and the right to audit and the right to copy at the Public Authority's cost all of the Subcontractor's books, records, contracts, correspondence, instructions, drawings, receipts, vouchers, purchase orders, and memoranda relating to the Work for a period of not less than 3 years following completion of the Work consistent with Ohio Revised Code ("ORC") Section 149.43 with regard to the Public Authority's obligation to maintain confidentiality of trade secrets.
- **6.5** <u>Indemnity</u>. To the fullest extent permitted by law, the Subcontractor shall indemnify, defend, and hold harmless the Public Authority, the Contractor, their consultants and employees from all claims and expenses for bodily injury and property damage other than to the Work itself that may arise from the performance of the Subcontract Work, including reasonable attorneys' fees, costs and expenses, but only to the extent caused by the negligent acts or omissions of the Subcontractor or a person or entity for whom the Subcontractor may be liable. This Subcontract does not require a Subcontractor to waive its immunity under the Workers Compensation laws of Ohio from claims brought against the Subcontractor by the Subcontractor's employees.

- **6.6** Prompt Pay. The Contractor shall at a minimum make payments to the Subcontractor in accordance with Applicable Law, including ORC Section 4113.61. Progress payments to the Subcontractor for satisfactory performance of Subcontract Work shall be made no later than 10 days after receipt by the Contractor of payment from the Public Authority for Subcontract Work.
- **6.7** <u>Retainage</u>. Subcontractor retainage shall be at a rate equal to the percentage retained from the Contractor's payment by the Public Authority for the Subcontract Work, unless a lesser percentage is otherwise specified.

6.7.1 Labor Payments.

- **6.7.1.1** Partial payments to the Subcontractor for labor performed shall be made at the rate of 92 percent of the amount invoiced through the Subcontractor's request for payment that shows the Work of the Subcontractor is 50 percent complete.
- **6.7.1.2** After the Work of the Subcontractor is 50 percent complete, as evidenced by payments of at least 50 percent of the total amount due under the Subcontract, no additional funds shall be retained from payments for labor.

6.7.2 Material Payments.

- **6.7.2.1** The Contractor shall pay the Subcontractor at the rate of 100 percent of the scheduled value for materials incorporated into the Project.
- **6.7.2.2** The Contractor shall pay the Subcontractor at the rate of 92 percent of the invoice cost, not to exceed the scheduled value, for materials delivered to the Site, or other off-site storage location approved by the A/E, provided the Subcontractor provides the following information with its request for payment:
 - .1 a list of the fabricated materials consigned to the Project, giving the place of storage, together with copies of invoices, in order to verify quantity and cost; and
 - .2 a certification of materials stored off-site, prepared by the Subcontractor and signed by the A/E to evidence that the materials are in conformity with the Specifications and have been tagged with the Project name and number for delivery to the Project. The Subcontractor shall reimburse the A/E, through the Contractor, for all costs incurred to visit a storage site, other than the areas adjacent to the Project.
 - 3 The Contractor shall pay the balance of the scheduled value when the materials are incorporated into and become a part of the Project.
- **6.8** Warranty. The Subcontractor fully warrants, for the benefit of the Public Authority, that all materials and equipment shall be new unless otherwise specified, of good quality, in conformance with the Contract Documents and free from defective workmanship or materials.
- **6.9** Non-Waiver of Lien Rights or Payment Bond Rights. This Subcontract shall not prohibit a Subcontractor from exercising its rights under ORC Chapter 1311 or under any Contractor-provided payment bond.
- **6.10** Non-Discrimination. The Subcontractor agrees to fully comply with Applicable Law regarding equal opportunity, including ORC Section 153.59 and, to the extent applicable, all Executive Orders issued by the Governor of the state of Ohio.
- **6.11** <u>Dispute Resolution</u>. The supplemental conditions to this Subcontract shall provide for a dispute resolution process comparable to the Contract's dispute resolution process in terms of timing, notice, substantiation, and informal dispute resolution efforts. The dispute resolution process provided in the supplemental conditions shall result in prompt access to the ultimate dispute resolution mechanism selected by the parties.
- **6.12** In the event that any supplemental conditions or other Subcontract terms conflict with the **State of Ohio Subcontract Form**, the **State of Ohio Subcontract Form** takes precedence and this Subcontract shall be read and enforced to include the provisions of the **State of Ohio Subcontract Form**.
- **6.13** The following exhibits are attached to and are a part of this Subcontract:

6.13.1 Exhibit A:

6.13.2 Exhibit B:

6.13.3 Exhibit C:

6.13.4 Exhibit D:

SIGNATURES

IN WITNESS WHEREOF, the parties have executed this Subcontract Form.

«INSERT SUBCONTRACTOR'S NAME»	«INSERT CONTRACTOR'S NAME»
Signature	Signature
Printed Name	Printed Name
Title	Title
	Date

END OF DOCUMENT

Document 00 61 13 - Performance and Payment Bond Form

State of Ohio Standard Requirements for Public Facility Construction

KNOW ALL PERSONS BY THESE PRESENTS, that we, the undersigned	
	, as Principal,
and	as Sureties,
are hereby held and firmly bound unto	
as Obligee(s), in the penal sum of	dollars,
for the payment of which well and truly to be made, we jointly and severally bind oursel	ves, our heirs, executors,
administrators, successors, and assigns.	
SIGNED AND SEALED this day of	·,
THE CONDITION OF THE ABOVE OBLIGATION IS SUCH, that whereas the	he above-named Principal did on the
day of,, enter into a Contract with the	e Obligee, which said Contract is
made a part of this Bond the same as though set forth herein and which is more fully des	cribed as:
Project Number:	
Project Name:	
Contract Description:	ectrical)

NOW, THEREFORE, if the above-named Principal shall well and faithfully do and perform the things agreed by the Obligee to be done and performed according to the terms of said Contract; and shall pay all lawful claims of Subcontractors, Material Suppliers, and laborers, for labor performed and materials furnished in the carrying forward, performing, or completing of said Contract; we agreeing and assenting that this undertaking shall be for the benefit of any Subcontractor, Material Supplier or laborer having a just claim as well as for the Obligee herein; then this obligation shall be void; otherwise the same shall remain in full force and effect; it being expressly understood and agreed that the liability of the Sureties for any and all claims hereunder shall in no event exceed the penal amount of this obligation as herein stated.

THE SAID Surety hereby stipulates and agrees that no modifications, omissions, or additions, in or to the terms of the said Contract or in or to the Plans and Specifications therefor shall in any wise affect the obligations of said Surety on its bond, and it does hereby waive notice of any such modifications, omissions or additions in or to the terms of the Contract, the Work or the Contract Documents, including without limitation the Plans and Specifications.

PRINCIPAL:		
Principal Signature		
Ву:		
Title:		
SURETY:	SURETY INFORMATION:	
Surety Signature	Street	
By:Attorney-in-Fact	City State	Zip
	Telephone Number	
	SURETY AGENT'S INFORMATI	ON:
	Agency Name	
	Street	
	City State	Zip
	Telephone Number	
	Email Address	

END OF DOCUMENT

Document 00 71 00 - Contracting Definitions (General Contracting Project) State of Ohio Standard Requirements for Public Facility Construction

Acceptable Component A component listed in the Specifications after the Basis of Design Component.

Addenda or Addendum Written or graphic instrument issued prior to the bid opening which modifies or

interprets the proposed Contract Documents by additions, deletions, clarifications, or corrections. Addenda become part of the Contract Documents when the Agreement

is executed.

A/E See "Architect/Engineer."

Agreement The form furnished by the Contracting Authority (including all of its exhibits) that,

when completed and signed by the Contractor and Contracting Authority evidences

entry into the Contract.

Allowance A sum stipulated in the Contract Documents for a defined scope of the Work that

may not be completely defined at the time of bidding. Allowance amounts do not

include the Contractor's Fee on account of the associated Work.

Alternate A change in the proposed Project scope, which may include but is not limited to

alternate materials or methods of construction, and an amount stated on the Bid form to be added to or deducted from the Base Bid if the corresponding Alternate is

incorporated into the Contract.

Alternative Dispute Resolution A voluntary and non-binding process for the administrative review, consideration,

and attempted settlement of a dispute, without resort to judicial process, including but not limited to partnering, negotiation, mediation, impartial fact-finding, dispute

review board, and mini-trials, but shall not include arbitration.

Applicable Law All federal, state, and local codes, statutes, ordinances, and regulations that apply to

the performance of the Work or the A/E's Services on the Project.

Architect/Engineer The Person responsible for providing professional design services and construction

contract administration for the Project as provided in the Contract Documents. The

A/E shall be a **(1)** registered architect holding a license and certificate of authorization issued by the Ohio Architects Board pursuant to ORC Chapter 4703,

(2) landscape architect holding a license and certificate of authorization issued by the Ohio Landscape Architects Board pursuant to ORC Chapter 4703, or (3) professional engineer or professional surveyor holding a license and certificate of authorization issued by the Ohio Engineers and Surveyors Board pursuant to ORC Chapter 4733.

As-Built Documents Documents, including but not limited to Drawings, Addenda, Specifications,

executed Change Orders, and other elements of the Contract Documents which the Contractor annotates and otherwise modifies to indicate changes made during the construction process, the location of concealed and buried items, and other

information useful to the Owner throughout the life of the completed Project.

Base Bid The amount stated in a Bid as the sum for which the Bidder offers to perform the

Work in a particular trade or other category, which is described in the Contract

Documents, excluding Alternates.

Basis of Design A document that records the concepts, calculations, decisions, and product selections

used to meet the Owner's Project Requirements and to satisfy applicable regulatory requirements, standards, and guidelines. The document includes both narrative

descriptions and lists of individual items that support the design process.

Basis of Design Component A component listed first in the Specifications.

Bid A written proposal to perform a Contract, submitted on a completed Bid Form,

accompanied by other required documents. The term Bid includes a proposal that has been digitally signed, encrypted, and submitted through the State's electronic

bidding application pursuant to OAC Section 153:1-8-01.

Bidder A Person that submitted a Bid.

BIM See "Building Information Model."

Bid Form A form furnished by the Contracting Authority with the proposed Contract

Documents that is to be completed, signed, and submitted containing the Bidder's

Bid.

Bid Guaranty A bid bond or other instrument of security authorized by ORC Section 153.54

submitted with the Bid to provide assurance that the Bidder will execute the

Agreement.

Bond A performance and payment bond in the format specified by ORC Section 153.57

submitted by the Contractor to provide assurance that the Contractor will perform the Work of the Contract, including making required payments to Subcontractors and

Materials Suppliers.

Building Information Model A digital representation of physical and functional characteristics of a facility; a

shared knowledge resource for information about a facility forming a reliable basis for decisions during its life-cycle, which is defined as existing from earliest conception to demolition; electronic files used to design and coordinate the Project; and may be used to describe a single model or multiple models used in the aggregate.

Certificate of Contract Completion

A form used to document that the Contractor's achievement of Contract Completion.

This form may also be used to document partial Contract Completion.

Certificate of Substantial Completion

A form used to document (1) that the Contractor has achieved Substantial

Completion of the Work or a designated portion of the Work for which the Contracting Authority and the Owner have agreed to take Partial Occupancy, and (2) the date on which the associated Substantial Completion of the Work was

achieved.

Change Directive A written document prepared by the A/E and executed by the Contracting Authority

that directs a change in the Work.

Change Order A document recommended by the A/E and executed by the Contracting Authority

and the Contractor that modifies the Contract.

Claim A demand or assertion, initiated by written notice, certified by one of the parties to

the Contract seeking, as a matter of right, adjustment or interpretation of Contract terms, payment of money, extension of time, or other relief with respect to the terms

of the Contract.

Claim Affidavit A sworn document used in conjunction with filing a lien, which contains a claim on

the funds that are due to a Contractor, in favor of a Person supplying labor, materials,

or services for the value of labor, materials, or services supplied.

Combined Bid A Bid that combines bid items for separate Contracts stated on the Bid Form.

Commission See "Ohio Facilities Construction Commission."

Commissioning Agent The Person identified by the Contracting Authority who leads, plans, schedules, and

coordinates the commissioning team to implement the Commissioning Process for

the Project.

Commissioning Plan A document that outlines the organization, schedule, allocation of resources, and

documentation requirements of the Commissioning Process.

Commissioning Process A quality-focused process for enhancing the delivery of a project. The process

focuses on verifying and documenting that the facility and all of its systems are planned, designed, installed, tested, operated, and maintained to meet the Owner's

Project Requirements.

Commissioning Report

A document that records the activities and results of the Commissioning Process. The Commissioning Report is developed from the final Commissioning Plan with its attached appendices.

Conformed Documents

Contract Documents with all Addenda items and accepted Alternates incorporated by the A/E, published, and issued to a successful Bidder for its use during performance of the Contract. The Conformed Documents are furnished solely for the Contractor's convenience. In the event of any conflict between the Contract Documents modified by Addenda and the Conformed Documents, the Contract Documents take precedence.

Construction Budget

The amount identified in the Agreement as adjusted by the Owner and Contracting Authority.

Construction Cost

The sum of the Contract Cost amounts for a phase of the Project.

Construction Progress Schedule

The critical path schedule for performance of the Contract; showing the time for completing the Work within the Contract Times; the planned sequence for performing the various components of the Work; the interrelationship between the activities of the Contractor, A/E, Contracting Authority, and Owner; and the Contractor's resource and cost loading information; as periodically updated during the performance of the Work.

Contract

The state of legal obligation entered into by the State and the Contractor, whereby they have agreed to an exchange of certain acts, materials, equipment, and services for certain monetary consideration, under all terms and conditions specified in the Contract Documents, which shall remain in full force and effect until such time as all obligations under the Contract have been lawfully and completely discharged, or the Contract is terminated under other conditions specified in the Contract Documents.

Contract Completion

The schedule Milestone in the progress of any Phase when the Work is completed in accordance with the terms of the Contract Documents and Contractor has satisfied all of its other obligations under the Contract Documents, including but not limited to (1) all governmental authorities have given final, written approval of the Work, (2) a final unconditional certificate of occupancy has been granted and issued to the Owner by the appropriate governmental authorities, (3) the Contractor's Work is 100 percent complete, and (4) all Punch List items have been completed or corrected, and (5) the Contractor has complied with conditions precedent to final payment and release of retained funds.

Contract Documents

Collectively, the documents that constitute the substance of the Contract including but not limited to Drawings, Specifications, Addenda if any, General Conditions, Supplementary Conditions if any, Bid Form, Wage Rates; and the executed Agreement, Bid Guaranty and Contract Bond, and Change Orders if any.

Contract Sum

The Contract Sum is the Contractor's entire compensation for the Contractor's proper, timely, and complete performance of the Work and is subject to adjustment as provided in the Contract.

Contract Times

The periods stipulated in the Agreement for the achievement of associated Milestones, in consecutive days, beginning on the date established by the Notice to Proceed, including adjustments authorized by executed Change Orders.

Contracting Authority

The party identified in the Agreement, which may be the Ohio Facilities Construction Commission; an agency of the state of Ohio; an Institution of Higher Education or division thereof; a School District Board; or the legislative body of a political subdivision.

Contractor

A firm, which is party to the Contract for the performance of Work on the Project in accordance with the Contract Documents.

Contractor's Documents

All Project-related documents, including those in electronic form, prepared by the Contractor and its Subcontractors.

Contractor's Fee

The portion of the Contract Sum attributable to the aggregate of the Contractor's profit and home-office overhead related to the Contractor's proper, timely, and complete performance of the Work.

Contractor Payment Request

The form furnished by the Commission that is to be used by the Contractor in requesting payments and which, when signed by the Contractor, shall serve as an affidavit that payments requested are in proportion to the Work completed as shown on the Schedule of Values.

Contractor's Punch List

A document prepared by the Contractor that consists of a list of items of Work to be completed or corrected by the Contactor as a condition precedent to Contract Completion.

Coordination Drawings

Drawings and Electronic Files prepared by the Contractor to demonstrate how multiple-system and interdisciplinary work will be coordinated. Clash reports generated by BIM authoring software may be included in the Coordination Drawing submittals if applicable.

Correction Period

A period of one year commencing on the date of Substantial Completion of the Work or a designated portion of the Work which the Contracting Authority and Owner have agreed to take Partial Occupancy.

CxA

See "Commissioning Agent."

Date of Commencement

The date established in a Notice to Proceed issued by the Contracting Authority to the Contractor to mark the start of the Work and the beginning of the running of the Contract Times.

day

A calendar day of 24 hours measured from midnight to midnight, unless otherwise expressly specified to mean a business day.

Defective Work

Work that does not conform to the Contract Documents; or does not meet the requirements of any applicable statute, rule or regulation, inspection, reference standard, test or approval; or has been damaged prior to the A/E's recommendation of final payment, unless responsibility for the protection thereof has been expressly assumed by the Owner; or that is not free from defects in workmanship, materials or equipment during the period of any warranty or guarantee.

Differing Site Condition

Either (1) a subsurface or otherwise concealed physical condition encountered at the Site that differs materially from the conditions indicated in the Contract Documents or (2) an unknown physical condition of an unusual nature encountered at the Site that differs materially from those ordinarily found to exist and generally recognized as inherent in construction activities of the character provided for in the Contract Documents.

Dispute Review Board

A form of Alternative Dispute Resolution that is typically comprised of three members, selected jointly by the Contractor and the Contracting Authority, to monitor the progress of construction and provide recommended resolutions to disputes that are brought before them.

Drawings

Graphic portions of the Contract Documents, showing the design, type of construction, location, dimension, and character of the Work to be provided by the Contractor, which generally includes plans, elevations, sections, details, schedules, diagrams, notes, and text.

Electronic File

Information maintained in a computer system or format that is intended to facilitate a Person's use and manipulation of the information including but not limited to Word, Excel, PDF, Primavera, CAD, and BIM files all in their native format.

Enclosure, Permanent

The condition in which the permanent exterior walls and roofs are in place, insulated and weathertight, and permanent windows and entrances are in place.

Enclosure, Temporary

The condition in which the permanent exterior walls and roofs are in place, insulated and weathertight, and windows and entrances are provided with suitable temporary enclosures.

Estimated Construction Cost

The sum of the Estimated Contract Cost amounts published in the Solicitation, as modified by Addenda, for a phase of the Project.

Estimated Contract Cost

The estimated amount for the Contract published in the Solicitation, including the Base Bid estimate and the estimates of selected Alternates, if any, as modified by Addenda.

Extra Materials

Materials required by the Contract Documents that are not incorporated into the Project but are given to the Owner to be used for future maintenance or repairs.

Final Inspection

The final review of the Work of the Contractor by the A/E to determine whether issuance of the Certificate of Contract Completion is appropriate.

furnish

Supply and deliver to the Site, or other specified location, ready for installation.

General Conditions

The State's Standard General Conditions currently in effect, which may be modified by the Commission from time to time.

General Conditions Costs

General Conditions Costs include only the Contractor's costs to provide the general conditions Work including without limitation the costs of all of the following Siterelated items: scheduling and coordinating the Work. telephone, telephone charges, facsimile, telegrams, postage, photos, photocopying, hand tools, simple scaffolds (one level high), tool breakage, tool repairs, tool replacement, tool blades, tool bits, and pre-approved travel, lodging, and parking costs. General Conditions Costs also include (1) Bond premiums and (2) premiums for builder's risk insurance if the Contractor purchases the builder's risk policy for the Project.

Hazardous Materials

Any material, substance, pollutant, or contaminant that is defined, regulated, referenced, or classified in the Comprehensive Environmental Response, Compensation and Liability Act, Federal Water Pollution Control Act, the Resource Conservation and Recovery Act, Clean Air Act, Hazardous Materials Transportation Uniform Safety Act, Toxic Substances Control Act, or any other Applicable Law relating to any hazardous, toxic, or dangerous waste, substance, or material. Any substance or material that, after release into the environment or upon exposure, ingestion, inhalation, or assimilation, either directly from the environment or directly by ingestion through food chains, will, or may reasonably be anticipated to, cause death, disease, behavior abnormalities, cancer or genetic abnormalities and specifically includes but is not limited to asbestos, polychlorinated biphenyls ("PCBs"), radioactive materials, including radon and naturally occurring radio nuclides, natural gas, natural gas liquids, liquefied natural gas, synthetic gas, oil, petroleum and petroleum-based derivatives and urea formaldehyde.

Indemnified Parties

The State, Contracting Authority, Owner, A/E, other Separate Consultants, and their respective officials, officers, consultants, agents, representatives, and employees, in both individual and official capacities.

install

Put into use or place in final position, complete and ready for intended service or use.

Institutional Designee

The party identified in the Agreement empowered with a level of authority similar to the Executive Director of the Commission, which may be the university architect or engineer, director of capital facilities, or an institution vice president.

Institution of Higher Education

Any state of Ohio university or college, community college, state of Ohio community college, technical college, university branch, community college district, technical college district, university branch district, and the applicable board of trustees or, in the case of a university branch district, any other managing authority.

Liquidated Damages

A sum established in the Contract Documents, pursuant to the statutory delay forfeiture authorized under ORC Section 153.19, to be paid to the Owner due to the Contractor's failure to complete the Work within the Contract Time for achievement of Substantial Completion, or any applicable portion of the Work on or prior to any Milestone date stated on the Agreement.

Material Supplier

A Person under a contract with the Contractor to furnish materials or supplies in furtherance of the Work, including all such Persons in any tier. Material Supplier

does not include any Separate Contractor unless expressly assigned in writing to the Contractor by the Owner and accepted by the Contractor.

mediation A voluntary process in which a neutral third party meets with the parties who have a

 $disagreement\ or\ dispute\ and\ attempts\ to\ facilitate\ a\ mutually\ satisfactory\ resolution.$

Milestone A principal event specified in the Contract relating to an intermediate completion

date or time prior to and including Substantial Completion of all Work.

Modification A (1) written amendment to the Contract signed by both parties, (2) Change Order,

(3) Change Directive, or (4) an order for a minor change in the Work.

negotiation A form of Alternative Dispute Resolution in which all parties involved are

represented by those invested with the authority to agree to a determination of an

adjustment in the Contract Sum, Contract Times, or both.

Neutral Facilitator An nonpartisan third-party without decision-making authority who is engaged to

assist the Project's key stakeholders in developing cooperative relationships, achieving project objectives, avoiding or minimizing disputes, and nurturing a more-

collaborative ethic characterized by trust, cooperation and teamwork.

Notice of Commencement A notice prepared by the Contracting Authority identifying the Project, the

Contractors, the Surety for each Contractor, and the name of the Contracting Authority's representative upon whom a Claim Affidavit may be served.

Notice of Intent to Award A written notice provided by the Contracting Authority to the apparent successful

Bidder stating that upon satisfactory compliance with all conditions precedent for execution of a Contract within the time specified, the Contracting Authority intends

to execute a Contract with the Bidder.

Notice to Proceed A written notice provided by the Contracting Authority authorizing the Contractor to

proceed with the Work and establishing the dates for commencement and completion

of the Work.

OAC Ohio Administrative Code

Ohio Facilities Construction Commission

The authorized contracting agent for public improvement projects in accordance with

ORC Chapters 123 and 153, acting by and through its Executive Director.

ORC Ohio Revised Code

Owner The state of Ohio agency, Institution of Higher Education or division thereof, School

District Board, or other instrumentality for whom the Project is being constructed.

Owner's Project Requirements A written document that details the functional requirements of the Project and the

expectations of how it will be used and operated. These include project goals, measureable performance criteria, cost considerations, benchmarks, success criteria,

and supporting information.

Partial Occupancy The condition that occurs when the Owner occupies or uses a portion of the Project

prior to Contract Completion, partial occupancy is approved by authorities having jurisdiction, and items of Work cannot be completed until a subsequent date.

partnering A voluntary dispute prevention process involving team building activities to help

define common goals, improve communication, and foster a problem solving attitude among a group of contracting parties that must work together throughout Contract

performance to be less adversarial and more cooperative.

Person An individual, corporation, business trust, estate, partnership, association, or other

public or private entity.

Phase A separation in the Work of the Project by sequence or time intervals, which may

include separate contractors for each Phase.

Plan Holder A prospective Bidder that received a set of Contract Documents prior to the bid

opening.

Product Data Manufacturer's standard illustrations, schedules, diagrams, performance charts,

instructions, and brochures that illustrate physical appearance, size, and other

characteristics of materials and equipment.

Project The public improvement, of which the Work performed under the Contract

Documents may be the whole or a part.

Project Manager A permanent employee of the Contracting Authority assigned to the Project and

authorized to perform specific responsibilities.

Project Manual That part of Construction Documents which consists of bound volume(s) of

primarily written material which generally contain Division 00 - "Procurement and Contracting Requirements," and Divisions 01 through 49 - "Specifications," and

other documents pertaining to the Project.

Proposal The offer of a Contractor to perform the Work set forth in a Proposal Request.

Proposal Request A document issued after execution of the Contract requesting a Proposal from the

Contractor(s), which may initiate a Change Order to modify the Contract.

provide Furnish and install, complete and ready for intended use.

Punch List A document listing items of Work requiring correction or completion by the

Contractor as a condition precedent to Contract Completion.

Record Documents Electronic files and printed documents of all nature prepared by the A/E, which

incorporate the information shown on the Contractor's As-Built Documents. They consist of the "Record Drawings" and "Record Project Manual," Certificate of Substantial Completion, Certificate of Contract Completion (as complete), Contractor's Warranty, Manufacturers' Warrantees, certificate(s) of occupancy, approved shop drawings and other action submittals, Change Directives, Proposal Requests, Requests for Interpretation, Addenda, Change Orders, Balancing Reports,

and the final version of the approved Construction Progress Schedule.

Record Drawings The Drawings, which have been revised by the A/E to show the changes made

during the construction process, conformed to represent the Work as executed by the

Contractor.

Record Model The Building Information Model, which has been revised by the A/E to show the

changes made during the construction process, conformed to represent the Work as

executed by the Contractor.

Record Project Manual The Project Manual of the Contract Documents, which has been revised by the A/E

to show the changes made during the construction process, based on the As-Built

Project Manual furnished by the Contractor.

Request for Change Order A written notice from the Contractor accompanied by a Proposal for a change in the

Work.

Request for Interpretation A written request to the A/E seeking an interpretation or clarification of the Contract

Documents.

RFI See "Request for Interpretation."

Samples Physical examples, color selection items, field samples, and mock-ups furnished by

the Contractor to illustrate functional and aesthetic characteristics of products, materials, equipment, or workmanship and establish criteria by which the Work shall

be judged.

Schedule of Values A full, accurate, and detailed statement furnished by the Contractor reflecting a

defined breakdown of the Contract Sum.

School District A local, exempted village, or city school district as defined in ORC Chapter 3311, or

a joint vocational school established pursuant to ORC Section 3311.18, performing essential governmental functions of state government pursuant to ORC Sections

3318.01 to 3318.20.

School District Board

The board of education of a School District.

Separate Consultant

A Person engaged by the Owner or Contracting Authority to provide Project-related professional services other than the services under this Contract. The term includes the Separate Consultant's authorized representatives, successors, assigns, and subconsultants regardless of tier.

Separate Contract

The contract between the Owner or Contracting Authority and a Separate Consultant or a Separate Contractor.

Separate Contractor

A Person under contract with the Owner or Contracting Authority to provide Project-related work other than the Work under this Contract. The term includes the Separate Contractor's authorized representatives, successors, assigns, and subcontractors regardless of tier.

Shop Drawings

Drawings, diagrams, illustrations, and schedules specifically prepared for the Project provided by the Contractor or a Subcontractor to illustrate some portion of the Work. Shop Drawings are not Contract Documents. Shop Drawings on equipment shall include a written statement from the manufacturer of the equipment certifying the equipment is in compliance with the Contract Documents.

Site

The location designated for the Project.

Specifications

Those portions of the Contract Documents consisting of detailed written administrative, procedural, and technical requirements, included in Divisions 01 through 49, for the construction of the Work, whether physically on the Drawings or bound in separate volumes, including identification of acceptable materials, methods, equipment, quality, and workmanship.

Stage

A distinct period in the life cycle of a facility from concept through construction, to use and deconstruction or demolition. Typical Stages include Program Verification, Schematic Design, Design Development, Construction Documents, Bidding and Award stages; and the Construction Stage, which includes Construction and Closeout activities.

Standard Requirements

The brief name of the "State of Ohio Standard Requirements for Public Facility Construction," including but not limited to General Conditions, and other Division 00 Documents and Division 01 Sections; currently in effect, which the Commission may modify from time to time.

State

The government of Ohio, including any organized body, office, or agency established by the laws of this state for the exercise of any function of state government, any state institution of higher education as defined in ORC Section 3345.011, or any School District Board as defined in ORC Section 3318.01.

Subcontract

Any contract or agreement between the Contractor and a Subcontractor for performance of a portion of the Work.

Subcontract Form

The **State of Ohio Subcontract Form** prescribed by OAC Section 153:1-3-02 and required for use with the General Contracting method of project delivery.

Subcontractor

A Person who undertakes to perform any part of the Work on the Project under a contract with a Contractor or with any Person other than the State, including all such Persons in any tier. The term "Subcontractor" includes Material Suppliers, but does not include any Separate Contractor unless expressly assigned in writing to the Contractor by the Owner and accepted by the Contractor.

Substantial Completion

The stage in the progress of the Work when the Work (or designated portion of the Work for which the Contracting Authority and Owner have agreed to take Partial Occupancy) is sufficiently complete in accordance with the Contract that the Owner can utilize the Work for its intended use, as determined by the A/E. The issuance of a certificate of occupancy or partial certificate of occupancy (if applicable) is a condition precedent to the achievement of Substantial Completion.

Substantially Complete

See "Substantial Completion."

Substitution

An article, device, material, equipment, form of construction, or other item, proposed by a prospective Bidder prior to the bid opening and approved by the A/E by Addendum, for incorporation or use in the Work as being functionally and qualitatively equivalent to essential attributes of a Basis of Design or Acceptable Component specified in the proposed Contract Documents.

Supplementary Conditions

Amendments to the General Conditions, issued as a separate document, which describe conditions of the Contract unique to a particular Owner or Project, which may include provisions regarding the assignment of responsibility for refuse removal, safety and security precautions and programs, temporary Project facilities and utilities, weather and fire protection, scaffolding and equipment, materials and services to be used commonly by the Contractor and Subcontractors and requiring the Contractor to provide assistance in the utilization of any applicable equipment system, preparation of operation and maintenance manuals, and training of Owner personnel for operation and maintenance of the Project. The General Conditions shall not be superseded or amended by Drawings and Specifications, unless so provided in Supplementary Conditions prepared by the Contracting Authority and approved by the Commission.

Supplementary Instructions

Amendments to the Instructions to Bidders, issued as a separate document, which describe instructions unique to a particular Owner or Project. The Instructions to Bidders shall not be superseded or amended by Drawings and Specifications, unless so provided in Supplementary Instructions prepared by the Contracting Authority and approved by the Commission.

Surety

A Person providing a Bid Guaranty or a Bond to a Bidder or a Contractor, as applicable, to indemnify the State against all direct and consequential damages suffered by failure of the Bidder to execute the Contract, or of the Contractor to perform the Contract and to pay all lawful claims of Subcontractors, Material Suppliers and laborers, as applicable.

Systems Manual

A system focused composite document that includes the operation manual, maintenance manual, and additional information of use to the Owner after they begin using the facility.

Unit Price

The cost of providing a unit of Work including labor, materials, services, and associated expenses. Unit Prices do not include the Contractor's Fee on account of the associated Unit Price Work.

Work

The labor, materials, equipment, and services, individually or collectively which are required by the Contract Documents, to be performed or provided by the Contractor for the Project. The furnishing of all material, labor, detailing, layout, supplies, plants, tools, scaffolding, transportation, temporary construction, superintendence, demolition, and all other services, facilities and items reasonably necessary for the full and proper performance and completion of the requirements of the Project as set forth in the Contract Documents, and items reasonably inferable therefrom and consistent therewith for the proper execution and completion of the construction and other services required by the Contract Documents, whether provided or to be provided by the Contractor or a Subcontractor, or any other entity for whom the Contractor is responsible, and whether or not performed or located on or off of the Site.

END OF DOCUMENT

Document 00 72 13 - General Conditions (General Contracting Project)

State of Ohio Standard Requirements for Public Facility Construction

TABLE OF CONTENTS

ARTICLE 1 - CONTRACTOR'S RESPONSIBILITIES	1
ARTICLE 2 - STATE'S RIGHTS AND RESPONSIBILITIES	5
ARTICLE 3 - A/E'S RESPONSIBILITIES	6
ARTICLE 4 - SUBCONTRACTORS	7
ARTICLE 5 - PRECONSTRUCTION ACTIVITIES	9
ARTICLE 6 - CONSTRUCTION AND CLOSEOUT	10
ARTICLE 7 - MODIFICATIONS	28
ARTICLE 8 - DISPUTE RESOLUTION	35
ARTICLE 9 - COMPENSATION AND PAYMENT	41
ARTICLE 10 - BONDS, INSURANCE, AND INDEMNIFICATION	45
ARTICLE 11 - SUSPENSION AND TERMINATION	51
ARTICLE 12 - GENERAL PROVISIONS	54
KEYWORD INDEX	58

ARTICLE 1 - CONTRACTOR'S RESPONSIBILITIES

1.1 Nondiscrimination

- **1.1.1** The Contractor shall comply with Applicable Law regarding equal employment opportunity, including ORC Section 153.59 and all Executive Orders issued by the Governor of the state of Ohio.
 - **1.1.1.1** As required under ORC Section 153.59, the Contractor agrees to both of the following:
 - .1 "in the hiring of employees for the performance of work under the contract or any subcontract, no contractor, subcontractor, or any person acting on a contractor's or subcontractor's behalf, by reason of race, creed, sex, disability or military status as defined in section 4112.01 of the Revised Code, or color, shall discriminate against any citizen of the state in the employment of labor or workers who is qualified and available to perform the work to which the employment relates; and"
 - .2 "no contractor, subcontractor, or any person on a contractor's or subcontractor's behalf, in any manner, shall discriminate against or intimidate any employee hired for the performance of work under the contract on account of race, creed, sex, disability or military status as defined in section 4112.01 of the Revised Code, or color."
 - **1.1.1.2** The Contractor shall cooperate fully with the State's Equal Opportunity Coordinator ("EOC"), with any other official or agency of the state or federal government that seeks to eliminate unlawful employment discrimination, and with all other state and federal efforts to assure equal employment practices under the Contract.
 - **1.1.1.3** In the event the Contractor fails to comply with these nondiscrimination clauses, the Contracting Authority shall deduct from the amount payable to the Contractor a forfeiture of the statutory penalty pursuant to ORC 153.60 for each person who is discriminated against or intimidated in violation of this **Section 1.1.1**.
 - **1.1.1.4** The Contract may be terminated or suspended in whole or in part by the Contracting Authority and all money to become due hereunder may be forfeited in the event of a subsequent violation of this **Section 1.1.1**.

1.1.2 Hiring Under State Public Improvement Contracts.

1.1.2.1 Any provision of a hiring hall contract or agreement which obligates the Contractor to hire, if available, only employees referred to the Contractor by a labor organization shall be void as against public policy and unenforceable with respect to employment under any public improvement contract unless at the date of execution of the hiring hall contract or agreement, or within 30 days thereafter, the labor organization has procedures in effect for referring qualified employees for hire without regard to race, color, religion, national origin, military status as defined in ORC Section 4112.01, or ancestry and unless the labor organization includes in its apprentice and

journeyperson's membership, or otherwise has available for job referral without discrimination, qualified employees, both whites and non-whites (including African-Americans).

1.1.3 Affirmative Action.

- **1.1.3.1** The Contractor and Subcontractors shall comply with the State's Equal Employment Opportunity requirements described under OAC Sections 123:2-3 through 123:2-9 that include, without limitation, the requirements described under this **Section 1.1.3**.
- **1.1.3.2** The Contractor shall demonstrate its good faith efforts to comply with the utilization goals currently established for minority and women employees and submit documentation to the EOC.
- **1.1.3.3** By the 10th day of each month, the Contractor and Subcontractors shall submit to the EOC via the internet a completed Ohio Construction Contract Information Report Input Form 29 (I-29) for the preceding month. The form shall be submitted through the Ohio Business Gateway: http://business.ohio.gov/efiling/.

1.2 Prevailing Wages

- **1.2.1** The Contractor shall comply with the prevailing wage requirements described under ORC Chapter 4115 that include, without limitation, the requirements described under this **Section 1.2**.
- **1.2.2** If the Project is subject to payment of prevailing wage rates, the Contractor shall:
 - **1.2.2.1** pay to laborers and mechanics performing Work on the Project the prevailing wage rates of the Project locality, as determined by the Ohio Department of Commerce, Wage and Hour Bureau;
 - **1.2.2.2** post in a prominent place readily accessible by all workers on the Site, a legible listing of the current classifications of laborers, workers, and mechanics employed under this Contract;
 - **1.2.2.3** ensure that the rates posted are current and remain posted in legible condition during the period of the Contract; and
 - **1.2.2.4** not be entitled to an increase in the Contract Sum on account of an increase in prevailing wage rates, except as otherwise provided by Applicable Law.
- **1.2.3** The Contractor may access the Ohio Department of Commerce, Wage & Hour Bureau at its website, https://wagehour.com.ohio.gov/w3/webwh.nsf/wrlogin/?openform, to obtain the current wage rates.

1.3 Royalties and Patents

- **1.3.1** The Contractor shall pay all royalties, license fees, and assume all costs incident to the use, in the performance of the Work or the incorporation in the Work, of any invention, design, process, product, or device that is the subject of patent rights or copyrights held by others.
- **1.3.2** If the Contractor has reason to believe that use of the specified item is subject to patent or copyright protection, the Contractor shall immediately notify the Contracting Authority.

1.4 Assignment of Antitrust Claims

1.4.1 By signing the Agreement, the Contractor assigns, conveys and transfers to the Contracting Authority any right, title, and interest to any claims or causes of action it may have or acquire under state or federal antitrust laws relating to any goods, products, or services purchased, procured, or rendered to the State pursuant to the Contract.

1.5 Use of Domestic Steel

- **1.5.1** The Contractor is required by law to supply domestically produced steel products used for load bearing structural purposes on all projects funded in whole or in part with State funds.
- **1.5.2** The Contractor and Subcontractors shall comply with ORC Section 153.011 regarding the use of domestically produced steel products, and furnish the certifications required by **Section 6.20.8**. Copies of ORC Section 153.011 may be obtained from the Ohio Facilities Construction Commission.

1.6 Drug Free Safety Program Participation

1.6.1 Throughout the performance of the Work, the Contractor shall be enrolled in and remain in good standing in the Ohio Bureau of Workers' Compensation ("OBWC") Drug-Free Safety Program ("DFSP") or a comparable program approved by the OBWC that meets the requirements specified in ORC Section 153.03 ("OBWC-approved DFSP").

- **1.6.2** As required under ORC Section 153.03(E):
 - **1.6.2.1** "Each contractor shall require all subcontractors with whom the contractor is in contract for the public improvement to be enrolled in and be in good standing in the Bureau of Workers' Compensation's Drug-Free Workplace Program or a comparable program approved by the Bureau that meets the requirements specified in section 153.03 of the Revised Code prior to a subcontractor providing labor at the project site of the public improvement."
 - **1.6.2.2** "Each subcontractor shall require all lower-tier subcontractors with whom the subcontractor is in contract for the public improvement to be enrolled in and be in good standing in the Bureau of Workers' Compensation's Drug-Free Workplace Program or a comparable program approved by the Bureau that meets the requirements specified in section 153.03 of the Revised Code prior to a lower-tier subcontractor providing labor at the project site of the public improvement."
 - **1.6.2.3** "Failure of a contractor to require a subcontractor to be enrolled in and be in good standing in the Bureau of Workers' Compensation's Drug-Free Workplace Program or a comparable program approved by the Bureau that meets the requirements specified in section 153.03 of the Revised Code prior to the time that the subcontractor provides labor at the project site will result in the contractor being found in breach of the contract and that breach shall be used in the responsibility analysis of that contractor or the subcontractor who was not enrolled in a program for future contracts with the State for 5 years after the date of the breach."
 - **1.6.2.4** "Failure of a subcontractor to require a lower-tier subcontractor to be enrolled in and be in good standing in the Bureau of Workers' Compensation's Drug-Free Workplace Program or a comparable program approved by the Bureau that meets the requirements specified in section 153.03 of the Revised Code prior to the time that the lower-tier subcontractor provides labor at the project site will result in the subcontractor being found in breach of the contract and that breach shall be used in the responsibility analysis of that subcontractor or the lower-tier subcontractor who was not enrolled in a program for future contracts with the State for 5 years after the date of the breach."
- **1.6.3** Prior to authorizing a Subcontractor to commence Work on the Site, the Contractor shall obtain the Contracting Authority's approval, and shall also submit written confirmation of the Subcontractor's enrollment on the **Subcontractor and Material Supplier Declaration** form to the A/E.
- **1.6.4** In addition to OBWC-approved DFSP Basic requirements, the Contractor, each Subcontractor, and each Separate Contractor that provides labor on the Site shall participate in a pool that performs random drug testing of at least 5 percent of its employees who perform labor on the Site. The random drug testing percentage shall also include the onsite supervisors of the Contractor, Subcontractors, and Separate Contractors. Basic random drug testing shall otherwise comply with the same testing guidelines and criteria as required for OBWC-approved advanced testing. The Contractor and Subcontractor shall provide evidence of required testing to the Contracting Authority upon request.

1.7 Use of the State's Web-based Project Management Software

- **1.7.1** If the Contracting Authority decides, in its sole discretion, to utilize the State's web-based project management software for the Project, the Contractor shall use such software for all compatible services required under this Contract.
- **1.7.2** All costs for the Contractor's use of the State's web-based project management software for the Project shall be included in the Contract Sum. If the Contractor is unfamiliar with the proper use of such software, the Contractor shall provide its employees for training without additional compensation.

1.8 EDGE Participation and Reporting

- **1.8.1** The Contractor shall participate in the "Encouraging Diversity, Growth and Equity" ("EDGE") Program by subcontracting with, and using one or more, businesses certified as an EDGE Business Enterprise ("EDGE-certified Business") by the EOC.
 - **1.8.1.1** If the Contractor is an EDGE-certified Business, the Contractor may include its own compensation under this Contract in the reporting.
 - **1.8.1.2** The amount of EDGE participation cannot exceed 100 percent of the Contract Sum.
 - **1.8.1.3** The Contractor shall include in the reporting only those expenditures to EDGE-certified Businesses that perform a commercially useful function as described in OAC Section 123:2-16-15.
- 1.8.2 The Contractor shall provide an EDGE Participation Report with each Contractor Payment Request.

- **1.8.2.1** The Contractor shall provide status reports, produced by the Contractor and each applicable EDGE-certified Business for the Contract, indicating:
 - .1 the name of each EDGE-certified Business;
 - .2 the federal tax identification number of each EDGE-certified Business;
 - .3 the date of the EDGE-certified Business contract, Subcontract, or purchase order;
 - **.4** the projected and actual start and end dates of the EDGE-certified Business contract, Subcontract, or purchase order;
 - .5 the original amount of the EDGE-certified Business contract, Subcontract, or purchase order with the Contractor;
 - .6 the current amount of the EDGE-certified Business contract, Subcontract, or purchase order;
 - .7 the amount invoiced to date;
 - .8 the amount paid to date;
 - .9 the status of the EDGE-certified Business contract, Subcontract, or purchase order (active, complete, or void); and
 - .10 a statement describing any substantive product or performance deficiencies.
- **1.8.2.2** The Contractor shall provide reports for each EDGE-certified Business; however, the reports may be consolidated and submitted as one document.
- **1.8.3** The Contractor shall provide an EDGE Participation Final Report simultaneously with its final Contractor Payment Request.
 - **1.8.3.1** The Contractor and each EDGE-certified Business shall provide in the report certification that the submitted document is a true and accurate accounting of the original contract amount paid to, and received by, each EDGE-certified Business.
- **1.8.4** The Contractor shall provide the EDGE Participation Reports in detail and form acceptable to the Contracting Authority.
 - **1.8.4.1** Failure to timely submit EDGE Participation Reports may result in withholding payment in accordance with **Section 9.8**.
- **1.8.5** The Contractor shall cooperate fully with requests for additional EDGE information and documentation from the EOC or Contracting Authority.

1.9 Owner Work Rules

1.9.1 The Contractor shall consult with the Owner to obtain full knowledge of the Owner's rules, regulations, or requirements affecting the Project.

1.10 Emergency

- **1.10.1** In the event of an emergency affecting the safety of the Project, other property, or individuals, the Contractor, without special instruction or authorization, shall act to prevent the threatened damage, injury, or loss.
- **1.10.2** If the Contractor believes that it is entitled to an adjustment of the Contract Sum or Contract Times, or both, on account of its actions in response to an emergency, the Contractor may request a Modification by giving written notice under **Section 7.3.2**.

1.11 Contractor's Standard of Care

1.11.1 The Contractor shall perform the Work in a workmanlike manner, consistent with the standards of skill and care exercised by entities licensed to perform (where required under Applicable Law) and regularly performing comparable work in the same or similar locality under the same or similar circumstances.

1.12 Limit of Contractor's Responsibility

1.12.1 The Contractor is not responsible for the A/E's negligence or the A/E's failure to properly perform the A/E's contract.

1.13 Sustainability Requirements

1.13.1 This Project shall be designed and constructed in accordance with the requirements of Am. Sub. H.B. 251 of the 126th General Assembly and the resulting rules, policies, and procedures adopted by the Ohio Facilities Construction

Commission establishing Sustainability Requirements for Capital Improvements Projects, including but not limited to the applicable provisions of OAC 3318-3.

1.13.2 If the Project is designed and constructed under the Leadership in Energy and Environmental Design ("LEED") Rating System developed by the U.S. Green Building Council or another rigorous rating system used to facilitate achievement of sustainability goals for the Project, the Contractor shall provide submittals certifying achievement of sustainable design rating system criteria for verification by the Green Building Certification Institute or other third party in accordance with the Contract Documents.

ARTICLE 2 - STATE'S RIGHTS AND RESPONSIBILITIES

2.1 Contracting Authority

- **2.1.1** The Contracting Authority shall designate a Project Manager for the Project. The Project Manager is authorized to act on behalf of the Contracting Authority to perform specific responsibilities under the Contract.
- **2.1.2** The Contracting Authority shall furnish information and services required of it in a timely manner.
- **2.1.3** The Contracting Authority shall have access to the Work at all times, whenever the Project is in preparation or progress.
- **2.1.4** The Ohio Facilities Construction Commission requires use of its forms where indicated in the Contract Documents. The party responsible for initiating forms shall utilize the latest edition obtained from the Commission's website: http://ofcc.ohio.gov. The Commission may make modifications to its forms at any time.
 - **2.1.4.1** The Contractor shall not modify any form provided by the Commission or Contracting Authority.
 - **2.1.4.2** If the Project is administered using the State's web-based project management software, the Contractor shall utilize the web-based forms and reports within the applicable business process. The State's web-based project management software is sponsored by the Commission, and such web-based forms and reports are acceptable to the Commission in lieu of its paper forms.
- **2.1.5** The Contracting Authority is not responsible for construction means, methods, manners, techniques, sequences, procedures, or for safety precautions and programs in connection with the Work, or for the Contractor's failure to carry out the Work in conformity with the Contract Documents.

2.2 Owner

- **2.2.1** The Owner shall designate a representative authorized to act on behalf of the Owner during the Project.
- **2.2.2** The Owner shall furnish information and services required of it in a timely manner.
- **2.2.3** The Owner shall have access to the Work at all times whenever the Project is in preparation or progress.
- **2.2.4** Upon issuance of the Notice to Proceed, the Owner shall provide the Site to the Contractor in a condition to permit the Contractor to perform the Work.
- **2.2.5** The Owner may request a change in the Work if the A/E recommends and the Contracting Authority approves the change.
- **2.2.6** The Owner shall communicate with the Contractor through the Contracting Authority.
- **2.2.7** The Owner is not responsible for construction means, methods, manners, techniques, sequences, procedures, or for safety precautions and programs in connection with the Work, or for the Contractor's failure to carry out the Work in conformity with the Contract Documents.

2.3 Approval of Owner, Contracting Authority, and State

2.3.1 The Owner, Contracting Authority, or State's review and approval of the Work and any information the Contractor submits to them is for the sole purpose of determining whether the Work and information are generally consistent with the Contract's intent, and will not relieve the Contractor of its sole responsibility for the performance, preparation, completeness, and accuracy of the Work and information.

2.4 Neutral Facilitation

2.4.1 The Contracting Authority or Owner may engage a Neutral Facilitator for the purposes of (1) building cooperative relationships among the Project participants to achieve discrete objectives; (2) encouraging educated, productive, and

expedited attempts to avoid, minimize, and resolve disputes; and (3) maximizing the effectiveness of each participant's resources.

- **2.4.1.1** For example, a Neutral Facilitator may facilitate the organizational meeting, partnering session(s), and efforts to resolve disputes throughout the Project.
- **2.4.2** The Contracting Authority, Owner, and Contractor are entitled to interact with the Neutral Facilitator with the full expectation that (1) they may act, speak, and disclose information with complete candor and (2) all communication, whether oral or written, made in the course of facilitated sessions is confidential.
- **2.4.3** At any hearing or proceeding regarding any dispute arising out of or related to the Project (1) the Neutral Facilitator will not be competent to testify and shall not be called as a witness and (2) the Neutral Facilitator's testimony and work product will not be admissible.
- **2.4.4** The Neutral Facilitator will not **(1)** perform any services with respect to or bear any responsibility for any legal services, design-professional services, construction, or construction management associated with the Project or **(2)** have any liability whatsoever for any claims related to any legal services, design-professional services, construction, or construction management associated with the Project, including without limitation, claims for legal or design-professional errors or omissions, delays, cost overruns, faulty construction, or increased costs.
- **2.4.5** The Neutral Facilitator's participation in the Project will not relieve the Contracting Authority, Owner, and Contractor of any of their respective rights or obligations under the Contract.

2.5 Contractor Performance Evaluation

- **2.5.1** The Contracting Authority may evaluate the Contractor's performance during the progress of the Work, at completion of a phase of the Project, completion of the Project, or any of the foregoing. The Contracting Authority shall retain the evaluation(s).
 - **2.5.1.1** The Contractor may request a copy of the completed evaluation(s). If the Contractor wishes to comment or take exception to any rating or remark, the Contractor must send a response in writing to the Contracting Authority within 30 days of receiving the evaluation(s).
 - **2.5.1.2** The Contracting Authority may use the evaluation(s) in determining the responsibility of the Contractor for award of future contracts.
 - **2.5.1.3** The Contracting Authority may request information from the Contractor for use in evaluating the A/E's performance. If information is requested, the Contractor must comply in a timely and responsive manner.
 - **2.5.1.4** If a breach of the Contract is committed by the Contractor or is attributable to a Subcontractor, that breach will be used in the responsibility analysis of the Contractor and Subcontractor (where applicable) for future contracts with the State or subcontracts on State projects for 5 years after the date of the breach.

ARTICLE 3 - A/E'S RESPONSIBILITIES

3.1 The A/E's Contract Administration Duties

- **3.1.1** The A/E shall administer the Contract as provided in the Contract Documents and Architect/Engineer Agreement, including, but not limited to, performance of the functions described as follows:
 - **3.1.1.1** The A/E shall attend and conduct progress meetings. The A/E shall prepare an agenda and produce a written report of each progress meeting, and distribute the report to the Contracting Authority, Owner, and Contractor within 3 business days after the meeting. The A/E shall not delegate the duty to prepare the agenda and written reports of any progress meeting.
 - **3.1.1.2** The A/E may authorize minor changes or alterations in the Work that are consistent with the intent of the Contract Documents and do not involve adjustment of the Contract Sum or Contract Times, or both. The A/E has no authority to authorize the Contractor to perform additional or extra Work for which the Contractor may seek adjustment of the Contract Sum or Contract Times, or both.
 - **3.1.1.3** The A/E shall review and recommend, certify, or approve applicable forms required under the Contract Documents.
 - **3.1.1.4** The A/E shall render decisions in connection with the Contractor's responsibilities under the Contract Documents, and submit recommendations to the Contracting Authority for enforcement of the Contract as necessary.

3.1.2 The A/E is the initial interpreter of all requirements of the Contract Documents. All decisions of the A/E are subject to final determination by the Contracting Authority.

3.2 Site Visits and Observation

- **3.2.1** The A/E shall notify, advise, and consult with the Contracting Authority and Owner and protect the State against Defective Work throughout completion of the Project, which includes the Correction Period.
 - **3.2.1.1** The A/E shall designate a field representative, subject to the Contracting Authority's approval, to attend to the Project, to observe and check the progress and quality of the Work, and to take action as necessary or appropriate to achieve conformity with the Contract Documents.
 - **3.2.1.2** The A/E shall have its consultants attend to the Project at intervals required by its agreement or the Contracting Authority.
- **3.2.2** The A/E is authorized to disapprove or reject Defective Work. The A/E shall immediately notify the Contracting Authority any time the A/E disapproves or rejects an item of Work.
- **3.2.3** The A/E is not responsible for construction means, methods, manners, techniques, sequences, procedures, or for safety precautions and programs in connection with the Work, or for the Contractor's failure to carry out the Work in conformity with the Contract Documents.

3.3 Testing and Inspection Services

3.3.1 Unless otherwise specified in the Contract Documents, the A/E shall apply for, secure, and pay for the costs of structural testing and special inspections under Chapter 17 of the Ohio Building Code; testing including geotechnical analysis, environmental testing and analysis, concrete, masonry, structural steel, reinforcing steel, welding, bolts, steel connections, HVAC systems and controls, plumbing and piping, air and water balancing and testing, or other testing; or approval required by Applicable Law.

3.4 Approval of A/E

3.4.1 The A/E's review and approval of the Work and any information the Contractor submits to the A/E is for the sole purpose of determining whether the Work and information are generally consistent with the Contract's intent, and will not relieve the Contractor of its sole responsibility for the performance, preparation, completeness, and accuracy of the Work and information.

3.5 Limitation of A/E's Authority

- **3.5.1** Under no circumstances is the A/E authorized to:
 - **3.5.1.1** bind the Owner or Contracting Authority to any authorizations under, modifications of, or amendments to any contract other than as expressly described under **Section 3.1.1.2**;
 - **3.5.1.2** accept any defective or non-conforming services, Work, or vendor-furnished items;
 - 3.5.1.3 make any settlements on behalf of the Owner or Contracting Authority; or
 - **3.5.1.4** assume any responsibilities of the Contractor or Subcontractors.

ARTICLE 4 - SUBCONTRACTORS

4.1 Evaluation and Approval

- **4.1.1** Within 10 days after the Notice to Proceed, or other period as mutually agreed by the Contractor and Contracting Authority, the Contractor shall submit to the A/E a **Subcontractor and Material Supplier Declaration** form through which the Contractor identifies its Subcontractors.
- **4.1.2** The Contractor's failure to timely submit the information regarding a proposed Subcontractor may result in withholding payment in accordance with **Section 9.8**.
- **4.1.3** After receiving the **Subcontractor and Material Supplier Declaration** form, the A/E shall verify that it is complete and deliver it to the Contracting Authority and Owner. If the A/E finds the form incomplete, the A/E shall return it to the Contractor and identify the incomplete information.

- **4.1.4** If the Contracting Authority rejects any proposed Subcontractor, the Contractor shall propose a replacement Subcontractor with no adjustment of the Contract Sum. The proposed replacement Subcontractor will be evaluated as described above.
- **4.1.5** No less than 10 days before Work is to be performed by the Subcontractor, or within a shorter period as mutually agreed by the Contractor and Contracting Authority, the Contractor shall submit to the Contracting Authority a complete copy of the executed Subcontract between the Contractor and Subcontractor.

4.2 Form of Subcontract

- **4.2.1** All Subcontracts shall be on the **State of Ohio Subcontract Form** prescribed by OAC Section 153:1-03-02.
- **4.2.2** No less than 10 days before Work is to be performed by a Subcontractor, or within a shorter period as mutually agreed by the Contractor and Contracting Authority, the Contractor shall submit to the Contracting Authority and A/E a complete copy of the executed Subcontract between the Contractor and Subcontractor. After receiving the Subcontract, the A/E shall verify that it is complete and deliver it to the Contracting Authority. If the A/E finds the Subcontract incomplete, the A/E shall return it to the Contractor and identify the incomplete information.

4.3 Replacement of Subcontractors

4.3.1 The Contractor shall not replace any Subcontractor after execution of the Subcontract without the prior written approval of the Contracting Authority.

4.4 Contractor's Responsibility

- **4.4.1** The Contractor is fully responsible for all acts and omissions of its Subcontractors and is responsible for scheduling and coordinating the Work of its Subcontractors.
 - **4.4.1.1** The Contractor is fully responsible for any delay, interference, disruption, or hindrance attributable to the Contractor's Subcontractors.
 - **4.4.1.2** The Contractor shall require that each of its Subcontractors have a competent supervisor at the Site whenever the Subcontractor is performing Work.
 - **4.4.1.3** The Contractor shall bind its Subcontractors to the terms of the Contract Documents, so far as applicable to the Work of the Subcontractor, and shall not agree to any provision, which seeks to bind the State to terms inconsistent with or at variance from the Contract Documents.
- **4.4.2** The Contractor will not be relieved of its full responsibility for Subcontractors and their performance of the Work by **(1)** the participation of the Owner, Contracting Authority, and A/E in the processes described under this **Article 4** or other related provisions of the Contract Documents or **(2)** the Contracting Authority's rejection of a Subcontractor or failure to reject a Subcontractor under **Section 4.1**.

4.5 Contingent Assignment of Subcontracts

4.5.1 The Contractor hereby assigns its agreement with each Subcontractor to the Contracting Authority provided that the assignment is effective only after termination of the Contract by the Contracting Authority and only for those agreements that the Contracting Authority accepts by notifying the Contractor and applicable Subcontractor in writing. The Contracting Authority may re-assign accepted agreements.

4.6 Prompt Payment

- **4.6.1** The Contractor shall make payments to Subcontractors in accordance with Applicable Law, including ORC Section 4113.61 that include, without limitation, the requirements described under this **Section 4.6**.
 - **4.6.1.1** If a Subcontractor requests payment in time to allow the Contractor to include the request in its Contractor Payment Request, the Contractor shall pay within 10 days after receipt of payment from the State:
 - .1 To a Subcontractor other than a Material Supplier, an amount equal to the percent of completion allowed by the Contracting Authority for the Subcontractor's Work.
 - .2 To a Material Supplier, an amount equal to all or that portion of the Contractor Payment Request that represents the materials furnished by the Material Supplier.
- **4.6.2** The Contractor may reduce the amount paid to a Subcontractor pursuant to **Section 4.6.1** at a rate equal to the percentage retained from the Contractor and may withhold amounts necessary to **(1)** resolve disputed liens or claims involving the Work of the Subcontractor or **(2)** account for the failure of the Subcontractor to perform its obligations under its agreement with the Contractor.

4.6.2.1 Labor Payments.

- .1 Partial payments to the Subcontractor for labor performed under either a Unit Price or lump sum Subcontract shall be made at the rate of 92 percent of the amount invoiced through the Subcontractor's request for payment that shows the Work of the Subcontractor is 50 percent complete.
- .2 After the Work of the Subcontractor is 50 percent complete, as evidenced by payments of at least 50 percent of the total amount due under the Subcontract, no additional funds shall be retained from payments for labor.

4.6.2.2 Material Payments.

- .1 The Contractor shall pay the Subcontractor at the rate of 100 percent of the scheduled value for materials incorporated into the Project.
- .2 The Contractor shall pay the Subcontractor at the rate of 92 percent of the invoice cost, not to exceed the scheduled value in a Unit Price or lump sum Subcontract, for materials delivered to the Site, or other offsite storage location approved by the A/E, provided the Subcontractor provides the information required by Sections 9.6.2.1 and 9.6.2.2 with its request for payment.
- **4.6.3** If the Contractor fails to comply with this **Section 4.6**, the Contractor shall pay to the applicable Subcontractor 18 percent interest, compounded annually, on any unpaid amount beginning on the 11th day after receipt of payment from the State.
- **4.6.4** In order to establish lien rights, Subcontractors shall comply with Applicable Law, including ORC Sections 1311.26, 1311.261, and 1311.29.
- **4.6.5** If the Contracting Authority receives a Claim Affidavit from a Subcontractor, it shall proceed as required by Applicable Law, including ORC Sections 153.63 and 1311.31.
- **4.6.6** Laborers, Subcontractors, and Material Suppliers may secure payment rights in accordance with Applicable Law, including ORC Section 153.56.

ARTICLE 5 - PRECONSTRUCTION ACTIVITIES

5.1 Partnering

- **5.1.1** The formation of a cohesive, mutually beneficial partnering arrangement among the Contractor, Contracting Authority, A/E, and Owner will accomplish the construction of the Project most effectively and efficiently. This arrangement draws on their collective strengths, skills, and knowledge to achieve a Project of the intended quality, within budget, and on schedule. To achieve that objective, participation in a partnering session is required for the following key stakeholders:
 - **5.1.1.1** Contracting Authority: Project Manager
 - **5.1.1.2** Owner: Primary representative
 - **5.1.1.3** A/E: Principal-in-charge, project manager, field representative, major consultants
 - **5.1.1.4** Contractor: Principal-in-charge, project manager, and superintendent
 - **5.1.1.5** Major Subcontractors (e.g., plumbing, HVAC, electrical): Principal-in-charge, project manager or superintendent
 - **5.1.1.6** CxA, if applicable
- **5.1.2** The purpose of the partnering arrangement is to build cooperative relationships between the Project's key stakeholders, avoid or minimize disputes, and nurture a more collaborative ethic characterized by trust, cooperation and teamwork. This arrangement is intended to produce a voluntary, non-binding, but formally structured agreement among the Project's key stakeholders, leading to an attitude that fosters risk sharing.
- **5.1.3** To create and implement the partnering arrangement, the Project's key stakeholders shall meet prior to the construction of the Project for developing a partnering agreement. The agreement should be comprehensive and focus on all issues necessary for successful completion of the Project, and shall identify common goals and objectives, develop a problem solution process, an Alternative Dispute Resolution ("ADR") strategy in accordance with **Section 8.13**, and an implementation plan for the partnering arrangement.
- **5.1.4** Formal contractual relations, responsibilities, and liabilities are not affected by any partnering arrangement. The cost associated with establishing this partnership, including but not limited to engaging the services of a Neutral

Facilitator, shall be included in an allowance in the Contractor's bid. The Contractor shall include in its base bid the resources necessary to participate in the partnering session.

5.1.5 Partnering services may extend over the entire period of performance of the Contract and may include intervention or project realignment services to be utilized if serious disputes arise. The Project's key stakeholders should agree, during the initial partnering session, to the types of situations and circumstances in which intervention or realignment services shall be utilized.

5.2 Building and Trade Permits and Licenses

5.2.1 Plan Approval.

- **5.2.1.1** The A/E shall secure the required structural, plumbing, HVAC, and electrical plan approvals.
- **5.2.1.2** The Contractor shall schedule and attend all intermediate and final inspections required for any permit applicable to the Work. The Contractor shall schedule the State Fire Marshal or local fire authority for the life safety inspection for occupancy permits. The Contractor shall give the A/E, Contracting Authority, and Owner reasonable notice of the dates and times arranged for inspections.
 - .1 The Contractor shall pay for any reinspections required as a result of the Contractor's failure to receive approval of its Work.

5.2.2 Trade Permits and Licenses.

5.2.2.1 The Contractor shall obtain, maintain, and pay for any permit, inspection, or license applicable to the Contractor's particular trade.

5.2.3 Local Permits.

5.2.3.1 The Contractor shall secure and pay the fees for any permits, inspections, licenses, capacity charges, or tap fees required by local authorities having jurisdiction over the Project. The Contractor shall give the A/E, Contracting Authority, and Owner reasonable notice of the date arranged for inspections.

5.2.4 National Pollutant Discharge Elimination System ("NPDES") Storm Water General Permit.

- **5.2.4.1** The A/E shall secure the NPDES general permit by submitting a Notice of Intent ("NOI") application form to the Ohio Environmental Protection Agency at least 45 days prior to the start of construction. The Contractor shall be a "co-permitee" if required under Applicable Law.
- **5.2.4.2** The A/E shall prepare and certify a storm water pollution prevention plan to provide sedimentation and erosion controls at the Project.
- **5.2.4.3** The A/E shall prepare and process the required Notice of Termination ("NOT") prior to Contract Completion.

ARTICLE 6 - CONSTRUCTION AND CLOSEOUT

6.1 Commencement of Work on the Site

6.1.1 Unless the Contracting Authority agrees otherwise in writing, the Construction Stage will commence with the Contracting Authority's issuance of the Notice to Proceed and will terminate upon Contract Completion.

6.2 Responsibility of the Contractor

- **6.2.1** The Contractor shall complete portions of the Work in the sequence and time in the Construction Progress Schedule.
- **6.2.2** The Contractor shall supervise the Work.
- **6.2.3** The Contractor must perform the Work so as not to interfere with, disturb, hinder, or delay the services of Separate Consultants or the work of Separate Contractors. The Contractor must cooperate and coordinate fully with all Separate Consultants and Separate Contractors and must freely share all of the Contractor's Project-related information with them to facilitate the timely and proper performance of the Work and of the services and work of the Separate Consultants and Separate Contractors.
- **6.2.4** The Contractor must afford every Separate Consultant and Separate Contractor proper and safe access to the Site and a reasonable opportunity for the introduction and storage of materials and equipment and the execution of their services and work.

- **6.2.5** If the Contractor damages the property or work of any Separate Consultant or Separate Contractor, or by failure to perform the Work with due diligence, delays, interferes with, hinders, or disrupts the services of any Separate Consultant or the work of any Separate Contractor who suffers additional expense and damage as a result, the Contractor is responsible for that damage, injury, or expense.
- **6.2.6** The intent of **Sections 6.2.3** through **6.2.5** is to benefit the Separate Consultants and Separate Contractors, and to demonstrate that the Separate Consultants and Separate Contractors are intended third-party beneficiaries of the Contractor's obligations under the Contract.
- **6.2.7** If the proper execution or results of any part of the Work depends upon work performed or services provided by the Owner, a Separate Consultant, or a Separate Contractor, the Contractor must inspect that other work and appropriate instruments of service, and promptly report to the Contracting Authority in writing any defects or deficiencies in that other work or services that render it unavailable or unsuitable for the proper execution and results of the Work. The Contractor's failure so to report will constitute an acceptance of the other work and services as fit and proper for integration with the Contractor's Work except for defects and deficiencies in the other work or services that were not reasonably discoverable at the time of the Contractor's inspection.
- **6.2.8** The Contractor shall not delay the Work on account of any claim, dispute, or action between the Contractor and a Separate Consultant or Separate Contractor.
- **6.2.9** The Contractor shall develop and keep current the Construction Progress Schedule in accordance with **Section 6.5**, and prepare and keep current a schedule of submittals that is coordinated with the Construction Progress Schedule, for the A/E and Contracting Authority's acceptance.
- **6.2.10** The Construction Progress Schedule shall not exceed the time limits current under the Contract Documents, shall provide for reasonable, efficient, and economical execution of the Project, and shall relate to the entire Project to the extent required by the Contract Documents.
- **6.2.11** The Contractor shall use the Construction Progress Schedule to plan, organize, and execute the Project, record and report actual performance and progress, and show how it plans to coordinate and complete all remaining work by Contract Completion.
- **6.2.12** The Contractor shall monitor the progress of the Work for conformance with the Construction Progress Schedule and shall initiate revisions as required by **Section 6.5.14**.
- **6.2.13** The Contractor shall establish the Project's regular working hours, subject to approval by the A/E and the Owner.
- **6.2.14** The Contractor shall coordinate the Work with the activities and responsibilities of the A/E, Owner, and Contracting Authority to complete the Project in accordance with the Contract Documents.
- **6.2.15** In the event of default of the Contractor, the Contractor shall cooperate with the A/E, Contracting Authority, and Contractor's Surety to achieve the Substantial Completion date and Contract Completion.
- **6.2.16** The Contractor shall remove all snow and ice as may be required for reasonably safe access to the Project including, but not limited to, building entries, driveways, parking lots, and sidewalks.
- **6.2.17** The Contractor shall keep a daily log containing a record of weather, number of workers on Site for the Contractor, identification of equipment, Work accomplished, problems encountered, and other similar relevant data.

6.3 Construction Procedures

- **6.3.1** The Contractor is solely responsible for and has control over all construction means, methods, manners, techniques, sequences, and procedures, for safety precautions and programs in connection with the Work, and for coordinating all portions of the Work.
 - **6.3.1.1** If the Contract Documents give instructions that affect construction means, methods, manners, techniques, sequences, or procedures, the Contractor shall evaluate the jobsite safety of them and, except as stated below, shall be fully and solely responsible for the jobsite safety of the means, methods, manners, techniques, sequences, or procedures.
 - **6.3.1.2** If the Contractor determines that the means, methods, manners, techniques, sequences, or procedures specified in the Contract Documents may not be safe, the Contractor shall give timely written notice to the A/E, Owner, and Contracting Authority. The Contractor shall not proceed with that portion of the Work without further written instructions from the A/E. Any modification of the Contract shall be in accordance with **Article 7**.

- **6.3.2** The Contractor shall lay out and coordinate all lines, levels, elevations, and measurements for all of the Work, coordinate and verify existing conditions, and notify the A/E of discrepancies and conflicts before proceeding with installation or excavation.
- **6.3.3** The Contractor shall perform all cutting, fitting, or patching required for the Work and shall not endanger the Project by cutting, excavating, or otherwise altering the Project, or any part of it.
 - **6.3.3.1** If the Contractor requires sleeves for the Work, the Contractor shall furnish and install the sleeves. The Contractor is responsible for the exact location and size of all holes and openings required to be formed or built for the Work.
 - **6.3.3.2** The Contractor's patching shall match and blend with the existing or adjacent surface(s).
- **6.3.4** The Contractor shall comply with ORC Sections 3781.25 through 3781.32. In addition, before starting excavation or trenching, the Contractor shall determine the location of any underground utilities and notify any public authority or utility having jurisdiction over the Project and secure any required approval.
 - **6.3.4.1** The Contractor shall give notice at least 2 business days in advance of excavation to the owners of underground utilities registered with the Ohio Underground Utility Protection Services ("OUPS" at http://oups.org, phone 811 or 800-362-2764), and the owners of underground utilities shown on the Drawings and Specifications who are not registered members of OUPS. The owner of an underground utility is required within 48-hours' notice to stake, mark, or otherwise designate the location of its utilities in the construction area together with its approximate depth. In the event that any underground utility owner fails to timely perform, the Contractor shall notify the A/E and contact the owner of the underground utility.
- **6.3.5** The Contractor shall install all Work in accordance with the Contract Documents and any installation recommendations of the manufacturer, including required temperature and humidity limits for installation of the various materials.
- **6.3.6** The Contractor shall comply with all requirements and conditions of the NPDES general permit, including, but not limited to, implementing and maintaining the sedimentation and erosion control measures specified in the storm water pollution prevention plan prepared by the A/E pursuant to **Section 5.2.4**, which are related to the Work, maintaining records of its construction activities, removing materials no longer required, and taking proper action if there is a reportable quantity spill.
- **6.3.7** The Contractor shall communicate with the Contracting Authority and Owner through the A/E.

6.4 Construction Supervision

- **6.4.1** Unless waived by the Contracting Authority in writing, the Contractor shall provide continuous supervision at the Site by a competent superintendent when any Work is being performed and the Contractor's superintendent shall not be involved with any work other than the Project.
- **6.4.2** The Contractor's project manager and superintendent shall each have the responsibility and authority to act on behalf of the Contractor. All communications to the Contractor's project manager or superintendent shall be binding as if given directly to the Contractor.
- **6.4.3** The Contractor shall submit an outline of the qualifications and experience of the Contractor's proposed project manager and proposed superintendent, including references, to the Contracting Authority no less than 10 days of the Notice to Proceed. For all Subcontracts in excess of \$200,000, and for all other Subcontracts on request from the Contracting Authority, the Contractor shall submit an outline of the qualifications and experience of the Subcontractor's proposed project manager and proposed superintendent, including references, to the Contracting Authority no less than 10 days before the Subcontractor is scheduled to begin Work on the Site.
 - **6.4.3.1** The Contracting Authority may reject the Contractor or Subcontractor's proposed project manager or proposed superintendent. If the Contracting Authority does not notify the Contractor of the rejection within 30 days after receiving the required information, it shall indicate that the Contracting Authority has no objection, but does not affect the Contracting Authority's rights under **Section 6.12.2** or any other provision relative to that project manager or superintendent.
 - **6.4.3.2** If the Contracting Authority rejects the Contractor or Subcontractor's proposed project manager or proposed superintendent, the Contractor shall replace, or cause the Subcontractor to replace the project manager or superintendent (as appropriate) with someone acceptable to the Contracting Authority at no additional cost.
- **6.4.4** The Contractor and its Subcontractors subject to **Section 6.4.3** shall not replace their respective project managers or superintendents without prior written approval of the Contracting Authority.

- **6.4.4.1** If the Contractor or a Subcontractor subject to **Section 6.4.3** proposes to change its project manager or superintendent, the Contractor shall submit written justification to the Contracting Authority, along with the name and qualifications of the proposed replacement.
- **6.4.4.2** The procedure provided in **Section 6.4.3** shall be conducted to evaluate the Contractor or Subcontractor's (as applicable) proposed replacement project manager or superintendent.

6.5 Construction Progress Schedule

- **6.5.1** If the Estimated Construction Cost is less than \$500,000, the Contractor may provide a bar chart schedule with a logical sequence of events and sufficient detail to properly anticipate and monitor construction progress. If the Estimated Construction Cost for the Project is \$500,000 or more, the Contractor shall prepare and maintain a resource-loaded Construction Progress Schedule using the critical-path method of scheduling that provides the following information:
 - **6.5.1.1** a graphic presentation of the sequence of the Work for the Project in the media and format required for the Project;
 - **6.5.1.2** identification of each stage of the Work and any Milestone dates;
 - **6.5.1.3** identification of activities and durations for review and approval of Shop Drawings and other action submittals, fabrication and review of mock-up Work, product review and procurement, fabrication, shop inspection, and delivery, including, but not limited to, lead time, coordination drawing delivery, Substantial Completion, Punch List, Punch List Correction, Project close-out requirements, occupancy requirements, and Contract Completion;
 - **6.5.1.4** identification of disruptions and shutdowns due to other operations;
 - **6.5.1.5** identification of the critical path of the Work;
 - **6.5.1.6** identification of the crew size and total resource hours for each activity in the schedule; and
 - **6.5.1.7** the Contractor's signature and date indicating approval.
- **6.5.2** The Contractor shall develop the Construction Progress Schedule using commercially available, personal computer software acceptable to the Contracting Authority and shall submit all baseline and updated schedules to the A/E in the schedules' native electronic format.
- **6.5.3** The Construction Progress Schedule shall not exceed the time limits current under the Contract Documents, shall provide for reasonable, efficient, and economical execution of the Project, and shall relate to the entire Project to the extent required by the Contract Documents.
- **6.5.4** The Contractor shall use the Construction Progress Schedule to plan, organize, and execute the Project, record and report actual performance and progress, and show how it plans to coordinate and complete all remaining Work within applicable Milestones. The Project participants shall use the Construction Progress Schedule as a tool for scheduling and reporting sequenced progress of the Work. The Contractor shall provide a clear graphics legend and other data including, but not limited to, Milestone dates, constraints, and other items required by the Project, A/E, Contracting Authority, and Owner. Each submission shall show the Contracting Authority's Project number and Project name, and provide a signature approval and date line for the Contractor.
- **6.5.5** The Contractor shall provide in each schedule: Activity identification and description for each activity broken down to a maximum duration that is appropriate for the activity, responsibility of the Contractor, Contractor's resources and crew size for each activity, provide early start, early finish, late start, late finish dates. Each schedule shall show predecessor activities and successor activities for each activity, entry free float, total float, and percentage of completion, and identify the appropriate predecessors and successors for all related activities.
- **6.5.6** The Construction Progress Schedule shall show all submittal dates, review and approval durations for coordination drawings, Shop Drawings, other action submittals, and mock-up Work.
- **6.5.7** Within 30 days of the date of the Notice to Proceed, the Contractor shall submit to the A/E a proposed Construction Progress Schedule approved by the Contractor. If the Project is \$4 million total construction cost or more, the Contractor may submit an intermediate Bar Chart Schedule for the first 120 days to the A/E within 30 days of the date of the Notice to Proceed; followed by the complete resource-loaded precedence or arrow diagram schedule within 90 days of the date of the Notice to Proceed.
 - **6.5.7.1** The Contractor shall submit the initial and all updates of the Construction Progress Schedule in graphic and tabular form to the A/E. With each monthly schedule update, the Contractor shall include a list of all changes to the previously approved baseline schedule or monthly updated schedule.

- **6.5.7.2** After receiving the Construction Progress Schedule, the A/E shall review and submit a copy of the Construction Progress Schedule to the Contracting Authority and Owner for review and acceptance, or reject and return it to the Contractor with recommendations for revisions.
- **6.5.8** The Construction Progress Schedule shall be managed using early start dates and early finish dates. The Contractor must exhaust existing float before claiming additional time for a Change Order, or show that it is not possible to use float to cover the time requirements of the Change Order.
- **6.5.9** The Contractor's failure to timely submit and properly maintain an approved Construction Progress Schedule may result in withholding payment in accordance with **Section 9.8**.
- **6.5.10** For each progress meeting, the Contractor shall provide a 2- to 6-week look-ahead schedule, as appropriate for the Project.
- **6.5.11** On a weekly basis, the Contractor shall prepare and submit to the A/E a written report describing:
 - **6.5.11.1** activities begun or finished during the preceding week;
 - **6.5.11.2** activities in progress and expected completion;
 - **6.5.11.3** activities to be started or finished in the upcoming 2 weeks, including but not limited to, the Contractor's workforce size and total resource hours associated with those activities; and
 - **6.5.11.4** other information requested by the A/E.
- **6.5.12** The A/E shall attach the above information to the minutes of the weekly progress meetings.
- **6.5.13** The Contractor shall provide monthly Progress Status Reports to the Contracting Authority, A/E, and Owner, which shall include recommendations for adjusting the Construction Progress Schedule to meet Milestone dates and the Substantial Completion date.
 - **6.5.13.1** If it is apparent to the A/E that the Contractor may be unable to meet critical path activities, Milestone completion dates, or the Substantial Completion date, the A/E shall direct the Contractor to submit within 3 days a recovery plan to avoid or minimize delay to the Project.
 - **6.5.13.2** A recovery plan shall include, but is not limited to, adjustments to one or more of the following:
 - .1 workforce
 - .2 hours per shift
 - .3 shifts per workday
 - .4 workdays per week
 - .5 equipment
 - .6 activity logic
 - **6.5.13.3** If the A/E approves the recovery plan, the Contractor shall prepare a revised Construction Progress Schedule approved in accordance with **Section 6.5.7**. If the A/E does not approve the recovery plan, the Contractor shall submit within 3 days an alternate recovery plan to the A/E in writing for review and approval in accordance with **Section 6.5.7**.
- **6.5.14** The Contractor shall update the Construction Progress Schedule on a monthly basis, or other interval approved by the Contracting Authority, in accordance with **Section 6.5.7**.
 - **6.5.14.1** The updated Construction Progress Schedule approved by the Contractor shall serve as an affirmation that the Contractor can meet the requirements of the updated Construction Progress Schedule.
 - **6.5.14.2** The Contractor shall submit a tabular copy showing all changes to the previously approved schedule including, but not limited to, logic, float, and actual start date of activities. The original or initially approved Construction Progress Schedule and all subsequent Construction Progress Schedules submitted by the Contractor, and accepted by the A/E, shall serve as an affirmation that the Contractor agrees to and can meet the applicable requirements of the updated Construction Progress Schedule.
- **6.5.15** The Contractor's failure to timely submit an approved, updated Construction Progress Schedule may result in withholding payment in accordance with **Section 9.8**.

6.6 Progress Meetings

6.6.1 The A/E shall schedule a weekly progress meeting for the Contractor and other Persons involved in the Project. The purpose of the progress meeting is to review progress on the Project during the previous week, discuss anticipated progress during the following weeks, review critical operations, and discuss critical problems.

- **6.6.2** The Contractor shall be represented at every progress meeting by a Person authorized with signature authority to make decisions regarding possible modification of the Contract Documents or Construction Progress Schedule.
 - **6.6.2.1** The A/E shall notify the Contractor and other Persons involved in the Project of the time and place of the progress meeting that shall thereafter be the same day and hour of the week for the duration of the Project, unless the A/E notifies the Contractor and other Persons involved in the Project of a different day and hour at least 2 days in advance.
 - **6.6.2.2** The Contractor shall have any of its Subcontractors attend the progress meeting as determined advisable by the Contractor, or as requested by the A/E.
- **6.6.3** The A/E shall prepare a written report of each progress meeting and distribute the report to the Contracting Authority, Owner, and Contractor. The A/E shall not delegate the duty to prepare a written report of any progress meeting.
 - **6.6.3.1** If any Person in attendance objects to anything in a report of a progress meeting, the Person shall notify the A/E, Contracting Authority, and any other affected Person in writing explaining the objection within 5 days.
 - **6.6.3.2** The report of each progress meeting shall reflect any objection made to the report of the previous progress meeting and any response.

6.7 Project Coordination

- **6.7.1** The Contractor shall prepare drawings ("Coordination Drawings") after the Contractor and appropriate Subcontractors ("Coordination Participants") (1) determine the sequence of the Project, (2) identify the areas requiring special attention ("Coordination Areas"), and (3) determine the need for a coordination drawing for any Coordination Area. The Contractor shall prepare the Coordination Drawings with Computer-Aided Design ("CAD") or Building Information Modeling ("BIM") software acceptable to the Contracting Authority. The Coordination Drawings shall show the sheet metal work with plan and elevation dimensions, which specifically locate all HVAC ductwork, HVAC equipment, and HVAC piping for each Coordination Area based upon the information, discussion, and resulting consensus of the Coordination Participants during the coordination meetings.
 - **6.7.1.1** After the Contractor completes the Coordination Drawings, the Contractor shall forward a copy of the Coordination Drawings to the A/E, Contracting Authority, and Owner.
 - **6.7.1.2** The A/E shall review the Coordination Drawings to determine whether the Coordination Participants achieved the goals listed in **Section 6.7.1**. The A/E shall report any concerns, in writing, to the Coordination Participants within 14 days after receiving the drawings.

6.8 Additional Tests and Inspections

- **6.8.1** If the A/E or the Contracting Authority determines that any portion of the Work requires special inspection, testing, or approval not otherwise required under the Contract Documents, the A/E shall order such inspection, testing, or approval.
 - **6.8.1.1** If the special inspection, testing, or approval reveals Defective Work, the Contractor shall pay all associated costs and will not be entitled to any related adjustment of the Contract Times. Those costs may include, but are not limited to:
 - .1 the cost of the special inspection, testing, or approval;
 - .2 the cost of additional special inspections, testing, or approvals to evaluate remedial Work;
 - .3 the cost of correcting the Defective Work; and
 - **.4** all related Owner-incurred fees and charges of contractors, engineers, architects, attorneys, and other professionals.
 - **6.8.1.2** The Contracting Authority may deduct the costs described under **Section 6.8.1.1** from payments then or thereafter due the Contractor. If payments then or thereafter due the Contractor are not sufficient to cover those amounts, the Contractor shall immediately pay the amount of the insufficiency to the Owner.
 - **6.8.1.3** If the special inspection, testing, or approval reveals that the Work complies with the Contract Documents, and the Contractor believes that it is entitled to an adjustment of the Contract Sum or Contract Times, or both, on account of the special inspection, testing, or approval, the Contractor may request a Change Order by giving written notice under **Section 7.3.2** within 7 days after the special inspection, testing, or approval.
- **6.8.2** If the Contractor is aware of a need for inspection, testing, or approval, or of a need to have any inspection, testing, or approval completed by a particular time to avoid delay, then the Contractor shall timely communicate such information to the A/E and Contracting Authority.

- **6.8.3** Except as described under **Section 6.8.1**, the Owner shall pay for any inspection, testing, or approval that did not become a requirement until after it awarded the Contract.
- **6.8.4** The Contractor shall coordinate with and give the A/E, Contracting Authority, and Owner reasonable notice of the anticipated dates of all inspections, testing, or approvals.
- **6.8.5** Within 5 days after completion of an inspection, testing, or approval, the A/E shall provide an original report/certificate of the inspection, testing, or approval to the Contractor and Contracting Authority with a recommendation for or against acceptance of the results therein.

6.9 Review of Contract Documents and Field Conditions

- **6.9.1** Before starting each portion of the Work, the Contractor shall carefully study and compare the various Contract Documents relative to that portion of the Work, shall take field measurements of any existing conditions related to that portion of the Work, and shall observe any conditions at the Site affecting it.
- **6.9.2** If the Contractor finds any perceived ambiguity, conflict, error, omission, or discrepancy on or between any of the Contract Documents, or between any of the Contract Documents and any Applicable Law, the Contractor, before proceeding with the Work, shall promptly submit a Request for Interpretation ("RFI") to the A/E for an interpretation or clarification.
 - **6.9.2.1** Before submitting any RFI to the A/E, the Contractor shall carefully review the Contract Documents to ensure that the Contract Documents do not answer the RFI.
 - **6.9.2.2** The A/E shall respond to an RFI within 3 days of receiving the RFI.
 - **6.9.2.3** Any interpretation or clarification of the Contract Documents made by any Person other than the A/E, or in any manner other than writing, shall not be binding and the Contractor shall not rely upon it.
- **6.9.3** If the Contractor believes that it is entitled to an adjustment of the Contract Sum or Contract Times, or both, on account of clarifications or instructions issued by the A/E in response to a RFI, the Contractor may request a Change Order by giving written notice under **Section 7.3.2** within 7 days of receiving the A/E's RFI response.
- **6.9.4** If the Contractor does not notify the A/E per **Section 6.9.3**, the Contractor will have accepted the RFI response without an adjustment to the Contract Sum or Contract Times.

6.10 Protection of the Project

- **6.10.1** The Contractor shall protect the Work from weather and maintain the Work and all materials, apparatus, and fixtures free from injury or damage until Substantial Completion of the Work.
 - **6.10.1.1** The Contractor shall at all times cover or protect the Work.
 - **6.10.1.2** The Contractor, at its expense, shall remove, and replace with new, any Work damaged as a result of the Contractor's failure to provide coverage or protection.
 - **6.10.1.3** The Contractor, at its expense, shall repair or replace any adjacent property, including, but not limited to, roads, walks, shrubbery, plants, trees, or turf, damaged during performance of the Work.
 - **6.10.1.4** After the date of Substantial Completion of the Work, the Owner is responsible for protecting and maintaining all materials, apparatus, and fixtures for the occupied portion of the Project free from injury or damage.
- **6.10.2** The Contractor shall protect the Project and existing or adjacent property from damage at all times and shall erect and maintain necessary barriers, furnish and keep lighted necessary danger signals at night, and take reasonable precautions to prevent injury or damage to individuals or property.
- **6.10.3** The Contractor shall not load, or permit any part of the Project to be loaded, in any manner that endangers the Project, or any portion thereof. The Contractor shall not subject any part of the Project or existing or adjacent property to stress or pressure that endangers the Project or property.
- **6.10.4** The Contractor shall provide all temporary bracing, shoring, and other structural support required for safety of the Project and proper execution of the Work.
- 6.10.5 Vibration, Noise, and Dust Control.
 - **6.10.5.1** The Contractor shall provide controls/barriers for vibrations, noise, and dust control in occupied buildings as required by the construction operations.

- **6.10.5.2** The Contractor will not be permitted to exhaust or release unfiltered air, dust, construction debris, or other undesirable products into the exterior atmosphere or into occupied areas of the building outside the Site. The Project Manager may limit or stop the Work if the Contractor does not maintain proper air-quality standards.
- **6.10.5.3** In certain occupied buildings, tasks might be of such a nature that noise and vibration cannot be tolerated. In such spaces, Work shall be scheduled for other than normal working hours. The Contractor is cautioned that weekend or overtime work, if required, shall be performed at no additional cost. Permission to work other than standard hours shall be received from the Contracting Authority prior to the occurrence. Weekend and overtime Work shall be reflected in the Construction Progress Schedule.
- **6.10.5.4** The Contractor is responsible for vibration control and control of transmission of noise arising from the Work. Principal considerations that shall be given to noise and vibration control are:
 - .1 Noise control in compliance with Occupational Safety and Health Administration ("OSHA") requirements for the health and safety of building occupants; control shall be for all areas of the facility, including equipment rooms, boiler rooms, and fan rooms.
 - .2 Vibration control to limit sound produced by construction equipment, and for protection of the equipment existing in a building and the building structure.
 - .3 Vibration control to provide for maximum usefulness of the facility by keeping levels of vibration within ranges conducive to study and work or other uses for which the facility is designed.

6.11 Materials and Equipment

- **6.11.1** The Contractor shall provide new materials and equipment of the quality specified in the Contract Documents.
- **6.11.2** The Contractor shall bring to or store at the Site only the materials and equipment required in the Work. If possible, materials and equipment should be installed in their final positions when brought to the Site.
 - **6.11.2.1** The Contractor shall properly store and protect all materials and equipment it provides to the Project.
 - **6.11.2.2** The Contractor shall timely remove from the Site any materials or equipment no longer required for the Work
- **6.11.3** The Contractor shall not allow materials or equipment to damage the Project or adjacent property, nor to endanger any individual at or near the Site.
- **6.11.4** If the Contractor provides an Acceptable Component, the Contractor shall be solely responsible for the costs of coordination and modification required.
- **6.11.5** If the Contractor provides approved Substitutions that require changes to the Contract Documents, the Contractor shall be solely responsible for the additional costs incurred as a result, including, but not limited to, changes to the design by the A/E.
- **6.11.6** The A/E shall consider Requests for Substitutions after the bid opening only when the Contractor can conclusively demonstrate to the A/E the following conditions:
 - **6.11.6.1** the specified Basis of Design Components, Acceptable Components, or previously-approved Substitutions, through no fault of the Contractor or a Subcontractor, are not available; or
 - **6.11.6.2** the specified Basis of Design Components, Acceptable Components, or previously-approved Substitutions will not perform as designed or intended.
- **6.11.7** The Contractor's incorporation of unapproved Substitutions in the Work shall constitute Defective Work.

6.12 Labor

- **6.12.1** The Contractor shall maintain a sufficient workforce and enforce good discipline and order among its employees and the employees of its Subcontractors. The Contractor shall not permit employment of individuals not skilled in tasks assigned to them.
- **6.12.2** The Contractor shall dismiss from the Project any individual employed by the Contractor, or a Subcontractor, who the Contracting Authority finds, in its sole discretion, to be incompetent, guilty of misconduct, or detrimental to the Project.
- **6.12.3** The Contractor shall employ all legal efforts to minimize the likelihood or effect of any strike, Work stoppage, or other labor disturbance. Informational pickets shall not justify any Work stoppage.

6.13 Safety Precautions

- **6.13.1** The Contractor shall take reasonable precautions to ensure the safety of individuals on the Project.
 - **6.13.1.1** The Contractor is responsible for designing and implementing its own safety program, including compliance with OSHA regulations. The Contractor's safety plans, such as fall protection, hazards, communications, competent person, etc., shall meet or exceed the Owner's safety plan (if any).
- **6.13.2** The Contractor shall pay any fine or cost incurred because of the Contractor's violation, or alleged violation, of Applicable Law.
- **6.13.3** Before starting any Work, the Contractor shall submit to the Contracting Authority a copy of the Contractor's site-specific safety plan and safety manuals.
- **6.13.4** The Contractor shall not introduce Hazardous Materials to the Project or burn any fires on the Site.
 - **6.13.4.1** The Contractor shall notify the Project Manager 24 hours before the start of non-routine or non-recurring hot-work. Use of sources of fire, flame or sparks and flammable materials shall be kept to an absolute minimum. At the beginning of the Project, the Contractor shall inform the Project Manager of its intent to use blowtorches, welding apparatus or similar exposed flame and sparking devices. Similar notice shall be given in regard to the use of flammable liquids, adhesives, and cleaners.
 - **6.13.4.2** The Contractor shall furnish an appropriate number of fire extinguishers (minimum of 1), which shall be within the immediate areas where work is being done at all times. The extinguisher shall be adequate and suitable for the class of fire likely to be caused by the Contractor's operations.

6.13.5 Work Stoppage Due to Hazardous Materials.

- **6.13.5.1** If the Contractor encounters material the Contractor reasonably believes to be, or contain, a Hazardous Material that has not been rendered harmless, the Contractor shall immediately stop Work in the affected area and verbally report the condition to the Contracting Authority and A/E, and within 1 business day deliver written notice of the condition to the Contracting Authority and A/E.
- **6.13.5.2** The Contracting Authority will promptly determine the necessity of the Owner retaining a qualified environmental consultant to evaluate the suspected Hazardous Material and to issue a related written report. Where appropriate, the Owner will engage a licensed abatement contractor to remove the material or render it harmless as directed.
- **6.13.5.3** The Contractor shall resume Work in the affected area upon written notice from the A/E that **(1)** the suspect material was evaluated and found not to be or contain a Hazardous Material, or **(2)** the suspect material has been removed or rendered harmless.
- **6.13.5.4** If the Contractor knowingly or negligently proceeds with the Work in an area where a Hazardous Material exists and has not been rendered harmless, the Contractor shall be solely responsible for all related claims, damages, losses, and expenses, including, but not limited to, attorneys' fees, arising out of or resulting from performing the Work in the affected area.
- **6.13.5.5** The term "rendered harmless" means that the level of exposure is less than any applicable exposure standards set forth in Applicable Law.

6.13.6 Safety Data Sheets.

- **6.13.6.1** The Contractor shall identify any material it uses at the Site with a Safety Data Sheet ("SDS") meeting the requirements of OSHA's Hazard Communication Standard (formerly known as a Material Safety Data Sheet).
- **6.13.6.2** The Contractor shall maintain a notebook containing all of its applicable SDSs. This notebook shall be kept at the Site for the duration of the Project.

6.14 Construction Facilities, Utilities, and Equipment

6.14.1 Facilities.

- **6.14.1.1** The Contractor shall provide and maintain in a clean condition suitable temporary facilities, equipment, services, and enclosed storage for its use at the Site.
- **6.14.1.2** The Contractor shall provide and maintain in a clean condition:
 - .1 suitable facilities, equipment, and services for use by the A/E and Contracting Authority;
 - **.2** adequate space, equipment, and furnishings to conduct progress meetings, and store approved documents and permits; and

.3 adequate sanitary facilities for use by all Persons at the Site.

6.14.2 Environmental Controls.

- **6.14.2.1** The Contractor shall protect its Work and materials from weather and damage from heat, cold, and humidity.
- **6.14.2.2** Until the permanent HVAC system is complete and available for use:
 - .1 the Contractor shall make arrangements and pay for installation and maintenance of temporary heating and ventilating systems; and
 - .2 the Contractor shall pay the costs incurred in operating the temporary heating and ventilating systems.
- **6.14.2.3** When the permanent HVAC system is complete and available for use:
 - .1 The Contractor shall start up and maintain operation of the permanent HVAC system, including filters, and promptly remove temporary heating and ventilating systems.
 - **.2** If the Project consists entirely of new construction, the Contractor shall pay the costs of energy consumed in operating the permanent HVAC system until Substantial Completion.
 - .3 If the Project is a renovation of an existing building or structure, addition(s) to an existing building or structure, or any combination of new construction and renovation work that does not allow separate metering of utilities, the Owner shall pay the costs of energy consumed in operating the permanent HVAC system.
- **6.14.2.4** From the date of Substantial Completion, the Owner shall pay the cost of operating the permanent HVAC system for the occupied portion of the Project.
- **6.14.2.5** If the permanent HVAC system is used during construction, the Contractor shall furnish an extended warranty and service contract in effect until the expiration of the Correction Period.

6.14.3 Water and Drainage.

- **6.14.3.1** The Contractor shall provide water necessary for the Work until the permanent plumbing system is available for use.
- **6.14.3.2** The Contractor shall provide temporary drainage and dewatering necessary for the Work and shall employ pumps, trenches, drains, sumps, and other necessary elements required to provide satisfactory working conditions for the protection, execution, and completion of the Project.
- **6.14.3.3** The Contractor shall make arrangements and pay for installation and maintenance of temporary plumbing systems until the permanent plumbing system is available for use.
- **6.14.3.4** When the permanent plumbing system is complete and available for use:
 - .1 The Contractor shall start up and maintain operation of the permanent plumbing systems, and make arrangements and pay for removal of temporary plumbing systems.
 - **.2** If the Project consists entirely of new construction, the Contractor shall pay the costs of water consumed and sewerage charges until Substantial Completion.
 - .3 If the Project is a renovation of an existing building or structure, addition(s) to an existing building or structure, or any combination of new construction and renovation work that does not allow separate metering of utilities, the Owner shall pay the costs of water consumed and sewerage charges.
- **6.14.3.5** From the date of Substantial Completion, the Owner shall pay the costs of water consumed and sewerage charges for the occupied portion of the Project.
- **6.14.3.6** If the permanent plumbing system is used during construction, the Contractor shall furnish an extended warranty and service contract in effect until the expiration of the Correction Period.

6.14.4 Electric Service.

- **6.14.4.1** The Contractor shall provide temporary light and power; pay the charges for temporary electric service installation, and removal if required.
- **6.14.4.2** If the Project consists entirely of new construction, the Contractor shall pay the cost of energy consumed until Substantial Completion.
- **6.14.4.3** If the Project is a renovation of an existing building or structure, addition(s) to an existing building or structure, or any combination of new construction and renovation work that does not allow separate metering of utilities, the Owner shall pay the cost of energy consumed.

- **6.14.4.4** From the date of Substantial Completion, the Owner shall pay the cost of energy consumed for the occupied portions of the Project.
- **6.14.4.5** If the permanent electrical system is used during construction, the Contractor shall furnish an extended warranty and service contract in effect until the expiration of the Correction Period.

6.14.5 Hoisting Facilities.

- **6.14.5.1** The Contractor shall erect and maintain any hoisting equipment required for its Work.
- **6.14.5.2** If the electric service requirements of hoisting facilities differ from that available at the Site, the Contractor shall provide and pay for all necessary connections.
- **6.14.5.3** If a permanent elevator is identified in the Contract Documents to be used for hoisting materials or personnel during construction, the Contractor shall furnish an extended warranty and service contract in effect until the expiration of the Correction Period.

6.15 Progress Cleaning

- **6.15.1** The Contractor shall remove all waste materials, rubbish, and mud attributable to the Work to an appropriate disposal location at, or near, the Site.
- **6.15.2** The Contractor shall perform weekly broom cleaning of hard flooring surfaces in the area of the Work.
- **6.15.3** The Contractor shall remove, once each working day or as appropriate for the Project, all waste materials and rubbish from the disposal location at, or near, the Site.
- **6.15.4** The Contractor shall remove, as appropriate for the Project or as the A/E or Owner directs, any waste materials or rubbish from areas adjacent to the Project.
 - **6.15.4.1** The Contractor shall dispose of waste materials, rubbish, and construction debris in a lawful manner in approved recycling facilities or landfills.
- **6.15.5** If the Contractor fails to clean up during the progress of the Work, the Contracting Authority may clean up on behalf of the Contractor and at the Contractor's expense. If the Contractor fails to maintain the areas adjacent to the Project clean and free of waste materials and rubbish, the Contracting Authority may also direct the local jurisdiction responsible for the area to have the area cleaned to its satisfaction at the Contractor's expense.
 - **6.15.5.1** The Contracting Authority may deduct the cleaning costs from payments then or thereafter due the Contractor. If payments then or thereafter due the Contractor are not sufficient to cover those amounts, the Contractor shall immediately pay the amount of the insufficiency to the Owner.
- **6.15.6** The Contractor shall remove excavated material and spoil to a suitable off-site location approved by the Contracting Authority.
 - **6.15.6.1** If the Owner designates a location on its property for disposal or storage of clean topsoil and/or subsoil in the Contract Documents, the Contractor shall remove such materials to the designated location.

6.16 Use of Premises

- **6.16.1** The Contractor shall use corridors, stairs, and elevators as designated by the Contracting Authority. The Contractor shall exercise extreme care to not exceed the carrying capacity of elevators or damage the cab interior in any way.
- **6.16.2** Loitering or wandering through interior of buildings or exterior grounds outside the limits of the Work will not be permitted.
- **6.16.3** The Contractor shall confine its apparatus, materials, and the operations of its workers to the limits indicated by law, ordinances, permits and the directions of the A/E or Project Manager.
- **6.16.4** No signs or advertising of any kind will be permitted on or about the Site, except those appearing on trucks and trailers.

6.16.5 Site Logistics Plan.

6.16.5.1 The Contractor shall prepare a plan of the Site indicating how the Contractor intends to use the Site. The plan should illustrate, as an example, areas to be used for lay down of material and equipment; office and storage trailer locations; vehicular access gates with ingress and egress routes; locations of wheel wash and concrete truck wash out activities; and offloading and hoisting locations.

6.16.6 Smoking and Tobacco Products.

6.16.6.1 All State buildings are smoke free. Smoking will not be permitted in any indoor area. The ban on tobacco products will be observed in all indoor and outdoor areas and parking areas on all State-owned and leased property. The Contractor shall enforce these restrictions on any individual employed by the Contractor, or a Subcontractor.

6.17 Interruption of Existing Services

- **6.17.1** Whenever it becomes necessary to interrupt existing services in use by the Owner or its tenants, including but not limited to sewer, water, gas, and steam lines, electric, telephone, and cable service, the Contractor shall continue the associated Work on a non-stop 24-hour per day basis until that Work is completed and the service restored, or at an alternate time required by the Contracting Authority.
- **6.17.2** Before beginning that Work, the Contractor shall apply in writing to, and receive approval in writing from, the Owner, through the A/E, to establish a time when interruption of the service will cause a minimum of interference with the activities of the Owner and its tenants.

6.18 Explosives and Blasting

- **6.18.1** The Contractor shall not conduct blasting on, or bring explosives to, the Site without the prior written approval of the Contracting Authority, Owner, and other authorities with jurisdiction.
- **6.18.2** The Contractor shall perform all blasting, storing, and handling of explosives as required under Applicable Law.
 - **6.18.2.1** The Contractor shall carry appropriate liability insurance coverage, as required by the Contract Documents, for its blasting and explosives storage and handling operations. Immediately upon request, the Contractor shall deliver evidence of that insurance to the Contracting Authority.

6.19 Building Commissioning

- **6.19.1** If the Project scope includes building commissioning, the Contractor shall participate in the Commissioning Process, as prescribed in the Contract Documents.
- **6.19.2** The Contractor shall permit the A/E, or a third-party Commissioning Agent ("CxA") if applicable, access to commission performance based equipment, fixtures, and/or systems (e.g., HVAC, fire protection, smoke evacuation, fume hoods, emergency power, etc.), prior to Substantial Completion.
- **6.19.3** The A/E, or CxA if applicable, shall promptly notify, in writing, the Contractor of any deficiency identified during the Commissioning Process.
- **6.19.4** To facilitate the Commissioning Process, the Contractor shall submit 4 sets of Operation and Maintenance Manuals for dynamic and engineered systems to the A/E, and CxA if applicable, for approval. This submission shall occur within 30 days following approval of all related Contractor submittals required by the Contract Documents.

6.20 Action Submittals

- **6.20.1** <u>Submittal Description</u>. Shop Drawings, Product Data, Samples, and other submittals for the A/E's review and action shall be provided by the Contractor for any item required by the Contract Documents but not fully described in the Contract Documents, unless waived by the A/E, and include, but are not limited to:
 - **6.20.1.1** construction of the various parts, method of joinery, type of materials, grade, quality and thickness of materials, alloy of materials, profiles of all sections, reinforcement, method of hanging doors or installing windows, anchorage, and type and grade of finish;
 - **6.20.1.2** capacities, types of materials and performance charts that are pertinent to the materials, and performance charts that are pertinent to the equipment item; and
 - **6.20.1.3** wiring diagrams, control diagrams, schematic diagrams, working and erection dimensions, arrangement and specifications.
- **6.20.2** Form of Submittals. The Contractor shall provide a transmittal letter, review and stamp its approval, and transmit the submittals to the A/E in accordance with the submittal schedule established by the A/E and Contractor.
 - **6.20.2.1** The Contractor shall submit a minimum of 1 reproducible and 3 copies of Shop Drawings, and a minimum of 4 copies of any other submittal, except when using the State's web-based project management software.
 - **6.20.2.2** The data shown on the Shop Drawings shall be complete with respect to quantities, dimensions, specified performance and design criteria, materials, and similar data to communicate to the A/E the materials and equipment that the Contractor proposes to provide.

- **6.20.2.3** Each Sample shall be identified clearly as to materials, supplier, pertinent data as catalog numbers, the intended use, and other uses as the A/E may require enabling the A/E to review the submittal.
- **6.20.3** <u>Variation from Contract Documents</u>. If the submittals show variations from the requirements of the Contract Documents, the Contractor shall specifically and clearly identify the variations in its letter of transmittal.
 - **6.20.3.1** Variations that may affect the construction quality, cost or timeline shall be submitted by the A/E to the Contracting Authority for review, and if approved, shall be incorporated into the Work by Change Order.
 - **6.20.3.2** The Contractor shall not be relieved of responsibility for deviations from the Contract Documents by the A/E's approval of submittals.
 - **6.20.3.3** Submittals are not Contract Documents. In the event of conflicts between submittals and the Contract Documents, the Contract Documents take precedence and govern the Work.
- **6.20.4** Contractor's Submittal Review. The Contractor shall review and stamp "approved" all submittals before forwarding them to the A/E. If it is apparent to the A/E that the Contractor has not reviewed the submittals, or has conducted an incomplete review, the A/E may reject the submittals.
 - **6.20.4.1** The Contractor shall field verify conditions as necessary and make corrections of dimensions, locations of various items, encroachments of work of Separate Contractors, or variations from the requirements of the Contract Documents.
 - **6.20.4.2** If required by the Contract Documents or Applicable Law, the Contractor shall have Shop Drawings or other submittals prepared by Persons possessing expertise and experience in an appropriate trade or profession or by a registered architect, professional engineer, or other professional.
 - **6.20.4.3** By approving and submitting submittals, the Contractor represents that the Contractor has determined and verified materials, field measurements, and field construction criteria related to the associated Work, or shall do so, and has checked and coordinated the information contained within the submittals with the requirements of the Work and of the Contract Documents.
- **6.20.5** <u>A/E's Submittal Review</u>. The A/E shall review submittals for conformity with design intent within 14 days of receiving them or in accordance with the approved submittal schedule, or other period as mutually agreed by the A/E and Contractor. The A/E's review of submittals is to determine if the items covered by the submittals will, after installation and incorporation into the Work, conform to the Contract Documents and be compatible with the design concept of the Project as a functioning whole.
 - **6.20.5.1** The Contractor shall make corrections required by the A/E and resubmit the required number of corrected copies of submittals until approved, which resubmission shall be acted upon by the A/E within 14 days of receiving them, or other period mutually agreed by the A/E and Contractor.
 - **6.20.5.2** When resubmitting corrected submittals, the Contractor shall direct the A/E's attention to revisions made by noting revisions on the resubmittal.
 - **6.20.5.3** The Contractor shall pay all reasonable costs of the A/E, Owner, and Contracting Authority for attendant delay, interference, hindrance or disruption of the Project due to excessive resubmittals without fault of the A/E, the Owner, or Contracting Authority. Resubmittals in excess of 2 without fault of the A/E, Owner, or Contracting Authority may be determined excessive by the Contracting Authority.
 - **6.20.5.4** The A/E may hold Samples and other submittals used to coordinate finishes, colors, patterns, textures, or other characteristics until submittals for adjacent materials are available. The A/E shall issue a written notice to the Contractor stating that the submittal is being held, within 7 days of receiving it.
 - **6.20.5.5** If coordinating submittals are not received within the period required for action on previously received submittals that are held in accordance with **Section 6.20.5.4**, review of the previously received submittals may be delayed.
 - **6.20.5.6** The A/E's review shall not extend to means, methods, manners, techniques, sequences, or procedures of construction, or to safety precautions or incident programs.
 - **6.20.5.7** The review and approval of a separate item shall not indicate approval of the assembly in which the item functions.
- **6.20.6** Risk of Nonpayment. The Contractor shall not commence any portion of the Work requiring Shop Drawings, Product Data, Samples, or other submittals until the submittal has been approved by the A/E. If the Contractor starts Work before the A/E's final approval of the submittal, the Contractor does so at its own risk that payment may not be approved by the Contracting Authority or made by the Owner for the related Work.

- **6.20.7** Equipment Statement. Shop Drawings on equipment shall include the following written statement from the manufacturer of the equipment:
 - **6.20.7.1** "This equipment submitted for approval shall perform as specified when installed in the arrangement shown on this drawing and in the Contract Documents and in conjunction with all other accessories as flues, breechings, piping, controls, and equipment not furnished by this manufacturer, but required as an accessory or supplement to this equipment, providing that the accessory or supplementary items perform as specified and are installed as shown in the Contract Documents."
 - .1 The Contractor will be deemed to have included the above statement as required even if the associated Shop Drawing does not actually contain the statement.
 - **6.20.7.2** This equipment statement shall not be required for Samples, Product Data, and other standard submittals that are not created specifically for this Project.
- **6.20.8** <u>Domestic Steel Certifications</u>. The Contractor shall include the following written certifications on the front cover or initial sheet of each structural steel fabrication Shop Drawing, signed and dated prior to fabrication:
 - **6.20.8.1** "Steel Fabricator Certification: The steel fabricator identified below certifies that for this project all load-bearing structural steel has been fabricated or produced, to the best of its knowledge, only from steel made in the United States in accordance with Ohio Revised Code Section 153.011. Further, the steel fabricator hereby certifies that it has read and understands that a monetary penalty for violations may be imposed under the authority of Ohio Revised Code Section 153.99." This certification shall be followed by the name of the fabrication company, name of the company official signing the certification, the signature of that company official, and the date of that signature.
 - 1 The Contractor will be deemed to have included the above certification as required even if the associated Shop Drawing does not actually contain the certification.
 - **6.20.8.2** "Contractor Certification: The contractor identified below certifies that it has required as a condition of purchase, that for this project all load-bearing structural steel shall be fabricated and produced using, to the best of its knowledge, only steel made in the United States in accordance with Ohio Revised Code Section 153.011. Further, the contractor hereby certifies that it has read and understands that a monetary penalty for violations may be imposed under the authority of Ohio Revised Code Section 153.99." This certification shall be followed by the name of the Contractor company, name of the company official signing the certification, the signature of that company official, and the date of that signature.
 - .1 The Contractor will be deemed to have included the above certification as required even if the associated Shop Drawing does not actually contain the certification.

6.21 Warranty

- **6.21.1** The Contractor warrants to the Contracting Authority and Owner that all materials and equipment furnished under the Contract shall be new and of good quality unless otherwise required or permitted by the Contract Documents, that the Work shall be free from defects not inherent in the quality required or permitted, and that the Work shall conform to the requirements of the Contract Documents. Work not conforming to those requirements, including Substitutions not properly approved and authorized, may be considered Defective Work. If required by the A/E, the Contractor shall furnish satisfactory evidence as to the kind and quality of materials and equipment.
 - **6.21.1.1** If the Contractor or a Subcontractor recommends a particular product, material, system, or item of equipment for incorporation into the Project and the Owner accepts that recommendation, the above warranty includes a warranty from the Contractor to the Owner that the recommended product, material, system, or item of equipment is fit and appropriate for the associated purpose.

6.22 Uncovering the Work

- **6.22.1** If the Contractor covers Work contrary to the requirements of the Contract Documents or contrary to the written request of the Contracting Authority or A/E, the Contractor shall, if the Contracting Authority or A/E requests in writing, uncover that Work for observation, correct it if not in conformity with the Contract Documents, and recover it at the Contractor's expense without adjustment of the Contract Times.
- **6.22.2** If the Contractor covers Work in accordance with the Contract Documents and not contrary to a request from the A/E or Contracting Authority for an opportunity to observe the Work prior to covering, the Contractor shall, if the A/E requests in writing, uncover that Work.
 - **6.22.2.1** If the uncovered Work is Defective Work, the Contractor shall pay the costs of uncovering, correcting, and recovering the Work and shall not be entitled to an adjustment of the Contract Times.

6.22.2.2 If the uncovered Work is not Defective Work and the Contractor believes that it is entitled to an adjustment of the Contract Sum or Contract Times, or both, on account of the uncovering and recovering of the Work, the Contractor may request a Change Order by giving written notice under **Section 7.3.2** within 7 days after the Contracting Authority or A/E observes the uncovered Work.

6.23 Correction of the Work

6.23.1 Before Substantial Completion.

- **6.23.1.1** If the Contractor provides Defective Work or fails or neglects to perform the Work in accordance with the Construction Progress Schedule, the Contracting Authority or A/E may issue a written notice to the Contractor and Contractor's Surety directing the Contractor to correct the Defective Work or recover schedule deficiencies. Unless otherwise specified in that written notice, the Contractor shall begin to correct the Defective Work and recover the schedule deficiencies within no more than three days after the Contracting Authority issues the written notice ("72-Hour Notice").
- **6.23.1.2** If the Contractor fails to promptly commence and diligently pursue correction of Defective Work or recovery of schedule deficiencies required under **Section 6.23.1.1**, the Owner may correct the Defective Work or take action to recover schedule deficiencies without giving further notice to the Contractor or Contractor's Surety.

6.23.2 After Substantial Completion.

- **6.23.2.1** In addition to the Contractor's other obligations under the Contract Documents, if any of the Work is found to be Defective Work after Substantial Completion, the Contractor shall correct it promptly after receipt of written notice from the A/E, Contracting Authority, or Owner to do so, unless the Contracting Authority and Owner have previously acknowledged and accepted the Defective Work in writing. The A/E, Contracting Authority, or Owner may send a copy of the written notice to the Contractor's Surety, but are not obligated to do so.
- **6.23.2.2** <u>During the Correction Period</u>. If the Contracting Authority or Owner issues a notice under **Section 6.23.2.1** during the Correction Period, the Owner may correct the Defective Work itself without giving further notice to the Contractor or Contractor's Surety if the Contractor fails to **(1)** notify the Owner in writing of the Contractor's intent to correct the Defective Work within 7 days after the Contracting Authority or Owner issues the notice and **(2)** thereafter promptly commence and diligently pursue correction of Defective Work.

6.23.2.3 The Correction Period:

- .1 commences on the date of Substantial Completion of the Work or a designated portion of the Work which the Contracting Authority and Owner have agreed to take Partial Occupancy;
- .2 relates only to the Contractor's specific obligation and opportunity to correct the Work during the Correction Period;
- .3 does not establish a period of limitation with respect to any of the Contractor's other obligations under the Contract Documents;
- .4 has no relationship to the time within which the State or Owner may seek to enforce the Contract;
- .5 does not establish a period of limitation within respect to the commencement of litigation to establish the Contractor's liability under the Contract or otherwise; and
- .6 shall not be extended by corrective Work performed by the Contractor under this Section 6.23.2.
- **6.23.2.4** <u>After the Correction Period</u>. If the Owner issues notice under **Section 6.23.2.1** after expiration of the Correction Period, the Owner may correct the Defective Work without giving further notice to the Contractor or Contractor's Surety if the Contractor fails to **(1)** notify the Owner in writing of the Contractor's intent to correct the Defective Work within 14 days after the Owner issues the notice and **(2)** thereafter promptly commence and diligently pursue correction of Defective Work.

6.23.3 Emergency Correction of Defective Work.

6.23.3.1 Notwithstanding any other provision of the Contract to the contrary, if in the Contracting Authority or Owner's opinion the Defective Work presents a threat of imminent harm or danger to people, property, or the environment, the Contracting Authority or Owner may order the Contractor to immediately correct Defective Work or the Owner may correct the Defective Work itself without any prior notice to the Contractor or Contractor's Surety.

6.23.4 Responsibility for Costs of Correction.

6.23.4.1 The Contractor shall pay all of the costs and damages associated with the correction of Defective Work and the recovery of schedule deficiencies under this **Section 6.23**. Those costs and damages may include, but are not limited to, the related fees and charges of contractors, engineers, architects, attorneys, and other professionals; and

the cost of correcting or replacing adjacent work. The Contracting Authority may deduct those costs and damages from payments then or thereafter due the Contractor. If payments then or thereafter due the Contractor are not sufficient to cover those amounts, the Contractor shall immediately pay the amount of the insufficiency to the Owner.

6.24 Acceptance of Defective Work

- **6.24.1** The Owner may accept any Defective Work instead of requiring its removal or correction, in which case the Contract Sum must be equitably reduced as described under **Article 7**.
 - **6.24.1.1** The Owner may only accept Defective Work though a deduct Change Order that makes explicit reference to this **Section 6.24**.
- **6.24.2** None of the following will constitute **(1)** acceptance of Defective Work, **(2)** a release of the Contractor's obligation to perform the Work in accordance with the Contract, or **(3)** a waiver of any rights set forth in the Contract or otherwise provided by Applicable Law:
 - **6.24.2.1** observations or inspections by the Owner, Contracting Authority, or A/E;
 - **6.24.2.2** the making of any payment;
 - **6.24.2.3** Substantial Completion or the issuance of a Certificate of Substantial Completion;
 - **6.24.2.4** Partial Occupancy and the Owner's use or occupancy of the Work or any part of it;
 - **6.24.2.5** Contract Completion or the issuance of a partial or final Certificate of Contract Completion;
 - **6.24.2.6** any review or approval of a submittal;
 - **6.24.2.7** any inspection, test, or approval by other Persons; or
 - **6.24.2.8** any correction of Defective Work by the Owner.

6.25 Project Document Maintenance and Submittal

6.25.1 During Construction.

- **6.25.1.1** The Contractor shall maintain in good order at a secure location on the Site:
 - .1 a complete copy of all Contract Documents; Shop Drawings, Product Data, Samples and similar required submittals; manufacturer operating and maintenance instructions; certificates; warranties; RFIs and responses thereto; and other Project-related documents, all marked currently and accurately to record field changes and selections made during construction and to show actual installation where installation varies from Work as originally shown, including the exact location and depth of underground utility lines; and
 - .2 a set of Drawings and Specifications, approved in accordance with **Section 5.2.1.1**, and the records required by **Section 6.2.17**.
- **6.25.1.2** Before submitting each Contractor Payment Request, the Contractor shall record all changes on the Contract Documents, neatly in a contrasting color, noting new information not shown on the original Contract Documents. Failure to record all changes may cause payment to be withheld or delayed by the Contracting Authority.
- **6.25.1.3** The Contractor shall keep a record of changes made to the Specifications, noting particularly any approved variation from manufacturer's installation instructions and recommendations.
- **6.25.1.4** If the Contractor uses Shop Drawings to indicate as-built conditions, the Contractor shall cross-reference the Shop Drawing sheet numbers to the corresponding sheet numbers on the Contract Documents. The Contractor shall note related numbers where applicable.
- **6.25.1.5** The Contractor shall at all times permit access to the documents described in this **Section 6.25.1** to authorized representatives of the State, local authorities having jurisdiction, Contracting Authority, Owner, and A/E.

6.25.2 Before Contract Completion.

- **6.25.2.1** The Contractor, as a condition precedent to execution of the Certificate of Contract Completion and final payment, shall organize the As-Built Documents into manageable sets, bind the sets with durable paper cover sheets, and deliver the As-Built Documents to the A/E.
- **6.25.2.2** The Contractor's As-Built Documents submission shall include, but is not limited to:
 - .1 Certificate of Occupancy;
 - .2 inspection certificates for pressure piping, elevator, boiler, electrical, plumbing or piping purification, etc.;

- .3 Letter of Approval from the local fire authority or State Fire Marshal for the fire suppression system;
- .4 Operation and Maintenance Manuals, organized into suitable sets of manageable size. Indexed data bound in individual binders, with pocket folders for folded sheet information and appropriate identification marked on the front and the spine of each binder;
- .5 neatly and accurately marked sets of As-Built Documents, and other Contract Documents reflecting the actual construction of the Project;
- **.6** detailed Drawings reflecting the exact location of any concealed utilities, mechanical or electrical systems, and components;
- .7 assignment to the Owner of all warranties and guarantees, including the most-recent address and telephone number of any Subcontractors or manufacturers;
- **.8** an affidavit to certify that all Subcontractors have been paid in full for all Work performed or materials furnished for the Project;
- .9 final certified payroll reports; and
- **.10** an affidavit to certify that the Contractor and each of its Subcontractors, regardless of tier, have complied with all requirements of ORC Chapter 4115.
- **6.25.2.3** By submitting the As-Built Documents to the A/E, the Contractor certifies that its As-Built Documents are complete, correct, and accurate.

6.25.3 Record Documents.

- **6.25.3.1** The A/E shall revise the original Contract Documents and related electronic files with the information contained on the As-Built Documents. The A/E shall label the revised original Contract Documents and related electronic files as "Record Documents" and reflect the date of the A/E's incorporation of the As-Built Documents.
- **6.25.3.2** The Owner may thereafter use the Record Documents for any purpose relating to the Project including, but not limited to, additions to or completion of the Project.

6.26 Final Cleaning

- **6.26.1** Before requesting the Substantial Completion inspection of the Work, the Contractor shall clean the Site, remove waste materials and rubbish attributable to the Project, and restore the property to its original condition so that upon Substantial Completion, the premises are ready for occupancy by the Owner.
- **6.26.2** If the Contractor performs any Work after final cleaning, the Contractor shall clean the affected area as provided above so that upon Substantial Completion, the premises are ready for occupancy by the Owner.
- **6.26.3** Final cleaning shall be done to the reasonable satisfaction of the A/E and Contracting Authority.

6.27 Substantial Completion

6.27.1 Contractor's Punch List.

- **6.27.1.1** When the Contractor considers the Work, or a designated portion thereof, Substantially Complete the Contractor shall inspect the Work and prepare a list of Defective Work and incomplete or unacceptable Work ("Contractor's Punch List"). The Contractor shall list all items of Work not in compliance with the Contract Documents, including items the Contractor is requesting to be deferred.
 - .1 The Contractor shall proceed to correct all items listed on the Contractor's Punch List and certify that the incomplete items listed on the Contractor's Punch List are to its knowledge an accurate and complete list by signing the Contractor's Punch List.
 - .2 The Contractor's failure to include an item on the Contractor's Punch List shall not alter the Contractor's responsibility to complete the Work in accordance with the Contract Documents.
 - .3 The Contractor shall submit the signed Contractor's Punch List to the A/E, together with a request for the Substantial Completion inspection of the Work.

6.27.2 Substantial Completion Inspection.

- **6.27.2.1** Within 3 business days after receipt of the request for the Substantial Completion inspection of the Work, the A/E shall notify the Contractor of acceptance or rejection of the request, stating reasons for any rejection.
 - .1 Within 7 days after its acceptance of the Contractor's request, the A/E shall conduct the Substantial Completion inspection to determine whether the Work, or designated portion, is in conformity with the Contract Documents and Substantially Complete. The A/E shall notify the Contractor, Contracting Authority, and Owner of the scheduled time of the inspection.

- .2 If the A/E determines that the Work is Substantially Complete, within 3 business days after the Substantial Completion inspection, the A/E shall prepare a Certificate of Substantial Completion that shall establish the date of Substantial Completion and include a list of Defective, incomplete, or unacceptable Work ("A/E's Punch List"). The A/E's Punch List shall include (1) the items on the Contractor's Punch List that are not yet completed or corrected as of the date of the Substantial Completion inspection, and (2) comments from the Contracting Authority and Owner.
- .3 The A/E shall submit the Certificate of Substantial Completion to the Contracting Authority, Owner, and Contractor for their written acceptance. Upon their acceptance and consent of the Contractor's Surety, and subject to the Owner's right to withhold payment, the Owner shall release retainage as described under Section 9.7.2.
- .4 The A/E's failure to include an item on the A/E's Punch List shall not alter the Contractor's responsibility to complete the Work in accordance with the Contract Documents.
- .5 If the A/E accepts the request and subsequently determines that the Work is not Substantially Complete, the A/E may request compensation for expenses related to excessive Punch List activities. The Contracting Authority may deduct that additional compensation to the A/E from payments then or thereafter due the Contractor. If payments then or thereafter due the Contractor are not sufficient to cover those amounts, the Contractor shall immediately pay the amount of the insufficiency to the Owner.

6.27.3 Completion of Punch List Items.

- **6.27.3.1** Within 30 days after the date of Substantial Completion and before the date of Final Contract Completion, the Contractor shall complete all items on the A/E's Punch List. After completing all items on the A/E's Punch List, the Contractor shall provide a written request for Final Inspection of the Work to the A/E.
 - .1 If Work on the A/E's Punch List cannot be timely completed, the Contractor shall justify in writing to the reasonable satisfaction of the Contracting Authority and A/E, the reasons the items cannot be completed, and the Contractor may propose, for the Contracting Authority and A/E's approval, a time when the Contractor shall complete those items.
 - .2 Within 3 business days after receipt of the request for the Final Inspection of the Work, the A/E shall complete a Final Inspection of the Work for compliance with the Contract Documents.
 - .3 If multiple inspections of items on the A/E's Punch List are required due to the Contractor's failure to properly and timely complete them, the Contractor shall pay any additional costs incurred by the A/E, Owner, and Contracting Authority resulting from any attendant delay. The Contracting Authority may deduct those additional costs from payments then or thereafter due the Contractor. If payments then or thereafter due the Contractor are not sufficient to cover those amounts, the Contractor shall immediately pay the amount of the insufficiency to the Owner.

6.28 Partial Occupancy

- **6.28.1** The Owner may occupy or use a portion of the Project prior to Contract Completion if:
 - **6.28.1.1** the building authority with jurisdiction over the Project issues a partial certificate of occupancy for the portion of the Project the Owner intends to occupy;
 - **6.28.1.2** the A/E with the Owner's assistance has provided written notice of the Partial Occupancy to the insurers providing property insurance for the Project; and
 - **6.28.1.3** the Contracting Authority has received notice of the Partial Occupancy from the A/E and has consented to it.
- **6.28.2** Before the Owner commences Partial Occupancy, the Owner, Contracting Authority, A/E, and Contractor shall proceed as described under **Section 6.27** for the area designated for Partial Occupancy.
- **6.28.3** The Contractor shall be relieved of the obligation to maintain the area accepted for Partial Occupancy, but shall remain obligated to complete and correct the Work and to carry the insurance required by the Contract Documents during performance of any such Work.

6.29 Demonstration and Training, Operating Appurtenances

6.29.1 The Contractor, as a condition precedent to execution of the Certificate of Contract Completion and final payment, shall perform demonstration and training of the Owner's maintenance personnel as specified in the Contract Documents.

- **6.29.2** The Contractor, as a condition precedent to execution of the Certificate of Contract Completion and final payment, shall organize and submit operating appurtenances and loose items related to operation and maintenance of the completed Project to the Owner, including, but not limited to:
 - **6.29.2.1** keys to door and window hardware, panels, and other devices not directly provided to the Owner from the manufacturer:
 - **6.29.2.2** operating handles, levers, cranks, specialized wrenches or drivers, remote controls, and similar items; and **6.29.2.3** extra materials (e.g., attic stock).

6.30 Contract Completion

6.30.1 Partial Contract Completion.

- **6.30.1.1** When items of Work cannot be completed until a subsequent date, the A/E shall prepare a partial Certificate of Contract Completion that shall include a detailed list of the deferred Work and the date(s) by which the Contractor will complete that Work.
- **6.30.1.2** The A/E shall submit the partial Certificate of Contract Completion to the Contracting Authority, Owner, and Contractor for their written acceptance. Upon their acceptance of the partial Certificate of Contract Completion and consent of the Contractor's Surety, the Contracting Authority may release payment to the Contractor, as determined in the sole discretion of the Contracting Authority.

6.30.2 Final Contract Completion.

- **6.30.2.1** When all items on the A/E's Punch List have been completed to the satisfaction of the A/E, all requirements of the Contract Documents have been completed, and the provisions of **Sections 6.25** through **6.29** have been fulfilled, the A/E shall prepare and recommend execution of a final Certificate of Contract Completion.
- **6.30.2.2** The date that the Contracting Authority executes the final Certificate of Contract Completion is the date of Contract Completion.

ARTICLE 7 - MODIFICATIONS

7.1 General

7.1.1 Changes in the Work.

- **7.1.1.1** The Contracting Authority may order changes in the Work without invalidating the Contract. Subject to the limitations stated in this **Article 7** and elsewhere in the Contract Documents, a change in the Work may be accomplished by a Change Order, Change Directive, or order for a minor change in the Work.
 - .1 The Contractor shall proportionately increase the amount of the Bond whenever the Contract Sum is increased.
 - .2 If notice of any change affecting the Contract is required by the provision of any Bond, notice is the Contractor's responsibility, and the amount of each applicable Bond shall be adjusted accordingly.
- **7.1.1.2** The Contractor shall not proceed with any change in the Work without the Contracting Authority's prior written authorization except as provided under **Sections 1.10** and **7.5**.
- **7.1.1.3** Except as provided in **Section 1.10**, the Contractor's failure to obtain prior written authorization for a change in the Work constitutes a waiver by the Contractor of an adjustment to the Contract Sum or Contract Times, or both, for the related Work.
- **7.1.1.4** The Contractor shall perform all changes in the Work under the applicable provisions of the Contract Documents, and the Contractor shall proceed promptly with the change unless otherwise provided in the Change Order, Change Directive, or order for a minor change in the Work

7.1.2 Paperwork Consolidation.

- **7.1.2.1** Related Modifications, with the same or similar justification (e.g., Owner Request or field resolution), may be consolidated into the same Change Order.
- **7.1.2.2** Add and deduct Modifications, with the same or similar justification, may be included on the same Change Order.
- **7.1.2.3** Modifications resulting from errors or omissions shall not be combined with other modifications for which the A/E will receive a fee.

7.1.3 Modification Numbering.

- 7.1.3.1 The A/E shall assign a number to each Modification, which shall uniquely identify it.
- **7.1.3.2** The A/E shall not duplicate or reuse any number throughout the Project or reuse assigned numbers for Proposal Requests that are initiated but cancelled in process.
- **7.1.3.3** The number for each Change Order shall be coordinated with any associated Proposal Request or Change Directive.

7.1.4 Modification Log.

- **7.1.4.1** The A/E shall create and maintain a Modification Log for the Project, which shall contain the following minimum information:
 - .1 number of the Modification;
 - .2 a brief description of the Modification;
 - .3 cost of the Modification;
 - .4 schedule impact of the Modification; and
 - .5 dates sent to, and received from, the parties.

7.1.5 Reconciliation of Unit Price Items.

- **7.1.5.1** The Contracting Authority may increase, decrease, or delete entirely the scheduled quantities of Work to be performed and materials to be furnished by Change Order.
- **7.1.5.2** The A/E shall issue a Change Order to reconcile the difference between the scheduled and actual quantities of Work performed and materials furnished.
- **7.1.5.3** If the actual quantity of a Unit Price item differs from the scheduled quantity by 20 percent or more, so that application of the Unit Price to the quantities of Work proposed would create an undue hardship on either the Owner or Contractor, the A/E shall issue a Proposal Request and subsequent Change Order to adjust the Unit Price.
 - .1 If a Unit Price is adjusted as described under **Section 7.1.5.3**, the new Unit Price will only apply to the units of Work performed that are (1) less than the 20 percent threshold if the Unit Price is changed on account of an over-estimation of the scheduled quantity of a Unit Price item involved in the Work or (2) in excess of the 20 percent threshold if the Unit Price is changed on account of an under-estimation of the scheduled quantity of a Unit Price item involved in the Work.
- **7.1.5.4** If the actual quantity of a Unit Price item exceeds the scheduled quantity by 20 percent or more, the Contractor shall immediately notify the A/E, who shall issue a Change Directive and subsequent Change Order to authorize an adjustment in the scheduled quantity.

7.2 Change Order Procedure

- **7.2.1** A Change Order is a written instrument prepared by the A/E and executed by the Contracting Authority and Contractor, stating their agreement upon all of the following:
 - **7.2.1.1** a change in the Work;
 - 7.2.1.2 the amount of the adjustment of the Contract Sum, if any; and
 - **7.2.1.3** the extent of the adjustment of the Contract Times, if any.
- **7.2.2** Except with the Contracting Authority's written consent as explicitly provided under **Section 7.4.8**, the Contractor is not entitled to reserve any rights or take other similar action with respect to a Change Order if the effect or intent of the reservation or action would be to accommodate a further adjustment of the Contract Sum or Contract Times, or both, after the Contractor signs the Change Order. By signing a Change Order, the Contractor irrevocably certifies that the elements of a Change Order described in **Section 7.2.1** are completely satisfied, and waives all rights, if any, to seek further adjustment of the Contract Sum or Contract Times, or both, at a later date with respect to the associated change in the Work including without limitation on account of the "cumulative impact" of the associated change in the Work in combination with one or more other changes in the Work.
- **7.2.3** The A/E shall prepare each Change Order form, attach the supporting documentation, and issue the Change Order to the Contractor for signature.
- **7.2.4** If the Contractor is in agreement with the Change Order under **Section 7.2.1**, the Contractor shall sign and return the Change Order to the A/E within 3 days after receiving it.

- **7.2.5** When the A/E receives the Change Order signed by the Contractor, the A/E will recommend approval by signing the form and transmitting the Change Order and the revised Change Order Log to the Owner.
- **7.2.6** When the Owner receives the Change Order, the Owner may sign the form accepting the Change Order, attach certification of funding, and transmit the Change Order to the Contracting Authority; or, if the Owner does not accept the Change Order, the Owner will reject and return it to the A/E.
- **7.2.7** When the Contracting Authority receives the Change Order, the Contracting Authority may sign the form approving the Change Order, and transmit the fully executed Change Order to all signers; or, if the Contracting Authority does not accept the Change Order, the Contracting Authority will reject and return it to the A/E.
- **7.2.8** When the Change Order is signed by the Contractor, A/E, Owner, and Contracting Authority, the fully executed Change Order modifies the Contract Documents and authorizes and directs the Contractor to proceed, and the Contractor shall promptly proceed with the associated change in the Work.

7.3 Initiation of Change Orders

7.3.1 Proposal Request.

- **7.3.1.1** The A/E shall prepare and issue a Proposal Request to the Contractor to obtain the Contractor's Proposal for the adjustment of the Contract Sum or the Contract Times, or both, associated with a contemplated Modification.
 - .1 In any Proposal for an adjustment of the Contract Sum, the Contractor shall specifically identify the items set forth in **Section 7.7**.
 - .2 In any Proposal for an adjustment of the Contract Times, the Contractor shall specifically identify the items set forth in **Section 7.8**.
 - .3 The Contractor's cost of preparing and providing Proposals is included in the Contract Sum.
- **7.3.1.2** The Contractor shall respond with a Proposal to the A/E and Contracting Authority within 14 days after receiving the Proposal Request. The allowable time for the Contractor's response may be extended by written agreement of the Contractor and A/E.
- **7.3.1.3** The Contractor shall hold the Proposal valid and open for acceptance for at least 45 days. The acceptance period may be adjusted by mutual consent of the Contractor and Contracting Authority. The time limits described under this **Section 7.3.1.3** apply only to Proposals submitted in response to a Proposal Request.
- **7.3.1.4** A Proposal may be accepted by the Contracting Authority only through a Change Order. A Proposal Request does not authorize the Contractor to proceed with a change in the Work.
- **7.3.1.5** If the Contractor does not timely submit a Proposal within the time required in **Section 7.3.1.2**, the Contractor waives its right to an adjustment to the Contract Sum or Contract Times, or both, associated with the contemplated change in the Work.

7.3.2 Request for Change Order.

7.3.2.1 The Contractor may initiate a change in the Work by submitting written notice to the A/E accompanied by a Proposal meeting the requirements of **Section 7.3.1**.

7.4 Change Directives

- **7.4.1** A Change Directive is a written order prepared by the A/E and executed by the Contracting Authority directing a change in the Work and may, if necessary:
 - 7.4.1.1 state a proposed basis for adjustment, if any, in the Contract Sum or Contract Times, or both; or
 - **7.4.1.2** limit the scope of the change in the Work on a time and materials basis, not to exceed a fixed adjustment of the Contract Sum.
- **7.4.2** If a change in the Work must start immediately to avoid an imminent impact to the schedule of the Project, the A/E may prepare a Change Directive for the Contracting Authority's and the Owner's signatures pursuant to **Section 7.4.1**, authorizing the Contractor to proceed.
- **7.4.3** A Change Directive shall be used to direct a change in the Work in the absence of total agreement on the terms of a Change Order.
 - **7.4.3.1** For the purposes of clarity, the Contract refers to a Change Directive as if it is only to be used in the absence of total agreement on the terms of a Change Order concerning the associated change of the Work. A Change Directive may also be used in the absence of agreement as to whether the subject of the Change Directive actually constitutes a change in the Work; such as the situation described under **Section 7.5.3**.

- 7.4.4 Upon receipt of a Change Directive, the Contractor shall promptly proceed with the change in the Work involved.
- **7.4.5** The Contractor may sign the Change Directive to accept the proposed basis for adjustment, if any, of the Contract Sum or Contract Times, or both. Thereafter, the A/E shall prepare and the A/E, Contracting Authority, Owner, and Contractor shall promptly execute an associated Change Order as described under **Section 7.2**.
- **7.4.6** Within 14 days after receiving the Change Directive, the Contractor shall respond with a Proposal meeting the requirements of **Section 7.3.1** to the A/E and Contracting Authority for adjustment of the Contract Sum or Contract Times, or both, on account of the change, unless the Change Directive is performed on a time and materials basis under **Section 7.4.1.2**. If the Change Directive is performed on a time and materials basis, the Contractor shall submit its Proposal within 7 days after completing the Work.
 - **7.4.6.1** The Proposal for the adjustment of the Contract Sum, if any, shall include: **(1)** written documentation as described under **Section 7.7**; and **(2)** a written statement from the Contractor that the proposed adjustment is the entire adjustment in the Contract Sum associated with the change.
 - **7.4.6.2** The Proposal for the change in the Contract Times, if any, shall include: **(1)** written documentation as described under **Section 7.8**; and **(2)** a written statement from the Contractor that the proposed adjustment is the entire adjustment of the Contract Times associated with the change.
- **7.4.7** If the Contractor does not respond to a Change Directive as required under **Section 7.4.5** or **Section 7.4.6**, the Contracting Authority shall determine the adjustments, if any, of the Contract Sum and Contract Times. If the Contractor does not agree with the Contracting Authority's determination, the Contractor shall initiate a Claim under **Article 8** within 10 days of the date that the Contracting Authority issues its determination, and the Contractor's failure to do so shall constitute an irrevocable waiver of the Claim.
- **7.4.8** Pending final determination of the total adjustment of the Contract Times on account of a Change Directive, the period of time not in dispute for that change in the Work may be included in the Construction Progress Schedule accompanied by a Change Order indicating the parties' agreement with part or all of the time adjustment.
- **7.4.9** If the Contracting Authority, Owner, and Contractor agree on the adjustments of the Contract Sum and Contract Times associated with a Change Directive, the A/E shall prepare an appropriate Change Order within 7 days after receiving the Contractor's Proposal. The A/E, Contracting Authority, Owner, and Contractor shall promptly sign the Change Order as described under **Section 7.2**.
- **7.4.10** If the Contracting Authority, Owner, and Contractor do not agree on the adjustments of the Contract Sum and Contract Times associated with a Change Directive within 60 days after the Change Directive is issued, the Contracting Authority shall determine the adjustments, if any, of the Contract Sum and Contract Times. If the Contractor does not agree with the Contracting Authority's determination, the Contractor shall initiate a Claim under **Article 8** within 10 days of the date that the Contracting Authority issues its determination, and the Contractor's failure to do so shall constitute an irrevocable waiver of the Claim.

7.5 Minor Changes in the Work

- **7.5.1** The A/E may order minor changes in the Work not involving adjustment of the Contract Sum or extension of the Contract Times and not inconsistent with the intent of the Contract Documents. Those changes shall be effected by written order issued to the Contractor.
- **7.5.2** The Contractor shall promptly carry out each order for a minor change in the Work if the Contractor agrees that the order does not involve adjustment of the Contract Sum or Contract Times, or both.
- **7.5.3** If the Contractor reasonably believes that it would be entitled to an adjustment of the Contract Sum or Contract Times, or both, on account of an order for a minor change in the Work, the Contractor, within 3 business days after receiving the order, shall give the Contracting Authority and A/E written notice of the Contractor's position, and not proceed with the subject Work without first receiving a Change Directive or Change Order related to it.
- **7.5.4** The Contractor waives its right to an adjustment of the Contract Sum or Contract Times on account of an order for a minor change in the Work by:
 - **7.5.4.1** starting the Work that is the subject of the order for a minor change in the Work; or
 - **7.5.4.2** failing to give the notice described under **Section 7.5.3** within 3 business days after receiving the order for a minor change in the Work.

7.6 Differing Site Conditions

- **7.6.1** If the Contractor encounters a Differing Site Condition, the Contractor shall stop Work on that Differing Site Condition and give immediate written notice of the condition to the A/E and Contracting Authority.
 - **7.6.1.1** The Contractor's failure to give notice of the Differing Site Condition as required under this **Section 7.6.1** shall constitute an irrevocable waiver of any associated Claim.
 - **7.6.1.2** The written notice of a Differing Site Condition under this **Section 7.6.1** shall be required before the notice of Claim under **Article 8**.
- **7.6.2** Promptly after receiving notice from the Contractor under **Section 7.6.1**, the A/E shall investigate to determine whether the Contractor has encountered a Differing Site Condition. The A/E shall give written notice of its determination to the Contracting Authority and Contractor within 10 days after completing the investigation.
 - **7.6.2.1** If the A/E determines that the Contractor has encountered a Differing Site Condition and the Contracting Authority agrees with the A/E's determination, the A/E shall process an appropriate Change Order.
 - **7.6.2.2** If the A/E determines that the Contractor has encountered a Differing Site Condition but the Contracting Authority disagrees with the A/E's determination, the A/E shall process an appropriate Change Directive through which the Contracting Authority may convey its disagreement with the A/E's determination.
 - **7.6.2.3** If the A/E determines that the Contractor has not encountered a Differing Site Condition and the Contractor does not agree with that determination, the Contractor must initiate a Claim under **Article 8** within 10 days of the date that the A/E issues its determination.

7.7 Change Order Cost or Credit Determination

7.7.1 General.

- **7.7.1.1** The maximum cost or credit resulting from a change in the Work shall be determined as described below.
 - .1 Proposals shall include the information required by **Section 7.7.1.4**.
 - .2 A Unit Price Proposal shall only be valid when incorporated into the Contract by Change Order.
 - .3 The maximum cost or credit includes all compensation for impact costs. Additional costs for impacts shall not be allowed.
- **7.7.1.2** The Contractor shall not assign any portion of the Work to another Person whereby the Contractor would benefit directly or indirectly from the double application of charges for overhead or profit.
- **7.7.1.3** The Contracting Authority may require notarized invoices for material costs and may audit the records of the Contractor and Subcontractors.
- **7.7.1.4** For each change in the Work, the Contractor shall furnish a detailed Proposal itemized on the **Proposal Worksheet Summary Form (Contractor)** published by the Ohio Facilities Construction Commission through which the Contractor shall document the related changes in the Contract Sum as described under **Section 7.7.2**. Any Subcontractor pricing shall be itemized on the appropriate **Proposal Worksheet Summary Form**.
- **7.7.1.5 Section 7.7.2** establishes the exclusive and maximum amount that the Owner shall pay for any Change Order, including, but not limited to, all amounts for interference with, delay, hindrance, disruption, or impact of the Work ("Pricing Criteria"). These Pricing Criteria also govern the value of deduct Change Orders and the Contractor's entitlement to additional compensation or damages through the Claims and dispute resolution processes on account of changes in the Work. In order to expedite the review and approval process, Proposals shall be prepared in the categories and order listed in **Section 7.7.2**.

7.7.2 Pricing Criteria.

- **7.7.2.1** Contractor Personnel Costs: The Contractor's on-Site management (including supervision and administrative personnel) not subject to prevailing wage under ORC Chapter 4115. These costs will be calculated on an hourly basis according to the rates acceptable to the Contracting Authority.
 - 1 In no event will the Contractor be entitled to an increase in the Contract Sum on account of Contractor Personnel Costs unless the Contractor actually incurs additional Contractor Personnel Costs solely on account of the associated change in the Work.
 - .2 Under no conditions will the increase under this **Section 7.7.2.1** exceed those additional Contractor Personnel Costs the Contractor actually incurs.
- **7.7.2.2** <u>Labor</u>: Field labor directly involved in the Work based upon the actual rate of pay to the worker. If the Project is subject to payment of prevailing wage rates, field labor shall be paid according to the relevant

classification of labor as established in the applicable prevailing wage determination for the Project locality, as determined by the Ohio Department of Commerce, Wage and Hour Bureau.

- .1 In no event will the Contractor be entitled to an increase in the Contract Sum on account of labor costs unless the Contractor actually incurs additional labor costs solely on account of the associated change in the Work.
- .2 Under no conditions will the increase under this **Section 7.7.2.2** exceed those additional labor costs the Contractor actually incurs.
- .3 The cost for supervision above the level of working forepersons (such as general forepersons, superintendent, project manager, etc.) is included in the adjustment under **Section 7.7.2.1** for the Contractor and under **Section 7.7.2.10** for Subcontractors.
- **7.7.2.3** Fringes: Fringe benefit credit for labor provided under **Section 7.7.2.2** is only allowable for prevailing wage fringe benefits pursuant to ORC Chapter 4115, including, but not limited to, Health and Welfare, vacation, apprenticeship training, and certain types of pension plans. The parties shall defer to the Ohio Department of Commerce's policy on which benefits are granted fringe benefit credit. Each fringe benefit for which credit is requested shall be calculated on an hourly basis and listed as a separate line item. The Contractor shall submit documentation supporting the calculation of the amounts for each fringe benefit for each worker classification, including labor provided by Subcontractors.
- **7.7.2.4** <u>Allowable Payroll Expenses</u>: Allowable payroll expenses for labor provided under **Section 7.7.2.2** including payroll taxes as well as other benefits that are required by Applicable Law, such as federal and state Unemployment and Workers' Compensation shall each be a separate line item and shall not be credited for compliance with ORC Chapter 4115.
- **7.7.2.5** Equipment Rentals: All charges for certain non-owned heavy or specialized equipment at up to 100 percent of the documented rental cost. No rental charges shall be allowed for hand tools, minor equipment, simple scaffolds, etc. Downtime due to repairs, maintenance and weather delays shall not be allowed. Contractor shall submit copies of actual paid invoices to substantiate rental costs.
- **7.7.2.6** Owned Equipment: All charges for certain heavy or specialized equipment owned by the Contractor or Subcontractor performing the Work at up to 100 percent of the cost listed by the current edition of the Associated Equipment Distributors' *AED Green Book* heavy equipment rental rates. No recovery shall be allowed for hand tools, minor equipment, simple scaffolds, etc. The longest period of time that the equipment is to be required for the Work shall be the basis for the pricing. Downtime due to repairs, maintenance, and weather delays shall not be allowed.
- **7.7.2.7** <u>Trucking</u>: A reasonable delivery charge or per-mile trucking charge for delivery of required materials or equipment. Charges for use of a pick-up truck shall not be allowed.
- **7.7.2.8** <u>Materials</u>: The actual cost (including all discounts, rebates or related credits) of all materials incorporated into the changed Work. Documentation shall show costs, quantities, or Unit Prices of all items, as appropriate.
 - .1 The cost or credit for reusable materials (e.g., concrete form lumber, shoring, or temporary enclosures) shall be limited to 33 percent of the material cost for each use.
- **7.7.2.9** Contractor's General Conditions Costs: The Contractor's General Conditions Costs to the extent attributable to an associated change in the Contract Time for achievement of Substantial Completion resulting from the change in the Work.
 - .1 In no event shall the Contract Sum adjustment per day of Contract Time adjustment exceed an amount equal to (1) the sum of the General Conditions Costs line items in the Contractor's Schedule of Values approved by the Contracting Authority, (2) divided by the total number of days of the original Contract Time for achievement of Substantial Completion.
 - .2 The Contractor shall (1) exclude the Bond premium from the Schedule of Values for the purposes of the calculation under **Section 7.7.2.9.1**, and (2) include the actual adjustment of the Bond premium attributable to an associated change in the Contract Sum.
 - .3 If the Contractor purchases the builder's risk insurance for the Project, the Contractor shall (1) exclude the builder's risk insurance premium from the Schedule of Values for the purposes of the calculation under Section 7.7.2.9.1, and (2) include the actual adjustment of the builder's risk insurance premium attributable to an associated change in the Contract Sum.
- **7.7.2.10** Subcontractor Overhead and Profit: Adjustment of the Contract Sum on account of a change in Subcontractor-performed Work shall include the Subcontractor's aggregate overhead and profit allowance equal to

15 percent of the sum of the Subcontractor's costs described under **Sections 7.7.2.2** through **7.7.2.8** that are associated with that changed Work.

- .1 The allowance applies to each Subcontractor tier.
- .2 The allowance covers: the costs required to schedule and coordinate the Work, telephone, telephone charges, facsimile, telegrams, postage, photos, photocopying, hand tools, simple scaffolds (one level high), tool breakage, tool repairs, tool replacement, tool blades, tool bits, home office estimating and expediting, home office clerical and accounting support, home office labor (management, supervision, engineering), all other home office expense, legal services, travel, and parking expenses.
- .3 An exception is allowed for shop or engineering labor on items in **Section 7.7.2.10.2**, which shall not be subject to Prevailing Wage rates for steel fabricators, sheet metal fabricators, and sprinkler system fabricators performing work off-site. Recovery for these matters shall be allowed on an hourly basis under items in **Sections 7.7.2.2**, **7.7.2.3**, and **7.7.2.4** of these Pricing Criteria.
- .4 An exception is allowed for field supervision labor on items in **Section 7.7.2.10.2**, for those portions of the Change Order Work that will be performed, or was performed, at times when the superintendent is not required to be on site under **Section 6.4**, including but not limited to overtime hours due to acceleration and extensions of the Contract Times. Recovery for this matter will be allowed on an hourly basis under items in **Sections 7.7.2.2**, **7.7.2.3**, and **7.7.2.4** of these Pricing Criteria.
- **7.7.2.11** Contractor's Fee: Adjustment of the Contract Sum on account of a change in the Work shall include an allowance for the Contractor's Fee equal to 10 percent of the sum of the costs described under **Sections 7.7.2.1** through **7.7.2.10** that are associated with that changed Work.
- **7.7.2.12** <u>Miscellaneous</u>: Adjustment of the Contract Sum on account of a change in Work may include the following costs with no allowance for Contractor's Fee under **Section 7.7.2.11** or Subcontractor overhead and profit under **Section 7.7.2.10**.
 - .1 The premium portion only for approved overtime (labor and fringes). The straight time portion is included in items in **Sections 7.7.2.2**, **7.7.2.3**, and **7.7.2.4**.
 - .2 State sales tax shall be allowed on items as defined by **Section 12.7**.
- **7.7.3** Costs that shall not be reimbursed for Change Order Work include the following:
 - **7.7.3.1** Voluntary employee deductions including, but not limited to, deductions for charitable donations or U.S. savings bonds.
 - **7.7.3.2** Employee profit sharing.

7.8 Time Extension

- **7.8.1** Every adjustment of the Contract Times associated with any change in the Work shall be determined as provided in this **Section 7.8**, which establishes the Contractor's maximum entitlement for any change in the Work, including without limitation all adjustments for interference, delay, hindrance, or disruption of the Work. This **Section 7.8** also governs time adjustments for deduct Change Orders and the Contractor's entitlement to additional time through the claims and dispute resolution processes on account of changes in the Work.
- **7.8.2** The Contractor shall substantiate all changes in the Contract Times with:
 - **7.8.2.1** a written description of the nature of the interference, disruption, hindrance or delay;
 - **7.8.2.2** identification of Persons and events responsible for the interference, disruption, hindrance or delay;
 - **7.8.2.3** date, or anticipated date, of commencement of the interference, disruption, hindrance or delay;
 - **7.8.2.4** identification of activities by schedule activity number and name on the Construction Progress Schedule, which may be affected by the interference, disruption, hindrance or delay, or new activities created by the interference, disruption, hindrance or delay and the relationship with existing activities;
 - 7.8.2.5 anticipated duration of the interference, disruption, hindrance or delay and of any remobilization period;
 - **7.8.2.6** specific number of days of extension requested and specific number of days for remobilization requested;
 - 7.8.2.7 recommended action to avoid or minimize any future interference, disruption, hindrance or delay; and
 - **7.8.2.8** a detailed written proposal as described under **Section 7.7** for an increase in the Contract Sum which would fully compensate the Contractor for all costs of acceleration of the Work needed to completely overcome the associated delay, if any.

- **7.8.3** <u>Critical Path</u>. Time extensions shall depend upon the extent to which the Work on the critical path of the Construction Progress Schedule is affected, if applicable.
 - **7.8.3.1** A Change Order granting a time extension may provide that the Contract Times shall be extended for only those specific elements so interfered with, disrupted, hindered, or delayed and related remobilization and that remaining Milestone dates shall not be altered and may further provide for adjustment of Liquidated Damages.

7.9 Examination and Audit of Contractor's Records

- **7.9.1** The Contracting Authority and Owner may examine all books, records, documents and other data of the Contractor and its Subcontractors related to the bidding, pricing, or performance of the Work for the purpose of evaluating any Contractor Payment Request, Proposal, Modification, or Claim.
- **7.9.2** The above referenced materials shall be made available at the office of the Contractor or Subcontractor, as applicable, at all reasonable times for inspection, audit, and reproduction until the expiration of 6 years after the date of Substantial Completion of all Work.
 - **7.9.2.1** The Contractor shall maintain, and require its Subcontractors to maintain, complete and accurate business records at its principal place of business. If the principal place of business is greater than 50 miles from the Site, the Contractor shall timely make records available, and shall require its Subcontractors to timely make records available, at the office of the Contracting Authority or Owner upon request for the records.
- **7.9.3** To the extent that the Contractor or Subcontractor, as applicable, informs the Contracting Authority or Owner in writing that any documents provided to the Contracting Authority or Owner are trade secrets, the Contracting Authority or Owner shall treat these documents, to the extent permitted by law, as trade secrets of the Contractor or Subcontractor, as applicable.
 - **7.9.3.1** If a dispute arises with any other Person about whether that Person should be given access to the documents, the Contractor or Subcontractor as applicable, shall indemnify the Contracting Authority and Owner against all costs, expenses, and damages, including but not limited to attorneys' fees, incurred or paid by reason of that dispute.
- **7.9.4** The right of inspection, audit, and reproduction extends to all documents necessary to permit adequate evaluation of the cost of pricing data submitted along with the computations and projections used therein.
- **7.9.5** If the Contract has been terminated, in whole or in part, the records relating to the Work terminated shall be made available to the Contracting Authority or Owner for a period of 6 years from the date of any applicable final settlement or payment, as applicable.
- **7.9.6** Records that relate to disputes, litigation, or settlement of Claims arising out of the performance of the Work shall be made available until the dispute, litigation or Claims have been finally decided or settled.

ARTICLE 8 - DISPUTE RESOLUTION

8.1 Initiation of a Claim

- **8.1.1** Every Claim shall accrue upon the date of occurrence of the event giving rise to the Claim.
- **8.1.2** Except as provided under **Section 1.10**, the Contractor shall initiate every Claim by giving written notice of the Claim to the A/E and Contracting Authority within 10 days after occurrence of the event giving rise to the Claim, with the following exceptions:
 - **8.1.2.1** The 10-day time limit on initiating a Claim arising from a determination of the Contracting Authority concerning a Change Directive begins to run on the date that the Contracting Authority issues its determination under **Section 7.4.7** or **Section 7.4.10**, as applicable.
 - **8.1.2.2** The 10-day time limit on initiating a Claim arising from the response of the A/E to a RFI begins to run on the date that the A/E issues the A/E's response to the RFI.
 - **8.1.2.3** The 10-day time limit on initiating a Claim arising from the A/E's determination concerning a Differing Site Condition begins to run on the date that the A/E issues the A/E's determination under **Section 7.6**.
- **8.1.3** The Contractor's written notice of a Claim shall provide the following information to permit timely and appropriate evaluation of the Claim, determination of responsibility, and opportunity for mitigation:
 - **8.1.3.1** nature and anticipated amount of the impact, including all costs for any interference, disruption, hindrance, or delay, which shall be calculated in accordance with **Section 7.7** and be a fair and reasonably accurate assessment of the damages suffered or anticipated by the Contractor;

- **8.1.3.2** identification of the circumstances responsible for causing the impact, including, but not limited to, the date or anticipated date, of the commencement of any interference, disruption, hindrance, or delay;
- **8.1.3.3** identification of activities on the Construction Progress Schedule that will be affected by the impact or new activities that may be created and the relationship with existing activities;
- **8.1.3.4** anticipated impacts and anticipated duration of any interference, disruption, hindrance, delay, or impact, and any remobilization period; and
- 8.1.3.5 recommended action to avoid or minimize any interference, disruption, hindrance, delay, or impact.
- **8.1.4** The Contractor's failure to initiate a Claim as and when required under this **Section 8.1** shall constitute the Contractor's irrevocable waiver of the Claim.
- **8.1.5** The A/E, in consultation with the Contracting Authority, shall respond to the written notice of the Claim within a reasonable time of receipt, but not to exceed 10 days.

8.2 Substantiation of Claims

- **8.2.1** Within 30 days after the initiation of a Claim, the Contractor shall submit 4 copies of all information and statements required to substantiate a Claim as provided in this **Article 8** and all other information that the Contractor believes substantiates the Claim. The Contractor shall file the 4 copies by delivery of 1 copy to the A/E, 1 copy to the Owner, and 2 copies to the Contracting Authority.
- **8.2.2** The Contractor shall substantiate all of its Claims by providing the following minimum information:
 - **8.2.2.1** a narrative of the circumstances, which gave rise to the Claim, including without limitation the start date of the event or events and the actual or anticipated finish date;
 - **8.2.2.2** detailed identification of the Work (e.g., activity codes from the Construction Progress Schedule) affected by the event giving rise to the Claim;
 - **8.2.2.3** copies of the Contractor's daily log (Section 6.2.17) for each day of impact;
 - **8.2.2.4** copies of relevant correspondence and other information regarding or supporting Contractor entitlement;
 - **8.2.2.5** copies of the Contractor's most recent income statement, including segregated general and administrative expenses for the most recent reporting period, and for the period of the Contract, if available, and similar information for any Subcontractor claim included; and
 - **8.2.2.6** the notarized certification described under **Section 8.5.1.1**.
- **8.2.3** The Contractor's failure to comply with the requirements of this **Section 8.2** shall constitute an irrevocable waiver of any related Claim.

8.3 Substantiation of Claims for Increase of the Contract Sum

- **8.3.1** The Contractor shall substantiate each Claim for an increase of the Contract Sum with:
 - **8.3.1.1** written documentation as described under **Section 7.7** of the actual additional direct and indirect costs to the Contractor due to the event giving rise to the Claim;
 - **8.3.1.2** a written statement from the Contractor that the increase requested is the entire increase in the Contract Sum associated with the Claim; and
 - **8.3.1.3** the general substantiation documentation described under **Section 8.2**.
- **8.3.2** The Contractor's failure to comply with the requirements of this **Section 8.3** shall constitute an irrevocable waiver of any related Claim.

8.4 Substantiation of Claims for Extension of the Contract Times

- **8.4.1** The Contractor shall substantiate each Claim for an extension of the Contract Times with:
 - **8.4.1.1** written documentation as described under **Section 7.8** of the actual delay to the critical path of the Construction Progress Schedule due to the event giving rise to the Claim;
 - **8.4.1.2** a detailed written Proposal as described under **Section 7.7** for an increase in the Contract Sum that would fully compensate the Contractor for all costs of acceleration of the Work needed to completely overcome the associated delay together with a statement consistent with **Section 8.3.1.2**;
 - **8.4.1.3** a written statement from the Contractor that the extension requested is the entire extension of the Contract Times associated with the Claim; and

- **8.4.1.4** the general substantiating documentation described under **Section 8.2**.
- **8.4.2** In addition to the requirements of **Section 8.4.1**, if adverse weather conditions are the basis for a Claim for additional time, the Contractor shall document the Claim with data substantiating that weather conditions were abnormal for the period, could not have been reasonably anticipated, and had an adverse effect on a critical element of the scheduled construction. The support for and evaluation of all adverse weather Claims shall be based upon average weather conditions during the 5 years immediately preceding the dates at issue in the Claim as those weather conditions were recorded at the government-controlled weather-recording facility nearest to the Site.
- **8.4.3** The Contractor's failure to comply with the requirements of this **Section 8.4** shall constitute an irrevocable waiver of any related Claim.

8.5 Certification of the Claim

- **8.5.1** The Contractor shall certify each Claim within 30 days after initiating the Claim under **Section 8.1** or before Contract Completion, whichever is earlier, by providing the notarized certification specified in **Section 8.5.1.1**, signed and dated by the Contractor:
 - **8.5.1.1** "The undersigned Contractor certifies that the Claim is made in good faith; that the supporting data is accurate and complete to the best of the Contractor's knowledge and belief; that the amount requested is a fair, reasonable, and necessary adjustment for which the Contractor believes the State is liable; and that the undersigned is duly authorized to certify the Claim on behalf of the Contractor."
- **8.5.2** The date that the Contractor's certified and fully substantiated Claim is received by the Contracting Authority, or the date that the Contractor is required to certify and fully substantiate a Claim pursuant to **Sections 8.2.1** and **8.5.1**, shall trigger the 120-day period for exhaustion of administrative remedies pursuant to ORC Section 153.16(B).
- **8.5.3** The Contractor's failure to comply with the requirements of this **Section 8.5** shall constitute an irrevocable waiver of any related Claim.

8.6 Delay and Delay Damage Limitations; Derivative Claims

- **8.6.1** Subject to other provisions of the Contract, the Contractor will be entitled to an extension of the Contract Times on account of delay in the commencement or progress of Work on the critical path of the Construction Progress Schedule caused by acts of Nature or the public enemy, acts of the government not arising from the Contractor's failure to comply with Applicable Law, fires, floods, epidemics, weather, and labor disputes beyond the Contractor's control.
- **8.6.2** Notwithstanding any other provision of the Contract Documents to the contrary, the Contractor shall not be entitled to an increase in the Contract Sum, or an extension of the Contract Times, or both:
 - **8.6.2.1** on account of the impact of any normal adverse weather on any of the Work or on account of the impact of any abnormal adverse weather on Work not on the critical path;
 - **8.6.2.2** to the extent that a delay occurs concurrently with a delay attributable to the Contractor; or
 - **8.6.2.3** on account of the delay of any Work not on the critical path.
- **8.6.3** Notwithstanding any other provision of the Contract Documents to the contrary, the Contractor shall not be entitled to an increase in the Contract Sum or any type of damages on account of a delay in the commencement or progress of Work on the critical path unless (1) the delay is caused by the Owner and (2) the delay was not authorized or permitted under the Contract.
- **8.6.4** Notwithstanding any other provision of the Contract Documents to the contrary, the Contractor shall not be entitled to an increase in the Contract Sum or any type of damages arising from a delay in the commencement or progress of any of the Work caused by the occurrence or non-occurrence of an event beyond the Owner's control such as acts of Nature or the public enemy, acts of the government, fires, floods, epidemics, labor disputes, unusual delivery delays, weather, or damages caused by the Contractor.
- **8.6.5** <u>Derivative Claims</u>. Notwithstanding any other provision of the Contract to the contrary, if the Owner prosecutes a claim, suit, or appeal against a Separate Consultant or Separate Contractor to recover damages the Contractor suffers on account of the acts or neglects of a Separate Consultant or Separate Contractor or a person or entity for whom either is legally responsible, the Owner's liability to the Contractor shall not exceed the amount the Owner actually recovers from the Separate Consultant or Separate Contractor on account of those damages less the costs the Owner incurs recovering them. The Owner is not obligated to prosecute any such claim, suit, or appeal.

8.7 Liquidated Damages

8.7.1 If the Contractor fails to achieve a Milestone within the associated Contract Time, it would be difficult, if not impossible, to determine the Owner's resulting damages. Therefore, if the Contractor fails to achieve a Milestone within the associated Contract Time, the Contractor shall (at the Owner's option) pay to or credit the Owner the Liquidated Damages per day sum determined according to the following schedule for each day that the Contractor fails to achieve a Milestone within the associated Contract Time.

Contract Sum	Liquidated Damages per day
Less than \$1,000,000	\$500
From \$1,000,000.01 to \$2,000,000	\$1,000
From \$2,000,000.01 to \$5,000,000	\$2,000
From \$5,000,000.01 to \$10,000,000	\$5,000
From \$10,000,000.01 to \$20,000,000	\$7,500
From \$20,000,000.01 to \$50,000,000	\$10,000
More than \$50,000,000	\$15,000

- **8.7.2** If the Contractor simultaneously fails to achieve two or more Milestones, the Owner shall be entitled to recover the sum of the associated Liquidated Damages per day rates.
- **8.7.3** The Liquidated Damages described in this **Section 8.7** are only intended to compensate the Owner for the direct damages it incurs as a result of the Contractor's failure to achieve the Milestones within their associated Contract Times.
- **8.7.4** The Liquidated Damages described in this **Section 8.7** are not intended to compensate the Owner for any damages the Owner incurs on account of (1) any claims attributable to the Contractor that are brought by others including Separate Consultants and Separate Contractors or (2) any failure of the Contractor to timely, properly, and completely perform the Contract other than the failure to achieve the Milestones within their associated Contract Times.
- **8.7.5** The parties acknowledge that the above-listed Liquidated Damages per day sums are not penalties, and they each irrevocably waive the right (if any) to challenge the validity and enforceability of those Liquidated Damages per day sums. Notwithstanding any other provision of the Contract Documents to the contrary, if a court determines that the Liquidated Damages per day sums or their application are void and unenforceable, the Owner shall be entitled to recover the actual damages that it incurs on account of the Contractor's failure to achieve one or more of the Milestones within the Contract Times.
- **8.7.6** In addition to other rights that the Owner may have relative to the Liquidated Damages, the Contracting Authority may deduct the Liquidated Damages from the Contract Sum as the damages accrue. If payments then or thereafter due the Contractor are not sufficient to cover such amounts, the Contractor shall immediately pay the amount of the insufficiency to the Owner.

8.8 Mutual Waiver of Consequential Damages

- **8.8.1** Except as provided under **Section 8.8.2**, the Owner and Contractor each waive against the other all Claims for consequential damages that may arise out of or relate to this Contract.
 - **8.8.1.1** The Owner's waiver includes Claims for loss of use, income, profit, revenue, financing, cost of capital, business and reputation, management and employee productivity, and consequential damages arising from termination of the Contract or related to insolvency.
 - **8.8.1.2** The Contractor's waiver includes Claims for unabsorbed home-office overhead; any other form of overhead in excess of that specifically provided for under **Section 7.7**; delay damages except as otherwise specifically provided for in **Section 8.6**; increased cost of funds for the Project; lost opportunity to work on other projects; losses of financing, business, and reputation; loss of profit except anticipated profit arising directly from properly performed Work; loss of bonding capacity; and consequential damages arising from termination of the Contract or related to insolvency.

8.8.2 Notwithstanding Section 8.8.1, this Section 8.8:

- **8.8.2.1** does not apply to any damages that would be covered by insurance provided in connection with the Project if the Contract did not include **Section 8.8.1**;
- **8.8.2.2** does not apply to the Contractor's indemnity obligations for third-party claims against the Indemnified Parties even if those claims are for damages that **Section 8.8.1** would otherwise preclude;
- 8.8.2.3 does not preclude the Owner's recovery of Liquidated Damages under Section 8.7; and

- **8.8.2.4** does not apply to Claims for damages arising from the Owner's or the Contractor's gross negligence or willful misconduct.
- **8.8.3** This **Section 8.8** shall survive termination of the Contract.

8.9 Review of the Claim

- **8.9.1** The A/E shall review the Claim and prepare a written analysis of its content, which shall include:
 - **8.9.1.1** a narrative of the A/E's examination of the facts giving rise to the Claim;
 - 8.9.1.2 identification of relevant Contract Documents and language;
 - **8.9.1.3** an analysis of whether the Contractor complied with the requirements of the Contract Documents pertaining to Claim initiation and substantiation including, without limitation, the issues of entitlement to, and calculation of, adjustments of the Contract Sum, Contract Times, or both;
 - 8.9.1.4 an analysis of claimed additional labor, materials, and equipment for the scope of the Work items described;
 - **8.9.1.5** an analysis of any time extension for any interference, disruption, hindrance, impact, or delay claimed (to include the calculation of any concurrent delays affecting entitlement);
 - **8.9.1.6** a concluding opinion regarding Contractor entitlement to, and the appropriateness and reasonableness of all, or any part of, the Claim; and
 - **8.9.1.7** an appendix containing copies of contemporaneous documentation supporting the concluding opinion.
- **8.9.2** The A/E shall submit the written analysis to the Project Manager no more than 30 days after receiving the Contractor's substantiated and certified Claim.

8.10 Claim Decision

- **8.10.1** The Project Manager shall examine the Contractor's Claim and A/E's analysis.
- **8.10.2** The Project Manager shall approve or deny all, or any part, of the Contractor's Claim and forward a written decision to the Contractor, A/E, Owner, and Contracting Authority within 14 days after receiving the A/E's analysis.
 - **8.10.2.1** The Project Manager may employ independent resources to assist in its review, or refer evaluation of the Claim to a consultant.
- **8.10.3** If the Contractor and Owner agree with the Project Manager's decision, the decision shall be incorporated into a Change Order.
- **8.10.4** Any Claim remaining unresolved after completion of the process described under this **Section 8.10** shall be subject to Claim decision review as described under **Section 8.11**.

8.11 Claim Decision Review

- **8.11.1** The Contractor may request review of the Project Manager's decision by written notice delivered by certified mail within 14 days of the Project Manager's decision.
 - **8.11.1.1** If the Project is administered by the Commission, jointly administered by the Commission and a public school district, or locally administered by authority granted to an agency of the state of Ohio by the Commission, the written notice shall be delivered to the Executive Director of the Commission.
 - **8.11.1.2** If the Project is locally administered by an Institution of Higher Education under ORC Section 3345.50 or ORC Section 3345.51, the written notice shall be delivered to the Institutional Designee who will review the Project Manager's decision instead of the Commission.
- **8.11.2** The Commission or Institutional Designee, if applicable, shall schedule and conduct a meeting within 30 days after receiving the Contractor's request for review.
 - **8.11.2.1** The Commission or Institutional Designee may employ independent resources to assist in the meeting and review.
- **8.11.3** The Commission or Institutional Designee, if applicable, shall determine the final disposition of the Contractor's request for review and provide a written decision to the Contractor and Owner within 14 days after the meeting.
- **8.11.4** The decision of the Commission or Institutional Designee is the final administrative decision of the Contracting Authority as described under ORC Section 153.12(B).

- **8.11.5** If the Contractor and Owner agree with the Commission's or the Institutional Designee's decision, the decision shall be incorporated into a Change Order.
- **8.11.6** Any Claim remaining unresolved after completion of the process described under this **Section 8.11** shall be subject to litigation, which may be preceded by Alternative Dispute Resolution ("ADR") as described under **Section 8.13**.

8.12 Delegation

8.12.1 No provision of this **Article 8** shall prevent the Executive Director from delegating the duties or authorities of the Commission to any other person selected at the Executive Director's sole discretion.

8.13 Alternative Dispute Resolution

- **8.13.1** The intent of the ADR process is to resolve disputes quickly and equitably in a manner agreed upon by all parties to the dispute.
- **8.13.2** The ADR procedure shall be accepted by all of the Project's key stakeholders.
- **8.13.3** The accepted ADR methods shall not include binding arbitration; alter any of the requirements for Claim initiation, certification, and substantiation; or alter the administrative process described under this **Article 8**.
- **8.13.4** The following forms of non-binding ADR may be considered:
 - **8.13.4.1** <u>Negotiation</u>: If negotiation is warranted, the parties to the dispute may agree to a progressive level of negotiators, invested with the authority to agree to a determination of an adjustment in the Contract Sum, Contract Times, or both.
 - **8.13.4.2** <u>Dispute Review Board</u>: If a dispute review board is the accepted ADR procedure, or the process to follow when negotiations are unsuccessful, the parties to the dispute shall jointly select 3 neutral third parties to monitor the progress of construction and provide recommended resolutions to disputes that are brought before them. The costs of the dispute review board shall be shared equally among the parties to the dispute.
 - **8.13.4.3** <u>Mediation</u>: If mediation is the accepted ADR procedure, or the process to follow when negotiations are unsuccessful, the parties to the dispute shall accept a neutral third party to mediate the dispute. The costs of mediation shall be shared equally among the parties to the dispute.
 - **8.13.4.4** Another ADR procedure accepted by all of the Project's key stakeholders.

8.14 Audit of the Claim

- **8.14.1** All Claims shall be subject to audit at any time following filing of the Claim, whether or not the Claim is part of a lawsuit.
- **8.14.2** The audit may be performed by employees of the Contracting Authority or by a consultant engaged by the Contracting Authority.
- **8.14.3** The audit may begin upon 10-days' notice to the affected Contractor or affected Subcontractor.
- **8.14.4** The Contractor shall cooperate with the request.
- **8.14.5** Failure of the Contractor or Subcontractor to produce sufficient records to allow the Contracting Authority to audit and verify a Claim shall constitute an irrevocable waiver of the Claim or portion of the Claim that could not be completely audited.
- **8.14.6** The Contractor shall make available to the Contracting Authority all Contractor and Subcontractor documents related to the Claim including, without limitation, the following documents:
 - **8.14.6.1** daily time sheets and superintendent's daily reports;
 - 8.14.6.2 union agreements, if any, and employer agreements;
 - **8.14.6.3** insurance, welfare, fringes, and benefits records;
 - 8.14.6.4 payroll register;
 - 8.14.6.5 earnings records;
 - 8.14.6.6 payroll tax returns;
 - **8.14.6.7** material invoices, purchase orders, Subcontracts, and all material and supply acquisition contracts;
 - **8.14.6.8** material cost distribution worksheets:

- **8.14.6.9** equipment records (list of Contractor equipment, rates, etc.);
- **8.14.6.10** vendor rental agreements and Subcontractor invoices;
- **8.14.6.11** Subcontractor payment certificates;
- 8.14.6.12 canceled checks (payroll and vendors);
- **8.14.6.13** job cost report;
- 8.14.6.14 job payroll ledger;
- **8.14.6.15** general ledger, general journal, (if used) and all subsidiary ledgers and journals together with all supporting documentation pertinent to entries made in these ledgers and journals;
- **8.14.6.16** cash disbursements journal;
- 8.14.6.17 financial statements for all years reflecting operations on the Project;
- **8.14.6.18** income tax returns for all years reflecting operations on the Project;
- **8.14.6.19** depreciation records on all equipment utilized whether the records are maintained by the Contractor, its accountant, or others;
- **8.14.6.20** if a source other than depreciation records is used to develop costs for the Contractor's internal purposes in establishing the actual cost of owning and operating equipment, all other source documents;
- **8.14.6.21** all documents that reflect the Contractor's actual profit and overhead during the years the Project was being performed;
- **8.14.6.22** all documents related to the preparation of the Contractor's Bid, including the final calculations on which the Bid was based, unless the documents are placed in escrow under provisions of the Instructions to Bidders;
- **8.14.6.23** all documents that relate to the Claim together with all documents that support the amount of damages as to the Claim;
- **8.14.6.24** worksheets used to prepare the Claim establishing the cost components for items of the Claim including, but not limited to, labor, fringes, benefits and insurance, materials, equipment, Subcontractors, and all documents that establish the periods of time, individuals involved, the hours and rate of pay for the individuals; and
- **8.14.6.25** all other documents required by the Contracting Authority to reasonably review the Claim.

8.15 False Certification of the Claim

8.15.1 If the Contractor falsely certifies all or any part of a Claim, the portion of the Claim falsely certified shall be denied, and may be sufficient cause for the State to debar the Contractor from future State contracting opportunities as permitted by law.

8.16 Performance and Payment

- **8.16.1** The Contractor shall proceed with the Work during any dispute resolution process, unless otherwise agreed by the Contractor and Contracting Authority in writing.
- **8.16.2** The Contracting Authority shall continue to make payment of any undisputed amounts in accordance with the Contract Documents pending final resolution of a Claim, unless otherwise agreed by the Contractor and Contracting Authority in writing.

ARTICLE 9 - COMPENSATION AND PAYMENT

9.1 Allowances

- 9.1.1 The Contract Sum includes the Allowances (if any) identified in the Contract.
- **9.1.2** All Allowances include the cost to the Contractor (less any applicable trade discounts) of materials and equipment required by the Allowances to be delivered at the Site, and all applicable taxes.
- **9.1.3** The Contractor's Fee and costs for unloading and handling on the Site, labor, installation costs, and other expenses contemplated for the Allowances are not in the stated Allowance amounts but are otherwise included in the Contract Sum.
- **9.1.4** Before final payment, an appropriate Change Order will be issued to reconcile the Contract Sum so that it reflects actual amounts due to the Contractor on account of Work covered by Allowances.

9.2 Unit Prices

- **9.2.1** Where the Contract provides that all or part of the Work is to be Unit Price Work, initially the Contract Sum will include for all Unit Price Work (1) an amount equal to the sum of the established Unit Prices for each separately identified item of Unit Price Work times the estimated quantity of each item as indicated in the Contract plus (2) the Contractor's Fee on that Unit Price Work.
- **9.2.2** The estimated quantities of items of Unit Price Work are not guaranteed and are solely for the purpose of comparison of Bids and determining an initial Contract Sum. The Contracting Authority will determine the actual quantities and classifications of Unit Price Work performed by Contractor.
- **9.2.3** The Contractor's Fee on account of Unit Price Work is not in the stated Unit Price amounts but are otherwise included in the Contract Sum.
- **9.2.4** Before final payment, an appropriate Change Order will be issued as described under **Section 7.1.5** to reconcile the Contract Sum so that it reflects actual amounts due to the Contractor on account of Unit Price Work actually performed.

9.3 Schedule of Values

- **9.3.1** Within 10 days after receipt of the Notice to Proceed, or other period as mutually agreed by the Contractor and Contracting Authority, the Contractor shall submit to the A/E a Schedule of Values on a form published by the Commission, with separate amounts shown for labor and materials for each branch of Work, following the numbers and titles of the Construction Specifications Institute's *MasterFormat* for individual work results, or *UniFormat* for assemblies in place.
 - **9.3.1.1** The Contractor shall clearly indicate on the Schedule of Values, the amount(s) allocated, including separate items for Contractor's Fee (overhead and profit), for each EDGE-certified Business used in the performance of the Work. The amount(s) shall indicate labor and materials, as appropriate.
- **9.3.2** The grand total shown on the Schedule of Values shall equal the total Contract Sum. The Contracting Authority may use the approved Schedule of Values to determine the cost or credit to the Owner resulting from any change in the Work.
 - **9.3.2.1** The first items shall be a breakdown of General Conditions Costs.
 - **9.3.2.2** The amounts for labor and materials shall accurately reflect the cost for each item. Separate items shall not be shown for Contractor's Fee, except when Work is performed or materials are supplied by an EDGE-certified Business, pursuant to **Section 9.3.1.1**. Contractor's Fee shall be included in the totals for labor and materials.
 - **9.3.2.3** If the material allocation exceeds 55 percent of the Contract Sum, the Contractor shall provide, upon request, sufficient information to support the higher percentage.
 - **9.3.2.4** Subcontract Work shall show amounts for labor and materials. Fringe benefits shall be shown as a part of labor costs.
 - **9.3.2.5** When more than one major structure is included in the Work, the Contractor shall subdivide the Schedule of Values accordingly, with cost details for each structure shown separately.
 - **9.3.2.6** The line items shall be coordinated with line items in the Project Schedule, which may require division of items of Work by area of the Project by floor, phase, or other appropriate area.
 - **9.3.2.7** Mechanical and electrical Work shall be included in separate line items for all major pieces of equipment, and group smaller equipment items by type.
 - **9.3.2.8** Line items shall be included for each Allowance, Punch List Work, Project Record Document Submittals, delivery of attic stock, and specified demonstrations and training.
- **9.3.3** The A/E may return the Schedule of Values to the Contractor for re-submittal if it does not meet the requirements or contains insufficient items or details of the Work, or approve the Schedule of Values if the A/E determines that it conforms to this **Section 9.3**.
- **9.3.4** No payment shall be made until the A/E has approved the Contractor's Schedule of Values.

9.4 Contractor Payment Request

9.4.1 The Contractor may submit a Contractor Payment Request for Work performed based upon the Schedule of Values to the A/E each month or upon another interval approved by the Contracting Authority. When the rate of Work and amount involved is sufficient that it is considered appropriate by the Contracting Authority, the Contractor may submit Contractor Payment Requests twice a month.

- **9.4.1.1** The Contractor shall support each Contractor Payment Request with documentation substantiating the Contractor's right to payment. The Contractor shall supply additional documentation as the A/E may request in connection with each payment to the Contractor.
- **9.4.1.2** The Contracting Authority may require proof of the renewal of required insurance as a condition precedent to payment.
- **9.4.1.3** The Contractor shall attach certified payroll reports for the relevant period to 1 copy of each Contractor Payment Request, see **Document 00 73 43 Prevailing Wage Requirements**.
- **9.4.1.4** The Contractor may list on the Contractor Payment Request any Change Orders approved and performed prior to submission of the Contractor Payment Request.
- **9.4.1.5** The Contractor shall submit its Contractor Payment Request using the Contractor Payment Request form or forms current at the time of each application and as provided by the Contracting Authority in the manner prescribed by the Contracting Authority.
- **9.4.1.6** The Contractor shall submit 1 draft copy of its Contractor Payment Request ("Pencil Copy") to the A/E not less than 1 week prior to submitting multiple copies of its Contractor Payment Request. The A/E shall review the Pencil Copy and provide comments to the Contractor within 3 days of receiving it. The Contractor shall incorporate the A/E's comments into its Contractor Payment Request prior to submitting multiple copies for payment.
- **9.4.1.7** The Contractor shall clearly indicate on the Contractor Payment Request, the amount(s) requested for each EDGE-certified Business used in the performance of the Contract. The amount(s) shall indicate labor and materials, as appropriate.
- **9.4.1.8** The Contractor shall submit an electronic copy of the Contractor Payment Request to the A/E with its paper copies of the Contractor Payment Request for collection and reporting of information used for contract compliance evaluation and statistical purposes. The Contractor may issue the copy in any electronic media acceptable to the Contracting Authority.
- **9.4.2** Payments, except for lump sum items, in Unit Price Contracts shall be made to the Contractor only for the authorized actual quantities of Work performed or materials furnished in accordance with the Contract Documents.
- **9.4.3** Subject to **Section 9.8**, the Owner shall pay an approved Contractor Payment Request within 30 days from the date the A/E recommends acceptance of the Contractor Payment Request.
 - **9.4.3.1** Payments due and not paid to the Contractor, through no fault of the Contractor, within the 30 day period shall, from the date payment is due, bear simple interest at the applicable statutory rate.
- **9.4.4** Notwithstanding any other provision of the Contract Documents, partial payments made pursuant to this **Section 9.4** constitutes neither acceptance of any Defective Work, nor a waiver of any rights set forth in the Contract Documents or otherwise provided by Applicable Law.
- 9.4.5 The Contracting Authority and Owner may audit Contractor Payment Requests as described under Section 7.9.

9.5 Labor Payments

- **9.5.1** Partial payments to the Contractor for labor performed under either a Unit Price or lump sum Contract shall be made at the rate of 92 percent of the amount invoiced through the Contractor Payment Request that shows the Work is 50 percent complete.
- **9.5.2** After the Work is 50 percent complete, as evidenced by payments of at least 50 percent of the Contract Sum including approved Change Orders to date, no additional funds shall be retained from payments for labor.

9.6 Material Payments

- **9.6.1** The Owner shall pay the Contractor at the rate of 100 percent of the scheduled value for materials incorporated into the Project.
- **9.6.2** The Owner shall pay the Contractor at the rate of 92 percent of the invoice cost, not to exceed the scheduled value in a Unit Price or lump sum Contract, for materials delivered to the Site, or other off-site storage location approved by the A/E, provided the Contractor provides the following information with the Contractor Payment Request:
 - **9.6.2.1** a list of the fabricated materials consigned to the Project, giving the place of storage, together with copies of invoices, in order to verify quantity and cost; and
 - **9.6.2.2** a certification of materials stored off-site, prepared by the Contractor and signed by the A/E to evidence that the materials are in conformity with the Specifications and have been tagged with the Project name and number for

- delivery to the Project. The Contractor shall directly reimburse the A/E for all costs incurred to visit a storage site, other than the areas adjacent to the Project.
- **9.6.2.3** The Owner shall pay the balance of the scheduled value when the materials are incorporated into and become a part of the Project.
- **9.6.3** When payment is allowed for materials delivered to the Site or other approved off-site storage location but not yet incorporated into the Project, the materials are the property of the Owner.
 - **9.6.3.1** The Owner may, at its sole discretion, retain any material not ultimately incorporated into the Project or return it to the Contractor for credit of an amount proportionate to the value of the extra materials.

9.7 Retainage

- **9.7.1** If the total Contract Sum is \$15,000 or more, when the Contract is 50 percent complete, all funds retained for faithful performance of the Work, in accordance with **Section 9.5.1**, shall be deposited in an escrow account with a bank in the state in accordance with the terms and conditions provided in an escrow agreement executed by the Contractor, Contracting Authority, and applicable bank.
- **9.7.2** When the Contractor has achieved Substantial Completion of all Work, and there is no other reason to retain funds; upon request of the Contractor, the funds retained in connection with that Work shall be released from escrow and paid to the Contractor, withholding only that amount necessary to assure faithful completion in the sole discretion of the Contracting Authority, including but not limited to compliance with **Section 6.25.2**.
- **9.7.3** Upon consent by the Contractor's Surety, the Contracting Authority may reduce the amount of funds retained for the faithful performance of Work by 50 percent of the amount of funds required to be retained, provided the Contractor's Surety remains responsible for all damages that may be caused due to default by the Contractor, including, but not limited to, the following:
 - **9.7.3.1** completion of the Work;
 - **9.7.3.2** all interference, disruption, hindrance and delay claims;
 - 9.7.3.3 all Liquidated Damages; and
 - **9.7.3.4** all additional expenses incurred by the State.

9.8 Payments Withheld

- **9.8.1** The A/E may recommend to the Contracting Authority that payments be withheld from, or Liquidated Damages be assessed against, a Contractor Payment Request.
- **9.8.2** The Contracting Authority may decline to approve any Contractor Payment Request or part thereof, or nullify any previous Contractor Payment Request, in whole or in part, to the extent necessary in the Contracting Authority's sole opinion to protect the Owner from loss because of:
 - **9.8.2.1** Defective Work not remedied:
 - **9.8.2.2** damage caused by the Contractor;
 - **9.8.2.3** reasonable evidence that the Work cannot be completed for the unpaid balance of the Contract Sum;
 - **9.8.2.4** reasonable evidence that the Work will not be completed within the Contract Times, and that the unpaid balance would not be adequate to cover damages under the Contract Documents for the anticipated delay;
 - **9.8.2.5** failure to comply with Applicable Law including, but not limited to, the requirements of ORC Chapter 4115;
 - 9.8.2.6 failure to timely submit EDGE Participation Reports in accordance with Section 1.8.2;
 - **9.8.2.7** failure to timely identify the Contractor's proposed Subcontractors in accordance with **Section 4.1.1**;
 - 9.8.2.8 failure to timely approve a Construction Progress Schedule in accordance with Section 6.5;
 - 9.8.2.9 failure to carry out the Work in accordance with the Contract Documents; or
 - **9.8.2.10** that which is permitted under other provisions of the Contract Documents.
- **9.8.3** If the Contractor remedies the basis for withholding payment under **Section 9.8.2** to the Contracting Authority's satisfaction, the Owner shall pay the amounts withheld.

9.9 Final Contractor Payment Request

- **9.9.1** The Contractor, as a condition precedent to execution of the Certificate of Contract Completion and to final payment, shall complete all requirements of the Contract Documents.
 - **9.9.1.1** The Contractor and each of its Subcontractors, regardless of tier, shall execute a Payment Release Affidavit to certify that the Contractor and each of its Subcontractors, regardless of tier, have complied with all requirements of ORC Chapter 4115, and to certify that all of its Subcontractors have been paid in full for all Work performed or materials furnished for the Project.
- **9.9.2** The Owner shall pay the final Contractor Payment Request within 30 days from the date the A/E recommends acceptance of the final Contractor Payment Request.
 - **9.9.2.1** Payments due and not paid to the Contractor within the 30 day period shall bear interest from the date payment is due under the Contract Documents at the applicable statutory rate.
- **9.9.3** Acceptance of final payment by the Contractor or a Subcontractor constitutes the payee's waiver of all claims against the State except those previously made in writing under **Article 8** and identified by that payee as unsettled at the time of the final Contractor Payment Request.

ARTICLE 10 - BONDS, INSURANCE, AND INDEMNIFICATION

10.1 Payment and Performance Bonds

- 10.1.1 Before signing the Agreement, the Contractor shall provide the Bond required under Applicable Law and below:
 - 10.1.1.1 If the Contractor provided **Document 00 43 13 Bid Security Form** as its Bid Guaranty, then that form shall be the Bond.
 - 10.1.1.2 If the Contractor provided another form of Bid Guaranty, then **Document 00 61 13 Performance and Payment Bond Form** shall be the Bond.
 - **10.1.1.3** Each Surety under the Bond shall be licensed to do business in Ohio and satisfactory to the Contracting Authority.
 - **10.1.1.4** If there is more than one Surety under the Bond, each of them shall be jointly and severally liable as surety under the Bond.
 - **10.1.1.5** Unless the Contracting Authority and the Owner are the same entity, the Bond shall name the obligee as follows: **(1)** the State by and through the Contracting Authority and **(2)** the Owner.
 - **10.1.1.6** The penal sum of the Bond, when initially submitted, shall be equal to one-hundred percent of the Contract Sum.
- **10.1.2** The Contractor shall submit with the executed Bond **(1)** a certified copy of the authority to act (power of attorney) of the agent signing the Bond on behalf of the Surety and **(2)** a current and signed Certificate of Compliance under ORC Section 9.311 issued by the Ohio Department of Insurance showing the Surety is licensed to do business in Ohio.
- **10.1.3** If the Contract Sum increases at any time such that it exceeds the penal sum of the Bond, the Contractor shall cause the penal sum of the Bond to be increased such that the penal sum equals one-hundred percent of the increased Contract Sum.
- **10.1.4** Any time the Contractor increases the penal sum of the Bond under **Section 10.1.3**, the Contractor shall deliver to the Contracting Authority written consent of the affected Surety or Sureties confirming the increased penal sum. The Contracting Authority's receipt of that written consent is a condition precedent to the Owner's obligation to pay the Contractor for any portion of the Work associated with the increase.
- **10.1.5** If notice of any change affecting the Contract is required by any Surety or by the provision of any Bond, the Contractor shall provide that notice.

10.2 Contractor's General Insurance Requirements

- **10.2.1** Throughout the performance of the Work or longer as may be described below, the Contractor shall obtain, pay for, and keep in force, the minimum insurance coverage described in this **Article 10**.
 - **10.2.1.1** Each requirement of this **Article 10** applies to Subcontractors just as it applies to the Contractor.
 - **10.2.1.2** If a Subcontractor's usual insurance coverage does not meet the minimum coverage requirements, before entering into an agreement with that Subcontractor, the Contractor shall submit to the Contracting Authority (1) a

- certificate of insurance evidencing the insurance the Subcontractor will carry without additional compensation and (2) if the Contracting Authority requests, a written proposal from the Subcontractor to provide coverage that meets the minimum coverage requirements. The Contracting Authority will decide whether to accept the non-conforming insurance coverage or the proposal to provide conforming coverage.
- **10.2.1.3** On a case-by-case basis, the Contracting Authority and Contractor may agree to adjust the below requirements for any particular Subcontractor.
- **10.2.2** Before starting the Work on the Site, upon renewal of any policy, and upon a change of any insurance carrier, the Contractor shall deliver to the Contracting Authority certificates evidencing that the required insurance is in force.
- **10.2.3** With the exception of government-controlled workers compensation coverage:
 - **10.2.3.1** the Contractor shall place the insurance with companies that **(1)** are satisfactory to the Contracting Authority, **(2)** hold an A.M. Best Rating of A-, X, or higher, and **(3)** are authorized to conduct business in Ohio;
 - **10.2.3.2** the policies shall be endorsed to require the Contractor's insurance carrier to **(1)** provide 30-days' written notice to the Contracting Authority (as certificate holder) of the cancellation or non-renewal of the insurance and **(2)** provide at least 10-days' written notice to the Contracting Authority (as certificate holder) of the cancellation of the insurance for non-payment of premium; and
 - **10.2.3.3** within 30 days of the Contracting Authority's request, the Contractor shall submit insurance-company certified copies of the policies, the policy endorsements, loss-run reports, or all three.
- **10.2.4** The Contractor shall pay all deductibles, or self-insured retentions, or both contained in the Contractor's policies of insurance required or provided in connection with the Project. The Contracting Authority reserves the right to approve or reject all levels of self-insured retention, captive insurance programs, or other alternative risk financing the Contractor may use to comply with any insurance requirement.
- **10.2.5** The Contractor shall pay a proportionate share of the deductibles, or self-insured retentions, or both contained in any insurance policy the Contracting Authority purchases for the Project. The Contractor's proportionate share will derive from the percentage of the associated claim or loss attributable to the alleged or actual negligence of the Contractor or a Subcontractor.
- **10.2.6** The Contracting Authority and Owner do not represent that required coverage or limits are adequate to protect the Contractor.
- **10.2.7** Failure of the Contracting Authority to demand a certificate or other evidence of full compliance with the insurance requirements or failure of Contracting Authority to identify a deficiency from evidence that is provided shall not be construed as a waiver of the Contractor's obligation to maintain the required insurance.
- **10.2.8** The Contracting Authority may terminate the Contract for cause on account of the Contractor's failure to maintain required insurance.

10.3 Contractor's Minimum Coverage Requirements

- **10.3.1** Workers Compensation. The Contractor shall maintain workers compensation coverage meeting the requirements of Applicable Law.
- **10.3.2** Employers Liability Coverage. The Contractor shall maintain employers liability coverage with **(1)** an each-accident limit of not less than \$1,000,000, **(2)** a disease each-employee limit of not less than \$1,000,000, and **(3)** a disease policy limit of not less than \$1,000,000.
- **10.3.3** Commercial General Liability. The Contractor shall maintain commercial general liability ("CGL") coverage that provides **(1)** an each-occurrence limit of not less than \$1,000,000, **(2)** a general-aggregate limit of not less than \$2,000,000, and **(3)** a products and completed-operations aggregate limit of not less than \$2,000,000.
 - **10.3.3.1** The CGL insurance shall be written on ISO occurrence form CG 00 01 10 01 or a substitute form, providing at least equivalent coverage for liability arising from premises, operations, independent contractors, products/completed-operations, personal and advertising injury, and liability assumed under an insured contract.
 - **10.3.3.2** The Contractor shall include the State, Contracting Authority, Owner, and A/E as additional insureds under the CGL policy using ISO endorsement CG 20 10 07 04 and ISO endorsement CG 20 37 07 04 or a substitute form(s) providing equivalent coverage.
 - **10.3.3.3** The CGL policy shall be endorsed using ISO endorsement CG 25 03 or a substitute form providing equivalent coverage to provide that the general aggregate limit applies separately to each of the insured's projects.

- **10.3.3.4** The CGL insurance shall apply as primary and non-contributory insurance with respect to any other insurance or self-insurance programs that cover the additional insured(s).
- **10.3.3.5** The CGL policy shall not exclude coverage to the additional insured(s) for bodily injury or property damage arising out of the products/completed-operations hazard.
- **10.3.3.6** The Contractor shall maintain the CGL insurance in effect for no less than 5 years after the earlier of the termination the Contract or Substantial Completion of all Work.
- **10.3.4** <u>Business Automobile Liability</u>. The Contractor shall maintain business automobile ("BA") coverage written on ISO form CA 00 01 10 01 or a substitute form, providing at least equivalent coverage with a limit of not less than \$1,000,000 each accident.
 - **10.3.4.1** The coverage shall extend to any auto.
 - **10.3.4.2** The Contractor shall include the State, Contracting Authority, Owner, and A/E as additional insureds under the BA policy.
- **10.3.5** <u>Umbrella/Excess Liability</u>. The Contractor may employ an umbrella/excess liability policy to achieve the above-required minimum coverage.
 - **10.3.5.1** The Contractor shall maintain umbrella/excess liability coverage with a limit of not less than \$2,000,000 (in addition to the above-required limits) if the Work (or the Work to be performed by the Subcontractor) includes any of the following:
 - .1 brick/block masonry;
 - .2 exterior caulking/sealant;
 - .3 cast-in-place or precast concrete;
 - .4 curtain wall;
 - .5 dampproofing/waterproofing;
 - .6 electrical;
 - .7 elevator;
 - .8 exterior glass and/or glazing;
 - .9 exterior marble, granite, and/or other stonework;
 - .10 miscellaneous metals;
 - .11 plaster/stucco;
 - .12 plumbing;
 - **.13** HVAC;
 - .14 roofing and/or sheet metal;
 - .15 scaffolding;
 - .16 spray-on fireproofing;
 - .17 sprinkler and/or fire protection; or
 - .18 structural steel and/or metal deck.
 - **10.3.5.2** The Contractor shall maintain umbrella/excess liability coverage with a limit of not less than \$5,000,000 (in addition to the above-required limits) if the Work (or the Work to performed by the Subcontractor) includes any of the following:
 - .1 caissons and/or piles;
 - .2 demolition;
 - .3 excavation and/or utility work;
 - .4 sheeting, shoring, and/or underpinning;
 - .5 window washing equipment; or
 - .6 wrecking.
- **10.3.6** Contractor's Pollution Liability. If the Work includes environmentally sensitive, hazardous types of activities (such as demolition, exterior insulation finish systems, Asbestos abatement, storage-tank removal, or similar activities), or involves Hazardous Materials, the Contractor shall maintain a contractor's pollution liability ("CPL") policy with **(1)** a per-claim limit of not less than \$1,000,000 and **(2)** an annual-aggregate limit of not less than \$1,000,000, covering the acts, errors and/or omissions of the Contractor for damages (including from mold) sustained by the Owner by reason of the Contractor's performance of the Work.

- **10.3.6.1** The CPL policy shall have an effective date, which is on or before the date that the Contractor first started to perform any Project-related services.
- **10.3.6.2** Upon submission of the associated certificate of insurance and at each policy renewal, the Contractor shall advise the Contracting Authority in writing of any actual or alleged claims that may erode the CPL policy's limits.
- **10.3.6.3** The Contractor shall maintain the CPL insurance in effect for no less than 5 years after the earlier of the termination of the Contract or Substantial Completion of all Work.
- **10.3.7** <u>Professional Liability—Contractor</u>. The Contractor shall maintain professional liability insurance (including without limitation for sprinkler and/or fire protection and other design-build work included in the Work) without design-build exclusions with limits not less than as identified in the following table:

Contract Sum	Each Claim	Annual Aggregate
Up to \$50,000,000	\$1,000,000	\$2,000,000
More than \$50,000,000	\$2,000,000	\$4,000,000

- **10.3.7.1** The professional liability policy shall have an effective date on or before the date that the Contractor first started to provide any Project-related services.
- **10.3.7.2** Upon submission of the associated certificate of insurance and at each policy renewal, the Contractor shall advise the Contracting Authority in writing of any actual or alleged claims that may erode the professional liability policy's limits.
- **10.3.7.3** The Contractor shall maintain the professional liability insurance in effect for no less than 5 years after the earlier of the termination of the Contract or Substantial Completion of all Work.
- **10.3.7.4** If the Contractor is not authorized under Applicable Law to directly provide professional design services, the Contractor may satisfy the requirements of this **Section 10.3.7** by providing a contractor's professional liability insurance policy.
- **10.3.7.5** If the Contractor is a joint venture:
 - .1 the Contractor may meet the requirements of this **Section 10.3.7** by providing a PL policy under which each joint venturer is the insured; or
 - .2 each joint venturer shall individually meet the requirements of this **Section 10.3.7** by providing a PL policy (1) under which the individual joint venturer is the insured and (2) that covers that joint venturer's interests in the joint venture by endorsement or otherwise. The certificate of insurance shall reflect that the PL policy covers the joint venturer's interest in the joint venture.

Example: Assume that the Contractor (1) is the "XY joint venture" of company "X" and company "Y"; and (2) is required under **Section 10.3.7** to maintain PL insurance limits of \$1M/\$2M. In order to comply with **Section 10.3.7.5.2**, "X" must maintain PL insurance limits of \$1M/\$2M and "Y" must maintain PL insurance limits of \$1M/\$2M.

- 10.3.7.6 If the Contractor is a limited-liability company, which members consist of two or more separate firms:
 - .1 the Contractor may meet the requirements of this **Section 10.3.7** by providing a PL policy under which the limited-liability company is the insured; or
 - 2 each member of the limited-liability company shall individually meet the requirements of this Section 10.3.7 by providing a PL policy (1) under which the individual member is the insured and (2) that covers that member's interests in the limited-liability company by endorsement or otherwise. The certificate of insurance shall reflect that the PL policy covers the member's interest in the limited-liability company.

Example: Assume that the Contractor (1) is the "XY limited-liability company," the members of which are "X" and "Y"; and (2) is required under Section 10.3.7 to maintain PL insurance limits of \$1M/\$2M. In order to comply with Section 10.3.7.6.2, "X" must maintain PL insurance limits of \$1M/\$2M and "Y" must maintain PL insurance limits of \$1M/\$2M.

10.3.8 <u>Professional Liability—Subcontractors</u>. If the Work to be performed by a Subcontractor includes any professional design services (including without limitation sprinkler and/or fire protection and other design-build work) the Subcontractor shall maintain professional liability insurance without design-build exclusions with limits not less than as identified in the following table:

Subcontract Sum	Each Claim	Annual Aggregate
Up to \$50,000,000	\$1,000,000	\$2,000,000
More than \$50,000,000	\$2,000,000	\$4,000,000

- **10.3.8.1** The professional liability policy shall have an effective date on or before the date that the Subcontractor first started to provide any Project-related services.
- **10.3.8.2** Upon submission of the associated certificate of insurance and at each policy renewal, the Contractor shall advise the Contracting Authority in writing of any actual or alleged claims that may erode the Subcontractor's professional liability policy's limits.
- **10.3.8.3** The Subcontractor shall maintain the professional liability insurance in effect for no less than 5 years after the earlier of the termination of the Contract or Substantial Completion of all Work.
- **10.3.8.4** If the Subcontractor is not authorized under Applicable Law to directly provide professional design services, the Subcontractor may satisfy the requirements of this **Section 10.3.7.5** by providing a contractor's professional liability insurance policy.
- **10.3.9** <u>Aviation Liability</u>. If the Contractor or a Subcontractor uses aircraft, including helicopters, in performance of the Work, the Contractor shall maintain aircraft or aviation liability coverage in an amount of no less than \$10,000,000. The Contracting Authority and Owner will not be liable for any damage to any aircraft owned, leased, rented, or borrowed by the Contractor or a Subcontractor.
- **10.3.10** Watercraft Liability. If the Contractor or a Subcontractor uses watercraft in performance of the Work, the Contractor shall maintain watercraft liability coverage including protection and indemnity insurance in an amount of no less than \$5,000,000. The Contracting Authority and Owner will not be liable for any damage to any watercraft owned, leased, rented, or borrowed by the Contractor or Subcontractor.
- **10.3.11** Equipment Coverage. The Contracting Authority and Owner will not insure or be liable for damage to any Contractor or Subcontractor owned, leased, rented, or borrowed tools, equipment, or vehicles. The Contractor and Subcontractors are solely responsible for maintaining all insurance necessary to cover their tools, equipment, and vehicles.
- **10.3.12** Ocean Marine Insurance. If the shipment of equipment or materials for the Work will not be covered by the builder's risk insurance required under **Section 10.4**, the Contractor shall maintain ocean marine insurance to the Site including cost, insurance, and freight with limits of not less than an amount equal to the full replacement cost of equipment/materials shipped to final destination point. The insurance shall include the following minimum requirements:
 - 10.3.12.1 all-risk basis including war risk and all forms of terrorism;
 - **10.3.12.2** coverage for general average and salvage charges;
 - **10.3.12.3** "on deck" coverage;
 - 10.3.12.4 warehouse-to-warehouse coverage;
 - 10.3.12.5 coverage to include losses from strikes, riots, and civil commotions ("SR&CC coverage");
 - 10.3.12.6 coverage to include losses from free of capture and seizure warranty ("FC&S Warranty coverage");
 - **10.3.12.7** "Inchmaree" clause;
 - **10.3.12.8** sue and labor;
 - 10.3.12.9 "both-to-blame" coverage;
 - 10.3.12.10 free of particular average;
 - 10.3.12.11 inland coverage including on-land shipment, port storage, and barge transit upon inland waterways; and
 - 10.3.12.12 damage by saltwater and rainwater perils and cargo sweat.
- **10.3.13** <u>Additional Property Insurance</u>. For any demolition, blasting, excavating, tunneling, shoring, or similar operations, the Contractor shall provide and maintain Property Damage Liability insurance with a limit of liability equal to the limit as specified in the applicable sections of **Article 10**.

10.4 Builder's Risk Insurance

- **10.4.1** The Contractor shall provide and maintain, during the progress of the Work and until Contract Completion, a builder's risk insurance policy to cover all Work in the course of construction including false-work, temporary buildings and structures, and materials used in the construction process, stored on or off-site, or while in transit. This insurance shall be on a special cause of loss form that provides coverage on an open perils basis insuring against the direct physical loss of, or damage to, covered property including, but not limited to, theft, vandalism, malicious mischief, earthquake, tornado, lightning, explosion, breakage of glass, flood, collapse, water damage, and hot and cold testing. This insurance shall be written on a replacement cost basis and shall also include debris removal, and/or demolition occasioned by enforcement of Applicable Law.
 - **10.4.1.1** The amount of coverage shall be not less than the total completed value of the Project, including the value of permanent fixtures and decorations, with a deductible of not more than \$25,000 per occurrence. Any deductible over the amount specified shall be authorized in writing by the Owner and Contracting Authority.
 - **10.4.1.2** The named insureds under the policy shall include the State, Contracting Authority, Owner, Contractor, Subcontractors at all tiers, and Separate Contractors.
 - **10.4.1.3** Coverage shall include a provision to pay the reasonable extra costs of acceleration and expediting temporary and permanent repairs to, or permanent replacement of, damaged property. This shall include overtime wages and the extra cost of "express" or other means for rapidly transporting materials and supplies necessary to the repair or replacement.
 - **10.4.1.4** Coverage shall include "soft cost endorsement" including, but not limited to, the reasonable extra costs of the A/E and reasonable Contractor extension or acceleration costs.
 - 10.4.1.5 Coverage shall include material in transit or stored off-site and identified for the Project.
 - **10.4.1.6** Coverage shall waive all rights between the Owner, Contracting Authority, Contractor, and Subcontractors at any tier, for damages caused by fire or any other perils to the extent of actual recovery of any insurance proceeds under the policy.
 - **10.4.1.7** Coverage shall include appropriate sub-limits for installation coverage.
 - 10.4.1.8 Coverage shall include provisions for mechanical or electrical breakdown, or boiler system testing.
 - **10.4.1.9** Coverage shall include temporary structures and scaffolding, along with collapse coverage.
 - **10.4.1.10** Coverage shall be primary to all other applicable insurance.
 - **10.4.1.11** The builder's risk policy shall specifically permit and allow for Partial Occupancy by the Owner prior to Contract Completion and coverage shall remain in effect until all punch list items are completed.
 - **10.4.1.12** The Contractor's tools and equipment shall not be covered under the builder's risk policy. It is the Contractor's sole responsibility to maintain such coverage, which shall be included in its Overhead (a component of Contractor's Fee) and not included as a separate item in the Contractor's Schedule of Values.
- **10.4.2** If the Contractor is involved solely in the installation of material and equipment and not in new building construction, the Contractor shall purchase and maintain a builder's risk, builder's risk-renovations, or installation floater insurance policy. The policy shall comply with the provisions of **Section 10.4.1**.

10.5 Waivers of Subrogation

- **10.5.1** To the fullest extent permitted by Applicable Law, the Contractor waives all rights against the Owner, Contracting Authority, and their agents and employees for damages to the extent covered by any insurance, except rights to the proceeds of that insurance. All policies shall accomplish the waiver of subrogation by endorsement or otherwise.
- **10.5.2** The Owner, Contracting Authority, and Contractor waive all rights against each other for damages caused by fire or other perils to the extent of actual recovery of any insurance proceeds under any property insurance, inland marine insurance, or builder's risk insurance applicable to the Work.

10.6 Indemnification for Injury or Damage

- **10.6.1** To the fullest extent permitted by Applicable Law, the Contractor shall indemnify, defend, and hold harmless the Indemnified Parties from and against all claims, costs, damages, losses, fines, penalties, and expenses (including but not limited to all fees and charges of attorneys and other professionals, and all court, arbitration, or other dispute-resolution costs) arising out of or in connection with the Project, provided that any such claim, cost, damage, loss, fine, penalty, or expense is attributable to:
 - **10.6.1.1** bodily injury, sickness, disease, or death, or to injury to or destruction of tangible property but only to the extent caused by the negligent acts, errors, or omissions of the Contractor or a person or entity for whom the Contractor may be liable;
 - **10.6.1.2** infringement of patent rights or copyrights by the Contractor or a person or entity for whom the Contractor may be liable; or
 - **10.6.1.3** a violation of Applicable Law but only to the extent attributable to the Contractor or a person or entity for whom the Contractor may be liable.
- **10.6.2** The Contractor's indemnification obligation under **Section 10.6** exists regardless of whether or not and the extent to which the claim, damage, loss, fine, penalty, or expense is caused in part by a party indemnified under **Section 10.6**. But nothing in **Section 10.6** obligates the Contractor to indemnify any individual or entity from and against the consequences of that individual or entity's own negligence.
- **10.6.3** The Contractor's obligations under **Section 10.6** shall not extend to the liability of the A/E, A/E's consultants, agents, representatives, or employees for negligent preparation or approval of Drawings, Specifications, Change Orders, opinions, and any other responsibility of the A/E, except to the extent covered by the Contractor's insurance.
- **10.6.4** In claims against an Indemnified Party by any direct or indirect employee (or the survivor or personal representative of that employee) of the Contractor or a person or entity for whom the Contractor may be liable, the indemnification obligation under **Section 10.6** will not be limited by a limitation on the amount or type of damages, compensation, or benefits payable under workers' compensation acts, disability benefit acts, or other employee benefit acts.
- **10.6.5** The Contractor's indemnification obligation under **Section 10.6** will not be limited by any insurance policy provided or required in connection with the Project.
- **10.6.6** The Contractor's obligations under **Section 10.6** shall not negate, abridge, or reduce other rights or obligations of indemnity, which would otherwise exist as to an Indemnified Party.
- **10.6.7** The Contractor's indemnification obligation under **Section 10.6** will survive termination of the Contract and Contract Completion.
- **10.6.8** The Contracting Authority may deduct from the Contract Sum the claims, damages, losses, fines, penalties, and expenses for which the Contractor is liable under **Section 10.6**. If those claims, damages, losses, fines, penalties, and expenses exceed the unpaid balance of the Contract Sum, the Contractor shall immediately pay the difference to the Owner.

ARTICLE 11 - SUSPENSION AND TERMINATION

11.1 Suspension of the Work

- **11.1.1** The Contracting Authority, without cause and without prejudice to any other right or remedy it may have, may order the Contractor in writing to suspend, delay, or interrupt performance of the Work in whole or in part for such period as the Contracting Authority may determine.
 - **11.1.1.1** If the Contracting Authority suspends the Work under this **Section 11.1.1** and the Contractor complies with **Article 8**, the Contract Sum and Contract Times shall be adjusted for increases in the cost and time caused by the suspension, delay, or interruption. The adjustment of the Contract Sum, however, shall not include profit (a component of Contractor's Fee).
 - **11.1.1.2** Notwithstanding the foregoing, no adjustment shall be made to the Contract Sum or Contract Times to the extent that:
 - .1 performance was, or could have been, suspended, delayed, or interrupted by a cause for which the Contractor is responsible; or
 - .2 an equitable adjustment is made or denied under another provision of the Contract.

- **11.1.1.3** If the Contracting Authority suspends the Work under this **Section 11.1.1** and the Contractor submits a proper Contractor Payment Request, subject to all other provisions of the Contract Documents, the Contractor shall be entitled to payment of compensation due under the Contract Documents for Work performed before the suspension based upon the Schedule of Values.
- 11.1.2 The Contracting Authority, without prejudice to any other right or remedy it may have, may order the Contractor in writing to suspend, delay, or interrupt the performance of the Work in whole or in part for such period as the Contracting Authority may determine for any of the following reasons: (1) Defective Work; (2) the Contractor is causing undue risk of damage to any part of the Project or adjacent area; (3) the Contractor fails to furnish or perform the Work in such a way that the complete Work will conform to the requirements of the Contract Documents; or (4) any other cause the Contracting Authority reasonably believes justifies suspension.
 - **11.1.2.1** The Contracting Authority's exercise of its right to suspend the Work under this **Section 11.1.2** shall not entitle the Contractor to any adjustment of the Contract Sum, Contract Times, or both.
 - **11.1.2.2** If the Contracting Authority is adjudged to have improperly suspended the Work under this **Section 11.1.2**, the suspension shall be deemed to have been a suspension under **Section 11.1.1**.
- **11.1.3** Upon receipt of notice of suspension under this **Section 11.1**, the Contractor shall cease Work on the suspended activities and take all necessary or appropriate steps to limit disbursements and minimize respective costs. The Contractor shall furnish a report to the Contracting Authority, within 5 days of receiving the notice of suspension, describing the status of the Work, including, but not limited to, results accomplished, resulting conclusions, and other information as the Contracting Authority may require.
- **11.1.4** The Contracting Authority's right to stop the Work shall not give rise to any duty to exercise the right for the benefit of the Contractor or any other party, and the Contracting Authority's exercise or failure to exercise the right shall not prejudice any of the Contracting Authority's other rights.

11.2 Termination for Convenience

- **11.2.1** The Contracting Authority may, at any time, terminate the Contract in whole or in part for the Owner's convenience and without cause, at any time upon 10 days' written notice to the Contractor.
- **11.2.2** Upon receipt of the notice of termination for convenience, the Contractor shall immediately proceed with performance of the following duties in accordance with instructions from the Contracting Authority:
 - 11.2.2.1 cease operation as specified in the notice;
 - **11.2.2.2** place no further orders and enter into no further subcontracts for materials, labor, services, or facilities, except as necessary to complete continued portions of the Project;
 - 11.2.2.3 terminate all subcontracts and orders to the extent they relate to the Work terminated;
 - 11.2.2.4 proceed with Work not terminated; and
 - **11.2.2.5** take actions that may be necessary, or that the Contracting Authority may direct, for the protection and preservation of the terminated Work.
- **11.2.3** Upon termination, the Contracting Authority shall pay the Contractor in accordance with the Schedule of Values for Work completed, including any retained funds, and the value of materials ordered and delivered, less any salvage credit the Contractor may receive for them.
 - **11.2.3.1** All materials, equipment, facilities, and supplies at the Site or stored off-site, for which the Contractor has received payment, shall become the property of the Owner.
 - **11.2.3.2** The Contractor is entitled to a fair and reasonable profit for Work performed and reasonable expenses directly attributable to termination of the Contract. In no event shall the Contractor be entitled to **(1)** Contractor's Fee on Work not performed or **(2)** compensation in excess of the total Contract Sum.
- **11.2.4** If the Contracting Authority terminates the Work under this **Section 11.2**, the termination shall not affect the rights or remedies of the State against the Contractor then existing or which may thereafter accrue.
- **11.2.5** Notwithstanding **Section 11.2.3**, if the Contracting Authority terminates the Work under this **Section 11.2**, but there exists an event of the Contractor's default, the Contractor shall be entitled to receive only such amounts as it would be entitled to receive following the occurrence of an event of default as provided in **Section 11.3**.

11.3 Termination for Cause

- **11.3.1** The Contracting Authority may terminate all or a portion of the Contract if the Contractor commits a material breach of the Contract including but not limited to:
 - 11.3.1.1 failure to prosecute the Work with the necessary force or in a timely manner;
 - **11.3.1.2** refusal to remedy Defective Work;
 - **11.3.1.3** failure to supply enough properly skilled workers or proper materials;
 - **11.3.1.4** failure to properly make payment to Subcontractors or Consultants;
 - 11.3.1.5 performance of any services outside of the United States;
 - 11.3.1.6 permitting its Subcontractors or Consultants to perform any services outside of the United States; or
 - **11.3.1.7** disregarding laws, ordinances, or rules, regulations, or orders of a public authority with jurisdiction over the Project.
- **11.3.2** If the Contracting Authority intends to exercise its termination rights under this **Section 11.3**, the Contracting Authority shall issue not less than 5 days' written notice to the Contractor and the Contractor's Surety in accordance with ORC Section 153.17 ("5-Day Notice").
 - **11.3.2.1** Notwithstanding any provision of the Contract to the contrary (1) the issuance of a 72-Hour Notice under **Section 6.23.1** is not a condition precedent to the Contracting Authority's exercise of its rights under **Section 11.3** and (2) the Contracting Authority's decision to not issue a 72-Hour Notice under **Section 6.23.1** will not prejudice the Contracting Authority's rights under **Section 11.3**.
- **11.3.3** If the Contractor fails to satisfy the requirements set forth in the 5-Day Notice within 15 days of receipt of the 5-Day Notice, the Contracting Authority may declare the Contractor in default, terminate the Contract, and employ upon the Work the additional force or supply materials or either as appropriate, and remove Defective Work.
- **11.3.4** If the Contract is terminated, the Contractor's Surety may perform the Contract. If the Contractor's Surety does not commence performance of the Contract within 10 days of the date of Contract termination, the Contracting Authority may complete the Work by means the Contracting Authority determines appropriate. The Contracting Authority may take possession of and use all materials, facilities, and equipment at the Site or stored off-site, for which the State has paid.
- **11.3.5** If the Contract is terminated, the Contractor shall not be entitled to further payment. If the unpaid balance of the Contract Sum is exceeded by the costs of finishing the Work, including without limitation the fees and charges of engineers, architects, attorneys, and other professionals and court costs, and other damages incurred by the Owner and not expressly waived, the Contractor or Surety shall immediately pay the amount of the insufficiency to the Owner. This obligation for payment shall survive termination of the Contract.
- **11.3.6** If the Contractor's Surety performs the Work, the provisions of the Contract Documents govern the Surety's performance, with the Surety in place of the Contractor in all provisions including, but not limited to, provisions for payment for the Work, and provisions of the right of the Contracting Authority to complete the Work.
- **11.3.7** If the Contracting Authority terminates the Contract under this **Section 11.3**, the termination shall not affect any rights or remedies of the State against the Contractor then existing or which may thereafter accrue. The Contracting Authority's retention or payment of funds due the Contractor shall not release the Contractor or the Contractor's Surety from liability for performance of the Work in accordance with the requirements of the Contract Documents.
- **11.3.8** If the Contracting Authority is adjudged to have improperly terminated the Contract under this **Section 11.3**, the termination will be deemed to have been a termination under **Section 11.2**.

11.4 Contractor Insolvency

11.4.1 Bankruptcy of Contractor.

11.4.1.1 If the Contractor files a voluntary petition in bankruptcy or has an involuntary petition in bankruptcy filed against it, the Contractor, the Contractor as the debtor-in-possession, or the trustee of the Contractor's bankruptcy estate shall file a motion to assume or reject the Contract under Bankruptcy Code §365, 11 U.S.C. §365, within 20 days after the filing of the voluntary petition or involuntary petition and shall diligently prosecute that motion to conclusion so as to obtain an order granting or denying that motion within 45 days after the filing of the voluntary or involuntary petition. The failure to file and prosecute that motion within the time limits provided by this Section 11.4 shall constitute a material breach of the Contract as time is of the essence with respect to Contractor's performance of all terms of this Contract. The Contractor agrees to the granting of relief from the automatic stay of

the Bankruptcy Code, 11 U.S.C. §362(a), to permit the Contracting Authority to terminate the Contract for cause in such instance and issue and serve all notices necessary to terminate the Contract or arising out of the termination of the Contract and to take any and all other action necessary to terminate the Contract.

11.4.2 Receivership or Assignment for the Benefit of Creditors.

11.4.2.1 If the Contractor makes a general assignment for the benefit of creditors or if a receiver is appointed for all or a substantial part of the Contractor's business or property, the Contracting Authority shall serve written notice on the Contractor and Contractor's Surety stating that any failure of the Contractor to provide adequate assurance of continued performance shall be considered a rejection of the Contract, which shall result in termination of the Contract for cause. Such termination of the Contract need not be evidenced by an order of any court.

ARTICLE 12 - GENERAL PROVISIONS

12.1 Contractor's Documents and Contract Documents

12.1.1 Ownership.

- **12.1.1.1** The Owner alone owns the Contractor's Documents and the Contract Documents and every right, title, and interest therein.
 - .1 The Contractor must execute and deliver and cause its employees and agents and all Subcontractors and Consultants to execute and deliver, to the Owner any transfers, assignments, documents, or other instruments (if any) necessary to vest in the Owner complete right, title, interest in and ownership of the Contractor's Documents and the Contract Documents.
- **12.1.1.2** The Contractor may retain copies, including reproducible copies, of the Contractor's Documents and the Contract Documents for information, reference, and performance of the Work.
- **12.1.1.3** The submission or distribution of the Contractor's Documents or the Contract Documents to meet official regulatory requirements or for similar purposes in connection with the Project is not a waiver of the Owner's reserved rights in the Contractor's Documents and the Contract Documents. Any unauthorized use of the Contractor's Documents or the Contract Documents shall be at the sole risk of the entity making the unauthorized use.
- **12.1.1.4** The Contractor shall provide Electronic Files (in native format) to Separate Consultants and Separate Contractors for their use in connection with the Project. The Contractor shall provide the Electronic Files (1) at no additional cost to the Separate Consultants, Separate Contractors, and Owner and (2) without requiring the Separate Consultants, Separate Contractors, or Owner to agree to any terms or conditions concerning the provision, receipt, or use of the Electronic Files that differ in any material respect from the Contract.

12.1.2 Intent.

- **12.1.2.1** The intent of the Contract Documents is to include all items necessary for the proper execution and completion of the Work by the Contractor.
- 12.1.2.2 The Contract Documents are complementary, and what is required by one is binding as if required by all.
- **12.1.2.3** The Contractor shall provide all labor and materials necessary for the entire completion of the Work described in the Contract Documents and reasonably inferable to produce the intended results.
- **12.1.2.4** The Drawings govern dimensions, details, and locations of the Work. The Specifications govern quality of materials and workmanship.
- **12.1.2.5** The organization of the Specifications in divisions, sections, and articles, and the arrangement of Drawings shall not restrict the Contractor in dividing the Work among Subcontractors or in establishing the extent of Work to be performed by any trade.
- **12.1.2.6** In the event of inconsistency or conflict within the Contract Documents, the Contractor shall provide the better quality or greater quantity of Work, and comply with the stricter requirement.
- **12.1.2.7** Unless otherwise defined in the Contract Documents, words that have well-known technical or construction industry meanings are used in accordance with those recognized meanings.
- **12.1.2.8** The Sections of Division 01 "General Requirements" govern the performance of the Work of all Sections of the Specifications.

12.1.3 Use of Electronic Files.

- **12.1.3.1** The Owner, Contracting Authority, A/E, and Contractor reasonably expect that they will provide Electronic Files to each other to facilitate the design and construction of the Project consistent with current practices and customs in the construction industry.
- **12.1.3.2** The Owner, Contracting Authority, A/E, and Contractor acknowledge that the use of Electronic Files involves risks not generally associated with the use of paper documents. Those risks include, for example and without limitation, alteration (inadvertent or intentional) and deterioration, both of which may not be readily apparent through casual observation.
- **12.1.3.3** The Owner, Contracting Authority, A/E, and Contractor do not warrant to each other that any Electronic File they provide (1) was not altered though transmission; (2) is compatible with the recipient's computer system or software; (3) will not be altered through degradation of the recipient's storage media; or (4) is suitable for conversion/translation to and subsequent use in a system or format other than the Electronic File's original system or format.
- **12.1.3.4** Before relying on any Electronic File it receives, the recipient is responsible for verifying that the Electronic File was not altered though transmission, degradation of the recipient's own storage media, or other causes.
- **12.1.3.5** If the recipient of an Electronic File converts/translates the Electronic File from its original system or format to an alternate system or format, the recipient assumes the risk that the conversion/translation created errors in the converted/translated file.
- **12.1.3.6** The Owner, Contracting Authority, A/E, and Contractor shall each maintain and operate its own computer systems and storage media in a commercially reasonable way and take reasonable steps to prevent errors in and deterioration of the Electronic Files it creates, provides, and receives.
- **12.1.3.7** In the event of a discrepancy between information contained in a paper version of a document and the Electronic File of that document, the paper version will govern.
- **12.1.3.8** This **Section 12.1.3** does not relieve the Contractor of its responsibility for the preparation, completeness, or accuracy of the Contractor's Documents.

12.2 Public Relations

- **12.2.1** <u>Publicity prior to completion of the Project</u>. Prior to completion of the Project, public relations or publicity about the Project shall be solely within the control, and with the consent of, the Owner.
- **12.2.2** <u>Publicity after completion of the Project</u>. After completion of the Project, the Contractor may exercise reasonable public relations and marketing efforts related to the Project, provided the Contractor properly identifies the Owner and Contracting Authority, and their participation in the Project.
- **12.2.3** <u>Professional Photography</u>. If the Contractor commissions photography of the completed Project, the Contractor shall include in its photography agreements a release for unrestricted and unlimited use of photographs by the Owner and Contracting Authority, and shall provide the Owner and Contracting Authority with a reasonable quantity of photographs for use in the Owner's and the Contracting Authority's marketing and awareness activities, including, but not limited to, profiles of the Project on their respective websites.
- **12.2.4** <u>Craft Awards and Other Recognition</u>. If the Contractor submits the Project for craft awards or other similar venues for recognition of the Project, the Contractor shall properly identify the Owner and Contracting Authority, and their participation in the Project. In addition, if the Project receives any craft award or other recognition, the Contractor shall provide duplicate copies of the award plaque or other memento of the award to the Owner and Contracting Authority.

12.3 Application and Governing Law

- **12.3.1** The Contract and the rights of the parties thereunder shall be governed by the laws of the state of Ohio and only Ohio courts shall have jurisdiction over any action or proceeding concerning the Contract and/or performance thereunder. The Contractor irrevocably consents to such jurisdiction.
- **12.3.2** The parties to the Contract shall comply with Applicable Law.
- **12.3.3** Other rights and responsibilities of the Contractor, A/E, Contracting Authority, and Owner are set forth throughout the Contract Documents and included under different titles, articles, and paragraphs for convenience.

12.4 Conditions of the Contract

12.4.1 These General Conditions govern, take precedence over, and shall not be superseded or amended by Drawings and Specifications, unless so provided in Supplementary Conditions prepared by the Contracting Authority and approved by the Ohio Facilities Construction Commission.

12.5 Notice of Commencement.

- **12.5.1** The Contracting Authority shall prepare a Notice of Commencement and make it available as required under ORC Section 1311.252.
- **12.5.2** Upon request, the Contracting Authority or the Contractor shall furnish the Notice of Commencement to Subcontractors or any other member of the public.

12.6 Written Notice

- **12.6.1** Notice under the Contract Documents shall be validly given if:
 - 12.6.1.1 delivered personally to a member of the organization for whom the notice is intended;
 - 12.6.1.2 delivered, or sent by registered or certified mail, to the last known business address of the organization; or
 - **12.6.1.3** sent by facsimile, email, or web-based project management software, provided the original, signed document is delivered within 3 business days after the date of the electronic transmission.
- **12.6.2** When the Owner, Contracting Authority, A/E, or Contractor gives notice to one of the other 3, it shall also simultaneously send a copy of that notice to the others.
- **12.6.3** A copy of all notices, certificates, requests, or other communications to the Contracting Authority shall be sent to the Project Manager.
- **12.6.4** In the event of an emergency involving the Project, including, but not limited to, a fatality, serious injury, fire, collapse, flood, utility, or power loss to occupied facilities, explosion, or environmental damage, the Contractor shall immediately notify the A/E, Contracting Authority, and Owner by telephone.
- **12.6.5** The Contracting Authority, Owner, A/E, or Contractor may, by written notice given hereunder, designate addresses, telephone numbers, email addresses, or facsimile numbers to which notices, certificates, requests, or communications shall be sent.

12.7 Taxes

- **12.7.1** Only those materials that ultimately become a part of the completed structure or improvement that constitutes the Project shall be exempt from state sales tax and state use tax.
- **12.7.2** The purchase, lease, or rental of material, equipment, parts, or expendable items as concrete form lumber, tools, oils, greases, and fuels, which are used in connection with the Work, are subject to the application of state sales tax and state use tax.

12.8 Computing Time

- **12.8.1** When the Contract Documents refer to a period of time by a number of days, the period shall be computed to exclude the first and include the last day of the period. If the last day of the period falls on a Saturday, Sunday, or a legal holiday, that day shall be omitted from the computation and the period shall end on the next succeeding day that is not a Saturday, Sunday, or legal holiday.
- **12.8.2** Except as excluded under **Section 12.8.1**, the Contract Times and all other periods referred to in the Contract Documents includes Saturdays, Sundays, and all days defined as legal holidays by **Section 12.8.4**.
- 12.8.3 The standard workdays for State projects are Monday through Friday, excluding legal holidays.
- **12.8.4** Legal holidays are as follows:
 - **12.8.4.1** New Year's Day First Day in January;
 - **12.8.4.2** Martin Luther King Jr. Day Third Monday in January;
 - **12.8.4.3** Washington-Lincoln (President's) Day Third Monday in February;
 - **12.8.4.4** Memorial Day Last Monday in May;
 - **12.8.4.5** Juneteenth Day Nineteenth Day of June;

- **12.8.4.6** Independence Day Fourth day of July;
- 12.8.4.7 Labor Day First Monday in September;
- **12.8.4.8** Columbus Day Second Monday in October;
- **12.8.4.9** Veterans' Day Eleventh Day of November;
- 12.8.4.10 Thanksgiving Day Fourth Thursday of November; and
- **12.8.4.11** Christmas Day Twenty-fifth day of December.
- **12.8.5** If a legal holiday falls on a Saturday, it is observed on the preceding Friday. If a legal holiday falls on a Sunday, it is observed on the following Monday.

12.9 Time of the Essence

- **12.9.1** Time limits stated in the Contract Documents are of the essence of the Contract and all obligations under the Contract. By signing the Agreement, the Contractor acknowledges that the Contract Times are reasonable, taking into consideration the usual weather and other conditions prevailing in the locality of the Project. By signing the Construction Schedule, the Contractor acknowledges that the specified Milestone dates are reasonable, taking into consideration the usual weather and other conditions prevailing in the locality of the Project.
 - **12.9.1.1** The Notice to Proceed establishes the date for commencement of the Work.
 - **12.9.1.2** The Contractor acknowledges that the Owner has entered into, or may enter into, agreements for use of all or part of the premises where the Work is to be completed based upon the Contractor achieving Contract Completion within the associated Contract Time.
 - **12.9.1.3** The Contractor shall perform the Work in a reasonable, efficient, and economical sequence, and in the order and time as provided in the Construction Progress Schedule.
 - **12.9.1.4** The Contractor acknowledges that it may be subject to interference, disruption, hindrance, or delay in the progress of the Work from any cause. The sole remedy for such interference, disruption, hindrance, or delay shall be an extension of the Contract Times under **Article 8**, unless otherwise required by ORC Section 4113.62.

12.10 Successors and Assigns

- **12.10.1** The Contracting Authority and Contractor each bind themselves, their successors, assigns, and legal representatives, to the other party to this Contract and to the successors, assigns, and legal representatives of the other party with respect to all terms of this Contract.
- **12.10.2** The Contracting Authority and Contractor each acknowledge that the Owner is an intended third-party beneficiary of this Contract.
- **12.10.3** The Contractor shall not assign, or transfer any right, title, or interest in this Contract without the Contracting Authority's prior written consent.

12.11 Extent of Contract

- **12.11.1** Entire Contract. The Contract Documents represent the entire and integrated agreement between the Contracting Authority and Contractor and supersede all prior negotiations, representations, or agreements, either written or oral.
- **12.11.2** <u>Multiple Counterparts</u>. This Contract may be executed in any number of counterparts, each of which shall be regarded as an original and all of which shall constitute but one and the same instrument.
- **12.11.3** <u>Captions</u>. The captions and headings in this Contract are for convenience only and in no way define, limit, or describe the scope or intent of any provisions or sections hereof.
- **12.11.4** <u>Precedence</u>. If there are any inconsistencies between the provisions of the Contract Documents and the provisions of the Contract, the provisions of this Contract shall prevail.

12.12 Severability

12.12.1 If any term or provision of this Contract or the application thereof to any Person or circumstance, is finally determined to be invalid or unenforceable by a court of competent jurisdiction, the remainder of this Contract or the application of such term or provision to other Persons or circumstances, shall not be affected thereby, and each term and provision of this Contract shall be valid and enforced to the fullest extent permitted by Applicable Law.

12.13 Electronic and Facsimile Signatures

12.13.1 Any party hereto may deliver a copy of its counterpart signature page to this Contract via electronic signature software, fax, e-mail, or web-based project management software. Each party hereto shall be entitled to rely upon an electronic, scanned, or facsimile signature of any other party delivered in such a manner as if such signature were an original.

12.14 No Third-Party Interest

12.14.1 Except as expressly provided under **Sections 6.2.3** through **6.2.5** and **Section 12.10.2**, **(1)** no person or entity, other than the Contracting Authority and Contractor, will have any right or interest under the Contract, and **(2)** the Contract does not create a contractual relationship of any kind between any people or entities other than the Contracting Authority and Contractor.

12.15 Ohio Retirement System

12.15.1 All individuals employed by the Contractor that provide personal services to the Contracting Authority or Owner are not public employees for the purposes of ORC Chapter 145, as amended.

12.15.2 If the Contractor is a PERS retirant, as defined by ORC Section 145.38, the Contractor shall notify the Contracting Authority of such status in writing prior to commencement of Work. The Contracting Authority, Owner, or State is not responsible for changes to the Contractor's retirement benefits resulting from entering into this Contract.

12.16 No Waiver

12.16.1 The failure of the Contracting Authority or Contractor to insist in any one or more instances upon the strict performance of any one or more of the provisions of the Contract or to exercise any rights under the Contract or provided by law will not be construed as a waiver or relinquishment of that provision or right or of the right to subsequently demand strict performance or exercise the right and the rights will continue unchanged and remain in full force and effect.

12.17 Rights and Remedies

12.17.1 The duties, obligations, rights, and remedies under the Contract are in addition to and not a limitation of the duties, obligations, rights, and remedies otherwise imposed by or available under Applicable Law.

12.18 Survival of Obligations

12.18.1 All representations, indemnity obligations, warranties, guarantees, and necessarily continuing obligations under the Contract, will survive final payment, completion and acceptance of the Work, and termination or completion of the Contract.

KEYWORD INDEX

Α

acceleration, 34, 36, 50
Acceptable Components, 17
Affirmative Action, 2
Agreement, 2, 45, 57
Allowance, 41, 42
Alternative Dispute Resolution ("ADR"), 9, 40
antitrust claims, 2
Applicable Law, 1, 2, 4, 7, 8, 9, 16, 18, 21, 22, 25, 33, 37, 43, 44, 46, 50, 51, 55, 58
approval, 3, 5, 7, 8, 11, 12, 13, 14, 15, 16, 21, 22, 23, 24, 25, 27, 30, 32, 51
Architect/Engineer Agreement, 6
As-Built Documents, 25, 26
audit, 32, 35, 40

В

Bankruptcy of Contractor, 53 Basis of Design Component, 17 Bond, 28, 33, 45 builder's risk, 33, 49, 50 Building Information Modeling ("BIM"), 15

C

capacity charges, 10
Certificate of Contract Completion, 25, 27, 28, 45
certificate of occupancy, 25, 27
Certificate of Substantial Completion, 25, 27
Change Directive, 28, 29, 30, 31, 32, 35
change in the Work, 5, 28, 29, 30, 31, 32, 33, 34, 42
Change Order, 14, 15, 16, 22, 24, 25, 28, 29, 30, 31, 32, 34, 35, 39, 40, 41, 42, 43, 51

Change Order Log, 30 Claim, 31, 32, 35, 36, 37, 39, 40, 41 Claim Affidavit, 9 cleaning, 20, 26 Commissioning, 21 Commissioning Agent ("CxA"), 9, 21 Computer-Aided Design ("CAD"), 15 construction procedures, 11 Construction Progress Schedule, 10, 11, 13, 14, 15, 24, 31, 34, 35, 36, 37, 57 Construction Specifications Institute ("CSI"), 42 Construction Stage, 10 construction supervision, 12 Contract, 1, 2, 3, 4, 5, 6, 7, 8, 10, 11, 16, 23, 24, 25, 28, 30, 32, 35, 36, 37, 41, 42, 43, 44, 45, 46, 47, 48, 49, 51, 52, 53, 54, 55, 56, 57, 58 Contract Completion, 10, 11, 13, 25, 27, 28, 37, 50, 51, 57 Contract Documents, 5, 6, 7, 8, 11, 12, 13, 15, 16, 17, 20, 21, 22, 23, 24, 25, 26, 27, 28, 30, 31, 37, 38, 39, 41, 43, 44, 45, 52, 53, 54, 55, 56, 57 Contract Sum, 2, 3, 4, 6, 8, 15, 16, 24, 25, 28, 29, 30, 31, 32, 33, 34, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 48, 51, 52, 53 Contract Times, 4, 6, 15, 16, 23, 24, 28, 29, 30, 31, 34, 35, 36, 37, 38, 39, 40, 44, 51, 52, 56, 57 Contractor Payment Request, 3, 4, 8, 25, 35, 42, 43, 44, 45, 52 Contractor Personnel Costs, 32 Contractor's Fee, 34, 41, 42 Coordination Areas, 15 Coordination Drawings, 15 coordination meetings, 15 Coordination Participant, 15 correction of the Work, 24 Correction Period, 7, 24 critical path, 13, 14, 35, 36, 37 D

daily log, 11, 36
default, 44, 52, 53
Defective Work, 7, 15, 17, 23, 24, 25, 26, 43, 44, 52, 53
demonstration and training, 27
Differing Site Conditions, 32, 35
dispute review board, 40
Domestic Steel, 2, 23
drainage, 19
Drawings, 12, 25, 26, 51, 54, 56
Drug Free Safety Program ("DFSP"), 2, 3

Ε

electric service, 19, 20 electronic signature, 58 emergency, 4, 56 Encouraging Diversity, Growth and Equity ("EDGE"), 3, 4, 42, 43, 44 environmental controls, 19
Equal Employment Opportunity, 2
Equal Opportunity Coordinator ("EOC"), 1, 2, 3, 4
equipment, 10, 11, 14, 15, 17, 18, 20, 21, 23, 33, 39, 41,
42, 47, 49, 50, 52, 53, 56
Estimated Construction Cost, 13
explosives, 21

F

facilities, 18, 19 Field Conditions, 16 Final Inspection, 27 Fire Marshal, 10, 26

G

General Conditions, 56 General Conditions Costs, 33, 42 Green Building Certification Institute, 5

Н

Hazardous Materials, 18, 47 hoisting facilities, 20

I

indemnification, 51 Institution of Higher Education, 39 Institutional Designee, 39, 40 insurance, 21, 27, 33, 40, 41, 43, 45, 46, 47, 48, 49, 50, 51 interruption of existing services, 21

J

joint venture, 48

L

labor, 2, 3, 9, 17, 32, 33, 34, 37, 39, 41, 42, 43, 49, 52, 54 Leadership in Energy and Environmental Design ("LEED") Rating System, 5 legal holiday, 56, 57 licenses, 10 limited-liability company, 48 Liquidated Damages, 35, 38, 44

M

MasterFormat, 42
material, 8, 9, 10, 12, 16, 17, 18, 19, 20, 21, 22, 23, 26, 28, 29, 30, 31, 32, 33, 35, 39, 40, 41, 42, 43, 44, 45, 49, 50, 52, 53, 54, 56
Material Safety Data Sheet, 18
Material Supplier, 8
mediation, 40
Milestone, 13, 14, 35, 38, 57
minor change in the Work, 6, 28, 31

Modification, 4, 28, 29, 30, 35

N

National Pollutant Discharge Elimination System ("NPDES"), 10, 12 negotiation, 40
Neutral Facilitator, 5, 6, 10 no damage for delay, 37
Nondiscrimination, 1
Notice of Commencement, 56
Notice to Proceed, 5, 7, 10, 13, 42, 57
Notice, 5-Day, 53
Notice, 72-Hour, 24, 53

0

Occupational Safety and Health Administration
("OSHA"), 17, 18
Ohio Building Code, 7
Ohio Bureau of Workers' Compensation ("OBWC"), 2, 3
Ohio Construction Contract Information Report, 2
Ohio Department of Commerce, 2, 33
Ohio Environmental Protection Agency, 10
Ohio Facilities Construction Commission, 5, 32, 39, 40, 42, 56
Ohio Underground Utility Protection Services ("OUPS"), 12
Operation and Maintenance Manuals, 21, 26

Р

Partial Occupancy, 24, 25, 27, 50 partnering, 9, 10 Pencil Copy, 43 performance evaluation, 6 permits, 10 Plan Approval, 10 Prevailing Wage Requirements, 43 Pricing Criteria, 32, 34 Product Data, 21, 22, 25 progress meetings, 6, 14, 15, 18 Project Manager, 5, 9, 17, 18, 20, 39, 56 Project Schedule, 42 Proposal, 30, 31, 32, 35, 36 Proposal Request, 29, 30 Protection of the Project, 16 Punch List, 13, 26, 27, 28, 42

R

Record Documents, 26, 42 Request for Change Order, 30 Request for Interpretation ("RFI"), 16, 25, 35 Retainage, 44 royalties and patents, 2

S

Safety Data Sheet ("SDS"), 18 Samples, 21, 22, 25 schedule of submittals, 11 Schedule of Values, 33, 42, 50, 52 Separate Consultant, 10, 11, 37, 38 Separate Contractor, 10, 11, 22, 37, 38 Shop Drawings, 13, 21, 22, 23, 25 snow and ice, 11 special inspection, 7, 15 Specifications, 12, 25, 43, 51, 54, 56 State, 2, 3, 5, 6, 7, 8, 9, 21, 24, 25, 37, 41, 44, 45, 50, 52, 53, 56 storm water, 10 structural testing, 7 Subcontract, 4, 8, 9, 12, 40, 42, 49 Subcontractor, 2, 3, 6, 7, 8, 9, 12, 13, 15, 17, 21, 23, 26, 32, 33, 34, 35, 36, 40, 41, 44, 45, 46, 49, 53, 54, 56 Substantial Completion, 11, 13, 14, 16, 19, 20, 21, 24, 25, 26, 27, 33, 35, 44, 47, 48, 49 Substitutions, 17 Supplementary Conditions, 56 Surety, 11, 24, 27, 28, 44, 45, 53, 54 Suspension of the Work, 51 sustainability, 4, 5

Т

tap fees, 10 taxes, 34, 56 Termination for Cause, 53 Termination for Convenience, 52 testing, 7, 15, 16, 50 tests and inspections, 15 third-party beneficiary, 11, 57, 58

U

U.S. Green Building Council, 5 uncovering the Work, 23 *UniFormat*, 42 Unit Price, 9, 29, 32, 33, 42, 43 utilities, 18

W

Waivers of Subrogation, 50 warranty, 23 waste materials and rubbish, 20 water, 19 weather delay, 37 written notice, 4, 11, 15, 16, 18, 22, 24, 27, 30, 31, 32, 35, 36, 39, 46, 52, 53, 54, 56

END OF DOCUMENT

Prevailing Wage Determination Cover Letter

County: RICHLAND ✓

Determination Date: 09/15/2023 **Expiration Date:** 12/15/2023

THE FOLLOWING PAGES ARE PREVAILING RATES OF WAGES ON PUBLIC IMPROVEMENTS FAIRLY ESTIMATED TO BE MORE THAN THE AMOUNT IN O.R.C. SEC. 4115.03 (b) (1) or (2), AS APPLICABLE.

Section 4115.05 provides, in part: "Where contracts are not awarded or construction undertaken within ninety days from the date of the establishment of the prevailing wages, there shall be a redetermination of the prevailing rate of wages before the contract is awarded." The expiration date of this wage schedule is listed above for your convenience only. This wage determination is not intended as a blanket determination to be used for all projects during this period without prior approval of this Department.

Section 4115.04, Ohio Revised Code provides, in part: "Such schedule of wages shall be attached to and made a part of the specifications for the work, and shall be printed on the bidding blanks where the work is done by contract..."

The contract between the letting authority and the successful bidder shall contain a statement requiring that mechanics and laborers be paid a prevailing rate of wage as required in Section 4115.06, Ohio Revised Code.

The contractor or subcontractor is required to file with the contracting public authority upon completion of the project and prior to final payment therefore an affidavit stating that he has fully complied with Chapter 4115 of the Ohio Revised Code.

The wage rates contained in this schedule are the "Prevailing Wages" as defined by Section 4115.03, Ohio Revised Code (the basic hourly rates plus certain fringe benefits). These rates and fringes shall be a minimum to be paid under a contract regulated by Chapter 4115 of the Ohio Revised Code by contractors and subcontractors. The prevailing wage rates contained in this schedule include the effective dates and wage rates currently on file. In cases where future effective dates are not included in this schedule, modifications to the wage schedule will be furnished to the Prevailing Wage Coordinator appointed by the public authority as soon as prevailing wage rates increases are received by this office.

"There shall be posted in a prominent and accessible place on the site of work a legible statement of the Schedule of Wage Rates specified in the contract to the various classifications of laborers, workmen, and mechanics employed, said statement to remain posted during the life of such contract." Section 4115.07, Ohio Revised Code.

Apprentices will be permitted to work only under a bona fide apprenticeship program if such program exists and if such program is registered with the Ohio Apprenticeship Council.

Section 4115.071 provides that no later than ten days before the first payment of wages is due to any employee of any contractor or subcontractor working on a contract regulated by Chapter 4115, Ohio Revised Code, the contracting public authority shall appoint one of his own employees to act as the prevailing wage coordinator for said contract. The duties of the prevailing wage coordinator are outlined in Section 4115.071 of the Ohio Revised Code.

Section 4115.05 provides for an escalator in the prevailing wage rate. Each time a new rate is established, that rate is required to be paid on all ongoing public improvement projects.

A further requirement of Section 4115.05 of the Ohio Revised Code is: "On the occasion of the first pay date under a contract, the contractor shall furnish each employee not covered by a collective bargaining agreement or understanding between employers and bona fide organizations of Labor with individual written notification of the job classification to which the employee is assigned, the prevailing wage determined to be applicable to that classification, separated into the hourly rate of pay and the fringe payments, and the identity of the prevailing wage Coordinator appointed by the public authority. The contractor or subcontractor shall furnish the same notification to each affected employee every time the job classification of the employee is changed."

Work performed in connection with the installation of modular furniture may be subject to prevailing wage.

THIS PACKET IS NOT TO BE SEPARATED BUT IS TO REMAIN COMPLETE AS IT IS SUBMITTED TO YOU. (Reference guidelines and forms are included in this packet to be helpful in the compliance of the Prevailing Wage law.) wh1500

Name of Union: Asbestos Local 207 OH

Change #: LCN01-2018fbLoc207OH

Craft: Asbestos Worker Effective Date: 08/23/2018 Last Posted: 08/23/2018

	BHR		Frin	ge Bene	fit Paym	ents		Irrevocable Fund		Total PWR	Overtime Rate
		H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification										
Asbestos Abatement	\$25.50	\$7.25	\$6.45	\$0.65	\$0.00	\$0.00	\$0.07	\$0.00	\$0.00	\$39.92	\$52.67
Trainee	\$16.50	\$7.25	\$1.50	\$0.65	\$0.00	\$0.00	\$0.07	\$0.00	\$0.00	\$25.97	\$34.22

Special Calculation Note:

Ratio:

3 Journeymen to 1 Trainee

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ASHLAND, ASHTABULA*, ATHENS, AUGLAIZE, BROWN, BUTLER*, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DARKE, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GEAUGA, GREENE, GUERNSEY, HAMILTON, HARDIN, HARRISON, HIGHLAND, HOCKING, HOLMES, HURON, KNOX, LAKE, LICKING, LOGAN, LORAIN, MADISON, MAHONING, MARION, MEDINA, MIAMI, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, PERRY, PICKAWAY, PORTAGE, PREBLE, RICHLAND, ROSS, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VINTON, WARREN*, WAYNE

Special Jurisdictional Note: Butler County:(townships of

Fairfield, Hanover, Liberty, Milford, Morgan, Oxford, Ripley, Ross, StClair, Union & Wayne.) (Lemon & Madison) Warren County: (townships of: Deerfield, Hamilton, Harlan, Salem, Union & Washington). (Clear Creek, Franklin, Mossie, Turtle Creek & Wayney). Ashtabula County: (post offices & townships of Ashtabula, Austinburg, Geneva, Harperfield, Jefferson, Plymouth & Saybrook) (townships of Andover, Cherry Valley, Colbrook, Canneaut, Denmark, Dorset, East Orwell, Hartsgrove, Kingville, Lenox, Monroe, Morgan, New Lyme, North Kingsville, Orwell, Pierpoint, Richmond Rock Creek, Rome, Shefield, Trumbull, Wayne, Williamsfield & Windsor) Erie County:(post offices & townships of Berlin, Berlin Heights, Birmingham, Florence, Huron, Milan, Shinrock & Vermilion)

Details:

Asbestos & lead paint abatement including, but not limited to the removal or encapsulation of asbestos & lead paint, all work in conjunction with the preparation of the removal of same & all work in conjunction with the

clean up after said removal. The removal of all insulation materials, whether they contain asbestos or not, from mechanical systems (pipes, boilers, ducts, flues, breaching, etc.) is recognized as being the exclusive work of the Asbestos Abatement Workers.

On all mechanical systems (pipes, boilers, ducts, flues, breaching, etc.) that are going to be demolished, the removal of all insulating materials whether they contain asbestos or not shall be the exclusive work of the Laborers.

An Abatement Journeyman is anyone who has more than 300 hours in the Asbestos Abatement field.

Name of Union: Asbestos Local 3 Heat & Frost Insulators

Change # : LCN01-2022sksLoc3

Craft: Asbestos Worker Effective Date: 09/21/2022 Last Posted: 09/21/2022

	B	HR		Fringe Benefit Payments						cable id	Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Asbestos Insulation Worker	\$4	1.23	\$14.40	\$10.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$65.63	\$86.25
Fire Stop Specialist	\$4	1.23	\$14.40	\$10.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$65.63	\$86.25
Fire Stop Technician	\$34	4.10	\$14.40	\$4.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$52.50	\$69.55
Apprentice	Per	cent										
1st year	50.20	\$20.70	\$14.40	\$1.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$36.10	\$46.45
2nd year	63.68	\$26.26	\$14.40	\$2.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$42.66	\$55.78
3rd year	69.25	\$28.55	\$14.40	\$3.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$45.95	\$60.23
4th year	82.70	\$34.10	\$14.40	\$4.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$52.50	\$69.55

Special Calculation Note: There are no special calculations for this classification.

Ratio:

3 Journeymen to 1 Apprentice per shop

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, ASHTABULA*, CARROLL, COLUMBIANA, COSHOCTON, CUYAHOGA, ERIE*, GEAUGA, HARRISON, HOLMES, HURON, LAKE, LORAIN, MAHONING, MEDINA, PORTAGE, RICHLAND, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, WAYNE

Special Jurisdictional Note: Ashtabula (the townships of Ashtabula, Austinburg, Geneva, Jefferson, Plymouth & Saybrook), The remainder of Ashtabula County will be considered open counties on a 90 day basis autormatically renewable unless revoked by the Union upon 15 day written notice by the employers. Erie (to Sandusky limits)

Details:

Mechanics & apprentices engaged in the

manufacture, fabrication, assembling, molding, handling, erection, spraying, pouring, mixing, hanging, clean-up, preparation, application, adjusting, alteration, repairing, dismantling, reconditioning, testing & maintenance of Heat & Frost Insulation such as Magnesia, Asbestos, Hair Felt, Wool Felt, Cork, Mineral Wool, Infusorial Earth, Mercerized Silk, Flax, Fiber, Fire Felt, Asbestos Paper, Asbestos Curtain, Asbestos Millboard, Fiberglass, Foam glass, Styrofoam, Polyurethane, fire stopping, smoke stopping, all recyclable material, soundproofing, all

penetrations, any flexible or rigid fireproofing, all jacketing systems including metal, lead, and PVC or other material.

Name of Union: Asbestos Local 84 Heat & Frost Insulators

Change #: LCN01-2023ibLoc84

Craft: Asbestos Worker Effective Date: 02/15/2023 Last Posted: 02/15/2023

	Bì	HR		Fring	ge Bene	fit Payr	nents	Irrevocable Fund		Total PWR	Overtime Rate	
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Asbestos Insulation Worker	\$34	4.57	\$7.90	\$9.50	\$0.36	\$0.00	\$6.39	\$0.24	\$0.00	\$0.00	\$58.96	\$76.24
Apprentice	Per	cent										
1st Year	50.02	\$17.29	\$7.90	\$9.50	\$0.36	\$0.00	\$6.39	\$0.24	\$0.00	\$0.00	\$41.68	\$50.33
2nd Year	60.00	\$20.74	\$7.90	\$9.50	\$0.36	\$0.00	\$6.39	\$0.24	\$0.00	\$0.00	\$45.13	\$55.50
3rd Year	70.00	\$24.20	\$7.90	\$9.50	\$0.36	\$0.00	\$6.39	\$0.24	\$0.00	\$0.00	\$48.59	\$60.69
4th Year	80.00	\$27.66	\$7.90	\$9.50	\$0.36	\$0.00	\$6.39	\$0.24	\$0.00	\$0.00	\$52.05	\$65.87

Special Calculation Note: Other is Industry and Labor Management Fund

Ratio:

3 Journeymen to 1 Apprentice per shop

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, ASHTABULA*, CARROLL, COLUMBIANA, COSHOCTON, HARRISON, HOLMES, MAHONING, MEDINA, PORTAGE, RICHLAND, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, WAYNE

Special Jurisdictional Note: Ashtabula County: except for the townships of Ashtabula, Austinburg, Geneva, Harpersfield, Jefferson, Plymouth and Saybrook.

Details:

The removal of all insulation materials, whether they contain asbestos or not, from mechanical systems (pipes, boilers, ducts, flues, breaching, etc.) is recognized as being the exclusive work of the Asbestos Workers. On all mechanical systems (pipes, boilers, ducts, flues, breaching, etc.) that are going to be demolished, the removal of all insulating materials whether they contain asbestos or not shall be the exclusive work of the Laborers.

Name of Union: Boilermaker Local 85

Change #: LCN01-2012kpLoc85

Craft: Boilermaker Effective Date: 03/28/2012 Last Posted: 03/28/2012

	BHR			Fring	ge Bene	fit Payı	nents		Irrevo Fur		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Boilermaker	\$3	1.01	\$6.97	\$10.77	\$0.35	\$0.00	\$3.00	\$2.09	\$0.00	\$0.00	\$54.19	\$69.69
Apprentice	Per	cent										
1st 6 months	70.00	\$21.71	\$6.97	\$0.25	\$0.35	\$0.00	\$0.25	\$2.09	\$0.00	\$0.00	\$31.62	\$42.47
2nd 6 months	72.50	\$22.48	\$6.97	\$0.25	\$0.35	\$0.00	\$0.25	\$2.09	\$0.00	\$0.00	\$32.39	\$43.63
3rd 6 months	75.00	\$23.26	\$6.97	\$0.25	\$0.35	\$0.00	\$0.25	\$2.09	\$0.00	\$0.00	\$33.17	\$44.80
4th 6 months	77.50	\$24.03	\$6.97	\$10.77	\$0.35	\$0.00	\$3.00	\$2.09	\$0.00	\$0.00	\$47.21	\$59.23
5th 6 months	80.00	\$24.81	\$6.97	\$10.77	\$0.35	\$0.00	\$3.00	\$2.09	\$0.00	\$0.00	\$47.99	\$60.39
6th 6 months	85.00	\$26.36	\$6.97	\$10.77	\$0.35	\$0.00	\$3.00	\$2.09	\$0.00	\$0.00	\$49.54	\$62.72
7th 6 months	90.00	\$27.91	\$6.97	\$10.77	\$0.35	\$0.00	\$3.00	\$2.09	\$0.00	\$0.00	\$51.09	\$65.04
8th 6 months	95.00	\$29.46	\$6.97	\$10.77	\$0.35	\$0.00	\$3.00	\$2.09	\$0.00	\$0.00	\$52.64	\$67.37

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time.

Ratio:

5 Journeymen to 1 Apprentice 10 Journeymen to 2 Apprentice 15 Journeymen to 3 Apprentice

NOT available.

Jurisdiction (* denotes special jurisdictional note):

ALLEN, ASHLAND, AUGLAIZE, CRAWFORD, DARKE, DEFIANCE, DELAWARE, ERIE, FULTON, HANCOCK, HARDIN, HENRY, HURON, KNOX, LOGAN, LUCAS, MARION, MERCER, MORROW, Helpers will be referred in the event that apprentices are OTTAWA, PAULDING, PUTNAM, RICHLAND, SANDUSKY, SENECA, SHELBY, UNION, VAN WERT, WILLIAMS, WOOD, WYANDOT

Special Jurisdictional Note:

Name of Union: Bricklayer Local 23 Heavy Hwy (A)

Change #: LCN01-2023ibLoc23HevHwyA

Craft: Bricklayer Effective Date: 06/07/2023 Last Posted: 06/07/2023

	Bl	HR		Fring	ge Bene	fit Payr	nents	Irrevocable Fund		Total PWR	Overtime Rate	
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Cement Mason Bricklayer Sewer Water Works A	\$32	2.40	\$9.75	\$9.03	\$0.52	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$51.70	\$67.90
Apprentice	Per	cent										
1st year	70.00	\$22.68	\$9.75	\$9.03	\$0.52	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$41.98	\$53.32
2nd year	80.00	\$25.92	\$9.75	\$9.03	\$0.52	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$45.22	\$58.18
3rd year	90.00	\$29.16	\$9.75	\$9.03	\$0.52	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.46	\$63.04

Special Calculation Note: NOT FOR BUILDING CONSTRUCTION.

Ratio:

3 Journeymen to 1 Apprentice 6 Journeymen to 2 Apprentice 9 Journeymen to 3 Apprentice 12 Journeymen to 4 Apprentice 15 Journeymen to 5 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GEAUGA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON, KNOX, LAKE, LAWRENCE, LICKING, LOGAN, LORAIN, LUCAS, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE

Special Jurisdictional Note:

- (A) Highway Construction, Sewer, Waterworks And Utility Construction, Industrial & Building Site Heavy Construction, Airport Construction Or Railroad Construction Work.
- (B) Power Plant, Tunnels, Amusement Park, Athletic Stadium Site Work ,Pollution Control,Sewer Plant, Waste Plant, & Water Treatment Facilities, Construction.

Name of Union: Bricklayer Local 23 Heavy Hwy (B)

Change #: LCN01-2023ibLoc23HevHwyB

Craft: Bricklayer Effective Date: 06/07/2023 Last Posted: 06/07/2023

	Bì	HR		Fring	ge Bene	fit Payr	nents	Irrevocable Fund		Total PWR	Overtime Rate	
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Cement Mason Bricklayer Power Plants Tunnels Amusement Parks B	\$3.	3.39	\$9.75	\$9.03	\$0.53	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$52.70	\$69.39
Apprentice	Per	cent										
1st year	70.00	\$23.37	\$9.75	\$9.03	\$0.53	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$42.68	\$54.37
2nd year	80.00	\$26.71	\$9.75	\$9.03	\$0.53	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$46.02	\$59.38
3rd year	90.00	\$30.05	\$9.75	\$9.03	\$0.53	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$49.36	\$64.39

Special Calculation Note: NOT FOR BUILDING CONSTRUCTION.

Ratio:

3 Journeymen to 1 Apprentice 6 Journeymen to 2 Apprentice 9 Journeymen to 2 Apprentice 12 Journeymen to 4 Apprentice 15 Journeymen to 5 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GEAUGA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON, KNOX, LAKE, LAWRENCE, LICKING, LOGAN, LORAIN, LUCAS, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, SUMMIT,

TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE

Special Jurisdictional Note:

- (A) Highway Construction, Sewer, Waterworks And Utility Construction, Industrial & Building Site Heavy Construction, Airport Construction Or Railroad Construction Work.
- (B) Power Plant, Tunnels, Amusement Park, Athletic Stadium Site Work ,Pollution Control,Sewer Plant, Waste Plant, & Water Treatment Facilities, Construction.

Name of Union: Bricklayer Local 23 (Mansfield)

Change #: LCN01-2023ibLoc23Mans

Craft: Bricklayer Effective Date: 06/01/2023 Last Posted: 05/31/2023

	Bl	HR		Fring	ge Bene	fit Payn	nents		Irrevo Fu		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classi	fication											
Bricklayer	\$33	3.50	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$57.43	\$74.18
Pointer Caulker Cleaner	\$33	3.50	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$57.43	\$74.18
Tile Setter, Stone, Marble & Cement Masons, Plasterer and Terrazzo & Mosaic Workers	\$33	3.50	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$57.43	\$74.18
Tile Marble Terrazzo Finishers	\$30	0.25	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$54.18	\$69.30
Lay Out Man	\$33	3.50	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$57.43	\$74.18
Saw Man	\$33	3.50	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$57.43	\$74.18
Stack Worker	\$35	5.00	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$58.93	\$76.43
Refractory Hot Work	\$36	5.00	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$59.93	\$77.93
Carbon Masonry and Swing Sand Blasting	\$35	5.00	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$58.93	\$76.43
Masonry Maintenance Specialist	\$10	6.75	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$16.75	\$25.12
Apprentice	Per	cent										
1st year	60.00	\$20.10	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$44.03	\$54.08
2nd year	70.00	\$23.45	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$47.38	\$59.10
3rd year	80.00	\$26.80	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$50.73	\$64.13

4th year	92.00	\$30.82	\$10.00	\$11.55	\$0.78	\$0.00	\$1.60	\$0.00	\$0.00	\$0.00	\$54.75	\$70.16
Mason Trainee												
1-90 Days	45.00	\$15.08	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$15.08	\$22.61
91-365 Days	45.00	\$15.08	\$10.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$25.08	\$32.61
2nd Year	50.00	\$16.75	\$10.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$26.75	\$35.13

Special Calculation Note: APPRENTICES BASED ON % OF EACH CLASS ABOVE PLUS FULL FRINGES

Ratio:

1-2 Journeymen to 1 Apprentice

3-4 Journeymen to 2 Apprentices

5-6 Journeymen to 2 Apprentices

6-10 Journeymen to 3 Apprentices

** Apprentices must be hired prior to hiring Mason Trainees***

Mason Finisher Ratio

- 1 Apprentice permits 1 Mason Trainee
- 2 Apprentice permits 1 Mason Trainee
- 3 Apprentice permits 2 Mason Trainee
- 4 Apprentice permits 2 Mason Trainee

Jurisdiction (* denotes special jurisdictional note): ASHLAND CRAWFORD HARDIN HOLMES

ASHLAND, CRAWFORD, HARDIN, HOLMES, MARION, MORROW, RICHLAND, WAYNE, WYANDOT

Special Jurisdictional Note:

Details:

All Free Standing Work shall be \$ 1.50 per hour above the Regular rate.

Radial brick, common brick, face brick, and acid brick linings, All sandblasting and the leaving of carbon masonry material on all swinging stage and/or scaffolding will be at the rate of \$1.50 per hour above Regular rate.

"Hot Work" shall receive \$ 2.50 per hour above Regular Rate.

Working on vertical slip forms, jump forms or continuous forming of any kind shall be \$1.50 per hour above Regular rate, for all work from the base up to 5th (50)feet. Above that height they shall be paid at the Regular rate of time and one-half.

Topping Materials (emery, iron etc.) will be \$.50 per hour above regular rate.

Layout man and Sawman shall receive .25 per hour over the Journeymen Rate.

Name of Union: Carpenter Commercial Zone NEO 4B

Change #: LCN01-2023ibLocNEZone4B

Craft: Carpenter Effective Date: 08/30/2023 Last Posted: 08/30/2023

	В	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Carpenter	\$3	1.62	\$7.91	\$10.83	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$53.40	\$69.21
Apprentice	Pe	rcent										
1st 3 Months	60.00	\$18.97	\$7.91	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$26.88	\$36.37
2nd 3 Months	60.00	\$18.97	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$29.92	\$39.41
2nd 6 Months is 1st year	65.00	\$20.55	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$31.50	\$41.78
3rd 6 Months	70.00	\$22.13	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$33.08	\$44.15
4th 6 Months is 2nd year	75.00	\$23.71	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$34.67	\$46.52
5th 6 Months	80.00	\$25.30	\$7.91	\$8.66	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$44.91	\$57.55
6th 6 Months is 3rd year	85.00	\$26.88	\$7.91	\$9.21	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$47.04	\$60.48
7th 6 Months	90.00	\$28.46	\$7.91	\$9.75	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$49.16	\$63.39
8th 6 Months is 4th year	95.00	\$30.04	\$7.91	\$10.29	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$51.28	\$66.30

Special Calculation Note: *Other is International Training

v	•	*1		
Г	٠a	u	0	

Jurisdiction (* denotes special jurisdictional note):

1 Journeymen to 1 Apprentice

ASHLAND, HURON, RICHLAND

Special Jurisdictional Note:

Name of Union: Carpenter Floorlayer Zone NEO 4B

Change #: LCN01-2023ibLocNEZone4B

Craft: Carpenter Effective Date: 08/30/2023 Last Posted: 08/30/2023

	Bì	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Carpenter Floorlayer	\$31.62		\$7.91	\$10.83	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$53.42	\$69.23
Apprentice	Per	cent										
1st 3 Months	60.00	\$18.97	\$7.91	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$26.88	\$36.37
2nd 3 Months	60.00	\$18.97	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$29.94	\$39.43
2nd 6 Months	65.00	\$20.55	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$31.52	\$41.80
3rd 6 Months	70.00	\$22.13	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$33.10	\$44.17
4th 6 Months	75.00	\$23.71	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$34.69	\$46.54
5th 6 Months	80.00	\$25.30	\$7.91	\$8.66	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$44.93	\$57.57
6th 6 Months	85.00	\$26.88	\$7.91	\$9.21	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$47.06	\$60.50
7th 6 Months	90.00	\$28.46	\$7.91	\$9.75	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$49.18	\$63.41
8th 6 Months	95.00	\$30.04	\$7.91	\$10.29	\$0.60	\$0.00	\$2.31	\$0.15	\$0.00	\$0.00	\$51.30	\$66.32

Special Calculation Note: *Other is International Training

Ratio :	Jurisdiction (* denotes special jurisdictiona
	note):

1 Journeymen to 1 Apprentice ASHLAND, HURON, RICHLAND

Special Jurisdictional Note:

Name of Union: Carpenter Hev Hwy Zone NHH C2-H

Change #: LCN01-2023ibLocNEZoneNHH-C2-H

Craft: Carpenter Effective Date: 08/30/2023 Last Posted: 08/30/2023

	Bì	HR		Fring	ge Bene	fit Payn	nents		Irrevocable Fund		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	assification											
Carpenter	\$3	1.70	\$7.91	\$10.83	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$53.48	\$69.33
Apprentice												
1st 3 Months	60.00	\$19.02	\$7.91	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$26.93	\$36.44
2nd 3 Months	60.00	\$19.02	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$29.97	\$39.48
2nd 6 Months	65.02	\$20.61	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$31.56	\$41.87
3rd 6 Months	70.00	\$22.19	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$33.14	\$44.24
4th 6 Months	75.00	\$23.77	\$7.91	\$0.00	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$34.73	\$46.61
5th 6 Months	80.00	\$25.36	\$7.91	\$8.66	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$44.97	\$57.65
6th 6 Months	85.00	\$26.94	\$7.91	\$9.21	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$47.11	\$60.58
7th 6 Months	90.00	\$28.53	\$7.91	\$9.75	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$49.23	\$63.50
8th 6 Months	95.00	\$30.11	\$7.91	\$10.29	\$0.60	\$0.00	\$2.31	\$0.13	\$0.00	\$0.00	\$51.36	\$66.41

S	necia	l Calcu	lation I	Note :	Other:	Training

		О		

Jurisdiction (* denotes special jurisdictional note):

1 Journeymen to 1 Apprentice

ASHLAND, HURON, RICHLAND

Special Jurisdictional Note:

Name of Union: Carpenter Insulation NE Zone 2D

Change #: OCR01-2022sksLocNEZone2D

Craft: Carpenter Effective Date: 06/29/2022 Last Posted: 06/29/2022

	В	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Carpenter Insulation	\$23.46		\$7.85	\$10.83	\$0.50	\$0.00	\$1.90	\$0.12	\$0.00	\$0.00	\$44.66	\$56.39
Apprentice	Per	cent										
1st 3 Months	50.00	\$11.73	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$11.73	\$17.59
2nd 3 Months	50.00	\$11.73	\$7.85	\$0.00	\$0.50	\$0.00	\$0.00	\$0.12	\$0.00	\$0.00	\$20.20	\$26.07
2nd 6 Months	50.00	\$11.73	\$7.85	\$0.00	\$0.50	\$0.00	\$0.00	\$0.12	\$0.00	\$0.00	\$20.20	\$26.07
3rd 6 Months	55.00	\$12.90	\$7.85	\$0.00	\$0.50	\$0.00	\$0.00	\$0.12	\$0.00	\$0.00	\$21.37	\$27.82
4th 6 Months	60.00	\$14.08	\$7.85	\$0.00	\$0.50	\$0.00	\$0.00	\$0.12	\$0.00	\$0.00	\$22.55	\$29.58
5th 6 Months	70.00	\$16.42	\$7.85	\$7.58	\$0.50	\$0.00	\$1.33	\$0.12	\$0.00	\$0.00	\$33.80	\$42.01
6th 6 Months	75.02	\$17.60	\$7.85	\$8.12	\$0.50	\$0.00	\$1.43	\$0.12	\$0.00	\$0.00	\$35.62	\$44.42
7th 6 Months	80.00	\$18.77	\$7.85	\$8.66	\$0.50	\$0.00	\$1.52	\$0.12	\$0.00	\$0.00	\$37.42	\$46.80
8th 6 Months	85.00	\$19.94	\$7.85	\$9.21	\$0.50	\$0.00	\$1.62	\$0.12	\$0.00	\$0.00	\$39.24	\$49.21

Special Calculation Note: *Other is Training

2 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, ERIE, HURON, RICHLAND

Special Jurisdictional Note:

Name of Union: Carpenter Millwright NE Zone M1-A

Change #: LCN01-2023ibLocNEZoneM1-A

Craft: Carpenter Effective Date: 08/30/2023 Last Posted: 08/30/2023

	В	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	ssification											
Carpenter Millwright	\$3.	3.69	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$59.21	\$76.06
Certified Welder	\$3	4.69	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$60.21	\$77.56
Layout man on Monorail	\$3	6.22	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$61.74	\$79.85
Apprentice	Per	cent										
1st 6 months	60.00	\$20.21	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$45.73	\$55.84
2nd 6 months	65.00	\$21.90	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$47.42	\$58.37
3rd 6 months	70.00	\$23.58	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$49.10	\$60.89
4th 6 months	75.00	\$25.27	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$50.79	\$63.42
5th 6 months	80.00	\$26.95	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$52.47	\$65.95
6th 6 months	85.00	\$28.64	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$54.16	\$68.47
7th 6 months	90.00	\$30.32	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$55.84	\$71.00
8th 6 months	95.00	\$32.01	\$7.99	\$11.33	\$0.60	\$0.00	\$5.42	\$0.18	\$0.00	\$0.00	\$57.53	\$73.53

Special Calculation Note: Other is Training.

Ratio:

1 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, ASHTABULA, CUYAHOGA, ERIE, GEAUGA, HURON, LAKE, LORAIN, MEDINA, PORTAGE, RICHLAND, SUMMIT

Special Jurisdictional Note:

The term "Millwright and Machine Erectors" jurisdiction shall mean the unloading, hoisting, rigging, skidding, moving, dismantling, aligning, erecting, assembling, repairing, maintenance and adjusting of all structures, processing areas either under cover, under ground or elsewhere, required to process material, handle, manufacture or service, be it powered or receiving power manually, by steam, gas, electricity, gasoline, diesel, nuclear, solar, water, air or chemically, and in industries such as and including, which are identified for the purpose of description, but not limited to, the following: woodworking plants; canning industries; steel mills; coffee roasting plants; paper and pulp; cellophane; stone crushing; gravel and sand washing and handling; refineries; grain storage and handling; asphalt plants; sewage disposal; water plants; laundries; bakeries; mixing plants; can, bottle and bag packing plants; textile mills; paint mills; breweries; milk processing plants; power plants; aluminum processing or manufacturing plants; and amusement and entertainment fields. The installation of mechanical equipment in atomic energy plants; installation of reactors in power plants; installation of control rods and equipment in reactors; and installation of mechanical equipment in rocket missile bases, launchers, launching gantry, floating bases, hydraulic escape doors and any and all component parts thereto, either assembled, semi-assembled or disassembled. The installation of, but not limited to, the following: setting-up of all engines, motors, generators, air compressors, fans, pumps, scales, hoppers, conveyors of all types, sizes and their supports; escalators; man lifts; moving sidewalks; hoists; dumb waiters; all types of feeding machinery; amusement devices; mechanical pin setters and spotters in bowling alleys; refrigeration equipment; and the installation of all types of equipment necessary and required to process material either in the manufacturing or servicing. The handling and installation of pulleys, gears, sheaves, fly wheels, air and vacuum drives, worm drives and gear drives directly or indirectly coupled to motors, belts, chains, screws, legs, boots, guards, booth tanks, all bin valves, turn heads and indicators, shafting, bearings, cable sprockets, cutting all key seats in new and old work, troughs, chippers, filters, calendars, rolls, winders, rewinders, slitters, cutters, wrapping machines, blowers, forging machines, rams, hydraulic or otherwise, planing, extruder, ball, dust collectors, equipment in meat packing plants, splicing of ropes and cables. The laying-out, fabrication and installation of protection equipment including machinery guards, making and setting of templates for machinery, fabrication of bolts, nuts, pans, drilling of holes for any equipment which the Millwrights install regardless of materials; all welding and burning regardless of type, fabrication of all lines, hose or tubing used in lubricating machinery installed by Millwrights; grinding, cleaning, servicing and any machine work necessary for any part of any equipment installed by the Millwrights; and the break-in and trial run of any equipment or machinery installed by the Millwrights. It is agreed the Millwrights shall use the layout tools and optic equipment necessary to perform their work.

Name of Union: Carpenter Pile Driver Hev Hwy Zone NHH P2-B

Change #: LCN01-2023ibLocNEZoneP2-B

Craft: Carpenter Effective Date: 08/30/2023 Last Posted: 08/30/2023

	В	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	lassification											
Carpenter Pile Driver	\$33.97		\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$59.21	\$76.20
Diver	\$5	0.96	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$76.20	\$101.68
Certified Welder	\$3.	5.02	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$60.26	\$77.77
Apprentice	Per	cent										
1st 6 months	60.00	\$20.38	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$45.62	\$55.81
2nd 6 months	65.00	\$22.08	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$47.32	\$58.36
3rd 6 months	70.00	\$23.78	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$49.02	\$60.91
4th 6 months	75.00	\$25.48	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$50.72	\$63.46
5th 6 months	80.00	\$27.18	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$52.42	\$66.00
6th 6 months	85.00	\$28.87	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$54.11	\$68.55
7th 6 months	90.00	\$30.57	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$55.81	\$71.10
8th 6 months	95.00	\$32.27	\$7.93	\$11.33	\$0.60	\$0.00	\$5.20	\$0.18	\$0.00	\$0.00	\$57.51	\$73.65

Special Calculation Note: *Other is Training

Ratio:

1 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, ASHTABULA, CUYAHOGA, ERIE, GEAUGA, HURON, LAKE, LORAIN, MEDINA, PORTAGE, RICHLAND, SUMMIT

Special Jurisdictional Note:

Details:

Pile Drivers duties shall include but not limited to: Pile driving, milling, fashioning, joining assembling,

erecting, fastening, or dismantling of all material of wood, plastic, metal, fiber, cork and composition and all other substitute materials: pile driving, cutting, fitting and placing of lagging, and the handling, cleaning, erecting, installing and dismantling of machinery, equipment and erecting pre-engineered metal buildings. Pile Drivers work but not limited to: unloading, assembling, erection, repairs, operation, signaling, dismantling and reloading all equipment that is used for pile driving including pule butts is defined as sheeting or scrap piling. Underwater work that may be required in connection with the installation of piling. The driver and his tender work as a team and shall arrive at their own financial arrangements with the contractor. Any configuration of wood, steel, concrete or composite that is jetted, driven or vibrated onto the ground by conventional pile driving equipment for the purpose of supporting a future load that may be permanent or temporary. The construction of all wharves and docks, including the fabrication and installation of floating docks. Driving bracing, plumbing, cutting off and capping of all piling whether wood, metal, pipe piling or composite, loading, unloading, erecting, framing, dismantling, moving and handling of pile driving equipment piling used in the construction and repair of all wharves, docks, piers, trestles, caissons, cofferdams and erection of all sea walls and breakwaters. All underwater and marine work on bulkheads, wharves, docks, shipyards, caissons, piers, bridges, pipeline, work, viaducts, marine cable and trestles, as well as salvage and reclamation work where divers are employed. Rate shall include carpenters, acoustic and ceiling installers, drywall installers, pile drivers and floorlayers.

Name of Union: Cement Mason Statewide HevHwy

Change #: LCN01-2023ibCementHevHwy

Craft: Cement Mason Effective Date: 05/01/2023 Last Posted: 04/26/2023

	Bì	HR		Fring	ge Bene	fit Payn	nents	Irrevo Fui		Total PWR	Overtime Rate	
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	ssification											
Cement Mason	\$3.	3.74	\$8.50	\$7.55	\$0.65	\$0.00	\$2.25	\$0.07	\$0.00	\$0.00	\$52.76	\$69.63
Apprentice	Per	cent										
1st Year	70.00	\$23.62	\$8.50	\$7.55	\$0.65	\$0.00	\$2.25	\$0.07	\$0.00	\$0.00	\$42.64	\$54.45
2nd Year	80.00	\$26.99	\$8.50	\$7.55	\$0.65	\$0.00	\$2.25	\$0.07	\$0.00	\$0.00	\$46.01	\$59.51
3rd Year	90.00	\$30.37	\$8.50	\$7.55	\$0.65	\$0.00	\$2.25	\$0.07	\$0.00	\$0.00	\$49.39	\$64.57

Special Calculation Note: Other \$0.07 is for International Training Fund

Ratio:

1 Journeymen to 1 Apprentice 2 to 1 thereafter

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA*, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA*, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON*, GALLIA, GEAUGA*, GREENE, GUERNSEY, HAMILTON, HANCOCK*, HARDIN, HARRISON, HENRY*, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON, KNOX, LAKE*, LAWRENCE, LICKING, LOGAN, LORAIN, LUCAS*, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM*, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WOOD*, WYANDOT

Special Jurisdictional Note : (A) Highway Construction, Sewer, Waterworks And Utility Construction, Industrial & Building Site, Heavy

Construction, Airport Construction Or Railroad Construction Work, Power Plant, Tunnels, Amusement Park, Athletic Stadium Site Work, Pollution Control, Sewer Plant, Waste & Water Plant, Water Treatment Facilities Construction.

*For Power Plant, Tunnels, Amusement Park, Athletic Stadium Site Work, Pollution Control, Sewer Plant, Waste & Water Plant, Water Treatment Facility Construction work in the following Counties: Ashtabula, Cuyahoga, Fulton, Geauga, Hancock, Henry, Lake, Lucas, Putnam and Wood Counties, those counties will use the Cement Mason Statewide Heavy Highway Exhibit B District 1 Wage Rate.

Details:

This rate replaces the previous Cement Mason Heavy Highway Statewide Rates (Exhibit A and Exhibit B rates), except for Cement Mason Statewide Heavy Highway Exhibit B Dist 1. sks

Name of Union: Cement Mason Local 132 (Columbus)

Change #: LCN01-2023ibLoc132Columbus

Craft: Cement Effective Date: 06/21/2023 Last Posted: 06/21/2023

	Bì	HR		Fring	ge Bene	fit Payn	nents	Irrevocable Fund		Total PWR	Overtime Rate	
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Cement Mason	\$3	1.37	\$7.90	\$4.65	\$0.65	\$0.00	\$2.25	\$0.06	\$0.00	\$0.00	\$46.88	\$62.57
Apprentice	Per	cent										
1st Year	70.00	\$21.96	\$7.90	\$4.65	\$0.65	\$0.00	\$2.25	\$0.06	\$0.00	\$0.00	\$37.47	\$48.45
2nd Year	80.00	\$25.10	\$7.90	\$4.65	\$0.65	\$0.00	\$2.25	\$0.06	\$0.00	\$0.00	\$40.61	\$53.15
3rd Year	90.00	\$28.23	\$7.90	\$4.65	\$0.65	\$0.00	\$2.25	\$0.06	\$0.00	\$0.00	\$43.74	\$57.86

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time. *Other is International Training.

Ratio:

3 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, COSHOCTON, CRAWFORD, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GUERNSEY, HOCKING, KNOX, LICKING, MADISON, MARION, MORROW, MUSKINGUM, PERRY, PICKAWAY, RICHLAND, ROSS, UNION, VINTON, WYANDOT

Special Jurisdictional Note:

Details:

Working on swing stage, slip scaffold or window jack scaffold shall receive the following rates: \$.50 above the regular rate for heights up to fifty (50) feet above grade level \$1.00 above the regular rate for heights over fifty (50) feet above grade level

Name of Union: Painter Local 788

Change # : LCN01-2023ibLoc788

Craft: Drywall Finisher Effective Date: 06/01/2023 Last Posted: 05/31/2023

	Bl	HR		Fring	ge Bene	fit Payı	nents		Irrevocable Fund		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classifica	tion											
Painter Drywall Finisher	\$20	5.78	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$44.25	\$57.64
REFINERY RATE												
Painter Drywall Finisher	\$29	9.67	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.14	\$61.98
POWERHOUSE RATE												
Painter Drywall Finisher	\$30	0.72	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.19	\$63.55
Apprentice	Per	cent										
1stYear	60.00	\$16.07	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$33.54	\$41.57
2nd Year	70.00	\$18.75	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$36.22	\$45.59
3rd Year	80.00	\$21.42	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$38.89	\$49.61
4th Year	90.00	\$24.10	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$41.57	\$53.62

Special Calculation Note: Apprentice rate based upon % of each classification.

Ratio:

1 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, ERIE, HANCOCK, HURON, MARION, MORROW, OTTAWA, RICHLAND, SANDUSKY, SENECA, WYANDOT

Special Jurisdictional Note:

Details:

B. \$0.50 per hour shall be added to the rate of pay for the classification of work, while working: Swing stage, Boatswain Chair, Needle Beam & Horizontal Cable.

C. \$0.50 per hour shall be added to the rate of pay for the classification of work, while operating: Spray guns to apply oil based paint spray bar joist ceilings or epoxy coatings, Sandblasting, Cob blasting, High Pressure Water blasting (4000 PSI), and for Automatic Taping & Finishing Tools for Drywall.

D. \$0.50 per hour shall be added to the rate of pay for the classification of work, for tending: three (3) or more

sprayers.

E. \$1.00 per hour shall be added to the rate of pay for the classification of work, for the application of: Catalyzed Epoxy, including latex Epoxy that is deemed hazardous, Lead Abatement, or for work or material, where special precautions beyond normal work duties must be taken. Questionable work or material shall be approved by the Business Representative and/or Joint Trade Board.

F. \$1.00 per hour shall be added to the rate of pay for the classification of work, for working on: Stacks, Tanks, and Towers over forty (40) feet in height.

Name of Union: Electrical Local 688 Inside

Change #: LCN01-2023ibLoc688in

Craft: Electrical Effective Date: 06/07/2023 Last Posted: 06/07/2023

	BHR		Fring	ge Bene	fit Payı	nents		Irrevo Fu		ble Total PWR	Overtime Rate
		H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classifica	ation										
Electrician	\$33.90	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$1.02	\$0.00	\$0.00	\$55.98	\$72.93
Over 50 feet	\$67.80	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$2.04	\$0.00	\$0.00	\$90.90	\$124.80
1st Level Construction Wireman 0- 2000 hours	\$13.13	\$6.51	\$0.39	\$0.76	\$0.00	\$0.39	\$0.00	\$0.00	\$0.00	\$21.18	\$27.75
2nd Level CW 2001- 4000 hours	\$14.00	\$6.51	\$0.42	\$0.76	\$0.00	\$0.42	\$0.00	\$0.00	\$0.00	\$22.11	\$29.11
3rd Level CW 4001- 6000 hours	\$14.88	\$6.51	\$0.45	\$0.76	\$0.00	\$0.45	\$0.00	\$0.00	\$0.00	\$23.05	\$30.49
4th Level CW 6001- 8000 hours	\$16.63	\$6.51	\$0.50	\$0.76	\$0.00	\$0.50	\$0.00	\$0.00	\$0.00	\$24.90	\$33.21
1st Level Construction Electrician 8001-10000 hours	\$18.38	\$6.51	\$0.55	\$0.76	\$0.00	\$0.55	\$0.00	\$0.00	\$0.00	\$26.75	\$35.94
2nd Level CE 10001- 12000 hours	\$20.13	\$6.51	\$0.60	\$0.76	\$0.00	\$0.60	\$0.00	\$0.00	\$0.00	\$28.60	\$38.67
3rd Level CE 12001- 14000 hours	\$25.38	\$6.51	\$0.76	\$0.76	\$0.00	\$0.76	\$0.00	\$0.00	\$0.00	\$34.17	\$46.86
Apprentice Indentured After 01/01/2021 40% 1st	\$15.26	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.46	\$0.00	\$0.00	\$25.92	\$33.55
45% 2nd	\$16.95	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.51	\$0.00	\$0.00	\$27.66	\$36.14
50% 3rd	\$18.65	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.56	\$0.00	\$0.00	\$40.27	\$49.60
65% 4th	\$22.04	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.66	\$0.00	\$0.00	\$43.76	\$54.78
70% 5th	\$25.43	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.76	\$0.00	\$0.00	\$47.25	\$59.96

	Per	cent										
85% 6th	85.01	\$28.82	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.86	\$0.00	\$0.00	\$50.74	\$65.15
Apprentice Indentured Before 01/01/2021												
1st	40.00	\$13.56	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.41	\$0.00	\$0.00	\$24.17	\$30.95
2nd	45.02	\$15.26	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.46	\$0.00	\$0.00	\$25.92	\$33.55
3rd	50.00	\$16.95	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.51	\$0.00	\$0.00	\$38.52	\$47.00
4th	65.02	\$22.04	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.66	\$0.00	\$0.00	\$43.76	\$54.78
5th	70.00	\$23.73	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.71	\$0.00	\$0.00	\$45.50	\$57.37
6th	85.02	\$28.82	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.86	\$0.00	\$0.00	\$50.74	\$65.15

Special Calculation Note: Other is NEBF (National Electrical Benifit Fund).

Ratio:

1-3 Jourenymen to 2 Apprentice 4-6 Jourenymen to 4 Apprentice 7-9 Jourenymen to 6 Apprentice Etc.

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, HURON*, KNOX*, MARION, MORROW, RICHLAND, WYANDOT*

Special Jurisdictional Note: In Knox County the following townships: Liberty, Clinton, Union, Howard, Monroe, Middleberry, Morris, Wayne, Berlin, Pike, Brown, Jefferson. In Wyandot County the following townships: Sycamore, Crane, Eden, Pitt, Antrim and Tymochee. In Huron County the following townships: Richmond, New Haven, Ripley, and Greenwich.

Details:

Scope of work for CW/CEs will be limited only by what the employer deems appropriate and within the individual's qualifications to properly perform safely and in a workmanlike manner. Projects where CW/CEs could be utilized are office buildings, shopping centers, gas stations, auto sales agencies and garages, educational facilities, food service centers, restaurants, entertainment facilities, funeral homes, hospitals, clinics, motels, retail and wholesale facilities not to exceed 200,000 square feet and small manufacturing facilities not to exceed 50,000 square feet. Changes were sent in by mistake for apprentice and journeyman updates that where not in effect yet by Carl Neutzling. made changes back to old rates on 3-22.17. fb

Name of Union: Electrical Local 688 Inside Lt Commercial South West

Change #: LCN01-2023ibLoc688inLtComSW

Craft: Electrical Effective Date: 06/07/2023 Last Posted: 06/07/2023

	В	HR		Fring	ge Bene	fit Payı	nents		Irrevo Fui	- 1	Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Clas	sification											
Electrician	\$3:	3.90	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$1.02	\$0.00	\$0.00	\$55.98	\$72.93
Over 50 feet	\$6	7.80	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$2.04	\$0.00	\$0.00	\$90.90	\$124.80
CE-3 12,001- 14,000 Hrs	\$2.	5.38	\$6.51	\$0.76	\$0.76	\$0.00	\$0.76	\$0.00	\$0.00	\$0.00	\$34.17	\$46.86
CE-2 10,001- 12,000 Hrs	\$2	0.13	\$6.51	\$0.60	\$0.76	\$0.00	\$0.60	\$0.00	\$0.00	\$0.00	\$28.60	\$38.67
CE-1 8,001- 10,000 Hrs	\$1	8.38	\$6.51	\$0.55	\$0.76	\$0.00	\$0.55	\$0.00	\$0.00	\$0.00	\$26.75	\$35.94
CW-4 6,001- 8,000 Hrs	\$1	6.63	\$6.51	\$0.50	\$0.76	\$0.00	\$0.50	\$0.00	\$0.00	\$0.00	\$24.90	\$33.21
CW-3 4,001- 6,000 Hrs	\$1-	4.88	\$6.51	\$0.45	\$0.76	\$0.00	\$0.45	\$0.00	\$0.00	\$0.00	\$23.05	\$30.49
CW-2 2,001- 4,000 Hrs	\$14	4.00	\$6.51	\$0.42	\$0.76	\$0.00	\$0.42	\$0.00	\$0.00	\$0.00	\$22.11	\$29.11
CW-1 0- 2,000 Hrs	\$1:	3.13	\$6.51	\$0.39	\$0.76	\$0.00	\$0.39	\$0.00	\$0.00	\$0.00	\$21.18	\$27.75
Apprentice Indentured After 01/01/2021												
1st 45%	\$1.	5.26	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.46	\$0.00	\$0.00	\$25.92	\$33.55
2nd 50%	\$1	6.95	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.51	\$0.00	\$0.00	\$27.66	\$36.14
3rd 55%	\$18.65		\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.56	\$0.00	\$0.00	\$40.27	\$49.60
	Per	cent										
4th	65.02	\$22.04	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.66	\$0.00	\$0.00	\$43.76	\$54.78
5th	75.02	\$25.43	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.76	\$0.00	\$0.00	\$47.25	\$59.97
6th	85.02	\$28.82	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.86	\$0.00	\$0.00	\$50.74	\$65.15

Apprentice Indentured Before 01/01/2021												
1st	40.00	\$13.56	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.41	\$0.00	\$0.00	\$24.17	\$30.95
2nd	45.02	\$15.26	\$9.60	\$0.00	\$0.60	\$0.00	\$0.00	\$0.46	\$0.00	\$0.00	\$25.92	\$33.55
3rd	50.00	\$16.95	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.51	\$0.00	\$0.00	\$38.52	\$47.00
4th	65.02	\$22.04	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.66	\$0.00	\$0.00	\$43.76	\$54.78
5th	70.00	\$23.73	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.71	\$0.00	\$0.00	\$45.50	\$57.37
6th	85.02	\$28.82	\$9.60	\$7.75	\$0.60	\$0.00	\$3.11	\$0.86	\$0.00	\$0.00	\$50.74	\$65.15

Special Calculation Note: Other is NEBF (National Electrical Benifit Fund) and Administration Fund

Ratio:

Journeymen 1-3 to 2 Apprentice Journeymen 4-6 to 4 Apprentice Journeymen 7-9 to 6 Apprentice Etc.

Construction Electrician and Construction Wireman Ratio

There shall be a minimum ratio of one inside Journeyman to every (4) employees of different classification per jobsite. An inside Journeyman Wireman is required on the project as the fifth (5th) worker or when apprentices are used. Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, HURON*, KNOX*, MARION, MORROW, RICHLAND, WYANDOT*

Special Jurisdictional Note: In Knox County the following townships: Liberty, Clinton, Union, Howard, Monroe, Middleberry, Morris, Wayne, Berlin, Pike, Brown, Jefferson. In Wyandot County the following townships: Sycamore, Crane, Eden, Pitt, Antrim and Tymochee. In Huron County the following townships: Richland, New Haven, Ripley, and Greenwich.

The scope of work for the light commercial agreement shall apply to the following facilities not to exceed 200,000 square feet; office buildings, shopping centers, auto sales agencies and garages, churches, funeral homes, nursing homes, hotels, retail and wholesale facilities, small stand-alone manufacturing facilities when free standing and not part of a larger facility (not to exceed 50,000 square fee), solar projects (500 panels or less) unless otherwise covered under the agreement, lighting retrofits (when not associated with remodels involving branch re-circuiting) lighting retrofits shall be defined as the changing of lamps and ballasts in existing light fixtures and shall also include the one for one replacement of existing fixtures, warehouses, gas stations, food service centers, restaurants, entertainment facilities, hospitals, clinics, motels, residential buildings.

Name of Union: Elevator Local 45

Change #: LCN01-2023ibLoc45

Craft: Elevator Effective Date: 02/01/2023 Last Posted: 02/01/2023

	B	HR		Fringe Benefit Payments					Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	Classification											
Elevator Mechanic	\$5:	5.63	\$16.07	\$10.76	\$0.70	\$4.45	\$9.80	\$2.09	\$0.00	\$0.00	\$99.50	\$127.32
Assistant. Mechanic	\$44	4.50	\$16.07	\$10.76	\$0.70	\$3.56	\$9.80	\$1.66	\$0.00	\$0.00	\$87.05	\$109.30
Helper	\$3	8.94	\$16.07	\$10.76	\$0.70	\$3.12	\$9.80	\$1.47	\$0.00	\$0.00	\$80.86	\$100.33
Apprentice	Per	cent										
Apprentice												
0-6 months Probation	50.00	\$27.82	\$0.00	\$0.00	\$0.00	\$1.67	\$0.00	\$0.00	\$0.00	\$0.00	\$29.48	\$43.39
1st year	55.00	\$30.60	\$16.07	\$10.76	\$0.70	\$1.84	\$9.80	\$1.15	\$0.00	\$0.00	\$70.92	\$86.21
2nd year	65.00	\$36.16	\$16.07	\$10.76	\$0.70	\$2.17	\$9.80	\$1.36	\$0.00	\$0.00	\$77.02	\$95.10
3rd year	70.00	\$38.94	\$16.07	\$10.76	\$0.70	\$2.34	\$9.80	\$1.47	\$0.00	\$0.00	\$80.08	\$99.55
4th year	80.00	\$44.50	\$16.07	\$10.76	\$0.70	\$2.67	\$9.80	\$1.66	\$0.00	\$0.00	\$86.16	\$108.42

Special Calculation Note: *Other is Holiday Pay

Ratio:

The total number of Helpers & Apprentices employed shall not exceed the number of Mechanics on any one job, except on jobs where (2) teams or more are working, (1) extra Helper or Apprentice may be employed for the first (2) teams and an extra Helper or Apprentice for each additional (3) teams.

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CARROLL, COLUMBIANA, COSHOCTON, HARRISON, HOLMES, MAHONING, MEDINA, PORTAGE, RICHLAND, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, WAYNE

Special Jurisdictional Note:

Details:

Vacation 6%/under 5 years based on regular hourly rate for all hours worked. 8%/over 5 years based on regular hourly rate for all hours worked.

Name of Union: Glazier Local 1162

Change # : LCN01-2023ibLoc1162

Craft: Glazier Effective Date: 05/24/2023 Last Posted: 05/24/2023

	В	BHR		Fring	ge Bene	fit Payn	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Glazier	\$29	9.37	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$44.04	\$58.73
Apprentice	Per	cent										
1st 6 months	55.00	\$16.15	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$30.82	\$38.90
2nd 6 months	60.00	\$17.62	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$32.29	\$41.10
3rd 6 months	65.00	\$19.09	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$33.76	\$43.31
4th 6 months	70.00	\$20.56	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$35.23	\$45.51
5th 6 months	75.02	\$22.03	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$36.70	\$47.72
6th 6 months	80.00	\$23.50	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$38.17	\$49.91
7th 6 months	85.00	\$24.96	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$39.63	\$52.12
8th 6 months	90.00	\$26.43	\$7.50	\$6.79	\$0.38	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$41.10	\$54.32

Special Calculation Note:

Ratio:

1 Journeyman to 1 Apprentice

2 Journeyman to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CARROLL, COSHOCTON, HOLMES, MEDINA, PORTAGE, RICHLAND, STARK, SUMMIT, TUSCARAWAS, WAYNE

Special Jurisdictional Note:

Details:

Add \$1.25 per hour for High Pay which is all work that requires the employee be supported by equipment which hangs or suspends from the roof of a building or structure including all repelling.

Name of Union: Ironworker Local 550

Change # : LCN01-2023ibLoc550

Craft: Ironworker Effective Date: 05/01/2023 Last Posted: 04/26/2023

	Bì	HR		Fring	ge Bene	fit Payn	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classification												
Ironworker	\$3.	3.00	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$55.68	\$72.18
Apprentice	Per	cent										
1st 6 months	65.00	\$21.45	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$44.13	\$54.85
2nd 6 months	69.00	\$22.77	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$45.45	\$56.84
3rd 6 months	73.00	\$24.09	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$46.77	\$58.81
4th 6 months	77.00	\$25.41	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$48.09	\$60.79
5th 6 months	81.00	\$26.73	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$49.41	\$62.78
6th 6 months	85.00	\$28.05	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$50.73	\$64.75
7th 6 months	90.00	\$29.70	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$52.38	\$67.23
8th 6 months	95.00	\$31.35	\$9.48	\$9.02	\$0.77	\$0.00	\$3.00	\$0.41	\$0.00	\$0.00	\$54.03	\$69.70

Special Calculation Note: OTHER IS: JOURNEYMAN UPGRADE AND WELLNESS FUND.

Ratio:

- 4 Journeymen to 1 Apprentice
- 1 Journeymen to 1 Apprentice, spinning of cable for suspension bridge
- 1 Journeymen to 1 Apprentice, ornamental work
- 2 Journeymen to 1 Apprentice, reinforcing work
- 1 Journeymen to 2 Apprentice, roadway

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CARROLL, COLUMBIANA*, COSHOCTON, HOLMES*, HURON, MAHONING*, MEDINA*, PORTAGE*, RICHLAND, STARK, SUMMIT*, TUSCARAWAS, WAYNE

Special Jurisdictional Note: The jurisdictional line between Local 17 and Local 550 is determined as follows: All territory North of Old Route 224 line to be within the jurisdiction of Local 17. All territory South of Old Route 224 line is to be the jurisdiction of Local 550, except for everything within the City limits of Barberton which shall be under the jurisdiction of Local 17.

Name of Union: Ironworker Local 550 Glass & Curtain Wall

Change #: LCN01-2017fbLoc550

Craft: Ironworker Effective Date: 07/01/2017 Last Posted: 06/28/2017

	BHR			Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Ironworker Glass & Curtain Wall	\$2.	2.00	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$36.89	\$47.89
Apprentice	Per	cent										
1st 6 months	60.00	\$13.20	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$28.09	\$34.69
2nd 6 months	65.00	\$14.30	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$29.19	\$36.34
3rd 6 months	70.00	\$15.40	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$30.29	\$37.99
4th 6 months	75.00	\$16.50	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$31.39	\$39.64
5th 6 months	80.00	\$17.60	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$32.49	\$41.29
6th 6 months	85.00	\$18.70	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$33.59	\$42.94
7th 6 months	90.00	\$19.80	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$34.69	\$44.59
8th 6 months	95.00	\$20.90	\$7.00	\$7.47	\$0.09	\$0.00	\$0.33	\$0.00	\$0.00	\$0.00	\$35.79	\$46.24

Special Calculation Note:

Ratio:

1 Apprentice to 1 Journeymen

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CARROLL, COLUMBIANA*, COSHOCTON, HOLMES, HURON*, MAHONING*, MEDINA*, PORTAGE*, RICHLAND, STARK, SUMMIT*, TUSCARAWAS, WAYNE

Special Jurisdictional Note: The jurisdictional line between Locals 17 and 550 is determined as follows: All territory North of Old Route 224 line is to be within the jurisdiction of Local 17. All territory South of Old Route 224 line is to be the jurisdiction of Local 550, except for everything within the City limits of Barberton which shall be under the jurisdiction of Local 17.

Details:

Name of Union: Labor HevHwy 3

Change #: LCN01-2023ibLocalHevHwy3

Craft: Laborer Group 1 Effective Date: 05/01/2023 Last Posted: 04/26/2023

	ВІ	łR		Fring	ge Bene	fit Payı	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Laborer Group 1	\$34	1.62	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$48.42	\$65.73
Group 2	\$34	1.79	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$48.59	\$65.98
Group 3	\$35	5.12	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$48.92	\$66.48
Group 4	\$35	5.57	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$49.37	\$67.15
Watch Person	\$27	7.35	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$41.15	\$54.83
Apprentice	Per	cent										
0-1000 hrs	60.00	\$20.77	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$34.57	\$44.96
1001-2000 hrs	70.00	\$24.23	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$38.03	\$50.15
2001-3000 hrs	80.00	\$27.70	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$41.50	\$55.34
3001-4000 hrs	90.00	\$31.16	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$44.96	\$60.54
More than 4000 hrs	100.00	\$34.62	\$8.20	\$4.05	\$0.45	\$0.00	\$1.00	\$0.00	\$0.10	\$0.00	\$48.42	\$65.73

Special Calculation Note: Watchmen have no Apprentices. Tunnel Laborer rate with air-pressurized add \$1.00 to the above wage rate.

Ratio:

- 1 Journeymen to 1 Apprentice
- 3 Journeymen to 1 Apprentice thereafter

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, DARKE, DEFIANCE, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, JACKSON, JEFFERSON, KNOX, LAWRENCE, LICKING, LOGAN, MADISON, MARION, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW,

MUSKINGUM, NOBLE, PAULDING, PERRY, PICKAWAY, PIKE, PREBLE, PUTNAM, RICHLAND, ROSS, SCIOTO, SENECA, SHELBY, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WYANDOT

Special Jurisdictional Note : Hod Carriers and Common Laborers - Heavy, Highway, Sewer, Waterworks, Utility, Airport, Railroad, Industrial and Building Site, Sewer Plant, Waste Water Treatment Facilities Construction

Details:

Group 1

Laborer (Construction); Plant Laborer or Yardman, Right-of-way Laborer, Landscape Laborer, Highway Lighting Worker, Signalization Worker, (Swimming) Pool Construction Laborer, Utility Man, *Bridge Man, Handyman, Joint Setter, Flagperson, Carpenter Helper, Waterproofing Laborer, Slurry Seal, Seal Coating, Surface Treatment or Road Mix Laborer, Riprap Laborer & Grouter, Asphalt Laborer, Dump Man (batch trucks), Guardrail & Fence Installer, Mesh Handler & Placer, Concrete Curing Applicator, Scaffold Erector, Sign Installer, Hazardous Waste (level D), Diver Helper, Zone Person and Traffic Control.

*Bridge Man will perfomr work as per the October 31, 1949, memorandum on concrete forms, byand between the United Brotherhood of Caprpenters and Joiners of America and the Laborers' International Union of North America, which states in; "the moving, cleaning, oiling and carrying to the next point of erection, and the stripping of forms which are not to be re-used, and forms on all flat arch work shall be done by members of the Laborers' International Union of North America."

Group 2

Asphalt Raker, Screwman or Paver, Concrete Puddler, Kettle Man (pipeline), All Machine-Driven Tools (Gas, Electric, Air), Mason Tender, Brick Paver, Mortar Mixer, Skid Steer, Sheeting & Shoring Person, Surface Grinder Person, Screedperson, Water Blast, Hand Held Wand, Power Buggy or Power Wheelbarrow, Paint Striper, Plastic fusing Machine Operator, Rodding Machine Operator, Pug Mill Operator, Operator of All Vacuum Devices Wet or Dry, Handling of all Pumps 4 inches and under (gas, air or electric), Diver, Form Setter, Bottom Person, Welder Helper (pipeline), Concrete Saw Person, Cutting with Burning Torch, Pipe Layer, Hand Spiker (railroad), Underground Person (working in sewer and waterline, cleaning, repairing and reconditioning). Tunnel Laborer (without air), Caisson, Cofferdam (below 25 feet deep), Air Track and Wagon Drill, Sandblaster Nozzle Person, Hazardous Waste (level B), ***Lead Abatement, Hazardous Waste (level C)

***Includes the erecting of structures for the removal, including the encapsulation and containment of Lead abatement process.

Group 3

Blast and Powder Person, Muckers will be defined as shovel men working directly with the miners, Wrencher (mechanical joints & utility pipeline), Yarner, Top Lander, Hazardous Waste (level A), Concrete Specialist, Curb Setter and Cutter, Grade Checker, Concrete Crew in Tunnels. Utility pipeline Tappers, Waterline, Caulker, Signal Person will receive the rate equal to the rate paid the Laborer classification for which the Laborer is signaling.

Group 4

Miner, Welder, Gunite Nozzle Person

A.) The Watchperson shall be responsible to patrol and maintain a safe traffic zone including but not limited to barrels, cones, signs, arrow boards, message boards etc.

The responsibility of a watchperson is to see that the equipment, job and office trailer etc. are secure.

Name of Union: Labor Local 1216 Building

Change # : LCN01-2023ibLoc1216

Craft: Laborer Effective Date: 05/01/2023 Last Posted: 04/26/2023

	BI	IR		Fring	ge Bene	fit Payr	nents		Irrevocable Fund		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	Classification											
Laborer Group 1	\$31	.67	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$44.42	\$60.25
Group 2	\$31	.87	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$44.62	\$60.55
Group 3	\$32	2.17	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$44.92	\$61.00
Group 4	\$29	0.00	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$41.75	\$56.25
Apprentice	Per	cent										
0- 1000HRS	60.00	\$19.00	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$31.75	\$41.25
1001-2000	70.00	\$22.17	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$34.92	\$46.00
2001-3000	80.00	\$25.34	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$38.09	\$50.75
3001-4000	90.00	\$28.50	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$41.25	\$55.50
More than 400 Hours	100.00	\$31.67	\$8.20	\$4.05	\$0.40	\$0.00	\$0.00	\$0.00	\$0.10	\$0.00	\$44.42	\$60.25

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time.

Ratio:

1 Journeyman to 1 Apprentice 4 Journeymen to 1 Apprentice thereafter per project

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, KNOX, MORROW, RICHLAND

Special Jurisdictional Note:

Details:

Group 1

Concrete Handler, Finisher tender, Building and Construction Laborer, Signalman, Flagman, Tool Cribman, Carpenter Tender, Utility Construction Laborer, Guardrail Erector, and Hazardous Waste (Level C,D)

Group 2

Gunite Operator, Bottom Men, Tunnel Laborer, Pipe Layer, Air and Power Driven Tools, Burner on Demolition work, Swinging Scaffold, Mucker, Caisson Worker, Cofferdam Worker, Powder Man and Dynamite Blaster, Creosote Worker, Form Setter, Plasterer Tender, Hod Carrier, Laser Beam Set-up Man, and Hazardous Waste (Level A, B)

Group 3

Fork Lift, Scaffold Builders, Mortar Mixer, Mason Tender, Stone Mason Tender

Group 4

Watchman

Hazardous Waste Removal and Lead Abatement

For laborers working in an exclusive or "hot" area with toxic or hazardous materials, one of the following personal protective equipment ensembles will be required for necessary protection against toxic contaminants.

Level A

Protective equipment is required when the area has been determined to contain extremely toxic contaminants of contaminants unknown but may be expected to be extremely toxic and/or immediately Dangerous to life and health (IDLH). This ensemble includes a full encapsulated chemical suit (moon suit)., Self-Contained Breathing Apparatus (SUBA), or Airline Fed Respirator, and various types and numbers of boots and gloves; cool vests and voice-activated radios are optional equipment sometimes worn. This level places the greatest physical and mental stress on the worker.

Level B

Protective equipment includes a chemically resistant splash suit and SCBA or airline Respirator. This ensemble is required when the situation is very hazardous, such as oxygen deficient atmospheres, IDLH atmospheres, or confined space entries, but the risk of skin exposure is nit as great as in Level D situations

Level C

Protective equipment includes a protective suit and an Air Purifying Respirator (APR) with the appropriate filter canisters. The ensemble is used when the contaminants are reliably known not to be hazardous to the skin and not IDLH (immediately Dangerous to Life or Health) and correct filter protection is available. This ensemble offers adequate protection for many jobs.

Level D

Normal work clothes to normal skin protection such as gloves, face shields, goggles, coveralls and occasionally respiratory protection.

Name of Union: Electrical Local 71 High Tension Pipe Type Cable

Change #: LCN01-2023ibLoc7

Craft: Lineman Effective Date: 03/01/2023 Last Posted: 03/01/2023

	BHR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
		H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification										
Electrical Lineman	\$48.59	\$7.00	\$1.46	\$0.49	\$0.00	\$11.66	\$0.75	\$0.00	\$0.00	\$69.95	\$94.24
Certified Lineman Welder	\$48.59	\$7.00	\$1.46	\$0.49	\$0.00	\$11.66	\$0.75	\$0.00	\$0.00	\$69.95	\$94.24
Certified Cable Splicer	\$48.59	\$7.00	\$1.46	\$0.49	\$0.00	\$11.66	\$0.75	\$0.00	\$0.00	\$69.95	\$94.24
Operator A	\$43.54	\$7.00	\$1.31	\$0.44	\$0.00	\$10.45	\$0.75	\$0.00	\$0.00	\$63.49	\$85.26
Operator B	\$38.54	\$7.00	\$1.16	\$0.39	\$0.00	\$9.25	\$0.75	\$0.00	\$0.00	\$57.09	\$76.36
Operator C	\$30.97	\$7.00	\$0.93	\$0.31	\$0.00	\$7.43	\$0.75	\$0.00	\$0.00	\$47.39	\$62.88
Groundman 0-12 months Exp	\$24.30	\$7.00	\$0.73	\$0.24	\$0.00	\$5.83	\$0.75	\$0.00	\$0.00	\$38.85	\$51.00
Groundman 0-12 months Exp w/CDL	\$26.72	\$7.00	\$0.80	\$0.27	\$0.00	\$6.41	\$0.75	\$0.00	\$0.00	\$41.95	\$55.31
Groundman 1 yr or more	\$26.72	\$7.00	\$0.80	\$0.27	\$0.00	\$6.41	\$0.75	\$0.00	\$0.00	\$41.95	\$55.31
Groundman 1 yr or more w/CDL	\$31.58	\$7.00	\$0.95	\$0.32	\$0.00	\$7.58	\$0.75	\$0.00	\$0.00	\$48.18	\$63.97
Equipment Mechanic A	\$38.54	\$7.00	\$1.16	\$0.39	\$0.00	\$9.25	\$0.75	\$0.00	\$0.00	\$57.09	\$76.36
Equipment Mechanic B	\$34.75	\$7.00	\$1.04	\$0.35	\$0.00	\$8.34	\$0.75	\$0.00	\$0.00	\$52.23	\$69.60
Equipment Mechanic C	\$30.97	\$7.00	\$0.93	\$0.31	\$0.00	\$7.43	\$0.75	\$0.00	\$0.00	\$47.39	\$62.88

X-Ray Technician	\$48	8.59	\$7.00	\$1.46	\$0.49	\$0.00	\$11.66	\$0.75	\$0.00	\$0.00	\$69.95	\$94.24
Apprentice	Per	cent										
1st 1000 hrs	60.00	\$29.15	\$7.00	\$0.87	\$0.29	\$0.00	\$7.00	\$0.75	\$0.00	\$0.00	\$45.06	\$59.64
2nd 1000 hrs	65.00	\$31.58	\$7.00	\$0.95	\$0.32	\$0.00	\$7.58	\$0.75	\$0.00	\$0.00	\$48.18	\$63.98
3rd 1000 hrs	70.00	\$34.01	\$7.00	\$1.02	\$0.34	\$0.00	\$8.16	\$0.75	\$0.00	\$0.00	\$51.28	\$68.29
4th 1000 hrs	75.00	\$36.44	\$7.00	\$1.09	\$0.36	\$0.00	\$8.75	\$0.75	\$0.00	\$0.00	\$54.39	\$72.61
5th 1000 hrs	80.00	\$38.87	\$7.00	\$1.17	\$0.39	\$0.00	\$9.33	\$0.75	\$0.00	\$0.00	\$57.51	\$76.95
6th 1000 hrs	85.00	\$41.30	\$7.00	\$1.24	\$0.41	\$0.00	\$9.91	\$0.75	\$0.00	\$0.00	\$60.61	\$81.26
7th 1000 hrs	90.00	\$43.73	\$7.00	\$1.31	\$0.44	\$0.00	\$10.50	\$0.75	\$0.00	\$0.00	\$63.73	\$85.60

Special Calculation Note: Other is Health Retirement Account

Operator "A"

John Henry Rock Drill, D-6 (or equivalent) and above, Trackhoe Digger, (320 Track excavator), Cranes (greater then 25 tons and less than 45 tons).

Operator "B"

Cranes (greater than 6 tons and up to 25 tons), Backhoes, Road Tractor, Dozer up to D-5, Pressure Digger- wheeled or tracked, all Tension wire Stringing equipment.

Operator "C"

Trench, Backhoe, Riding type vibratory Compactor, Ground Rod Driver, Boom Truck (6 ton & below), Skid Steer Loaders, Material Handler.

*All Operators of cranes 45 ton or larger shall be paid the journeyman rate of pay. \$0.30 is for Health Retirement Account.

Ratio:

1 Journeyman to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DARKE, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GALLIA, GEAUGA, GREENE, GUERNSEY, HAMILTON, HARRISON, HIGHLAND, HOCKING, HOLMES, JACKSON, JEFFERSON, KNOX, LAKE, LAWRENCE, LICKING, LOGAN, LORAIN, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, RICHLAND, ROSS, SCIOTO,

SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VINTON, WARREN, WASHINGTON, WAYNE

Special Jurisdictional Note:

Details:

Heli - Arc Welding will be paid \$.30 above Journeyman rate. Additional compensation of 10% over the Journeyman Lineman and Journeyman Technician for performing work on structures outside of buildings such as water towers, smoke stacks, radio and television towers, more than 75' above the ground.

Name of Union: Electrical Local 71 Outside Utility Power

Change # : LCN01-2023ibLoc7

Craft: Lineman Effective Date: 03/01/2023 Last Posted: 03/01/2023

	BHR		Fring	ge Bene	fit Payı	nents		Irrevo Fu		ole Total PWR	Overtime Rate
		H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)		1 1111	Ture
Class	sification										
Electrical Lineman	\$46.03	\$7.00	\$1.38	\$0.46	\$0.00	\$11.05	\$0.75	\$0.00	\$0.00	\$66.67	\$89.68
Substation Technician	\$46.03	\$7.00	\$1.38	\$0.46	\$0.00	\$11.05	\$0.75	\$0.00	\$0.00	\$66.67	\$89.68
Cable Splicer	\$48.21	\$7.00	\$1.45	\$0.48	\$0.00	\$11.57	\$0.75	\$0.00	\$0.00	\$69.46	\$93.56
Operator A	\$41.26	\$7.00	\$1.24	\$0.41	\$0.00	\$9.90	\$0.75	\$0.00	\$0.00	\$60.56	\$81.19
Operator B	\$36.47	\$7.00	\$1.09	\$0.36	\$0.00	\$8.75	\$0.75	\$0.00	\$0.00	\$54.42	\$72.65
Operator C	\$29.28	\$7.00	\$0.88	\$0.29	\$0.00	\$7.03	\$0.75	\$0.00	\$0.00	\$45.23	\$59.87
Groundman 0-12 months Exp	\$23.02	\$7.00	\$0.69	\$0.23	\$0.00	\$5.52	\$0.75	\$0.00	\$0.00	\$37.21	\$48.72
Groundman 0-12 months Exp w/CDL	\$25.32	\$7.00	\$0.76	\$0.25	\$0.00	\$6.08	\$0.75	\$0.00	\$0.00	\$40.16	\$52.82
Groundman 1 yr or more	\$25.32	\$7.00	\$0.76	\$0.25	\$0.00	\$6.08	\$0.75	\$0.00	\$0.00	\$40.16	\$52.82
Groundman 1 yr or more w/CDL	\$29.92	\$7.00	\$0.90	\$0.30	\$0.00	\$7.18	\$0.75	\$0.00	\$0.00	\$46.05	\$61.01
Equipment Mechanic A	\$36.47	\$7.00	\$1.09	\$0.36	\$0.00	\$8.75	\$0.75	\$0.00	\$0.00	\$54.42	\$72.65
Equipment Mechanic B	\$32.88	\$7.00	\$0.99	\$0.33	\$0.00	\$7.89	\$0.75	\$0.00	\$0.00	\$49.84	\$66.28
Equipment Mechanic C	\$29.28	\$7.00	\$0.88	\$0.29	\$0.00	\$7.03	\$0.75	\$0.00	\$0.00	\$45.23	\$59.87
Line Truck w/uuger	\$32.28	\$7.00	\$0.97	\$0.32	\$0.00	\$7.75	\$0.75	\$0.00	\$0.00	\$49.07	\$65.21

Apprentice	Per	cent										
1st 1000 hrs	60.00	\$27.62	\$7.00	\$0.83	\$0.28	\$0.00	\$6.63	\$0.75	\$0.00	\$0.00	\$43.11	\$56.92
2nd 1000 hrs	65.00	\$29.92	\$7.00	\$0.90	\$0.30	\$0.00	\$7.18	\$0.75	\$0.00	\$0.00	\$46.05	\$61.01
3rd 1000 hrs	70.00	\$32.22	\$7.00	\$0.97	\$0.32	\$0.00	\$7.73	\$0.75	\$0.00	\$0.00	\$48.99	\$65.10
4th 1000 hrs	75.00	\$34.52	\$7.00	\$1.04	\$0.35	\$0.00	\$8.28	\$0.75	\$0.00	\$0.00	\$51.94	\$69.20
5th 1000 hrs	80.00	\$36.82	\$7.00	\$1.10	\$0.37	\$0.00	\$8.84	\$0.75	\$0.00	\$0.00	\$54.88	\$73.30
6th 1000 hrs	85.00	\$39.13	\$7.00	\$1.17	\$0.39	\$0.00	\$9.39	\$0.75	\$0.00	\$0.00	\$57.83	\$77.39
7th 1000 hrs	90.00	\$41.43	\$7.00	\$1.24	\$0.41	\$0.00	\$9.94	\$0.75	\$0.00	\$0.00	\$60.77	\$81.48

Special Calculation Note: Other is Health Retirement Account

Operator "A"

John Henry Rock Drill, D-6 (or equivalent) and above, Trackhoe Digger, (320 Track excavator), Cranes (greater then 25 tons and less than 45 tons).

Operator "B"

Cranes (greater than 6 tons and up to 25 tons), Backhoes, Road Tractor, Dozer up to D-5, Pressure Digger- wheeled or tracked, all Tension wire Stringing equipment.

Operator "C"

Trench, Backhoe, Riding type vibratory Compactor, Ground Rod Driver, Boom Truck (6 ton & below), Skid Steer Loaders, Material Handler.

Ratio:

(1) Journeyman Lineman to (1) Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DARKE, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GALLIA, GEAUGA, GREENE, GUERNSEY, HAMILTON, HARRISON, HIGHLAND, HOCKING, HOLMES, JACKSON, JEFFERSON, KNOX, LAKE, LAWRENCE, LICKING, LOGAN, LORAIN, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, RICHLAND, ROSS, SCIOTO, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VINTON, WARREN, WASHINGTON, WAYNE

Special Jurisdictional Note: 0.30 is for Health Retirement Account.

Details:

Heli - Arc Welding will be paid \$.30 above Journeyman rate. Additional compensation of 10% over the

Journeyman Lineman and Journeyman Technician for performing work on structures outside of buildings such as water towers, smoke stacks, radio and television towers, more than 75' above the ground.

Name of Union: Electrical Local 71 Outside (Central OH Chapter)

Change # : LCN01-2023ibLoc71CentralOhio

Craft: Lineman Effective Date: 03/01/2023 Last Posted: 03/01/2023

	BHR		Fring	ge Bene	fit Payr	nents		Irrevo Fui	- 11		Overtime Rate
		H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classi	fication										
Electrical Lineman	\$43.02	\$7.00	\$1.29	\$0.43	\$0.00	\$8.60	\$0.56	\$0.00	\$0.00	\$60.90	\$82.41
Traffic Signal & Lighting Journeyman	\$41.43	\$7.00	\$1.24	\$0.41	\$0.00	\$8.29	\$0.56	\$0.00	\$0.00	\$58.93	\$79.64
Equipment Operator	\$37.78	\$7.00	\$1.13	\$0.38	\$0.00	\$7.56	\$0.56	\$0.00	\$0.00	\$54.41	\$73.30
Groundman 0-12 months (W/O CDL)	\$22.91	\$7.00	\$0.69	\$0.23	\$0.00	\$4.58	\$0.56	\$0.00	\$0.00	\$35.97	\$47.42
Groundman 0-12 Months W/CDL	\$25.03	\$7.00	\$0.75	\$0.25	\$0.00	\$5.01	\$0.56	\$0.00	\$0.00	\$38.60	\$51.12
Groundman greater than 1 Year W/CDL	\$27.71	\$7.00	\$0.81	\$0.28	\$0.00	\$5.43	\$0.56	\$0.00	\$0.00	\$41.79	\$55.65
Traffic Signal Apprentices											
1st 1,000 hours	\$24.86	\$7.00	\$0.75	\$0.25	\$0.00	\$4.97	\$0.56	\$0.00	\$0.00	\$38.39	\$50.82
2nd 1,000 hours	\$26.93	\$7.00	\$0.81	\$0.27	\$0.00	\$5.39	\$0.56	\$0.00	\$0.00	\$40.96	\$54.43
3rd 1,000 hours	\$29.00	\$7.00	\$0.87	\$0.29	\$0.00	\$5.80	\$0.56	\$0.00	\$0.00	\$43.52	\$58.02
4th 1,000 hours	\$31.07	\$7.00	\$0.93	\$0.31	\$0.00	\$6.21	\$0.56	\$0.00	\$0.00	\$46.08	\$61.62
5th 1,000 hours	\$33.14	\$7.00	\$0.99	\$0.33	\$0.00	\$6.63	\$0.56	\$0.00	\$0.00	\$48.65	\$65.22
6th 1,000 hours	\$37.29	\$7.00	\$1.12	\$0.37	\$0.00	\$7.76	\$0.56	\$0.00	\$0.00	\$54.10	\$72.75

Apprentice Lineman	Per	cent										
1st 1,000 Hours	60.00	\$25.81	\$7.00	\$0.77	\$0.26	\$0.00	\$5.16	\$0.56	\$0.00	\$0.00	\$39.56	\$52.47
2nd 1,000 Hours	65.00	\$27.96	\$7.00	\$0.84	\$0.28	\$0.00	\$5.59	\$0.56	\$0.00	\$0.00	\$42.23	\$56.21
3rd 1,000 Hours	70.00	\$30.11	\$7.00	\$0.90	\$0.30	\$0.00	\$6.02	\$0.56	\$0.00	\$0.00	\$44.89	\$59.95
4th 1,000 Hours	75.00	\$32.27	\$7.00	\$0.97	\$0.32	\$0.00	\$6.54	\$0.56	\$0.00	\$0.00	\$47.66	\$63.79
5th 1,000 Hours	80.00	\$34.42	\$7.00	\$1.03	\$0.34	\$0.00	\$6.88	\$0.56	\$0.00	\$0.00	\$50.23	\$67.43
6th 1,000 Hours	85.00	\$36.57	\$7.00	\$1.10	\$0.37	\$0.00	\$7.31	\$0.56	\$0.00	\$0.00	\$52.91	\$71.19
7th 1,000 Hours	90.00	\$38.72	\$7.00	\$1.16	\$0.39	\$0.00	\$7.74	\$0.56	\$0.00	\$0.00	\$55.57	\$74.93

Special Calculation Note: Other is Safety & Education Fund (\$0.06) and HRA (\$0.50).

Ratio:

1 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ASHLAND, ATHENS, COSHOCTON, CRAWFORD, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GALLIA, GUERNSEY, HIGHLAND, HOCKING, JACKSON, KNOX, LAWRENCE, LICKING, MADISON, MARION, MEIGS, MONROE, MORGAN, MORROW, MUSKINGUM, NOBLE, PERRY, PICKAWAY, PIKE, RICHLAND, ROSS, SCIOTO, TUSCARAWAS, UNION, VINTON, WASHINGTON

Special Jurisdictional Note:

Details:

A groundman when directed shall assist a Journeyman Lineman, Traffic Signal and Lighting Journeyman or Equipment Operator in the performance of his/her work on the ground, including the use of hand tools. Under no circumstances shall this classification climb poles, towers, or work from an elevated platform or bucket truck. This classification shall not perform work normally assigned to an Apprentice.

No more than three (3) Groundmen shall work alone. Jobs with more that three Groundmen shall be supervised by a Groundcrew Foreman, Journeyman Lineman, Journeyman Traffic Signal Technician or an Equipment Operator.

Scope of Work: installation and maintenance of highway and street lighting, highway and street sign lighting, electronic message boards and traffic control systems, camera systems, traffic signal work, substation and line construction including overhead and underground projects for private and industrial work as in accordance with the IBEW Constitution. This Agreement includes the operation of all tools and equipment necessary for the installation of the above projects.

Name of Union: Operating Engineers - Building Local 18 - Zone III

Change #: LCN01-2023ibLoc18zone3

Craft: Operating Engineer Effective Date: 05/01/2023 Last Posted: 04/26/2023

Craft : Op		HR				fit Payr			Irrevo Fu	cable	Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Operator Group A	\$4	1.49	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$57.74	\$78.48
Operator Group B	\$4	1.37	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$57.62	\$78.30
Operator Group C	\$40	0.33	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$56.58	\$76.74
Operator Group D	\$39	9.15	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$55.40	\$74.97
Operator Group E	\$3.	3.69	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$49.94	\$66.78
Master Mechanic	\$4	1.74	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$57.99	\$78.86
Cranes & Mobile Concrete Pumps 150'-180'	\$4	1.99	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$58.24	\$79.23
Cranes & Mobile Concrete Pumps 180'-249'	\$42	2.49	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$58.74	\$79.98
Cranes & Mobile Concrete Pumps 249' and over	\$4.	2.74	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$58.99	\$80.36
Apprentice	Per	cent										
1st Year	50.00	\$20.75	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$37.00	\$47.37
2nd Year	60.00	\$24.89	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$41.14	\$53.59
3rd Year	70.00	\$29.04	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$45.29	\$59.81
4th Year	80.00	\$33.19	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$49.44	\$66.04
Field Mechanic Trainee												

1st Year	50.00	\$20.75	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$37.00	\$47.37
2nd Year	60.00	\$24.89	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$41.14	\$53.59
3rd Year	70.00	\$29.04	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$45.29	\$59.81
4th Year	80.00	\$33.19	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$49.44	\$66.04

Special Calculation Note: Other: Education & Safety \$0.09; *Misc is National Training

Ratio:

For every (3) Operating Engineer Journeymen employed by the company there may be employed (1) Registered Apprentice or trainee Engineer through the referral when they are available. An apprenice, while employed as part of a crew per Article VIII, paragraph 78, will not be subject to the apprenticeship ratios in this collective bargaining agreement

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COSHOCTON, CRAWFORD, DARKE, DEFIANCE, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, JACKSON, JEFFERSON, KNOX, LAWRENCE, LICKING, LOGAN, MADISON, MARION, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, **WYANDOT**

Special Jurisdictional Note:

Details:

Note: There will be a 10% increase for the apprentices on top of the percentages listed above provided they are operating mobile equipment. Mechanic Trainees will receive 10% increase if required to have CDL

Group A- Barrier Moving Machines; Boiler Operators or Compressor Operators, when compressor or boiler is mounted on crane (Piggyback Operation); Boom Trucks (all types); Cableways Cherry Pickers; Combination - Concrete Mixers & Towers; All Concrete Pumps with Booms; Cranes (all types); Compact Cranes, track or rubber over 4,000 pounds capacity; Cranes self-erecting, stationary, track or truck (all configurations); Derricks (all types); Draglines; Dredges (dipper, clam or suction) 3-man crew; Elevating Graders or Euclid Loaders; Floating Equipment; Forklift (rough terrain with winch/hoist); Gradalls; Helicopter Operators, hoisting building materials; Helicopter Winch Operators, Hoisting building materials; Hoes (All types); Hoists (with two or more drums in use); Horizonal Directional Drill; Hydraulic Gantry (lift system); Laser Finishing Machines; Laser Screed and like equipment; Lift Slab or Panel Jack Operators; Locomotives (all types); Maintenance Operator/Technician(Mechanic Operator/Technician and/or Welder); Mixers, paving (multiple drum); Mobile Concrete Pumps, with booms; Panelboards, (all types on site); Pile Drivers; Power Shovels; Prentice Loader; Rail Tamper (with automatic lifting and aligning device); Rotary Drills (all), used on caissons for foundations and sub-structure; Side Booms; Slip Form Pavers; Straddle Carriers (Building Construction on site); Trench Machines (over 24" wide); Tug Boats.

Group B - Articulating/end dumps (minus \$4.00/hour from Group B rate); Asphalt Pavers; Bobcat-type and/or skid steer loader with hoe attachment greater than 7000 lbs.; Bulldozers; CMI type Equipment; Concrete Saw, Vermeer-type; Endloaders; Hydro Milling Machine; Kolman-type Loaders (Dirt Loading); Lead Greasemen; Mucking Machines; Pettibone-Rail Equipment; Power Graders; Power Scoops; Power Scrapers; Push Cats;, Rotomills (all), grinders and planers of all types.

Group C - A-Frames; Air Compressors, Pressurizing Shafts or Tunnels; All Asphalt Rollers; Bobcat-type and/or Skid Steer Loader with or without attachments; Boilers (15 lbs. pressure and over); All Concrete Pumps (without booms with 5 inch system); Fork Lifts (except masonry); Highway Drills - all types (with integral power); Hoists (with one drum); House Elevators (except those automatic call button controlled), Buck Hoists, Transport Platforms, Construction Elevators; Hydro Vac/Excavator (when a second person is needed, the rate of pay will be "Class E"); Man Lifts; Material hoist/elevators; Mud Jacks; Pressure Grouting; Pump Operators (installing or operating Well Points or other types of Dewatering Systems); Pumps (4 inches and over discharge); Railroad Tie (Inserter/Remover); Rotovator (Lime-Soil Stabilizer); Submersible Pumps (4"and over discharge); Switch & Tie Tampers (without lifting and aligning device); Trench Machines (24" and under); Utility Operators.

Group D - Backfillers and Tampers; Ballast Re-locator; Batch Plant Operators; Bar and Joint Installing Machines; Bull Floats; Burlap and Curing Machines; Clefplanes; Compressors, on building construction; Concrete Mixers, more than one bag capacity; Concrete Mixers, one bag capacity (side loaders); All Concrete Pumps (without boom with 4" or smaller system); Concrete Spreader; Conveyors, used for handling building materials; Crushers; Deckhands; Drum Fireman (in asphalt plants); Farm type tractors pulling attachments; Finishing Machines; Form Trenchers; Generators: Gunite Machines; Hydro-seeders; Pavement Breakers (hydraulic or cable); Post Drivers; Post Hole Diggers; Pressure Pumps (over 1/2") discharge); Road Widening Trenchers; Rollers (except asphalt); Self-propelled sub-graders; Shotcrete Machines; Tire Repairmen; Tractors, pulling sheepsfoot post roller or grader; VAC/ALLS; Vibratory Compactors, with integral power; Welders.

Group E – Allen Screed Paver (concrete); Boilers (less than 15 lbs. pressure); Cranes-Compact, track or rubber (under 4,000 pounds capacity); Directional Drill "Locator"; Fueling and greasing +\$3.00; Inboard/outboard Motor Boat Launches; Light Plant Operators; Masonry Fork Lifts; Oilers/Helpers; Power Driven Heaters (oil fired); Power Scrubbers; Power Sweepers; Pumps (under 4 inch discharge); Signalperson, Submersible Pumps (under 4" discharge).

Master Mechanics - Master Mechanic

Cranes 150' – 180' - Boom & Jib 150 - 180 feet

Cranes 180' – 249' - Boom & Jib 180 - 249 feet

Cranes 250' and over - Boom & Jib 250-feet or over

Name of Union: Operating Engineers - HevHwy Zone II

Change #: LCN01-2023ibLoc18hevhwyll

Craft: Operating Engineer Effective Date: 05/01/2023 Last Posted: 04/26/2023

	B)	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Operator Class A	\$4	1.49	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$57.74	\$78.48
Operator Class B	\$4	1.37	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$57.62	\$78.30
Operator Class C	\$40	0.33	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$56.58	\$76.74
Operator Class D	\$39	9.15	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$55.40	\$74.97
Operator Class E	\$3.	3.69	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$49.94	\$66.78
Master Mechanic	\$4	1.74	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$57.99	\$78.86
Apprentice	Per	cent										
1st Year	50.00	\$20.75	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$37.00	\$47.37
2nd Year	60.00	\$24.89	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$41.14	\$53.59
3rd Year	70.00	\$29.04	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$45.29	\$59.81
4th Year	80.00	\$33.19	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$49.44	\$66.04
Field Mech Trainee Class 2												
1st year	50.00	\$20.75	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$37.00	\$47.37
2nd year	60.00	\$24.89	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$41.14	\$53.59
3rd year	70.00	\$29.04	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$45.29	\$59.81
4th year	80.00	\$33.19	\$9.01	\$6.25	\$0.85	\$0.00	\$0.00	\$0.09	\$0.00	\$0.05	\$49.44	\$66.04

Special Calculation Note: Other: Education & Safety Fund is \$0.09 per hour. *Misc is National **Training**

Ratio:

For every (3) Operating Engineer Journeymen employed by the company, there may be employed (1) BELMONT, BROWN, BUTLER, CARROLL, Registered Apprentice or Trainee Engineer through the CHAMPAIGN, CLARK, CLERMONT, CLINTON, referral when they are available. An Apprentice, while COSHOCTON, CRAWFORD, DARKE, DEFIANCE,

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ATHENS, AUGLAIZE,

employed as part of a crew per Article VIII, paragraph
65 will not be subject to the apprenticeship ratios in this FULTON, GALLIA, GREENE, GUERNSEY,
collective bargaining agreement
HAMILTON, HANCOCK, HARDIN, HARRISON,

FULTON, GALLIA, GREENE, GUERNSEY,
HAMILTON, HANCOCK, HARDIN, HARRISON,
HENRY, HIGHLAND, HOCKING, HOLMES,
HURON, JACKSON, JEFFERSON, KNOX,
LAWRENCE, LICKING, LOGAN, LUCAS,
MADISON, MARION, MEIGS, MERCER, MIAMI,
MONROE, MONTGOMERY, MORGAN, MORROW,
MUSKINGUM, NOBLE, OTTAWA, PAULDING,
PERRY, PICKAWAY, PIKE, PREBLE, PUTNAM,
RICHLAND, ROSS, SANDUSKY, SCIOTO,
SENECA, SHELBY, STARK, TUSCARAWAS,
UNION, VAN WERT, VINTON, WARREN,
WASHINGTON, WAYNE, WILLIAMS, WOOD,
WYANDOT

Special Jurisdictional Note:

Details:

**Apprentices wilt receive a 10% increase on top of the percentages listed above provided they are operating mobile equipment. Mechanic Trainees will receive 10% increase if they are required to have CDL.

Class A - Air Compressors on Steel Erection; Asphalt Plant Engineers (Cleveland District Only); Barrier Moving Machine; Boiler Operators, Compressor Operators, or Generators, when mounted on a rig; Boom Trucks (all types); Cableways; Cherry Pickers; Combination- Concrete Mixers & Towers; Concrete Plants (over 4 yd capacity); Concrete Pumps; Cranes (all types); Compact Cranes track or rubber over 4,000 pounds capacity; Cranes self-erecting stationary, track or truck; Derricks (all types); Draglines; Dredges dipper, clam or suction; Elevating Graders or Euclid Loaders; Floating Equipment (all types); Gradalls; Helicopter Crew (Operator-hoist or winch); Hoes (all types); Hoisting Engines; Hoisting Engines, on shaft or tunnel work; Hydraulic Gantry (lifting system); Industrial-type Tractors; Jet Engine Dryer (D8 or D9) diesel Tractors; Locomotives (standard gauge); Maintenance Operators/Technicians (class A); Mixers, paving (single or double drum); Mucking Machines; Multiple Scrapers; Piledriving Machines (all types); Power Shovels, Prentice Loader; Quad 9 (double pusher); Rail Tamper (with automatic lifting and aligning device); Refrigerating Machines (freezer operation); Rotary Drills, on caisson work; Rough Terrain Fork Lift with winch/hoist; Side Booms; Slip Form Pavers; Survey Crew Party Chiefs; Tower Derricks; Tree Shredders; Trench Machines (over 24" wide); Truck Mounted Concrete Pumps; Tug Boats; Tunnel Machines and /or Mining Machines; Wheel Excavators.

Class B - Asphalt Pavers; Automatic Subgrade Machines, self-propelled (CMI-type); Bobcat-type and /or Skid Steer Loader with hoe attachment greater than 7000 lbs.; Boring Machine Operators (more than 48 inches); Bulldozers; Concrete Saws, Vermeer type; Endloaders; Horizontal Directional Drill (50,000 ft. lbs. thrust and over); Hydro Milling Machine; Kolman-type Loaders (production type-dirt); Lead Greasemen; Lighting and Traffic Signal Installation Equipment includes all groups or classifications; Maintenance Operators/Technicians, Class B; Material Transfer Equipment (shuttle buggy) Asphalt; Pettibone-Rail Equipment; Power Graders; Power Scrapers; Push Cats; Rotomills (all), Grinders and Planners of all types, Groovers (excluding walk-behinds); Trench Machines (24 inch wide and under).

Class C - A-Frames; Air Compressors, on tunnel work (low Pressure); Articulating/straight bed end dumps if assigned (minus \$4.00 per hour); Asphalt Plant Engineers (Portage and Summit Counties only); Bobcat-type and/or skid steer loader with or without attachments; Drones; Highway Drills (all types); HydroVac/Excavator (when a second person is needed, the rate of pay will be "Class E"); Locomotives (narrow gauge); Material Hoist/Elevators; Mixers, concrete (more than one bag capacity); Mixers, one bag capacity (side loader); Power Boilers (over 15 lbs. pressure); Pump Operators (installing or operating well Points); Pumps (4 inch and over discharge); Railroad Tie Inserter/Remover; Rollers, Asphalt; Rotovator (lime-soil Stabilizer); Switch & Tie Tampers (without lifting and aligning device); Utilities Operators, (small equipment); Welding Machines and

Generators.

Class D – Backfillers and Tampers; Ballast Re-locator; Bar and Joint Installing Machines; Batch Plant Operators; Boring Machine Operators (48 inch or less); Bull Floats; Burlap and Curing Machines; Concrete Plants (capacity 4 yds. and under); Concrete Saws (multiple); Conveyors (highway); Crushers; Deckhands; Farm type tractors, with attachments (highway); Finishing Machines; Firemen, Floating Equipment (all types); Fork Lifts (highway), except masonry; Form Trenchers; Hydro Hammers; Hydro Seeders; Pavement Breakers (hydraulic or cable); Plant Mixers; Post Drivers; Post Hole Diggers; Power Brush Burners; Power Form Handling Equipment; Road Widening Trenchers; Rollers (brick, grade, macadam); Self-Propelled Power Spreaders; Self-Propelled Sub-Graders; Steam Firemen; Survey Instrument men; Tractors, pulling sheepsfoot rollers or graders; Vibratory Compactors, with integral power.

Class E - Compressors (portable, Sewer, Heavy and Highway); Cranes-Compact, track or rubber under 4,000 pound capacity; Drum Firemen (asphalt plant); Fueling and greasing (Primary Operator with Specialized CDL Endorsement Add \$3.00/hr); Generators; Inboard-Outboard Motor Boat Launches; Masonry Fork Lifts; Oil Heaters (asphalt plant); Oilers/Helpers; Power Driven Heaters (oil fired); Power Scrubbers; Power Sweepers; Pumps (under 4 inch discharge); Signalperson; Survey Rodmen or Chairmen; Tire Repairmen; VAC/ALLS. Master Mechanic - Master Mechanic

Name of Union: Painter Local 639

Change #: LCNO1-2015fbLoc639

Craft: Painter Effective Date: 06/10/2015 Last Posted: 06/10/2015

	BHR		Frin	ge Bene	fit Paym	ients		Irrevo Fui	I	Total PWR	Overtime Rate
		H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classific	ation										
Painter Metal Finisher/Helpers											
Top Helper Class A	\$19.09	\$3.65	\$0.00	\$0.00	\$0.66	\$0.00	\$0.00	\$0.00	\$0.00	\$23.40	\$32.94
Top Helper Class B	\$19.09	\$3.65	\$0.65	\$0.00	\$1.03	\$0.00	\$0.37	\$0.00	\$0.00	\$24.79	\$34.33
Top Helper Class C	\$19.09	\$3.65	\$1.00	\$0.00	\$1.76	\$0.00	\$0.37	\$0.00	\$0.00	\$25.87	\$35.41
Helper Class A	\$14.69	\$3.65	\$0.00	\$0.00	\$0.51	\$0.00	\$0.00	\$0.00	\$0.00	\$18.85	\$26.19
Helper Class B	\$14.69	\$3.65	\$0.65	\$0.00	\$0.79	\$0.00	\$0.28	\$0.00	\$0.00	\$20.06	\$27.40
Helper Class C	\$14.69	\$3.65	\$1.00	\$0.00	\$1.64	\$0.00	\$0.28	\$0.00	\$0.00	\$21.26	\$28.60
New Hire 90 Days	\$11.00	\$3.65	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$14.65	\$20.15

Special Calculation Note: Other is Sick and Personal Time

Ratio:

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GEAUGA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON, KNOX, LAKE, LAWRENCE, LICKING, LOGAN, LORAIN, LUCAS, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY,

SCIOTO, SENECA, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WOOD, WYANDOT

Special Jurisdictional Note:

Details:

Top Helper: Shall perform the responsibilities of a Helper and be responsible for the setup, break down, safety and quality of the company's product.

Helper: Shall be responsible for performing tasks in refinishing, compliance with safety procedures, setting up and breaking down job sites, scaffolding and swing stages and preparing surfaces for refinishing including but not limited to, masking and stripping and cleaning, oxidizing, polishing and scratch removal on various surfaces

Class A Workers: Less than 1 Year of Service.

Class B Workers: More than 1 and less than 8 Years of Service.

Class C Workers: More than 8 Years of Service.

Metal Polisher Scope of Work: Polishing, buffing, stripping, coloring, lacquering, spraying, cleaning and maintenance of ornamental and architectural metals, iron, bronze, nickel, aluminum and stainless steel and in mental specialty work, various stone finishes, stone specialty work and any other work pertaining to the finishing of metal, stones, woods, and any window washing/cleaning done in conjunction with this work, using chemicals, solvents, coatings and hand applied lacquer thinner, removing scratches from mirrow finished metals, burnishing of bronze, statuary finishes on exterior and interior surfaces and the use of all tools required to perform such work, including but not limited to polishes, spray equipment and scaffolding.

Swing State Rate: All work on scaffold 4 sections or higher, including any boom lifts and swing stage scaffolds including the rigging and derigging of hanging/suspended swing stage systems and rappelling/bolson chair work, ADD \$1.50 per hour.

Name of Union: Painter Local 639 Zone 1 Sign

Change #: LCN01-2023ibLoc639Zone1Sign

Craft: Painter Effective Date: 07/05/2023 Last Posted: 07/05/2023

	B	HR		Fring	e Bene	fit Pay	ments		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classification												
Painter Sign Erector Service/Patteren/Metal Fab/Neon Class A	\$2:	5.38	\$8.41	\$5.57	\$0.25	\$0.76	\$0.00	\$1.06	\$0.00	\$0.00	\$41.43	\$54.12
Painter Sign Erector/Service/Patteren/Metal Fab/Neon Class B	\$2:	5.38	\$8.41	\$5.57	\$0.25	\$1.51	\$0.00	\$1.06	\$0.00	\$0.00	\$42.18	\$54.87
Painter Sign Erector/Service/Patteren/Metal Fab/Neon Class C	\$2:	5.38	\$8.41	\$5.57	\$0.25	\$2.27	\$0.00	\$1.06	\$0.00	\$0.00	\$42.94	\$55.63
Painter Sign Erector/Service/Patteren/Metal Fab/Neon Class D	\$2:	5.38	\$8.41	\$5.57	\$0.25	\$3.03	\$0.00	\$1.06	\$0.00	\$0.00	\$43.70	\$56.39
Computer Operator, Router, Spray Painter/Wood Class A	\$2.	3.78	\$8.41	\$5.57	\$0.25	\$0.73	\$0.00	\$1.02	\$0.00	\$0.00	\$39.76	\$51.65
Computer Operator, Router, Spray Painter/Wood Class B	\$2.	3.78	\$8.41	\$5.57	\$0.25	\$1.45	\$0.00	\$1.02	\$0.00	\$0.00	\$40.48	\$52.37
Computer Operator, Router, Spray Painter/Wood Class C	\$2.	3.78	\$8.41	\$5.57	\$0.25	\$2.18	\$0.00	\$1.02	\$0.00	\$0.00	\$41.21	\$53.10
Computer Operator, Router, Spray Painter/Wood Class D	\$2:	3.78	\$8.41	\$5.57	\$0.25	\$2.90	\$0.00	\$1.02	\$0.00	\$0.00	\$41.93	\$53.82
Final Assembly,Helper Class A	\$19	9.06	\$8.41	\$5.57	\$0.25	\$0.64	\$0.00	\$0.89	\$0.00	\$0.00	\$34.82	\$44.35
Final Assembly,Helper Class B	\$19	9.06	\$8.41	\$5.57	\$0.25	\$1.27	\$0.00	\$0.89	\$0.00	\$0.00	\$35.45	\$44.98
Final Assembly,Helper Class C	\$19	9.06	\$8.41	\$5.57	\$0.25	\$1.90	\$0.00	\$0.89	\$0.00	\$0.00	\$36.08	\$45.61
Final Assembly,Helper Class D	\$19	9.06	\$8.41	\$0.00	\$0.00	\$2.54	\$0.00	\$0.89	\$0.00	\$0.00	\$30.90	\$40.43
Apprentice	Per	cent										
1-2000 hrs	50.00	\$12.69	\$8.41	\$5.57	\$0.25	\$0.00	\$0.00	\$0.72	\$0.00	\$0.00	\$27.64	\$33.99
2001-3000 hrs	55.00	\$13.96	\$8.41	\$5.57	\$0.25	\$0.54	\$0.00	\$0.76	\$0.00	\$0.00	\$29.49	\$36.47
3001-4000 hrs	60.00	\$15.23	\$8.41	\$5.57	\$0.25	\$0.57	\$0.00	\$0.79	\$0.00	\$0.00	\$30.82	\$38.43
4001-5000 hrs	65.00	\$16.50	\$8.41	\$5.57	\$0.25	\$1.18	\$0.00	\$0.83	\$0.00	\$0.00	\$32.74	\$40.99
5001-6000 hrs	70.00	\$17.77	\$8.41	\$5.57	\$0.25	\$1.23	\$0.00	\$0.86	\$0.00	\$0.00	\$34.09	\$42.97

6001-7000 hrs	85.00	\$21.57	\$8.41	\$5.57	\$0.25	\$1.38	\$0.00	\$0.96	\$0.00	\$0.00	\$38.14	\$48.93
7001-8000 hrs	90.00	\$22.84	\$8.41	\$5.57	\$0.25	\$1.43	\$0.00	\$1.00	\$0.00	\$0.00	\$39.50	\$50.92

Special Calculation Note: Other is for paid holidays. Apprentice Pay Rate should be based on proper Classification.

Ratio:

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, ASHTABULA, CUYAHOGA, GEAUGA, LAKE, MEDINA, PORTAGE, RICHLAND, SUMMIT

Special Jurisdictional Note:

Details:

Class A Worker: More than 1 year but less that 2 years. Class B Worker: More than 2 years but less than 10 years. Class C Worker: More than 10 years but less that 20 years.

Class D Worker: More than 20 years

Name of Union: Painter Local 788

Change #: LCN01-2023ibLoc788

Craft: Painter Effective Date: 06/01/2023 Last Posted: 05/31/2023

	Bì	HR		Fring	ge Bene	fit Payı	nents		Irrevo Fur		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classifica	tion											
Painter Brush Roll	\$2:	5.78	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$43.25	\$56.14
Paperhanger	\$20	5.18	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$43.65	\$56.74
Structural Steel	\$2	7.38	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$44.85	\$58.54
REFINERY RATE												
Painter Brush Roll	\$27	7.57	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$45.04	\$58.83
Paperhanger	\$28	8.77	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$46.24	\$60.63
Structural Steel	\$28	8.97	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$46.44	\$60.92
POWERHOUSE RATE												
Painter Brush Roll	\$30	0.22	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.69	\$62.80
Paperhanger	\$30	0.48	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.95	\$63.19
Structural Steel	\$30	0.67	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.14	\$63.48
Apprentice	Per	cent										
1st Year	60.00	\$15.47	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$32.94	\$40.67
2nd Year	70.00	\$18.05	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$35.52	\$44.54
3rd Year	80.00	\$20.62	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$38.09	\$48.41
4th Year	90.00	\$23.20	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$40.67	\$52.27

Special Calculation Note: Apprentice rate based upon % of each classification.

Ratio:

1 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, ERIE, HANCOCK, HURON, MARION, MORROW, OTTAWA, RICHLAND, SANDUSKY, SENECA, WYANDOT

Special Jurisdictional Note:

Details:

B. \$0.50 per hour shall be added to the rate of pay for the classification of work, while working: Swing stage,

Boatswain Chair, Needle Beam & Horizontal Cable.

- C. \$0.50 per hour shall be added to the rate of pay for the classification of work, while operating: Spray guns to apply oil based paint spray bar joist ceilings or epoxy coatings, Sandblasting, Cob blasting, High Pressure Water blasting (4000 PSI), and for Automatic Taping & Finishing Tools for Drywall.
- D. \$0.50 per hour shall be added to the rate of pay for the classification of work, for tending: three (3) or more sprayers.
- E. \$1.00 per hour shall be added to the rate of pay for the classification of work, for the application of: Catalyzed Epoxy, including latex Epoxy that is deemed hazardous, Lead Abatement, or for work or material, where special precautions beyond normal work duties must be taken. Questionable work or material shall be approved by the Business Representative and/or Joint Trade Board.
- F. \$1.00 per hour shall be added to the rate of pay for the classification of work, for working on: Stacks, Tanks, and Towers over forty (40) feet in height.

Name of Union: Painter Local 788 Hvy Hwy

Change # : LCN01-2023ibLoc788HvyHwy

Craft: Painter Effective Date: 06/01/2023 Last Posted: 05/31/2023

	B	HR		Fring	ge Bene	fit Payı	nents		Irrevo Fui	I	Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classificatio	n											
Painter Bridge Class 1 Bridge Blaster	\$3′	7.26	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$54.73	\$73.36
Class 2 Bridge Painter, RiggerContainment Builder, Spot Blaster	\$34	4.26	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$51.73	\$68.86
Class 3 Equipment Operator/Field Mechanic, Grit Reclamation, Paint Mixer, Traffic Control Boat Person, Driver (0-5 Years Exp.)	\$2'	7.26	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$44.73	\$58.36
Class 3 Equipment Operator/Field Mechanic, Grit Reclamation, Paint Mixer, Traffic Control Boat Person, Driver (5 Plus Years Exp.)	\$30	0.26	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.73	\$62.86
Class 4 Concrete Sealing, Concrete Blasting/Power Washing/Etc	\$30).26	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.73	\$62.86
Class 5 Quality Control.Quality Assurance, Traffic Safety, Competent Person	\$30).26	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.73	\$62.86
Apprentice	Per	cent	_									
1st Year	60.00	\$22.36	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$39.83	\$51.00
2nd Year	70.00	\$26.08	\$8.72	\$8.30		\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$43.55	\$56.59

3rd Year	80.00	\$29.81	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.28	\$62.18
4th Year	90.00	\$33.53	\$8.72	\$8.30	\$0.45	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$51.00	\$67.77

Special Calculation Note: *Apprentice pay based upon % of each classification

Ratio:

1 Apprentice to 1 Journeyman

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, ERIE, HANCOCK, HURON, MARION, MORROW, OTTAWA, RICHLAND, SANDUSKY, SENECA, WYANDOT

Special Jurisdictional Note:

Details:

Name of Union: Plasterer Local 132 (Columbus)

Change #: LCN01-2023sksLoc132

Craft: Plasterer Effective Date: 06/01/2023 Last Posted: 05/31/2023

	Bì	HR		Fring	ge Bene	fit Payn	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Plasterer	\$23	8.54	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$42.89	\$57.16
Apprentice	Per	cent										
1st 800 hrs	70.00	\$19.98	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$34.33	\$44.32
2nd 800 hrs	74.00	\$21.12	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$35.47	\$46.03
3rd 800 hrs	78.00	\$22.26	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$36.61	\$47.74
4th 800 hrs	82.00	\$23.40	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$37.75	\$49.45
5th 800 hrs	86.00	\$24.54	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$38.89	\$51.17
6th 800 hrs	90.00	\$25.69	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$40.04	\$52.88
7th 800 hrs	94.00	\$26.83	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$41.18	\$54.59
8th 800 hrs	98.00	\$27.97	\$7.50	\$4.30	\$0.50	\$0.00	\$2.00	\$0.05	\$0.00	\$0.00	\$42.32	\$56.30

Special Calculation Note: *Other is International Training Fund

Ratio:

3 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, COSHOCTON, CRAWFORD, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GUERNSEY, HOCKING, KNOX, LICKING, MADISON, MARION, MORROW, MUSKINGUM, PERRY, PICKAWAY, RICHLAND, ROSS, UNION, VINTON, WYANDOT

Special Jurisdictional Note:

Details:

PLASTERER IMPROVERS:

Is a person who has skills between an Apprentice and a Journeyman can be signed in as an Improver. An Improver receives 85% of the current wage and pension. All other benefits are same as Journeyman. The Improver has the opportunity to advance to Journeyman level by:

- (1) Working through a trial period of no more than 2,000 hrs.
- (2) Attending all safety and upgrading classes held or required.

Working on swing stage, slip scaffold or window jack scaffold shall receive the following rates: \$.50 above the regular rate for heights up to fifty (50) feet above grade level

1.00 above the regular rate for heights over fifty (50) feet above grade level	

Name of Union: Plumber Pipefitter Local 42

Change #: LCN01-2023ibLoc42

Craft: Plumber/Pipefitter Effective Date: 07/01/2023 Last Posted: 06/28/2023

	B	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui	I	Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Plumber Pipefitter	\$3:	5.62	\$12.62	\$11.75	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$61.09	\$78.90
Plumber Pipefitter Heavy Industrial	\$3	7.62	\$12.62	\$11.75	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$63.09	\$81.90
Apprentice Heavy Industrial												
1st Year	\$20	0.20	\$8.92	\$0.00	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$30.22	\$40.32
2nd Year	\$23	3.87	\$12.62	\$7.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$45.22	\$57.16
3rd Year	\$2	7.63	\$12.62	\$7.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.98	\$62.80
4th Year	\$30	0.39	\$12.62	\$8.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$52.74	\$67.93
5th Year	\$1	.16	\$12.62	\$9.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$24.51	\$25.09
Apprentice	Per	cent										
1st Year	54.32	\$19.35	\$8.92	\$0.00	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$29.37	\$39.04
2nd Year	64.06	\$22.82	\$12.62	\$7.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$44.17	\$55.58
3rd Year	74.05	\$26.38	\$12.62	\$7.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.73	\$60.91
4th Year	81.24	\$28.94	\$12.62	\$8.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$51.29	\$65.76
5th Year	88.45	\$31.51	\$12.62	\$9.63	\$1.10	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$54.86	\$70.61

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time.

Ratio:

1 Journeyman to 1 Apprentice 2 Journeymen to 2 Apprentice Then 1 Journeyman to 5 Apprentices thereafter with No Max

Water Treatment Work described below is a ratio of: 1 Journeyman to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, ERIE, HURON, KNOX, LORAIN, MORROW, RICHLAND, WYANDOT

Special Jurisdictional Note:

Details:

Includes but not limited to: all water services from main to building including water meters and water meter foundations, all lawn sprinkler work including piping, fittings, and lawn sprinkler heads, all power plant piping of every description. All fire extinguishing systems and piping whether by water, steam,gas, or chemical, fire alarm piping and control tubing.

On Water Treatment Plants, waste water treatment plants, prefabricated water treatment plants, lift stations, elevated water tanks, meter vaults, underground work on site at treatment, water mains and fire protection external mains, all construction work on public utilities obtained by employer other than plumbing and heating.

On all construction projects wherein the work involves sanitary sewers, storm sewers and water lines (site work) performed outside the structure of the building.

Name of Union: Roofer Local 88

Change #: LCN01-2023ibLoc88

Craft: Roofer Effective Date: 06/07/2023 Last Posted: 06/07/2023

	В	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fu	- 11	Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Clas	sification											
Roofer	\$3	0.07	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$51.45	\$66.49
HELPERS												
Helper -500 Hrs. 1st 6 months	\$1	6.84	\$2.25	\$0.00	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$21.17	\$29.59
Helper - 500 Hrs. 2nd 6 months	\$1	8.65	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$40.03	\$49.35
2nd year Helper	\$2	0.45	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$41.83	\$52.05
Brd year Helper	\$2	2.26	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$43.64	\$54.77
4th year Helper	\$2	4.06	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$45.44	\$57.47
5th year Helper	\$2	5.86	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$47.24	\$60.17
Apprentice	Pei	cent										
1st 6 months w/500 hrs	56.00	\$16.84	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$38.22	\$46.64
2nd 6 months w/500 hrs	62.02	\$18.65	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$40.03	\$49.35
3rd 6 months w/500 hrs	68.00	\$20.45	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$41.83	\$52.05
4th 6 months w/500 hrs	74.02	\$22.26	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$43.64	\$54.77
5th 6 months w/500 hrs	80.00	\$24.06	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$45.44	\$57.46

6th 6 months w/500 hrs	86.00	\$25.86	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$47.24	\$60.17
7th 6 months w/500 hrs	92.02	\$27.67	\$9.50	\$9.80	\$0.40	\$0.00	\$1.50	\$0.18	\$0.00	\$0.00	\$49.05	\$62.89

Special Calculation Note: Roofers working in any form of coal tar pitch, whether hot or cold, installing and/or removing will be paid \$.25 more per hour. Other \$0.18 is for C.I.D.B.

Ratio:

No helper shall be used on any one job unless 1 Journeymen, and 1 Apprentices are working on said job CRAWFORD, HOLMES, HURON, LORAIN*, .One

(1) Journeymen to One (1) Apprentice to One (1) Helper

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CARROLL, COSHOCTON, MEDINA, PORTAGE, RICHLAND, STARK, SUMMIT, TUSCARAWAS, WAYNE

Special Jurisdictional Note: In Lorain County (South of the Turnpike)

Details:

Name of Union: Sheet Metal Local 33 Industrial Door

Change #: LCN01-2023ibLoc33IndustrialDoor

Craft: Sheet Metal Worker Effective Date: 08/02/2023 Last Posted: 08/02/2023

	BHR		Fringe Benefit Payments						Irrevocable Fund		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classi	fication											
Sheet Metal Worker	\$2:	5.42	\$8.66	\$5.55	\$0.17	\$0.00	\$2.15	\$0.00	\$0.00	\$0.00	\$41.95	\$54.66
Trainees	Percent											
1st 60 days Probationary Perios	52.00	\$13.22	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$13.22	\$19.83
61st day-12 months	58.00	\$14.74	\$8.66	\$1.92	\$0.17	\$0.00	\$1.41	\$0.00	\$0.00	\$0.00	\$26.90	\$34.28
2nd yr	68.00	\$17.29	\$8.66	\$1.92	\$0.17	\$0.00	\$1.59	\$0.00	\$0.00	\$0.00	\$29.63	\$38.27
3rd yr	73.00	\$18.56	\$8.66	\$1.92	\$0.17	\$0.00	\$1.69	\$0.00	\$0.00	\$0.00	\$31.00	\$40.27
4th yr	80.00	\$20.34	\$8.66	\$1.92	\$0.17	\$0.00	\$1.80	\$0.00	\$0.00	\$0.00	\$32.89	\$43.05
5th yr	86.00	\$21.86	\$8.66	\$1.92	\$0.17	\$0.00	\$1.91	\$0.00	\$0.00	\$0.00	\$34.52	\$45.45

Special	Calcu	lation	Note:
---------	-------	--------	-------

Rat	Hio.			
Nai	LIO			

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, ASHTABULA, CARROLL, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DEFIANCE, ERIE, FULTON, GEAUGA, HANCOCK, HENRY, HOLMES, HURON, LAKE, LORAIN, LUCAS, MAHONING, MEDINA, OTTAWA, PAULDING, PORTAGE, PUTNAM, RICHLAND, SANDUSKY, SENECA, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, WAYNE, WILLIAMS, WOOD

Special Jurisdictional Note:

Details:

Name of Union: Sheet Metal Local 33 (Akron)

Change #: LCN01-2023ibLoc33Akron

Craft: Sheet Metal Worker Effective Date: 06/01/2023 Last Posted: 05/31/2023

	B	HR	Fringe Benefit Payments						Irrevocable Fund		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classification												
Sheet Metal Worker	\$34.90		\$9.65	\$13.20	\$0.93	\$0.00	\$7.64	\$0.00	\$0.00	\$0.00	\$66.32	\$83.77
1st year	60.00	\$20.94	\$9.65	\$4.81	\$0.17	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$35.57	\$46.04
2nd year	65.02	\$22.69	\$9.65	\$5.97	\$0.93	\$0.00	\$3.82	\$0.00	\$0.00	\$0.00	\$43.06	\$54.41
3rd year	70.00	\$24.43	\$9.65	\$6.37	\$0.93	\$0.00	\$3.82	\$0.00	\$0.00	\$0.00	\$45.20	\$57.41
4th year	80.00	\$27.92	\$9.65	\$7.18	\$0.93	\$0.00	\$3.82	\$0.00	\$0.00	\$0.00	\$49.50	\$63.46

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time.

Ratio:

1 Journeymen to 1 Apprentice

2 Journeymen to 1 Apprentice

3 Journeymen to 2 Apprentice

4 Journeymen to 2 Apprentice

5-7 Journeymen to 3 Apprentice

8-10 Journeymen to 4 Apprentice

11-13 Journeymen to 5 Apprentice

14, 15 Journeymen to 6 Apprentice

and maintaining a three to one apprentice ratio

thereafter.

Special Jurisdictional Note:

Details:

Scope of Work: This Agreement covers the rates of pay and conditions of employment of all employees of the Employer engaged in, but not limited to, the a) manufacture, fabrication, assembling, handling, erection, installation, dismantling, conditioning, adjustment, alteration, repairing and servicing of all ferrous or nonferrous metal work and all other materials used in lieu thereof and of all HVAC systems, air-veyor systems, exhaust systems, and air handling systems regardless of material used, including the setting of all equipment and

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CARROLL, COSHOCTON, CRAWFORD, HOLMES, MEDINA, PORTAGE, RICHLAND, STARK, SUMMIT, TUSCARAWAS, **WAYNE**

all reinforcements in connection therewith; (b) all lagging over insulation and all duct-lining; (c) testing, servicing, and balancing of all air-handling equipment and duct work; (d) the preparation of all shop and field sketches, whether manually drawn or computer assisted, used in fabrication and erection, including those taken from original architectural and engineering drawings or sketches, and (e) metal roofing; and (f) all other work included in the jurisdictional claims of Sheet Metal Worker's International Association.

Industrial Door-Installation and service of overhead doors roll up doors, docks and dock leveling.

Prevailing Wage Rate Skilled Crafts

Name of Union: Sprinkler Fitter Local 669

Change #: LCN01-2022sksLoc669

Craft: Sprinkler Fitter Effective Date: 04/06/2022 Last Posted: 04/06/2022

	Bl	HR		Fring	ge Bene	fit Payn	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Sprinkler Fitter	\$43.75		\$10.99	\$7.10	\$0.52	\$0.00	\$5.12	\$0.00	\$0.00	\$0.00	\$67.48	\$89.35
Apprentice Indentured after April 1, 2013	Per	cent										
CILASS 1	45.00	\$19.69	\$7.85	\$0.00	\$0.52	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$28.06	\$37.90
CLASS 2	50.02	\$21.88	\$7.85	\$0.00	\$0.52	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$30.25	\$41.20
CLASS 3	54.43	\$23.81	\$10.99	\$7.10	\$0.52	\$0.00	\$1.15	\$0.00	\$0.00	\$0.00	\$43.57	\$55.48
CLASS 4	59.43	\$26.00	\$10.99	\$7.10	\$0.52	\$0.00	\$1.15	\$0.00	\$0.00	\$0.00	\$45.76	\$58.76
CLASS 5	64.43	\$28.19	\$10.99	\$7.10	\$0.52	\$0.00	\$1.40	\$0.00	\$0.00	\$0.00	\$48.20	\$62.29
CLASS 6	69.43	\$30.38	\$10.99	\$7.10	\$0.52	\$0.00	\$1.40	\$0.00	\$0.00	\$0.00	\$50.39	\$65.57
CLASS 7	74.43	\$32.56	\$10.99	\$7.10	\$0.52	\$0.00	\$1.40	\$0.00	\$0.00	\$0.00	\$52.57	\$68.85
CLASS 8	79.42	\$34.75	\$10.99	\$7.10	\$0.52	\$0.00	\$1.40	\$0.00	\$0.00	\$0.00	\$54.76	\$72.13
CLASS 9	84.43	\$36.94	\$10.99	\$7.10	\$0.52	\$0.00	\$1.40	\$0.00	\$0.00	\$0.00	\$56.95	\$75.42
CLASS 10	89.44	\$39.13	\$10.99	\$7.10	\$0.52	\$0.00	\$1.40	\$0.00	\$0.00	\$0.00	\$59.14	\$78.70

Special Calculation Note:

Ratio:

1 Journeyman to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON, KNOX, LAWRENCE, LICKING, LOGAN, LUCAS, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW,

MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WOOD, WYANDOT

Special Jurisdictional Note:

Details:

Sprinkler Fitter work shall consist of the installation, dismantling, maintenance, repairs, adjustments, and corrections of all fire protection and fire control systems including the unloading, handling by hand, power equipment and installation of all piping or tubing, appurtenances and equipment pertaining thereto, including both overhead and underground water mains, fire hydrants and hydrant mains, standpipes and hose connections to sprinkler systems used in connection with sprinkler and alarm systems. Also all tanks and pumps connected thereto, also included shall be CO-2 and Cardox Systems, Dry Chemical Systems, Foam Systems and all other fire protection systems.

Prevailing Wage Rate Skilled Crafts

Name of Union: Truck Driver Bldg & HevHwy Class 1 Locals 20,40,92,92b,100,175,284,438,377,637,908,957

Change #: LCN01-2023ibBldgHevHwy

Craft: Truck Driver Effective Date: 05/01/2023 Last Posted: 04/26/2023

	ВІ	łR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Truck Driver CLASS 1 4 wheel service, dump, and batch trucks; drivers on tandems; truck sweepers (not to include power sweepers & scrubbers)	\$31	.24	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.39	\$64.01
Apprentice	Per	cent										
First 6 months	80.00	\$24.99	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$42.14	\$54.64
7-12 months	85.00	\$26.55	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$43.70	\$56.98
13-18 months	90.00	\$28.12	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$45.27	\$59.32
19-24 months	95.00	\$29.68	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$46.83	\$61.67
25-30 months	100.00	\$31.24	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.39	\$64.01

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time.

Ratio:

3 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK,

CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON, KNOX, LAWRENCE, LICKING, LOGAN, LORAIN, LUCAS, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WOOD, WYANDOT

Special Jurisdictional Note:

Details:

Prevailing Wage Rate Skilled Crafts

Name of Union: Truck Driver Bldg & HevHwy Class 2 Locals 20,40,92,92b,100,175,284,438,377,637,908,957

Change #: LCN01-2023ibBldgHevHwy

Craft: Truck Driver Effective Date: 05/01/2023 Last Posted: 04/26/2023

	BI	IR		Fring	ge Bene	fit Payı	ments		Irrevo Fur		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Classification												
Truck Driver CLASS 2 Tractor Trailer-Semi Tractor Trucks; Pole Trailers; Ready Mix Trucks; Fuel Trucks; 5 Axle & Over; Belly Dumps; Low boys - Heavy duty Equipment(irrespective of load carried) when used exclusively for transportation; Truck Mechanics (when needed)	\$31	.66	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.81	\$64.64
Apprentice	Perc	cent										
First 6 months	80.00	\$25.33	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$42.48	\$55.14
7-12 months	85.00	\$26.91	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$44.06	\$57.52
13-18 months	90.00	\$28.49	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$45.64	\$59.89
19-24 months	95.00	\$30.08	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$47.23	\$62.27
25-30 months	100.00	\$31.66	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.81	\$64.64

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time.

Ratio:

3 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GREENE, GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON,

KNOX, LAWRENCE, LICKING, LOGAN, LORAIN, LUCAS, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WOOD, WYANDOT

Special Jurisdictional Note:

Details:

Prevailing Wage Rate Skilled Crafts

Name of Union: Truck Driver Bldg & HevHwy Class 3 Locals 20,40,92,92b,100,175,284,438,377,637,908,957

Change #: LCN01-2023ibBldgHevHwy3

Craft: Truck Driver Effective Date: 05/01/2023 Last Posted: 04/26/2023

	ВЕ	IR		Fring	ge Bene	fit Payı	nents		Irrevo Fu	I	Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Truck Driver CLASS 3 Articulated Dump Trucks; Ridge- Frame Rock Trucks; Distributor Trucks)	\$32	2.66	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$49.81	\$66.14
Apprentice	Per	cent										
First 6 months	80.00	\$26.13	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$43.28	\$56.34
7-12 months	85.00	\$27.76	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$44.91	\$58.79
13-18 months	90.00	\$29.39	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$46.54	\$61.24
19-24 months	95.00	\$31.03	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$48.18	\$63.69
25-30 months	100.00	\$32.66	\$7.75	\$9.20	\$0.20	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$49.81	\$66.14

Special Calculation Note: No special calculations for this skilled craft wage rate are required at this time.

Ratio:

3 Journeymen to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ALLEN, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, DARKE, DEFIANCE, DELAWARE, ERIE, FAIRFIELD, FAYETTE, FRANKLIN, FULTON, GALLIA, GREENE,

GUERNSEY, HAMILTON, HANCOCK, HARDIN, HARRISON, HENRY, HIGHLAND, HOCKING, HOLMES, HURON, JACKSON, JEFFERSON, KNOX, LAWRENCE, LICKING, LOGAN, LORAIN, LUCAS, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW, MUSKINGUM, NOBLE, OTTAWA, PAULDING, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, PUTNAM, RICHLAND, ROSS, SANDUSKY, SCIOTO, SENECA, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VAN WERT, VINTON, WARREN, WASHINGTON, WAYNE, WILLIAMS, WOOD, WYANDOT

Special Jurisdictional Note:

Details:

Prevailing Wage Rate Skilled Crafts

Name of Union: Electrical Local 688 Voice Data Video

Change #: LCN01-2022sksLoc688VDV

Craft: Voice Data Video Effective Date: 06/29/2022 Last Posted: 06/29/2022

	В	HR		Fring	ge Bene	fit Payr	nents		Irrevo Fui		Total PWR	Overtime Rate
			H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	sification											
Electrical Installer Technician B	\$2	9.50	\$9.65	\$2.14	\$0.70	\$0.00	\$1.21	\$0.68	\$0.00	\$0.00	\$43.88	\$58.63
Installer Technician A	\$30	0.75	\$9.65	\$2.18	\$0.70	\$0.00	\$1.21	\$0.71	\$0.00	\$0.00	\$45.20	\$60.58
Cable Puller	\$1.	4.75	\$9.65	\$1.70	\$0.70	\$0.00	\$1.21	\$0.34	\$0.00	\$0.00	\$28.35	\$35.73
Apprentice	Per	cent										
1st Period 0-1000hrs	55.00	\$16.23	\$9.65	\$1.74	\$0.70	\$0.00	\$1.21	\$0.38	\$0.00	\$0.00	\$29.90	\$38.02
2nd 1001- 2000hours	60.00	\$17.70	\$9.65	\$1.79	\$0.70	\$0.00	\$1.21	\$0.41	\$0.00	\$0.00	\$31.46	\$40.31
3rd 2001- 3000 hours	65.00	\$19.17	\$9.65	\$1.83	\$0.70	\$0.00	\$1.21	\$0.45	\$0.00	\$0.00	\$33.02	\$42.60
4th 3001- 4000 hours	70.00	\$20.65	\$9.65	\$1.87	\$0.70	\$0.00	\$1.21	\$0.48	\$0.00	\$0.00	\$34.56	\$44.89
5th 4001- 5000 hours	75.00	\$22.12	\$9.65	\$1.92	\$0.70	\$0.00	\$1.21	\$0.51	\$0.00	\$0.00	\$36.12	\$47.18
6th 5001- 6000 hours	80.00	\$23.60	\$9.65	\$1.96	\$0.70	\$0.00	\$1.21	\$0.55	\$0.00	\$0.00	\$37.67	\$49.47

Special Calculation Note: Other is for Holiday Pay. Vacation: Only applies to employees with one (1) continuous year of service with a firm.

Ratio:

1 Journeyman Installer to 1 Apprentice

Jurisdiction (* denotes special jurisdictional note):

ASHLAND, CRAWFORD, HURON*, KNOX*, MARION, MORROW, RICHLAND, WYANDOT*

Special Jurisdictional Note: In Knox County the following townships: Liberty, Clinton, Union,

Howard, Monroe, Middleberry, Morris, Wayne, Berlin, Pike, Brown, Jefferson.

In Wyandot County: Sycamore, Crane, Eden, Pitt, Antrim & Tymochee.

In Huron County: Richmond, New Haven, Ripley, & Greenwich.

Details:

An employee who is required to wear an electronic device after hours will receive an additional 1.00 per hour for all hours worked.

HOLIDAYS: Memorial Day, 4th of July, Labor Day, Thanksgiving Day, Christmas Day, New Years Day.

The following work is EXCLUDED from the Teledata Technician work scope:

- Installation of computer systems in industrial applications such as assembly lines, robotics, computer controller manufacturing systems.
- Installation of conduit &/or raceways shall be installed by Inside Wireman . On sites where there is no Inside Wireman employed, the Teledata Technician may install raceway, or conduit not greater than 10 foot.
- Fire Alarm work is excluded on all new construction sites or wherever the fire alarm system is installed in conduit
- All HVAC control work.

TECHNICIAN (A) is a Technician B who holds a current Technician Certification from BICSI (Building Industry Consulting Service International, Inc.)

CABLE PULLERS are for the installation of cable from one termination point to another.

Prevailing Wage Rate Skilled Crafts

Name of Union: Electrical Local 71 Voice Data Video Outside

Change #: LCR01-2017fbLoc71VDV

Craft: Voice Data Video Effective Date: 10/18/2017 Last Posted: 10/18/2017

	BHR		Frin	ige Bene	fit Paym	ients		Irrevo Fu		Total PWR	Overtime Rate
		H&W	Pension	App Tr.	Vac.	Annuity	Other	LECET (*)	MISC (*)		
Class	ification										
Electrical Installer Technician I	\$23.46	\$5.50	\$0.70	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$29.96	\$41.69
Installer Technician II	\$22.37	\$5.50	\$0.67	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$28.84	\$40.03
Equipment Operator I	\$22.37	\$5.50	\$0.67	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$28.84	\$40.03
Equipment Operator II	\$18.43	\$5.50	\$0.55	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$24.78	\$33.99
Installer /Repair Outside	\$22.37	\$5.50	\$0.67	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$28.84	\$40.03
Ground Driver W/CDL	\$15.83	\$5.50	\$0.47	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$22.10	\$30.01
Groundman	\$13.24	\$5.50	\$0.40	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$19.44	\$26.06
Cable Splicer	\$23.46	\$5.50	\$0.70	\$0.00	\$0.00	\$0.30	\$0.00	\$0.00	\$0.00	\$29.96	\$41.69

Special Calculation Note:

Ratio:

Jurisdiction (* denotes special jurisdictional note):

ADAMS, ASHLAND, ASHTABULA, ATHENS, AUGLAIZE, BELMONT, BROWN, BUTLER, CARROLL, CHAMPAIGN, CLARK, CLERMONT, CLINTON, COLUMBIANA, COSHOCTON, CRAWFORD, CUYAHOGA, DARKE, DELAWARE, FAIRFIELD, FAYETTE, FRANKLIN, GALLIA, GEAUGA, GREENE, GUERNSEY, HAMILTON, HARRISON, HIGHLAND, HOCKING, HOLMES, JACKSON, JEFFERSON, KNOX, LAKE, LAWRENCE, LICKING, LOGAN, LORAIN, MADISON, MAHONING, MARION, MEDINA, MEIGS, MERCER, MIAMI, MONROE, MONTGOMERY, MORGAN, MORROW,

MUSKINGUM, NOBLE, PERRY, PICKAWAY, PIKE, PORTAGE, PREBLE, RICHLAND, ROSS, SCIOTO, SHELBY, STARK, SUMMIT, TRUMBULL, TUSCARAWAS, UNION, VINTON, WARREN, WASHINGTON, WAYNE

Special Jurisdictional Note:

Details:

Cable Splicer: Inspect and test lines or cables, analyze results, and evaluate transmission characteristics. Cover conductors with insulation or seal splices with moisture-proof covering. Install, splice, test, and repair cables using tools or mechanical equipment. This will include the splicing of fiber.

Journeyman Technician I: Must know all aspects of telephone and cable work. This is to include aerial, underground, and manhole work. Must know how to climb and run bucket. Must have all the tools required to perform these tasks. Must be able to be responsible for the safety of the crew at all times. Must also have CDL license and have at least 5 years experience.

Installer/Repairman: Perform tasks of repairing, installing, and testing phone and CATV services.

Technician II: Have at least three years of telephone and CATV experience. Must have the knowledge of underground, aerial, and manhole work. Must be able to climb and operate bucket. Must have CDL. Must have all tools needed to perform these tasks.

Equipment Operator I: Able to operate a digger derrick or bucket truck. Have at least 5 years of experience and must have a valid CDL license.

Equipment Operator II: Able to operate a digger derrick or bucket truck. Have at least 3 years of experience and must have a valid CDL license.

Groundman W/CDL: Must have a valid CDL license and be able to perform tasks such as: climbing poles, pulling downguys, making up material, and getting appropriate tools for the job. Must have at least 5 year's experience.

Groundman: Perform tasks such as: climbing poles, pulling downguys, making up material, and getting appropriate tools for the job. Experience 0-5 years.

DAS-OIT223 - BUTLER GUYED TOWER REPLACEMENT SECTION 01 10 00 - PROJECT DESCRIPTION

PROJECT DESCRIPTION

This project involves the reconstruction of a new 500-foot-tall self-supporting lattice framework emergency communications towers. The tower will be located at 6469 Garber Road, Belleville, Ohio; Richland County, OH (40°34'58.6"N Lat., 82°28'24.7"W Long).

The current requirements of manufacturer's recommendations for installation, Richland County, and the current Construction and Materials Specifications of the Ohio Department of Transportation, including all supplements thereto, shall govern the materials and workmanship to complete the improvements set forth in the Construction Documents unless specified otherwise in the Construction Documents.

The Contractor shall provide for the construction and completion of every detail of the Work described. The Contractor shall perform all items of Work covered and stipulated in this proposal and perform altered and extra Work, furnish all labor, equipment, materials, tools, transportation, and supplies required to complete the work in accordance with the specifications and terms of the Contract Documents. Should any misunderstanding arise as to the intent or meaning of the plans, specifications, and special provisions of this proposal, or any discrepancy appear, the decision of the Owner or its authorized representative shall be final and conclusive.

Whenever in the plans and specifications references are made to Director, it shall be interpreted to mean Owner or its authorized representative.

Whenever in the plans and specifications references are made to Engineer, it shall be interpreted to mean Verdantas, LLC. or its authorized representative.

Whenever in the plans and specifications references are made to State of Ohio, it shall be interpreted to mean the Owner or its authorized representative.

All construction and material usage shall be in accordance with climatic conditions addressed in the current issue of the Ohio Department of Transportation Construction and Materials Specifications.

DAS-OIT223 - BUTLER GUYED TOWER REPLACEMENT SECTION 01 20 00 - BID ITEMS

- A. The Contractor shall furnish all labor, materials, tools, equipment, appurtenances, and all services necessary to perform all Work required.
- B. Except where specifically stated in individual pay items, no direct or separate payment will be made for providing miscellaneous temporary or accessory works, plant services, Contractor's field office, layout surveys, job signs, sanitary requirements, testing, safety devices, approval and record drawings, water supplies, power, maintaining traffic, removal of waste, watchmen, bonds, insurance, project coordination and all other requirements of the Contract Documents.
- C. Furthermore, all work shown on the Contract Drawings shall be a part of this Contract, whether specifically noted in the Project Manual and Specifications or not. Compensation for these items shall be included in the various items of the Contract.
- D. All Bidders shall completely read each individual pay item description and become familiar with their responsibility there under.

BID ITEMS

- 1. General Conditions/Permitting
 - i. Description: The design engineer has applied for the necessary FCC & FAA permits. The Contractor shall be responsible for submitting the final tower design to the Engineer to finalize permitting through the state. Prior to commencement of construction, the Contractor shall notify the FAA of construction (existing permit number to be supplied by design engineer). Upon completion of the tower, the Contractor shall certify the height and provide this information to the designer for final permit submittals to the FCC and FAA.
- 2. Item 103 Premium for Contract Performance & Payment Bond
 - i. Description: Each Bidder is required to furnish with its Bid Proposal, a Bid Guaranty and Contract Bond in accordance with Section 153.54 of the Ohio Revised Code.
 - ii. Reference Sections
 - 1. General Conditions
 - 2. ODOT Item 103
 - 3. Bid Documents
 - iii. Payment Method Lump Sum
- 3. Item 203 Earthwork
 - i. Description: This Work consists of all excavation and embankment required to achieve finish grade for the compound as well as the relocated drive around within the parking area. Excess material is to be spread onsite in conjunction with Item #12 (Site Work), while maintaining positive drainage away from the tower site.
 - ii. Reference Sections
 - 1. General Conditions
 - 2. ODOT Item 203
 - 3. Bid Documents
 - iii. Payment Method Lump Sum

4. Item 624 – Mobilization

- i. Description: This Work consists of the preparatory Work and operations including, but not limited to, those necessary for the movement of personnel, equipment, supplies, and incidentals to the project site; for all other Work and operations that must be performed, or costs incurred before beginning the Work on the other contract items; and for demobilization.
- ii. Reference Sections
 - 1. General Conditions
 - 2. ODOT Item 624
- iii. Payment Method Lump Sum

5. Item Special – Aggregate Surface

- i. Description: This item includes all materials and workmanship necessary to install the aggregate section at the tower and under the ice bridge. This items also includes the French drain system designed to aid in drainage.
- ii. Reference Sections:
 - 1. ODOT Item 204 Subgrade Compaction
 - 2. Item Special GeoGrid
 - 3. ODOT Item 703 #57 Stone
 - 4. Bid Documents
- iii. Payment Method Lump Sum

6. Item Special - Tower, Complete

- i. Description: This bid item shall include a 500' tower to be installed per the manufacturer's recommendation. This item shall include all labor, materials and methods necessary to install the complete 500' self-supporting tower, including equipment, jumpers, stand-off brackets, coaxial, and hardware. Also included with this item shall be (1) Flash Technologies, FAA Lighting E Towers, E-1 (reference plans for specifications). Final design/shop drawings will be submitted for review and approval. Nello, All State Tower Inc. manufactured towers as well as Sabre towers are approved manufactures.
- ii. Reference Sections:
 - 1. Preliminary Manufacturers tower specifications and recommendations for installation.
 - 2. Detail specifications for tower top antennas and amplifiers. These items are to be provided to the contractor for installation on the tower and used for final tower design loading.
 - 3. Bid Documents
- iii. Payment Method Lump Sum

7. Item Special – Ice Bridge

- i. Description: The ice bridge shall be installed from the existing building to the proposed tower, per plan and specifications. This item shall include all materials and workmanship for the bridge, bridge foundations and any other items necessary for complete installation.
- ii. Reference Sections:
 - 1. Manufacturer's specifications and recommendations for installation.
 - 2. Bid Documents
- iii. Payment Method Lump Sum

8. Item Special – Wiring & Conduit

i. Description: Includes the materials and workmanship to install the conduit and coaxial from the equipment building to the equipment on the tower. In addition,

the Contractor will allow for a minimum of 20' additional coaxial at the control building to allow for connection to the equipment within the building. Connection to the equipment within the building will be performed by others.

- ii. Reference Sections:
 - 1. Manufacturer's recommendations and specifications
 - 2. National Electric Code
 - 3. Bid Documents
- iii. Payment Method Lump Sum
- 9. Item Special Grounding
 - i. Description: Furnish and install all items necessary to properly ground the system per NEC and site conditions.
 - ii. Reference Sections:
 - 1. Manufacturer's recommendations and specifications
 - 2. National Electric Code
 - 3. Bid Documents
 - iii. Payment Method Lump Sum
- 10. Item Special Tower Foundation
 - i. Description Final foundation design will be based upon the tower manufacturer's final design recommendations. Preliminary foundation specifications and design have been included with these documents. This item shall include all material and workmanship to install the tower foundations per tower manufacturer's design and specifications.
 - ii. Reference Sections:
 - 1. Manufacturer's recommendations and specifications
 - iii. Payment Method Lump Sum
- 11. Item Special Site Work
 - i. Description: Shall include all items necessary to prepare the site for construction, control erosion and sedimentation during construction, and restore the site to its pre-construction condition. This item shall include but is not limited to:
 - 1. striping/stockpiling/disposal/placement of topsoil;
 - 2. repair of any potholes or ruts created during construction;
 - 3. seeding/mulching and erosion & sedimentation control.
 - ii. Reference Sections:
 - 1. ODOT Item(s) 201, 651, 652, 653, Supplemental Spec 832
 - iii. Payment Method Lump Sum
- 12. Item Special Construction Layout Stakes
 - i. Description: This Work consists of furnishing, placing, and maintaining construction layout stakes necessary for the proper prosecution of the Work under the contract and removing all stakes at the completion of the project.
 - ii. Reference Sections:
 - 1. ODOI Item 623
- 13. Item Special Perimeter Fence
 - i. Description: This Work consists of furnishing and installing the security fence around the tower site as shown in the plans and disposal or reuse of the existing fence.
 - ii. Reference Sections:
 - 1. Manufacturer's recommendations and specifications
 - 2. Bid Documents
 - iii. Payment Method Lump Sum

14. Item Special – Electric Service

- i. Description: This work consists of providing underground electric service to the equipment room & tower, including all materials. This also includes correspondence with local electrical provider for transformer connection.
- ii. Reference Sections:
 - 1. Manufacturer's recommendations and specifications
 - 2. Bid Documents
- iii. Payment Method Lump Sum

15. Item Special – Antennas/Equipment

Group A (MARCS) Quantities shown will be installed as part of this Project. Contractor is to provide tower design at 3x loading of Group A

- i. (2) RFI CC807-11-T1 w/ (2) 6' Pivot Side Arm & (2) 1 5/8" Line
 - (1) RFI CC807-11-T1 w/6' Pivot Side Arm
 - (1) RX TTA 428D w/ 7/8" line & 1/2" jumper
 - (1) TTA 1/2" test line (from equipment shelter to TTA)
- ii. Payment Method Lump Sum

Group B (Agile) This equipment group is for loading purposes only and will not be installed as part of this project.

- i. (4) RADWIN RW-9612-3338 W/ (4) 3/8" CAT5
 - (2) 3' HP3-11
 - (2) CERAGON FibeAIR IP-20C w/ (2) 3/8" COAX

Group C (iHeart Radio) This equipment group is for loading purposes only and will not be installed as part of this project.

i. (1) MXP-1E

16. Item Special – Demolition of Existing Tower

- i. Description: This work shall consist of removing and disposing of all parts of the existing guyed tower including, but not limited to, tower, foundation, wires, fencing, etc. The existing tower shall remain in service while the construction of the proposed tower is ongoing. The contractor shall provide a plan, including means and methods, on the removal of the tower to the engineer and owner for approval prior to beginning the work. The contractor shall provide information for any subcontractors who will perform work under this item. Upon completion of the project, the contractor shall coordinate with the engineer and the county the removal of the stone for the construction entrance.
- ii. Reference Sections:
 - 1. Bid Documents
- iii. Payment Method Lump Sum

17. Item Special – Shelter Modification

- i. Description: This work shall consist of installing a new Polyphasor Entry Port (8EEPM) to accommodate the new ice bridge location as well as any other materials needed to complete the work.
- ii. Reference Sections:
 - 1. Bid Documents
- iii. Payment Method Lump Sum

DAS-OIT223 - BUTLER GUYED TOWER REPLACEMENT SECTION 01 30 00 - GEOTECHNICAL REPORT



Professional Service Industries, Inc. 4960 Vulcan Ave, Columbus, Ohio 43228

Phone: (614) 876-8000

Fax: (614) 876-0548

October 31, 2022

Ms. Amanda Spencer Verdatas 59 Grant Street Newark, Ohio 43055

Re:

Geotechnical Exploration Report
Butler Self-Supported Lattice Tower

6469 Garber Road

Bellville, Richland County, Ohio PSI Project No. 01022110

Dear Ms. Spencer:

Thank you for choosing Professional Service Industries, Inc. (PSI), an Intertek company, as your consultant for the proposed Butler Self-Supported Lattice Tower located at 6469 Gaber Road in Bellville, Richland County, Ohio. The information you requested is attached.

PSI performed the geotechnical engineering study that you requested in general accordance with our agreement. PSI transmits one (1) copy with this letter.

We thank you for your business and we look forward to finding ways to grow our partnership, expand our services, and continue Building Better Together.

For Professional Service Industries, Inc.

John Xu, P.E.

Senior Project Manager

The Professional Engineering Seal and Signature is an electronic reproduction of the original seal and signature. This electronic reproduction shall not be construed as an original or certified document.

JX/PH/ph

Enclosures

Paul S. Hundley, P.E.

Paul S. Hundley

Geotechnical Dept. Manager/Principal Consultant







Geotechnical Exploration Report

Butler 500' Self-Supporting Tower 6469 Garber Road Bellville, Richland County, Ohio

Prepared for

Verdantas LLC 5400 Limestone Road Wilmington, Delaware 19808

Prepared by

Professional Service Industries, Inc. 4960 Vulcan Avenue Columbus, Ohio 43228

October 31, 2022

PSI Project No. 01022110

John Xu, P. E. Senior Project Engineer

Paul S. Hundley, P.E. Geotechnical Dept. Manager/Principal Consultant



TABLE OF CONTENTS

1	PROJE	CT INFORMATION	
	1.1	PROJECT AUTHORIZATION	1
	1.2	PROJECT DESCRIPTION	1
	1.3	PURPOSE AND SCOPE OF SERVICES	2
2	SITE A	ND SUBSURFACE CONDITIONS	3
	2.1	SITE LOCATION AND DESCRIPTION	3
	2.2	SITE GEOLOGY	3
	2.3	SUBSURFACE CONDITIONS	3
	2.4	WATER LEVEL MEASUREMENTS	5
	2.5	LABORATORY TEST RESULTS.	5
3	GEOTE	CHNICAL EVALUATION	
	3.1	GEOTECHNICAL DISCUSSION	6
4	GEOTE	CHNICAL RECOMMENDATIONS	7
	4.1	FOUNDATION RECOMMENDATIONS	
		4.1.1 DRILLED SHAFTS	
	4.2	EARTHQUAKE AND SEISMIC DESIGN CONSIDERATION	8
	4.3	UTILITIES TRENCHING	g
	4.4	SILTATION CONTROL	g
5	CONST	RUCTION CONSIDERATIONS	11
	5.1	MOISTURE SENSITIVE SOILS/WEATHER RELATED CONCERNS	11
	5.2	DRAINAGE AND GROUNDWATER CONSIDERATIONS	11
	5.3	EXCAVATIONS	11
6	GEOTE	CHNICAL RISK	13
7	REPOR	T LIMITATIONS	14

APPENDIX - Site Location Map

Boring Location Plan

Boring Log

Laboratory Test Results

USGS Seismic Design Maps Detailed Report

General Notes

Unified Soil Classification Chart (USCS)





1 PROJECT INFORMATION

1.1 PROJECT AUTHORIZATION

The following table summarizes, in chronological order, the Project Authorization History for the services performed and represented in this report by Professional Service Industries, Inc. (PSI).

DOCUMENT AND REFERENCE	DATE	REQUESTED/PROVIDED BY
Request for Proposal	08/30/2021	Ms. Amanda Spencer of Hull Inc.
PSI Proposal No.: 0102-349519	09/08/2021	Daniel Karch & Paul Hundley of PSI
Project Authorization	03/23/2022	Ms. Amanda Spencer of Verdantas LLC

1.2 PROJECT DESCRIPTION

According to the provided information and documents, the project involves the construction of proposed Self-Supporting Tower located at 6469 Garber Road in Bellville, Richland County, Ohio. The proposed tower is planned to be 500 feet in height and located at coordinates 40.5829° N and 82.47354° W.

The following table lists the material and information provided for this project:

DESCRIPTION OF MATERIAL	PROVIDER/SOURCE	DATE	
Email Description and Scope	Verdantas LLC	08/30/2021	

The following table lists the structural loads and site features that are estimated for the design basis for the conclusions of this report:

STURCTURAL LOAD/PROPERTY REQUIREMENT/REPORT BASIS									
BUILD	R*	В*							
Maximum Loads	Not provided		\boxtimes						
Settlement Tolerances	I'' Total, ¾" Differential		\boxtimes						
	GRADING								
Planned grade variations at site, feet	± 2 ft		\boxtimes						
Utility Depths	N/A								

^{*&}quot;R" = Requirement indicates specific design information was supplied.

The geotechnical recommendations presented in this report are based on the available project information for the proposed Self-Supporting Tower located at 6469 Garber Road in Bellville, Richland County, Ohio, and the subsurface materials described in this report. If any of the information noted above is incorrect, please inform PSI in writing so that we may amend the recommendations presented in this report, if necessary. PSI will not be responsible for the implementation of its recommendations when it is not notified of changes in the project.

[&]quot;B" = Report Basis indicates specific design information was not supplied; therefore, this report is based on this parameter.



1.3 PURPOSE AND SCOPE OF SERVICES

The purpose of this study was to explore the subsurface conditions at the site to prepare foundation recommendations for the proposed self-supporting tower. PSI's contracted scope of services included drilling three (3) soil test boring at the site to a depth of 30 to 50 feet below the ground surface or after 10 feet of rock coring, select laboratory testing, and preparation of this geotechnical report. This report briefly outlines the testing procedures, presents available project information, describes the site and subsurface conditions, and presents recommendations regarding the following:

- A general assessment of area geology based on our local knowledge and study of available geological literature
- General location and description of materials encountered in the boring which may interfere with construction progress or structure performance, including existing fills, cobbles/boulders, or organic soils
- Identification of water levels encountered at the time of drilling and recommendations for dewatering if required
- Recommendations for fill including the selection of materials for use and procedures for placement
- Foundation system evaluations and the assessment of the feasibility of utilizing shallow, intermediate, or deep foundations
- Swell potential of surface soil based on the laboratory tests, and recommendations, if any, for potentially swelling soils
- Site preparation as needed for support of foundations
- Design parameters required for the foundation system, including allowable bearing pressure, minimum foundation width, foundation bearing levels, and estimated total and differential settlements
- Recommendations, with attachments including a boring location drawing, and a computer-generated boring log

The scope of services did not include an environmental assessment for determining the presence or absence of wetlands, or hazardous or toxic materials in the soil, bedrock, surface water, groundwater, or air on, below, or around this site. Any statements in this report or on the boring logs regarding odors, colors, and unusual or suspicious items or conditions are strictly for informational purposes.

PSI's scope also did not provide any service to investigate or detect the presence of moisture, mold or other biological contaminants in or around any structure, or any service that was designed or intended to prevent or lower the risk of the occurrence or the amplification of the same. The Client should be aware that mold is ubiquitous to the environment with mold amplification occurring when building materials are impacted by moisture. The Client should also be aware that site conditions are outside of PSI's control, and that mold amplification will likely occur, or continue to occur, in the presence of moisture. As such, PSI cannot and shall not be held responsible for the occurrence or reoccurrence of mold amplification.



2 SITE AND SUBSURFACE CONDITIONS

2.1 SITE LOCATION AND DESCRIPTION

The site for the proposed self-supporting tower is located at 6469 Garber Road in Bellville, Richland County, Ohio. The site latitude and longitude are approximately 40.5829° N and 82.4735° W, respectively. The site currently consists of the existing guyed tower and a chain link fence. The site is relatively flat with about 10 feet of relief over the guyed tower site. The site is an open field and wooded to the southeast.

2.2 SITE GEOLOGY

Based on the geologic map published by the Ohio Geological Survey, the site lies in Illinoian Glaciated Allegheny Plateau. Bedrock consists of the middle portion of the Waverly Group which includes Berea and Black Hand sandstone. Overburden consists of Illinoian drift.

Information obtained from the Ohio Department of Natural Resources (ODNR) website also indicated that no known abandoned mine was recorded in the vicinity of the site area. "Known and Probable Karst in Ohio" map published by ODNR shows no Karst (sink hole) in the vicinity of the project site.

2.3 SUBSURFACE CONDITIONS

The site subsurface conditions were explored with three (3) soil test boring within the proposed tower area on October 5th and 6th, 2022. The boring locations were staked by the owner's survey crew. The test borings were advanced in the vicinity of the proposed tower and were terminated at a depths ranging from 23.7 feet to 28.7 feet.

The boring was advanced utilizing 3½ inch inside diameter, hollow stem auger drilling methods. Soil samples were routinely obtained during the drilling process. Select soil samples were later tested in the laboratory to obtain soil material properties for the foundation recommendations. Drilling, sampling, and laboratory testing was accomplished in general accordance with ASTM procedures. The laboratory test results are included in each boring log. A description of the classification system and the results of the laboratory tests are included in the Appendix.

<u>SURFACE MATERIALS</u>: An 7-inch topsoil layer was encountered at the surface of all test borings. Topsoil thicknesses should be expected to vary across the site. *Surface material thickness are included in this report for informational purposes only and should not be used for bidding or estimating purposes.*

<u>CLAY SOILS:</u> At Boring B-01, underlying the topsoil, **Sandy Lean Clay (CL)** was encountered to a depth of 3 ½ feet. The Standard Penetration Test value ("N"-value) for the clay soil was thirteen (13) blows per foot indicating a "stiff" consistency. The moisture content of the clay soil sample was fourteen (14) percent.

<u>BEDROCK:</u> Highly Weathered to Weathered Sandstone, Weathered shale, and Clay Shale were encountered beginning at a depth of 0.6 feet and extending to a depth of 18 % feet. Underlying the Highly Weathered Sandstone, Clay Shale and Shale is Weathered Shale interbedded with Sandstone extending to the bottom of the boring at 28 % feet. From a depth of 18 % to 28 % feet the rock was cored with a recovery of 93 percent and



Rock Quality Designation (RQD) of 83 percent. An intact sample of rock at a depth of 26 feet has an unconfined compressive strength of 7664 psi. Rock core photos are included in the Appendix.

The following table briefly summarizes the range of results from the field and laboratory testing programs. Please refer to the attached boring logs and laboratory data sheets for more specific information:

SUMMARY OF SPT N VALUES, MOISTURE CONTENT & GROUND WATER LEVELS

mpling t)	S	PT N	Value	s		mpling t)	Мо	isture	Cont	ent		
Top of Soil Sampling Depth (ft)	B-01 B-02 B-03 Average		Top of Soil Sampling Depth (ft)	B-01	B-02	B-03	Average					
1.0	13	26	150	63		1.0	14	8	5	9		
3.5	59	120	200	126		3.5	8	7	6	7		
6.0	56	120	122	99		6.0	11	9	7	9		
8.5	300	85	150	178		8.5	3	7	4	5		
11.0	150	300	600	350		11.0	5	7	3	5		
13.5	120	120	200	147		13.5	6	8	8	7		
15.5	300	300	122	241		15.5	6	6	12	8		
18.5	120	-	120	120		18.5	6	5	10	7		
23.5	300	-	150	225		23.5	8		8	8		
28.5	.5 300 300 28.5 7 7											
Groun	dwate	er Lev	el Re	ading	an	d Boreh	ole Ca	ving	Depth	(ft)		
Wat	Water Level Encountered While Drilling											
Wate			ading omple	Encou	ınt	ered	-	6.5	-			
Caving	Dept	h afte	r Casi	ng W	ith	drawal	21.7	18.2	25.0			

Weathered Rock

The above subsurface description is of a generalized nature to highlight the major subsurface stratification features and material characteristics. The boring log included in the Appendix should be reviewed for specific information at individual boring locations. This record includes soil descriptions, stratifications, penetration resistances, and location of the sample and laboratory test data. The stratifications shown on the boring log represent the conditions only at the actual boring location. Variations may occur and should be expected away from the boring location. The stratifications represent the approximate boundary between subsurface materials and the actual transition may be gradual. The samples that were not altered by laboratory testing will be retained for 60 days from the date of this report and then will be discarded.



2.4 WATER LEVEL MEASUREMENTS

Groundwater was encountered upon completion at a depth of 6.5 feet as a result of using water to core rock. Borehole caving was observed at a depths ranging from 18.2 feet to 25 feet.

2.5 LABORATORY TEST RESULTS

Laboratory testing was performed on representative split-spoon samples obtained during drilling. The laboratory tests included natural moisture content, Atterberg Limits, and unconfined compressive strength of rock. The laboratory test results are summarized in the following table:

Summary of Laboratory Index Test Results

Sample Sample	Sample	Moisture	Percent	Att	erberg Lir	USCS Soil	
Location	Depth (ft)	Content (%)	Fines (%)	ш	PL	PI	Classification
B-01	1.0-3.5	14	67.8	24	14	10	CL

Summary of Laboratory Compressive Strength of Rock Results

Sample	Sample	Compressive
Location	epth (ft)	Strength (psi)
B-02	26	7,664



3 GEOTECHNICAL EVALUATION

3.1 GEOTECHNICAL DISCUSSION

According to our investigation findings, the following key item is highlighted for the project design and construction:

- Natural soils encountered generally consisted of "stiff" clays underlain by weathered sandstone and shale and deeper, stronger shale interbedded with sandstone. Borehole caving was observed at depths of 18.2 to 25 feet.
- Drilled shaft foundations can be utilized for the towerfoundations. A minimum shaft diameter of 42 inches
 in soil and highly weathered rock with a minimum rock socket diameter of 36 inches is recommended. PSI
 recommends socketing into the competent Shale interbedded with Sandstone bedrock at a depth of 18 ½
 feet and deeper.



4 GEOTECHNICAL RECOMMENDATIONS

The following geotechnical related recommendations have been developed based on the subsurface conditions encountered and PSI's understanding of the proposed development. Should changes in the project criteria occur, a review must be made by PSI to determine if modifications to our recommendations will be required.

4.1 FOUNDATION RECOMMENDATIONS

4.1.1 DRILLED SHAFTS


Drilled shafts are anticipated to be utilized for the foundations of the proposed tower. The vertical and lateral load resistance of the drilled shafts can be calculated with the parameters given in the following tables. These parameters are for analytical programs such as AllPile or COM624P which will analyze both the applied load verses strain resistance of the soil and the deflection of the structural element. PSI recommends the proposed drilled shaft base be set at minimum depth of 18 feet below the existing grade into the sandstone bedrock.

Recommended Soil Parameters for Drilled Shaft Pile Design Top of Shaft 1440 Feet											
Soil Layer	Soil Description	Depth Range Below Grade (ft)	Average SPT N Value (blows/ft)	Total Unit Weight, Y' (pcf)	Soil Cohesion, C (psf)	Soil Internal Angle of Friction, ϕ (Deg)	Static Lateral Modulus, K (pci)	Strain Factor, E 50 (%)	Downward Average Unit Side Resistance (ksf)	Uplift Average Unit Side Resistance (ksf)	Average Unit End Bearing Resistance (ksf)
1	Sandy Lean Clay (CL), Highly weathered shale	3	13	130	1800	0	500	0.7	Ignore	Ignore	Ignore
2	Highly weathered Sandstone	3 to 10	100	140	-	-	2000	0.4	1.0	1.0	Ignore
3	Weathered Sandstone and Shale	10 to 18.5	100	140	-	-	2000	0.4	1.0	1.0	10.0
4	Weathered to slightly weathered Shale interbedded with sandstone	18.5 to 28.5	-	145	-	-	-	-	5.0	5.0	80.0

Note: The Table was prepared using simplified soil profiles and a water level at great depth. Some adjustments may be necessary by the design engineers.

Exclusion zones are the upper 5 feet. Rock unit side resistance values above are Allowable Values with F.S. = 3.0 and Average Unit End Bearing Resistance with F. S. = 5.0.

Settlement can be estimated according to FHWA-HI-88-042 Manual – Drilled Shafts", for short term settlement. Once the drilled shaft design is completed the settlement can be estimated based on diameter of base and loading ratio (Actual load/Ultimate load) of the drilled shafts.





The caisson should have a minimum diameter of 42 inches in soil and 36 inches in competent rock. The construction of the caisson should be specified in keeping with ACI 336.1-01, "Specification for the Construction of Drilled Piers". In addition, the caisson should be constructed following the guidelines in ACI 336.3 Chapter 4. A qualified representative of *PSI* should assess that the caisson is founded on competent bearing materials and that the caisson installation procedures comply with the specifications.

Prior to the placement of the reinforcement cage or concrete, the bottom of the caisson excavation should be thoroughly cleaned and free of all loose or soft materials. This is critical for end-bearing shafts. For end bearing shafts a final bottom check should be performed just before concrete placement to check for small cave-ins or accumulated sediment. Reinforcing should be placed after the Geotechnical Engineer has approved the shaft for concrete placement. The reinforcement should be centered using spacers as needed and should not contact the side walls of the shaft. PSI recommends that the drilled shaft have a minimum diameter of 36 inches to facilitate cleaning and inspection before placement of the reinforcing cage.

Concrete should be placed inside the casing as soon as possible after the completion of drilling operations. We recommend placing the caisson concrete on the same day that the caisson is drilled. During the placement of concrete, we recommend that the slump be between 5 to 7 inches; this will allow for proper distribution of the concrete and limit the potential for segregation and air pockets.

A temporary casing, which is removed when concrete is placed, should be utilized to prevent collapse of the overburden and infiltration of the groundwater. When temporary casing is utilized, extreme care should be given as to limit the amount of disturbance along the sides of the drilled shaft. The contractor must fill any voids or enlargements in the shaft excavations with concrete at the time of concrete placement. When removing the casing, a minimum head of 5 feet of concrete should be maintained above the bottom of the casing at all times, and in some instances, a much higher head is required. The volume of concrete placed in the excavation should be checked to confirm that no substantial sloughing of the excavation occurred during concrete placement or removal of the casing. If any discrepancies are noted, the geotechnical engineer should be notified immediately.

4.2 EARTHQUAKE AND SEISMIC DESIGN CONSIDERATION

Please note that the project site is located within a municipality that employs the Ohio Building Code (OBC), 2017 edition. As part of this code, the design of structures must consider dynamic forces resulting from seismic events. These forces are dependent upon the magnitude of the earthquake event as well as the properties of the soils that underlie the site.

Part of the OBC code procedure references ASCE 7 to evaluate seismic forces and requires the evaluation of the Seismic Site Class, which categorizes the site based upon the characteristics of the subsurface profile within the upper 100 feet of the ground surface.

To define the Seismic Site Class for this project, and as proposed, PSI has interpreted the results of our soil test borings drilled within the project site and estimated appropriate soil properties below the base of the borings to a depth of 100 feet. The estimated soil properties were based upon borings drilled on this site, data available in published geologic reports, ODNR water well data base, as well as our experience with subsurface conditions in the general site area. For this site the depth to bedrock is estimated to be 5 feet.



Based on the depth to rock, the estimated shear strength of cohesive soil, and the standard penetration test values of granular soil at the boring locations, **Site Class "C"** is recommended. The USGS-NEHRP probabilistic ground motion values near latitude 40.58298° N and 82.47354° W were determined by accessing the Structural Engineers Association of California Office of Statewide Health Planning and Development website Seismic Design Maps to determine site coefficients and parameters for seismic design. The use of this tool requires the input of the building "Risk Category". For estimating purposes, PSI has used a Risk Category II. The structural engineer should determine the actual Risk Category and make changes to the seismic design coefficients and parameters as appropriate.

PERIOD (seconds)	2% PROBABILITY OF EVENT IN 50 YEARS (g%)	SITE	MAX. SPECTRAL ACCELERATION PARAMETERS	DESIGN SP ACCELERA PARAME	ATION
0.2 (S _s)	11.5	F _a = 1.2	$S_{ms} = 0.137$	$S_{Ds} = 0.092$	$T_0 = 0.139$
1.0 (S ₁)	5.6	$F_{v} = 1.7$	$S_{m1} = 0.096$	$S_{D1} = 0.064$	$T_s = 0.696$

4.3 UTILITIES TRENCHING

Excavation for utility trenches shall be performed in accordance with OSHA regulations as stated in 29 CFR Part 1926. It should be noted that utility trench excavations have the potential to degrade the properties of the adjacent fill materials. Utility trench walls that can move laterally can lead to reduced bearing capacity and increased settlement of adjacent structural elements and overlying slabs.

Backfill for utility trenches is as important as the original subgrade preparation or structural fill placed to support either a foundation or slab. Therefore, it is imperative that the backfill for utility trenches be placed to meet the project specifications for the structural fill of this project. PSI recommends that granular material, flowable fill or lean mix concrete be utilized for utility trench backfill. If on-site soils are placed as trench backfill, the backfill for the utility trenches should be placed in four to six inch loose lifts and compacted to a minimum of 98% of the maximum dry density achieved by the standard Proctor test. The backfill soil should be moisture conditioned to be within 2% of the optimum moisture content as determined by the standard Proctor test. Up to four inches of bedding material placed directly under the pipes or conduits placed in the utility trench can be compacted to the 98% compaction criteria with respect to the standard Proctor. Compaction testing should be performed for every 200 cubic yards of backfill place or each lift within 200 linear feet of trench, whichever is less. Backfill of utility trenches should not be performed with water standing in the trench. If granular material is used for the backfill of the utility trench, the granular material should have a gradation that will filter protect the backfill material from the adjacent soils. If this gradation is not available, a geosynthetic non-woven filter fabric should be used to reduce the potential for the migration of fines into the backfill material. Granular backfill material shall be compacted to meet the above compaction criteria. The clean granular backfill material should be compacted to achieve a relative density greater than 75% or as specified by the geotechnical engineer for the specific material used.

4.4 SILTATION CONTROL

The Clean Water Act, implemented in 1990 includes a federal permit program called the National Pollutant Discharge Elimination System (NPDES). This program requires that projects sites more than one (1) acre or are part of a development which exceeds one (1) acre be covered under a permit. This typically includes the



PSI Project Number: 01022110 Butler 500' Self Supporting Tower October 31, 2022 Page 10

development of a storm water pollution prevention plan (SWPPP) as well as period inspections (typically once a week plus after significant rainfall). PSI is available to assist with these services.



5 CONSTRUCTION CONSIDERATIONS

PSI should be retained to provide observation and testing of construction activities involved in the foundation, earthwork, and related activities of this project. PSI cannot accept responsibility for conditions that deviate from those described in this report, nor for the performance of the foundation system if not engaged to also provide construction observation and testing for this project.

5.1 MOISTURE SENSITIVE SOILS/WEATHER RELATED CONCERNS

The upper fine-grained soils encountered at this site will be sensitive to disturbances caused by construction traffic and to changes in moisture content. During wet weather periods, increases in the moisture content of the soil can cause significant reduction in the soil strength and support capabilities. In addition, soils that become wet may be slow to dry and thus significantly retard the progress of grading and compaction activities. It will, therefore, be advantageous to perform earthwork and foundation construction activities during dry weather.

5.2 DRAINAGE AND GROUNDWATER CONSIDERATIONS

PSI recommends that the Contractor determine the actual groundwater levels at the site at the time of the construction activities to assess the impact groundwater may have on construction. Water should not be allowed to collect in the foundation excavation or on prepared subgrades of the construction area either during or after construction. Undercut or excavated areas should be sloped toward one corner to facilitate removal of collected rainwater, groundwater, or surface runoff. Positive site drainage should be provided to reduce infiltration of surface water around the perimeter of the foundation. The grades should be sloped away from the foundation and surface drainage should be collected and discharged such that water is not permitted to infiltrate the backfill area of the foundation.

It is possible that seasonal variations will cause fluctuations or a water table to be present in the upper soils. Additionally, perched water may be encountered in discontinuous zones within the overburden or near the contact with bedrock. Water should be removed from excavations by pumping. Should excessive and uncontrolled amounts of seepage occur, the Geotechnical engineer should be consulted.

5.3 EXCAVATIONS


In Federal Register, Volume 54, Number 209 (October 1989), the United States Department of Labor, Occupational Safety and Health Administration (OSHA) amended its "Construction Standards for Excavations, 29 CFR, part 1926, Subpart P". This document was issued to better enhance the safety of workers entering trenches or excavations. It is mandated by this federal regulation that excavations, whether they be utility trenches, basement excavation or footing excavations, be constructed in accordance with the new OSHA guidelines. It is PSI's understanding that these regulations are being strictly enforced and if they are not closely followed, the owner and the contractor could be liable for substantial penalties.

The contractor is solely responsible for designing and constructing stable, temporary excavations and should shore, slope, or bench the sides of the excavations as required to maintain stability of both the excavation sides and bottom. The contractor's "responsible person", as defined in 29 CFR Part 1926, should evaluate the soil exposed in the excavations as part of the contractor's safety procedures. In no case should slope height, slope inclination, or excavation depth, including utility trench excavation depth, exceed those specified in local, state, and federal safety regulations.



PSI Project Number: 01022110 Butler 500' Self Supporting Tower October 31, 2022 Page 12


PSI is providing this information solely as a service to our client. PSI does not assume responsibility for construction site safety or the contractor's or other parties' compliance with local, state, and federal safety or other regulations. Atrench safety plan was beyond the scope of our services for this project.





6 GEOTECHNICAL RISK

The concept of risk is an important aspect of the geotechnical evaluation. The primary reason is the analytical methods used to develop geotechnical recommendations do not comprise an exact science. The analytical tools which geotechnical engineers use are generally empirical and must be used in conjunction with engineering judgment and experience. Therefore, the solutions and recommendations presented in the geotechnical evaluation should not be considered risk-free and, more importantly, are not a guarantee that the interaction between the soils and the proposed structure will perform as planned. The engineering recommendations presented in the preceding section constitutes PSI's professional estimate of those measures that are necessary for the proposed structure to perform according to the proposed design based on the information generated and referenced during this evaluation, and PSI's experience in working with these conditions.





7 REPORT LIMITATIONS

The recommendations submitted are based on the available subsurface information obtained by PSI and design details furnished by Verdantas LLC. If there are revisions to the plans for this project or if deviations from the subsurface conditions noted in this report are encountered during construction, PSI should be notified immediately to determine if changes in the foundation recommendations are required. If PSI is not retained to perform these functions, PSI will not be responsible for the impact of those conditions on the project.


The geotechnical engineer warrants that the findings, recommendations, specifications, or professional advice contained herein have been made in accordance with generally accepted professional geotechnical engineering practices in the local area. No other warranties are implied or expressed.

After the plans and specifications are more complete, the geotechnical engineer should be retained and provided the opportunity to review the final design plans and specifications to check that our engineering recommendations have been properly incorporated into the design documents. At that time, it may be necessary to submit supplementary recommendations. This report has been prepared for the exclusive use of Verdantas LLC for the specific application to the proposed Self-Supporting Tower located at 6469 Garber Road in Bellville, Richland County, Ohio.



APPENDIX

Site Location Map
Boring Location Plan
Boring Log
Laboratory Test Results
USGS Seismic Design Maps Detailed Report
General Notes
Unified Soil Classification Chart (USCS)





Professional Services Industries, Inc. 4960 Vulcan Ave. Suite C Columbus, OH 43228 Telephone: (614) 876-8000

Site Vicinity Map

Butler 500' SST

6469 Garber Road, Belleville, Richlande County, Ohio
PSI Project No.: 01022110






Professional Services Industries, Inc. 4960 Vulcan Ave. Suite C Columbus, OH 43228 Telephone: (614) 876-8000

Boring Location Plan

Butler 500' SST
6469 Garber Road, Belleville, Richlande County, Ohio
PSI Project No.: 01022110

DATE STARTED: 10/6/22 DRILL COMPANY: PSI, Inc. DATE COMPLETED: 10/6/22 DRILLER: J.E. LOGGED BY: C.W. COMPLETION DEPTH 23.7 ft DRILLING METHOD: Hollow Stem Auger ELEVATION: 1442 ft SAMPLING METHOD: 2-in SS LATITUDE: 40.58298° HAMMER TYPE: Automatic LONGITUDE: -82.47354° EFFICIENCY 87% STATION: N/A OFFSET: N/A REVIEWED BY: PSH REMARKS: N ₆₀ denotes the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification MATERIAL DESCRIPTION MATERIAL DESCRIPTION MATERIAL DESCRIPTION BORING B While Drilling Upon Completion 2 caved BORING LOCATION: STANDARD PENETRATION TEST DATA N in blows/ft ® X Moisture PSI, Inc. LOGGED BY: C.W. While Drilling Upon Completion V Caved BORING LOCATION: STANDARD PENETRATION TEST DATA N in blows/ft ® X Moisture PIL Moisture PSI, Inc. DRILL RG: LOGGED BY: C.W. STANDARD PENETRATION TEST DATA N in blows/ft ® X Moisture PL Moisture PIL Moisture PSI, Inc. DRIL RG: LOGGED BY: C.W. STANDARD PENETRATION TEST DATA N in blows/ft ® X Moisture PL Mois	- feet - feet 21.7 feet 21.7 feet Additional Remarks L = 24 PL = 14 Fines=67.8%
BENCHMARK: N/A DRILLING METHOD: Hollow Stem Auger ELEVATION: 1442 ft SAMPLING METHOD: 2-in SS LATITUDE: 40.58298° HAMMER TYPE: Automatic LONGITUDE: -82.47354° EFFICIENCY 87% STATION: N/A OFFSET: N/A REVIEWED BY: PSH REMARKS: N _{so} denotes the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification (1994) Upon Completion Caved BORING LOCATION: STANDARD PENETRATION TEST DATA N in blows/ft © Y STANDARD PENETRATION TEST DATA N in blows/ft © Y STANDARD PENETRATION TEST DATA N in blows/ft © Y STANDARD PENETRATION TEST DATA N in blows/ft © Y STRENGTH, tsf Qu # Qp 4.0 O TOPSOIL (7") STIFF, BROWN, SANDY LEAN CLAY,	- feet 21.7 feet Additional Remarks
LATITUDE: 40.58298° HAMMER TYPE: Automatic LONGITUDE: -82.47354° EFFICIENCY 87% STATION: N/A OFFSET: N/A REVIEWED BY: PSH REMARKS: N _{so} denotes the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification TEST DATA N in blows/ft ® X Moisture PL White Street Stree	Additional Remarks
LATITUDE: 40.58298° HAMMER TYPE: Automatic LONGITUDE: -82.47354° EFFICIENCY 87% STATION: N/A OFFSET: N/A REVIEWED BY: PSH REMARKS: N _{so} denotes the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification TEST DATA N in blows/ft ® X Moisture PL White Street Stree	Additional Remarks LL = 24 PL = 14
STATION: N/A OFFSET: N/A REVIEWED BY: PSH REMARKS: N _{so} denotes the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification Visual Classification	Remarks L = 24 PL = 14
STATION: N/A OFFSET: N/A REVIEWED BY: PSH REMARKS: N _{so} denotes the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification Up to the complex of the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification STANDARD PENETRATION TEST DATA N in blows/ft © A Moisture PL LL So SON DESCRIPTION Which is the complex of the complex o	Remarks L = 24 PL = 14
REMARKS: N _{so} denotes the normalization to 60% efficiency as described in ASTM D4633. Soil symbol in "()" = Visual Classification (1)	Remarks L = 24 PL = 14
0	Remarks L = 24 PL = 14
0	Remarks L = 24 PL = 14
0	_L = 24 PL = 14
TOPSOIL (7") STIFF, BROWN, SANDY LEAN CLAY,	PL = 14
STIFF, BROWN, SANDY LEAN CLAY,	PL = 14
7/////	PL = 14
1440	
BROWNHIGHLY WEATHERED SANDSTONE	
2 16 22-20-21 8 × >>® N ₆₀ =59	
BROWN, HIGHLY WEATHERED SANDSTONE	
1435 3 18 27-22-17 11 × >> ©	
BROWN, WEATHERED SANDSTONE 50/2 3 × >>®	
1430————————————————————————————————————	
6 3 50/5 6 × >>®	
1425— 7 1 50/2 6 × >>®	
BROWN AND GRAY, SLIGHTLY WEATHERED SHALE INTERBEDDED WITH SANDSTONE BROWN AND GRAY, SLIGHTLY SO/5 6 × >>®	
1420 — 9 2 BROWN, WEATHERED SANDSTONE 50/2 8 ×	
Professional Service Industries, Inc. 4960 Vulcan Ave, Suite C Columbus, OH 43228 Telephone: (614) 876-8000 PROJECT NO.: PROJECT NO.: PROJECT: Butler 500' SS LOCATION: Bellwille Ohio	




							DRILL COMP			SI, I			BORING B-02				
DATE						10/5/22	DRILLER:		LOGGE				_		/hile Drilli		- feet
	PLETIC HMAF		РІГ	' –		28.6 ft N/A	DRILL RIG: DRILLING MI		ME 45 C		em Auger	_			pon Com	-	6.5 feet
	ATION	_				40 ft	SAMPLING N				n SS	_	Ĭ	_	aved	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	18.2 feet
LATIT		_			40.5		HAMMER TY			toma					CATION:		
LONG	ITUDE	E:			-82.4	17359°	EFFICIENCY		87	%							
STAT	_		I/A		OFFS		REVIEWED B			SH		_					
REMA	ARKS:	N ₆₀ den	otes	the no	rmalizat	ion to 60% efficiency as d	lescribed in ASTM	D4633. Soil s	ymbol in "()	" = Vi	1	ion				=	
Elevation (feet)	th, (feet)	Graphic Log	Sample Type	Sample No.	ery (inches)	MATEF	RIAL DESCI	RIPTION		USCS Classification	Blows per 6-inch (SS)	Moisture, %		TES	PENETR ST DATA blows/ft @ re		Additional Remarks
Eleva	Depth, (Gra	Sam	San	Recovery					nscs	SPT Blows	Moi	0	STRE Qu	NGTH, tsf #	Qp	remane
	- 0 -	7/1/N . 7/				TOPSOIL (7")							0		2.0	4.0	
	 		M	1	17	BROWN AND GR SHALE	RAY, Highly V	VEATHERE	D		6-7-11 N ₆₀ =26	8	×				
1435—	 - 5 -			2	4	BROWN, HIGHLY SANDSTONE INT			E		50/5	7	×			>>@)
				3	3	7					50/5	9	>	<		>>@	
1430-	 - 10 -			4	10	BROWN, HIGHLY SANDSTONE Silty Sand with Gr)			39-9-50/4 N ₆₀ =85	7 !	* ×			>>@	Non-Plastic Fines=21.4%
			M	5	2	BROWN AND GR HIGHLY WEATHE					50/2	7	×			>>@)
1425—	 - 15 -			6	4	BROWN AND GR	RAY, WEATHE I	RED SHALI	E		50/5	8	×			>>@	
		0 0	M	7	2	BROWN, WEATH	IERED SANDS	STONE			50/2	6	×			>>@	
1420-	 - 20 - 			8	1	F GRAY AT 18.0FT HARD, GRAY AN FRACTURED, SL SANDSTONE INT	D BROWN, SL IGHTLY WEA	THERED	E		50/1	5	×			>>@	
1415—	 - 25 -			9	111	c	Continued Next	Page			RQD=83 Rec=93%						
	in	tert	e	<_		Professional			nc.				CT N	D.:		010221	
		1		1		4960 Vulcan Columbus, C		C				OJE	CT: ION:			er 500' S Bellwille	ST
		J.				Telephone:		3000			LC	,UAI	IUN.			Ohio	

	STAF		_		1	10/5/22	_ DRILL COMPANY:		PSI, II		BORING B-02					
	COM			_		10/5/22	DRILLER: J.E.		GGED BY		_		While Dri		- feet	
	PLETIC		: 111	1 –		28.6 ft	_ DRILL RIG:		45 C ATV		te		Upon Coi		6.5 feet	
	HMAF ATION	_				N/A I40 ft	DRILLING METHO SAMPLING METHO		Hollow Ste	n SS	∣š	While Drilling Upon Completion 6. Z Caved 18.				
	TUDE:				40.5829° HAMMER TYPE: Automatic							BORING LOCATION:				
	SITUDI					47359°	EFFICIENCY		87%							
STAT	ION:_	١	I/A		OFFS	SET: N/A	REVIEWED BY:		PSH							
REMA	ARKS:	N ₆₀ der	otes	the no	rmalizat	tion to 60% efficiency as	s described in ASTM D4633.	. Soil symbo	ol in "()" = Vi							
Elevation (feet)	Depth, (feet)	Graphic Log	Sample Type	Sample No.	Recovery (inches)		ERIAL DESCRIPT		USCS Classification	SPT Blows per 6-inch (SS)	2 ×	N ii Mois	25 RENGTH, 1	A ⊚ 2 PL b LL 50	Remarks	
	_ 25 -					FRACTURED, S	IND BROWN, SLIGHT SLIGHTLY WEATHER ITERBEDDED WITH S	ED						4.0		
		-0-		, -		Profession:	al Service Industri	ies Inc	<u>l</u>	PR∩	IECT I	10 ·		010221	10	
	S	tert	.e			4960 Vulca	an Ave, Suite C	, 1110.		PRO			Bu	tler 500' S		
	0		5			Columbus,	OH 43228			LOCA	ATION	:		Bellwille	_	
			-	70		Telephone	: (614) 876-8000							Ohio		

							DRILL COMP			PSI, I		_ [BORING B-03				
DATE				.—		10/6/22	DRILLER:		LOGGE			_	<u>-</u>		nile Drilli		- feet
COMP			PIF	1 –		28.7 ft	DRILL RIG:		ME 45 C			-			on Com	-	- feet
BENC ELEV						N/A 40 ft	DRILLING MI SAMPLING N	_			em Auger	-	Š		ved	JICTION	25 feet
LATIT		_			40.58		HAMMER TY			2-in SS Automatic				NG LOC			20 1000
LONG	_					17348°	EFFICIENCY			37%	alic	_	DOM	10 LOC	ATION.		
STAT			I/A		OFFS		REVIEWED B			PSH		_					
	_			the no	_	ion to 60% efficiency as d					isual Classificat	on .					
eet)	et)	od	/pe	o.	(inches)					ication	Blows per 6-inch (SS)	%	STA		ΓDATA ows/ft ⊚	,	
Elevation (feet)	Depth, (feet)	Graphic Log	Sample Type	Sample No.	Recovery (in	MATER	RIAL DESCI	RIPTION		USCS Classification	ows per 6	Moisture,	0	Moisture	25	PL LL 50	Additional Remarks
Ele			S	0)	Rec					OSO	SPT BIO		•	STREN Qu	GTH, tsf *	I .	
	- 0 -	$\overline{z_{IN}}$. $\overline{z_{I}}$				TOPSOIL (7")											
	 			1	9	BROWN, HIGHLY SANDSTONE BROWN, WEATH					10-50/4	5	×			>>@	
1435—	 - 5 -		M	2	2						50/3	6	×			>>@	
	 			3	9	BROWN, HIGHLY SANDSTONE, TR					24-34-50/1 N ₆₀ =122	7	×			>>@	
1430-	 - 10 -		M	4	2						50/4	4	×			>>@	
	 		M	5	1						50/1	3	×			>>@	
1425—	 - 15 -		M	6	8	BROWN AND GR TRACE SANDSTO		RED SHALI	Ε,		43-50/3	8				>>@	
	 		XI.	7	16	BROWN, WEATH	IERED SANDS	STONE			12-34-50/4 N ₆₀ =122	12		×		>>@	
1420-	 - 20 -			8	5						50/5	10) 	×		>>@	
1415—			X	9	4		Continued Next				50/4	8	×			>>@	
Professional Service Industries, Inc. 4960 Vulcan Ave, Suite C							HC.			OJE OJE	CT NO	J.:	Dutt	0102211			
		1				Columbus, C		C					ION:			er 500' SS Bellwille	D1
		J.	-			Telephone:		3000								Ohio	
						•	. ,										

DATE STARTED: DATE COMPLETED:	10/6/22 10/6/22	DRILL COMPANY: DRILLER: J.E. L	PSI, Ir OGGED BY		BORING B-03				
COMPLETION DEPTH			E 45 C ATV		ē		Orilling	- feet	
BENCHMARK:		DRILLING METHOD:			Water		Completion	- feet	
ELEVATION:	1440 ft	SAMPLING METHOD:				▼ Caved		25 feet	
LATITUDE:	40.58291°	HAMMER TYPE:							
LONGITUDE: STATION: N/A	-82.47348° OFFSET: N/A	EFFICIENCY REVIEWED BY:							
	normalization to 60% efficiency as			sual Classification					
Elevation (feet) Characteristics Characteristics Craphic Log Sample Type Sample No	Д Д	RIAL DESCRIPTION	USCS Classification	SPT Blows per 6-inch (SS)	× 0	ANDARD PEN TEST DA N in blows. Moisture 25	ATA /ft ⊚	Additional Remarks	
				50/2			>>@		
	Drofessions	Contino Industrias Is			IFOT :	10 -	04000411	`	
intertek		l Service Industries, In n Ave, Suite C	C.	PRO. PRO.	IECT N IECT:		01022110 Butler 500' SS		
nci	Columbus, (OH 43228			ATION:		Bellwille	·	
	Telephone:	(614) 876-8000					Ohio		



Boring ID: B-02

Run 1: 18.6' - 28.6' Rec: 93% RQD: 83%



18.6′



28.6



Rock Core Plate

Butler 500' SST

Bellville, Ohio


PSI Project No.: 01022110


Unconfined Compressive Strength of Intact Rock Core Specimens ASTM D7012C

Projec	t Name:	Вι	utler 500' SS	ST	, .	Project	Number:	1022	2110
Boring Number	Sample Depth (ft)	Elevation (ft)	Average Core Diameter (in)	Average Core Length (in)	Core L/D Ratio	Average Cross- Section Area (in ²)	Failure Load (lb)	Compressive Strength (psi)	Rock Type
B-02	26.0	1414.0	1.970	4.011	2.0	3.048	23360	7664	Sandstone/Shale



Tested By: Wes Johnson Test Date: 10/26/2022










Butler 500' SST

Latitude, Longitude: 40.58298, -82.47354



Date	10/31/2022, 2:06:56 PM
Design Code Reference Document	ASCE7-10
Risk Category	II
Site Class	C - Very Dense Soil and Soft Rock

Туре	Value	Description
S _S	0.115	MCE _R ground motion. (for 0.2 second period)
S ₁	0.056	MCE _R ground motion. (for 1.0s period)
S _{MS}	0.137	Site-modified spectral acceleration value
S _{M1}	0.096	Site-modified spectral acceleration value
S _{DS}	0.092	Numeric seismic design value at 0.2 second SA
S _{D1}	0.064	Numeric seismic design value at 1.0 second SA

Туре	Value	Description
SDC	Α	Seismic design category
Fa	1.2	Site amplification factor at 0.2 second
F _v	1.7	Site amplification factor at 1.0 second
PGA	0.054	MCE _G peak ground acceleration
F _{PGA}	1.2	Site amplification factor at PGA
PGA _M	0.064	Site modified peak ground acceleration
TL	12	Long-period transition period in seconds
SsRT	0.115	Probabilistic risk-targeted ground motion. (0.2 second)
SsUH	0.126	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration
SsD	1.5	Factored deterministic acceleration value. (0.2 second)
S1RT	0.056	Probabilistic risk-targeted ground motion. (1.0 second)
S1UH	0.062	Factored uniform-hazard (2% probability of exceedance in 50 years) spectral acceleration.
S1D	0.6	Factored deterministic acceleration value. (1.0 second)
PGAd	0.5	Factored deterministic acceleration value. (Peak Ground Acceleration)
PGA _{UH}	0.054	Uniform-hazard (2% probability of exceedance in 50 years) Peak Ground Acceleration
C _{RS}	0.911	Mapped value of the risk coefficient at short periods

https://www.seismicmaps.org

Type	Value	Description
C _{R1}	0.91	Mapped value of the risk coefficient at a period of 1 s
C _V		Vertical coefficient

https://www.seismicmaps.org 2/3

DISCLAIMER

While the information presented on this website is believed to be correct, <u>SEAOC</u> /<u>OSHPD</u> and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in this web application should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. SEAOC / OSHPD do not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the seismic data provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the search results of this website.

https://www.seismicmaps.org 3/3

intertek 05

GENERAL NOTES

SAMPLE IDENTIFICATION

The Unified Soil Classification System (USCS), AASHTO 1988 and ASTM designations D2487 and D-2488 are used to identify the encountered materials unless otherwise noted. Coarse-grained soils are defined as having more than 50% of their dry weight retained on a #200 sieve (0.075mm); they are described as: boulders, cobbles, gravel or sand. Fine-grained soils have less than 50% of their dry weight retained on a #200 sieve; they are defined as silts or clay depending on their Atterberg Limit attributes. Major constituents may be added as modifiers and minor constituents may be added according to the relative proportions based on grain size.

DRILLING AND SAMPLING SYMBOLS

SFA: Solid Flight Auger - typically 4" diameter flights, except where noted.

SS: Split-Spoon - 1 3/8" I.D., 2" O.D., except where noted.

HSA: Hollow Stem Auger - typically 31/4" or 41/4 I.D.

ST: Shelby Tube - 3" O.D., except where noted.

openings, except where noted.

BS: Bulk Sample

M.R.: Mud Rotary - Uses a rotary head with Bentonite

PM: Pressuremeter

or Polymer Slurry

CPT-U: Cone Penetrometer Testing with Pore-Pressure

Readings

R.C.: Diamond Bit Core Sampler

H.A.: Hand Auger

P.A.: Power Auger - Handheld motorized auger

SOIL PROPERTY SYMBOLS

N: Standard "N" penetration: Blows per foot of a 140 pound hammer falling 30 inches on a 2-inch O.D. Split-Spoon.

N₆₀: A "N" penetration value corrected to an equivalent 60% hammer energy transfer efficiency (ETR)

Q.: Unconfined compressive strength, TSF

Q_p: Pocket penetrometer value, unconfined compressive strength, TSF

w%: Moisture/water content, %

LL: Liquid Limit, %

PL: Plastic Limit, %

PI: Plasticity Index = (LL-PL),%

DD: Dry unit weight, pcf

▼.∇.▼ Apparent groundwater level at time noted

RELATIVE DENSITY OF COARSE-GRAINED SOILS ANGULARITY OF COARSE-GRAINED PARTICLES

Relative Density	N - Blows/foot	<u>Description</u>	<u>Criteria</u>
Very Loose	0 - 4	Angular:	Particles have sharp edges and relatively plane sides with unpolished surfaces
Loose Medium Dense	4 - 10 10 - 30	Subangular:	Particles are similar to angular description, but have rounded edges
Dense Very Dense	30 - 50 50 - 80	Subrounded:	Particles have nearly plane sides, but have well-rounded corners and edges
Extremely Dense	80+	Rounded:	Particles have smoothly curved sides and no edges

GRAIN-SIZE TERMINOLOGY

PARTICLE SHAPE

Component	Size Range	Description	Criteria
Boulders:	Over 300 mm (>12 in.)	Flat:	Particles with width/thickness ratio > 3
Cobbles:	75 mm to 300 mm (3 in. to 12 in.)	Elongated:	Particles with length/width ratio > 3
Coarse-Grained Gravel:	19 mm to 75 mm (¾ in. to 3 in.)	Flat & Elongated:	Particles meet criteria for both flat and
Fine-Grained Gravel:	4.75 mm to 19 mm (No.4 to 3/4 in.)		elongated
Coarse-Grained Sand:	2 mm to 4.75 mm (No.10 to No.4)		
Medium-Grained Sand:	0.42 mm to 2 mm (No.40 to No.10)	<u>RELATIVE I</u>	PROPORTIONS OF FINES

Fine-Grained Sand: 0.075 mm to 0.42 mm (No. 200 to No.40)

Descriptive Term % Dry Weight

>12%

Modifier:

Page 1 of 2



GENERAL NOTES (Continued)

CONSISTENCY OF FINE-GRAINED SOILS

MOISTURE CONDITION DESCRIPTION

Q _U - TSF	N - Blows/foot	Consistency	Description Criteria
0 - 0.25	0 - 2	Very Soft	Dry: Absence of moisture, dusty, dry to the touch Moist: Damp but no visible water Wet: Visible free water, usually soil is below water table
0.25 - 0.50	2 - 4	Soft	
0.50 - 1.00	4 - 8	Firm (Medium Stiff)	
1.00 - 2.00 2.00 - 4.00	8 - 15 15 - 30	Stiff Very Stiff	RELATIVE PROPORTIONS OF SAND AND GRAVEL Descriptive Term % Dry Weight
4.00 - 8.00	30 - 50	Hard	Trace: < 15% With: 15% to 30%
8.00+	50+	Very Hard	

PORTIONS OF SAND AND GRAVEL

ith: 15% to 30% Modifier: >30%

STRUCTURE DESCRIPTION

Description	Criteria	Description	Criteria
Stratified:	Alternating layers of varying material or color with	Blocky:	Cohesive soil that can be broken down into small
	layers at least 1/4-inch (6 mm) thick		angular lumps which resist further breakdown
Laminated:	Alternating layers of varying material or color with	Lensed:	Inclusion of small pockets of different soils
	layers less than 1/4-inch (6 mm) thick	Layer:	Inclusion greater than 3 inches thick (75 mm)
Fissured:	Breaks along definite planes of fracture with little	Seam:	Inclusion 1/8-inch to 3 inches (3 to 75 mm) thick
	resistance to fracturing		extending through the sample
Slickensided:	Fracture planes appear polished or glossy,	Parting:	Inclusion less than 1/8-inch (3 mm) thick
	sometimes striated		

SCALE OF RELATIVE ROCK HARDNESS ROCK BEDDING THICKNESSES

Q _U - TSF	<u>Consistency</u>	<u>Description</u>	Criteria
_	F (Very Thick Bedded	Greater than 3-foot (>1.0 m)
2.5 - 10	Extremely Soft	Thick Bedded	1-foot to 3-foot (0.3 m to 1.0 m)
10 - 50	Very Soft	Medium Bedded	4-inch to 1-foot (0.1 m to 0.3 m)
50 - 250	Soft	Thin Bedded	11/4-inch to 4-inch (30 mm to 100 mm)
250 - 525	Medium Hard	Very Thin Bedded	1/2-inch to 11/4-inch (10 mm to 30 mm)
525 - 1,050	Moderately Hard	Thickly Laminated	1/8-inch to ½-inch (3 mm to 10 mm)
1,050 - 2,600 >2,600	Hard Very Hard	Thinly Laminated	1/8-inch or less "paper thin" (<3 mm)

ROCK VOIDS

Voids			mentary Rock)	
	<6 mm (<0.25 in)		Size Range	
	6 mm to 50 mm (0.25 in to 2	Very Coarse Grained	>4.76 mm	
•	50 mm to 600 mm (2 in to 2	Coareo Grainad	2.0 mm - 4.76 mm	
•	>600 mm (>24 in)	Medium Grained	0.42 mm - 2.0 mm	
Cave	>000 Hilli (>24 III)	Fine Grained	0.075 mm - 0.42 mm	
		Very Fine Grained	<0.075 mm	

ROCK QUALITY DESCRIPTION

DEGREE OF WEATHERING

Page 2 of 2

GRAIN-SIZED TERMINOLOGY

Rock Mass Description Excellent Good Fair	RQD Value 90 -100 75 - 90 50 - 75	Slightly Weathered:	Rock generally fresh, joints stained and discoloration extends into rock up to 25 mm (1 in), open joints may contain clay, core rings under hammer impact.
Poor Very Poor	25 -50 Less than 25	Weathered:	Rock mass is decomposed 50% or less, significant portions of the rock show discoloration and weathering effects, cores cannot be broken by hand or scraped by knife.
		Highly Weathered:	Rock mass is more than 50% decomposed, complete discoloration of rock fabric, core may be extremely broken and gives clunk sound when struck by hammer, may be shaved with a knife.

SOIL CLASSIFICATION CHART

MA IOD DIVIGIONS			SYMBOLS		TYPICAL	
MAJOR DIVISIONS			GRAPH	LETTER	DESCRIPTIONS	
	GRAVEL AND	CLEAN GRAVELS		GW	WELL-GRADED GRAVELS, GRAVEL - SAND MIXTURES, LITTLE OR NO FINES	
	GRAVELLY SOILS	(LITTLE OR NO FINES)		GP	POORLY-GRADED GRAVELS, GRAVEL - SAND MIXTURES, LITTLE OR NO FINES	
COARSE GRAINED SOILS	MORE THAN 50% OF COARSE FRACTION	GRAVELS WITH FINES		GM	SILTY GRAVELS, GRAVEL - SAND - SILT MIXTURES	
	RETAINED ON NO. 4 SIEVE	(APPRECIABLE AMOUNT OF FINES)		GC	CLAYEY GRAVELS, GRAVEL - SAND - CLAY MIXTURES	
MORE THAN 50% OF MATERIAL IS	SAND AND	CLEAN SANDS		SW	WELL-GRADED SANDS, GRAVELLY SANDS, LITTLE OR NO FINES	
LARGER THAN NO. 200 SIEVE SIZE	SANDY SOILS	(LITTLE OR NO FINES)		SP	POORLY-GRADED SANDS, GRAVELLY SAND, LITTLE OR NO FINES	
	MORE THAN 50% OF COARSE	SANDS WITH FINES		SM	SILTY SANDS, SAND - SILT MIXTURES	
	FRACTION PASSING ON NO. 4 SIEVE	(APPRECIABLE AMOUNT OF FINES)		sc	CLAYEY SANDS, SAND - CLAY MIXTURES	
		LIQUID LIMIT LESS THAN 50		ML	INORGANIC SILTS AND VERY FINE SANDS, ROCK FLOUR, SILTY OR CLAYEY FINE SANDS OR CLAYEY SILTS WITH SLIGHT PLASTICITY	
FINE GRAINED SOILS	SILTS AND CLAYS			CL	INORGANIC CLAYS OF LOW TO MEDIUM PLASTICITY, GRAVELLY CLAYS, SANDY CLAYS, SILTY CLAYS, LEAN CLAYS	
30.20				OL	ORGANIC SILTS AND ORGANIC SILTY CLAYS OF LOW PLASTICITY	
MORE THAN 50% OF MATERIAL IS SMALLER THAN NO. 2017				МН	INORGANIC SILTS, MICACEOUS OR DIATOMACEOUS FINE SAND OR SILTY SOILS	
SIZE	SILTS AND CLAYS	LIQUID LIMIT GREATER THAN 50		СН	INORGANIC CLAYS OF HIGH PLASTICITY	
				ОН	ORGANIC CLAYS OF MEDIUM TO HIGH PLASTICITY, ORGANIC SILTS	
НІ	GHLY ORGANIC S	SOILS	\(\lambda \) \(PT	PEAT, HUMUS, SWAMP SOILS WITH HIGH ORGANIC CONTENTS	



DAS-OIT223 - BUTLER GUYED TOWER REPLACEMENT SECTION 01 40 00 - TOWER PRELIMINARY DESIGN



Corporate Headquarters 1201 S. Sheridan St. South Bend, IN 46619 (800) 806-3556 Fax: (574) 288-5860

9/20/2023

Verdantas

59 Grant Street Newark, OH 43055

Attn.: Amanda E Spencer (740) 224-0600

Per your request, please review our quotation #87115 for a 500' tall Nello Model NSX Self Support Tower for Butler / iHeart FM option.

If you have any questions or require further information, please feel free to contact me at (800) 806-3556, ext. 1226 or email me at mferguson@nelloinc.com.

Thank you for the opportunity to earn your business.

Sincerely,

Nello Corporation

Mike Ferguson

Enclosure: Per Above

LAN

09/20/2023 13:09 Page 1 of 8



Quotation 87115 - Rev. 1

Nello Inside Contact

Mike Ferguson

Office: (800)806-3556 Ext.: 1226 Email: mferguson@nelloinc.com

Fax: (574)288-5860

Quotation Prepared For

Verdantas

N

Amanda E Spencer 59 Grant Street Newark, OH 43055

Phone: (740) 224-0600 Email:

Quote Date:	9/20/2023				
Expires:	10/4/2023				
Tower Type					
Self Support					
zur zuppert					

Butler / iHeart FM option		
Richland County, OH		
FOB	Terms	
South Bend, IN	TBD	

Tower Design Parameters

The tower has been designed for an ultimate wind speed of 115 mph with 0-in of radial ice in accordance with ANSI/TIA-222-G.

The tower has also been designed for a basic wind speed of 40 mph with 0.75-in of radial ice in accordance with ANSI/TIA-222-G.

The tower has been designed with a twist/sway limit per ANSI/TIA-222-G.

Revision G Parameters: Topo. Category - 1

Tower Items	Quantity	Unit Price	Sub-Total
Tower Configuration (500' Tower)			

Pipe, Exposure Category C, Risk Category 3

1 \$251,650.00 \$251,650.00

Materials to be provided include:

All necessary tower sections and assembly hardware.

Hot dip galvanized after fabrication.

Step bolts for climbing on one tower leg and step bolts for all three legs on all 2 panel sections.

1. Beacon extender

09/20/2023 13:09 Page 2 of 8



Quotation Prepared For

Quotation 87115 - Rev. 1

Nello Inside Contact

Mike Ferguson

Office: (800)806-3556 Ext.: 1226
Email: mferguson@nelloinc.com

Fax: (574)288-5860

NELLO

Verdantas

Amanda E Spencer 59 Grant Street Newark, OH 43055 Phone: (740) 224-0600

Email:

Quote Date:	9/20/2023			
Expires:	10/4/2023			
Tower Type				
Self Support				

Site Location / Reference			
Butler / iHeart FM option			
Richland County, OH			
FOB	Terms		
South Bend, IN	TBD		

Freight Items

Estimated freight charges to ship anchor steel prior to tower shipment. \$600.00

Estimated freight charges with unloading by others to the nearest access point to the site. (4 Trucks) \$8,000.00

Optional Items

Item	Description	Quantity	UnitPrice	Sub-Total
100131	Two Post Waveguide Bridge Kit, 24" x 10'. Triple Level Trapeze, Two 14' burial posts.	1	\$1,468.00	\$1,468.00
100196	Large Leg Adapter Kit Assembly for 4-1/2" to 10-3/4 OD	4	\$75.00	\$300.00
115463	Self Supporting Tower Template Assembly to Simultaneously Position Anchor Bolts for Proper Alignment with Tower Base Legs	1	\$1,641.00	\$1,641.00
125035	Bolt-On 21' Lightning Rod Extender Assembly with 5/8" x 10' Galv. Lightning Rod (Channel Type) (Fits 1-1/2" O.D. to 4-1/2" Legs)	1	\$704.18	\$704.18
125706	Adjustable Beacon Extender Assembly for NSX/NGX - 1-1/2" to 3" Pipe or 1-1/2" to 2-1/2" Solid Rod Legs - No Lightning Rod	1	\$196.50	\$196.50
205698	Universal Cable Ladder, 27-1/8" wide x 20' long,12-hole Z-bracket (1-3/4" x 1-3/4" x 1/8" Angle)(2-1/4" Spacing waveguide brackets)	25	\$155.76	\$3,894.00
303059	6' Side Arm - X Assembly, 1-1/4" to 4-1/2" OD - Straight	3	\$549.00	\$1,647.00
497413	Beacon Side Mount Assembly 3" Extended, Tapered or Straight (1-1/2 to 4-1/2" OD)	2	\$118.20	\$236.40
527731	Anchor Bolts and Embedment Plates	1	\$5,000.00	\$5,000.00
542890	Grounding Assembly for Base of NSX/NGX/NTP Tower TIA-222-G and TIA-222-H (Harger Ground Clamp)	1	\$625.00	\$625.00
ENG-F	Conventional foundation design based on customer supplied soil report with or without State PE seal. (State seal specified by customer)	1	\$600.00	\$600.00
ENG-SS	Site specific tower drawings with or without state PE seal (as specified by customer)	1	\$600.00	\$600.00
misc	FAA E1+1-FTS 372 IR Avian Dual L864/L865 Med. Intensity LED w/ Red LED side markers. (Flash Technology - FTS 372d / Dry Contacts only) (201' - 350') (100' extra cable) (E1+1- 372/E1+1 FTS372d LED Avian)	1	\$22,509.00	\$22,509.00
misc	AllFasteners NSX Safety Climb Kit, 500', Galvanized Cable	1	\$2,959.00	\$2,959.00
-			•	•

09/20/2023 13:09 Page 3 of 8



Quotation 87115 - Rev. 1

Nello Inside Contact

Mike Ferguson

Office: (800)806-3556 Ext.: 1226
Email: mferguson@nelloinc.com

Fax: (574)288-5860

NELLO

Quotation Prepared For

Verda	ntas

Amanda E Spencer 59 Grant Street Newark, OH 43055 Phone: (740) 224-0600

Email:

Quote Date:	9/20/2023	
Expires:	10/4/2023	
Tower Type		
Self Support		

Site Location / Reference	
Butler / iHeart FM option	
Richland County, OH	
FOB	Terms
South Bend, IN	TBD
	1

Antenna / Mount Loading

Item	Quantity	Height (Ft)
Beacon LED on 4' Extender	1	500
MPX-1E	1	499
CC807-08	3	475
Side Arm-X - 6'	3	475
Beacon LED on 4' Extender	1	475
21' Lightning Rod	1	475
TTA - Tower Top Amplifier	3	475
CC807-08	6	455
Side Arm-X - 6'	6	455
Radwin RW-9612-3338	4	435
Dish Pipe Mount	2	415
Ceragon FibeAir IP-20S	2	415
Beacon LED (21in Dia.)	2	250

Dish Loading

Item	Quantity	Height (Ft)
3' HP Dish	2	415

Feedline Loading

Item	Quantity	Height (Ft)
1" Conduit	2	500
LDF5-50A (7/8 FOAM)	1	495
LDF5-50A (7/8 FOAM)	3	475
LDF4-50A (1/2 FOAM)	3	475
LDF7-50A (1-5/8 FOAM)	6	455
CATEGORY 5e (1 WIRE)	4	435
LDF2-50 (3/8 FOAM)	2	415

09/20/2023 13:09 Page 4 of 8



Quotation

87115 - Rev. 1

Nello Inside Contact

Mike Ferguson

Office: (800)806-3556 Ext.: 1226
Email: mferguson@nelloinc.com

Fax: (574)288-5860

NELLO

Quotation Prepared For

Verdantas

Amanda E Spencer 59 Grant Street Newark, OH 43055

Phone: (740) 224-0600

Email:

Quote Date: 9/20/2023		
Expires:	10/4/2023	
Tower Type		
Self Support		

Site Location / Reference	
Butler / iHear	rt FM option
Richland C	ounty, OH
FOB	Terms
South Bend, IN	TBD

EW63	2	415
1" Conduit	2	250

09/20/2023 13:09 Page 5 of 8



Quotation 87115 - Rev. 1

Nello Inside Contact

Mike Ferguson

Office: (800)806-3556 Ext.: 1226
Email: mferguson@nelloinc.com

Fax: (574)288-5860

NELLO

Quotation Prepared For

Verdantas

Amanda E Spencer 59 Grant Street Newark, OH 43055 Phone: (740) 224-0600

Email:

Quote Date:	9/20/2023	
Expires:	10/4/2023	
Tower Type		
Self Support		

Site Location	n / Reference
Butler / iHeart FM option	
Richland County, OH	
FOB	Terms
South Bend, IN	TBD

Notes

Typical lead times are 4 - 6 weeks for fabrication to be verified upon acceptance of order and drawings/anchor steel to follow within 2 weeks of order. Please see Additional Item notes above for specifically requested lead times.

Note: Ultimate wind speed is based on wind map from ASCE-7-16.

Note: Nello will require verification of tower loading. Any difference between actual versus what has been used for quoted design may change tower design/price.

Note: No coordinates provided at the time of quote. Coordinates will need to be provided to ensure the tower is designed using accurate code requirements. Any differences between actual versus what has been loaded for the design may change the design/price.

The quote is based on the TNX tower design and should be verified when reviewing the quote. Quote may be updated if more information becomes available.

Please review optional items included with this quote. If changes are required the quote may be updated.

Code requirements are based on coordinates supplied with this quote. If no coordinates were supplied the structure will be designed per the default TIA code for the structure location.

Loading for required lighting will be added for any structure with an appurtenance reaching over 200ft. Structures under 200ft will not include loading for lights unless specified in the quote request.

If no specific site location is given at the time of the quote. Rev G defaults Class II, Exposure C, and Topographic Category 1 are used, along with county TIA-Rev G requirements. The tower design/price may change when actual coordinates are provided.

Purchaser agrees to accept delivery on the mutually agreed to delivery date. If this date passes and the product is completed and staged for delivery, the Purchaser agrees that the transaction will be on a "bill and hold" basis. In accepting the bill and hold transaction, the Purchaser acknowledges that it has accepted title to the goods, including all risks of ownership and that the order is a fixed commitment to purchase goods from Nello Corporation. Quotation subject to Nello Corporation's Terms and Conditions.

Storage charges of \$350.00 per month may apply starting 60 days after original scheduled ship date.

Dimensional information is preliminary only; it may change upon final design.

The effects of torsion HAVE NOT been considered in the EPA values shown. These EPA values are correct for symmetrically loaded instances where torque is not present (such as one top mounted antenna at the center of the tower, or three leg mounted panel antennas symmetrically mounted around the tower). Should torque be present, the allowable EPA value shown will be reduced. In some cases this reduction will be significant. Please consult a Nello representative to determine if torque needs to be considered and how much the allowable EPA value will be reduced due to its inclusion.

Due to the fluctuation in material price any structure order placed on hold is subject to a price review at the time of its release from hold status. This may cause an increase in price to occur.

Due to the fluctuation in material price, Nello reserves the right to review all material pricing prior to accepting any order.

All Nello mounts are quoted with support pipes of appropriate length for most applications if not otherwise specified. If different support pipe lengths are required at the time of the order, additional costs may be incurred.

All sector mounts are quoted at default azimuths of 120 degrees apart if not otherwise specified. Any changes in the sector azimuths may result in additional charges and/or an increase in delivery lead times.

Freight charges quoted are for provided materials only. Additional freight charges may be incurred with the order of additional items.

09/20/2023 13:09 Page 6 of 8



Quotation 87115 - Rev. 1

Nello Inside Contact

Mike Ferguson

Office: (800)806-3556 Ext.: 1226 mferguson@nelloinc.com

Fax: (574)288-5860

Quotation Prepared For

Verdantas

N

Amanda E Spencer 59 Grant Street Newark, OH 43055

Email:

Phone: (740) 224-0600

Quote Date:	9/20/2023	
Expires: 10/4/2023		
Tower Type		
Self Support		

Site Location / Reference				
Butler / iHeart FM option				
Richland County, OH				
FOB Terms				
South Bend, IN TBD				

Estimates for freight are only estimates, actual freight charges will be invoiced at the time of shipment.

This quotation does not include any sales, use, excise, contractors or any other taxes not specifically detailed in this proposal.

If a Customer requests to pick up a tower, a \$300.00 per truck charge may apply for dunage and loading.

If sales tax is listed as an option the sales tax is calculated on tower steel and included options only. Additional items will increase sales tax.

If additional/future growth is required for the structure design, unless otherwise specified in the documents provided by the customer, Nello will adjust the overall capacity rating to achieve this requirement.

Standard TIA-Rev G grounding has been supplied with the quote only (drawings/material list is available upon request). If the site requires more than the TIA-Rev G standard please discuss this with your inside sales representative.

09/20/2023 13:09 Page 7 of 8



NELLO

Quotation 87115 - Rev. 1

Nello Inside Contact

Mike Ferguson

Office: (800)806-3556 Ext.: 1226
Email: mferguson@nelloinc.com

Fax: (574)288-5860

Quotation Prepared For

Verdantas

Amanda E Spencer 59 Grant Street Newark, OH 43055 Phone: (740) 224-0600

Email:

Quote Date:	9/20/2023				
Expires:	10/4/2023				
Tower Type					
Self Support					

Site Location / Reference					
Butler / iHeart FM option					
Richland County, OH					
Terms					
TBD					

This quotation is based on the terms and conditions proposed above including the standard terms and conditions at www.nelloinc.com and is subject to our review and final acceptance of your order. No other terms are valid unless signed by an authorized officer of Nello Corporation.

Submitted By: Nello Corporation

Mike Ferguson

Acceptance of Customer:

Please enter our order for the above items in accordance with this proposal.

Signature:	
Name (print):	
Title:	
Purchase Order:	
Date:	

09/20/2023 13:09 Page 8 of 8

									2			500.0 ft																
T	154				۵						533.0	480.0 ft	X															
T2	P2x.154											509.3	400.0 K	X														
T3	P3x.216		L1 3/4x1 3/4x1/8								768.5	460.0 ft	X															
			L1 3/4x							2		440.0 ft	X															
T4	P4x.237									28 @	980.8	420.0 ft	X															
T5	P6x.28										1521.5	400.0 ft	X															
9L											2459.3		X															
1											2506.0	380.0 ft	X															
18	P8x.322					N.A.	N.A.	N.A.	6.5		2487.0	360.0 ft	8															
-			9			ż	ż	ż	80			340.0 ft																
T9			L2 1/2x2 1/2x3/16						LO.		2556.9	320.0 ft																
T10			L2 1/2x;						9.5		3420.2	300.0 ft																
T11													1	2999	3498.1													
T12									12.5	24 @ 6.66667	3578.4	280.0 ft																
	20	-20		-50					14	7		260.0 ft																
T13	P10x.365	A500	A500-50	A500	A500	A500	A500	A500	A500	A500	A500		A529-50	N.A.			16	16	3676.6	240.0 ft								
T14	2													∢								4020.1	220.0 ft					
T15										В						18		4971.8										
T16										L4x4x1/4		x3/16	70		4907.0	200.0 ft												
			x1/4			4	1/2x2 1/2x3/16	L2 1/2x2 1/2x3/16	22			<u>180.0 ft</u>																
T17			L4x4x1/4			L4x4x5/16		121	24		5169.0	<u>160.0 ft</u>																
T18																					L4	L2				0.0000	140.0 ft	
T19	P12x.375		ပ			5/16	3/16	3/16	26		6751.8	120.0.4																
T20						L5x5x5/16	L3x3x3/16	L3x3x3/16	28		7450.5	120.0 ft																
E									30	20 @ 10		<u>100.0 ft</u>																
T21			,16			L5x5x3/8	L3x3x1/4	4	32		9194.3	80.0 ft																
T22			L5x5x5/16			1	ដ	L3x3x1/4			9450.5	60.0 ft																
T23	P12x.5						4		34		10 102.1	40.00																
T24						L6x6x3/8	L3 1/2x3 1/2x1/4	x1/4	36	-	10503.2	40.0 ft																
			43/8			L6x	L3 1/2x	L3 1/2x3 1/2x1/4	38			<u>20.0 ft</u>																
T25			L5x5x3/8					13.1	40		9.9 11364.1	<u>0.0 ft</u>																
E		rade	nals	nal Grade	irts	ontals	Horizontals	Diagonals	Vidth (ft)	(tt) @ sle	t (lb)118409.9																	

DESIGNED APPURTENANCE LOADING

TYPE	ELEVATION	TYPE	ELEVATION
Beacon LED on 4' Extender	500	(2) CC807-08	455
MPX-1E	499 - 492	(2) Side Arm-X - 6'	455
CC807-08	475	(2) Side Arm-X - 6'	455
Side Arm-X - 6'	475	(2) CC807-08	455
TTA - Tower Top Amplifier	475	(2) Radwin RW-9612-3338	435
Beacon LED on 4' Extender	475	Radwin RW-9612-3338	435
Side Arm-X - 6'	475	Radwin RW-9612-3338	435
CC807-08	475	Ceragon FibeAir IP-20S	415
Side Arm-X - 6'	475	Dish Pipe Mount	415
CC807-08	475	Ceragon FibeAir IP-20S	415
TTA - Tower Top Amplifier	475	Dish Pipe Mount	415
TTA - Tower Top Amplifier	475	3' HP Dish	415
21' Lightning Rod	475	3' HP Dish	415
(2) CC807-08	455	Beacon LED (21in Dia.)	250
(2) Side Arm-X - 6'	455	Beacon LED (21in Dia.)	250

SYMBOL LIST

MARK	SIZE	MARK	SIZE
Α	L3x3x3/16	D	L1 3/4x1 3/4x1/8
В	L3 1/2x3 1/2x1/4	E	L2 1/2x2 1/2x1/4
С	I 4x4x5/16		

MATERIAL STRENGTH

GRADE	Fy	Fu	GRADE	Fy	Fu
A500-50	50 ksi	62 ksi	A529-50	50 ksi	65 ksi

TOWER DESIGN NOTES

- Tower designed for Exposure C to the TIA-222-G Standard.
 Tower designed for a 115 mph ultimate wind in accordance with the TIA-222-G Standard.
 Tower is also designed for a 40 mph basic wind with 0.75 in ice. Ice is considered to increase in thickness with height.
- 4. Deflections are based upon a 60 mph wind.5. Tower Risk Category III and IV.
- 6. Topographic Category 1 with Crest Height of 0.00 ft 7. TOWER RATING: 99.9%

ALL REACTIONS ARE FACTORED

MAX. CORNER REACTIONS AT BASE:

DOWN: 830520 lb SHEAR: 84050 lb

UPLIFT: -677072 lb SHEAR: 67878 lb

AXIAL 420066 lb SHEAR MOMENT 29015 lb 6901208 lb-ft

> TORQUE 611 lb-ft 40 mph WIND - 0.7500 in ICE

AXIAL 151612 lb SHEAR MOMENT 128799 lb 27027342 lb-ft

> TORQUE 2028 lb-ft REACTIONS - 115 mph WIND

> > Nello Corporation 1201 S. Sheridan Street South Bend, IN. 46619 Phone: 800-806-3556 FAX:

ob: RFQ87115	5		
Project:			
Client: Verdantas			
Code: TIA-222-G			
Path: N:\eri_Proposal\87	Dwg N	o. E-1	



574-288-3632 (phone) 574-288-5860 (fax) www.nelloinc.com

v3.05

Quote Number: 87115 Tower Model:

Company: Site Name:

Verdantas Butler / iHeart FM option


County: Richland State: ОН

Preliminary Design Summary

Foundation Dimensions	
Depth	28.5'
Pier Extension	0.5'
Pier Diameter	3.5'
Clear Cover	3"
Volume-Per Pier	10.3 cubic yards
Volume-Total	31.0 cubic yards
Pier Reinforcement	
Quantity-Per Pier	17
Quantity-Total	51
Size	#11
Length	342"
Weight-Per Pier	2574.0 lb
Weight-Total	7722.0 lb
Tie Reinforcement	
Quantity-Per Pier	22
Quantity-Total	66
Size	#4
Total Length	125.5"
Weight-Per Pier	154.0 lb
Weight-Total	462.0 lb

Preliminary Design, DO NOT INSTALL
Concrete compressive strength, fc: 4500 psi
Submitted Soil Report (Rock conditions at 0.5 ft.)

* Not to scale, shown with typical reinforcement pattern



Corporate Headquarters



211 W. Washington St. Suite 2000 South Bend, IN 46601 Phone: (800) 806-3556 Fax: 574-288-5860 www.nelloinc.com

- CLASSIFICATION SUMMARY -

EXPOSURE CATEGORIES

*Default: Exposure C

Exposure categories consider the surface roughness of the ground. Roughness is determined by type and prevalence of ground obstructions such as general topography, vegetation and constructed features that will decrease wind speed near the ground.

- Exposure B: Terrain characterized by the prevalence of crowded obstructions such as urban, suburban or wooded landscapes. Surface features must be of comparable size to single-family homes or larger. Such consistent terrain must encircle the tower for the greater distance of a minimum 2,600 ft or 20 times the height of the tower.
- **Exposure C:** Terrain characterized by an open landscape with dispersed obstructions generally less than 30 ft in height such as open country, grasslands and shorelines in hurricane prone regions. Includes sites within Exposure B terrain where it is located less than 20 times the height of the structure from but more than 2 miles from terrain consistent with Exposure D.
- **Exposure D:** Terrain characterized by flat, unobstructed shorelines susceptible to winds moving across open water for a minimum distance of 1 mile (non-hurricane regions). This terrain includes inland waterways, lakes, non-hurricane coastal areas, mud flats, salt flats and those alike. This exposure applies inland for the greater distance of 660 ft or 20 times the height of the tower.

STRUCTURE CLASSIFICATION

*Default: Class II

Structure classes consider the risk if critical failure were to occur to a specific tower. These risks are based upon the height, use or location of the tower.

- Class I: Risk represents a low hazard to human life and property damage. Tower importance is consistent with services that are not required or where a delay in returning services is permissible. [e.g. residential wireless and conventional 2-way radio communications; television, radio and scanner reception: wireless cable: amateur and CB radio communications]
- Class II: Risk represents a significant hazard to human life and/or property damage. Tower importance is consistent with services that may be supported in another manner. [e.g. commercial wireless communications; television and radio broadcasting; cellular, PCS, CATV, and microwave communications]
- Class III: Risk represents a substantial hazard to human life and/or property damage. Tower importance is consistent with services that are predominantly used for essential purposes. [e.g. civil or national defense; emergency, rescue or disaster operations; military and navigation facilities]

DAS-OIT223 - BUTLER GUYED TOWER REPLACEMENT SECTION 01 50 00 - COAX CABLE SPECIFICATIONS



AVA5-50, HELIAX® Andrew Virtual Air™ Coaxial Cable, corrugated copper, 7/8 in, black PE jacket (Halogen free jacketing non-fire-retardant)

Product Classification

Product Type Coaxial wireless cable

Product Brand HELIAX®
Product Series AVA5-50

Ordering Note CommScope® standard product (Global)

General Specifications

Flexibility Standard

Jacket Color Black

Specification Sheet Revision Level B

Dimensions

 Diameter Over Dielectric
 24.13 mm | 0.95 in

 Diameter Over Jacket
 27.991 mm | 1.102 in

 Inner Conductor OD
 9.449 mm | 0.372 in

 Outer Conductor OD
 25.4 mm | 1 in

Nominal Size 7/8 in

Electrical Specifications

Cable Impedance 50 ohm ±1 ohm

Capacitance 73 pF/m | 22.25 pF/ft

dc Resistance, Inner Conductor1.435 ohms/km| 0.437 ohms/kftdc Resistance, Outer Conductor1.116 ohms/km| 0.34 ohms/kft

dc Test Voltage 6000 V

Inductance 0.184 μ H/m | 0.056 μ H/ft

Insulation Resistance 100000 Mohms•km

Page 1 of 5



AVA5-50

Jacket Spark Test Voltage (rms) 8000 V

Operating Frequency Band 1 – 5000 MHz

 Peak Power
 91 kW

 Velocity
 91 %

VSWR/Return Loss

Frequency Band	VSWR	Return Loss (dB)
680-800 MHz	1.13	24.3
800-960 MHz	1.13	24.3
1700-2200 MHz	1.13	24.3

Attenuation

Frequency (MHz)	Attenuation (dB/100 m)	Attenuation (dB/100 ft)	Average Power (kW)
1.0	0.113	0.034	74.43
1.5	0.138	0.042	60.73
2.0	0.16	0.049	52.56
10.0	0.359	0.11	23.37
20.0	0.51	0.156	16.46
30.0	0.627	0.191	13.39
50.0	0.814	0.248	10.32
85.0	1.068	0.326	7.86
88.0	1.088	0.332	7.72
100.0	1.162	0.354	7.23
108.0	1.209	0.368	6.95
150.0	1.433	0.437	5.86
174.0	1.548	0.472	5.43
200.0	1.665	0.507	5.05
204.0	1.682	0.513	4.99
300.0	2.059	0.628	4.08
400.0	2.398	0.731	3.5
450.0	2.553	0.778	3.29
460.0	2.583	0.787	3.25
500.0	2.7	0.823	3.11
512.0	2.735	0.834	3.07
600.0	2.977	0.907	2.82

Page 2 of 5



AVA5-50

700.0	3.235	0.986	2.6
800.0	3.478	1.06	2.42
824.0	3.534	1.077	2.38
894.0	3.694	1.126	2.27
960.0	3.841	1.171	2.19
1000.0	3.927	1.197	2.14
1218.0	4.377	1.334	1.92
1250.0	4.44	1.353	1.89
1500.0	4.912	1.497	1.71
1700.0	5.268	1.605	1.59
1794.0	5.429	1.655	1.55
1800.0	5.439	1.658	1.54
2000.0	5.771	1.759	1.46
2100.0	5.933	1.808	1.42
2200.0	6.091	1.856	1.38
2300.0	6.247	1.904	1.34
2500.0	6.55	1.996	1.28
2700.0	6.845	2.086	1.23
3000.0	7.272	2.217	1.15
3400.0	7.819	2.383	1.07
3600.0	8.083	2.464	1.04
3700.0	8.213	2.503	1.02
3800.0	8.342	2.542	1.01
3900.0	8.47	2.581	0.99
4000.0	8.596	2.62	0.98
4100.0	8.722	2.658	0.96
4200.0	8.846	2.696	0.95
4300.0	8.969	2.734	0.94
4400.0	9.092	2.771	0.92
4500.0	9.213	2.808	0.91
4600.0	9.333	2.845	0.9
4700.0	9.453	2.881	0.89
4800.0	9.572	2.917	0.88
4900.0	9.689	2.953	0.87
5000.0	9.806	2.989	0.86

AVA5-50

Material Specifications

Dielectric Material Foam PE

Jacket Material PE

Inner Conductor Material Copper tube

Outer Conductor Material Corrugated copper

Mechanical Specifications

Minimum Bend Radius, multiple Bends254 mm | 10 inMinimum Bend Radius, single Bend127 mm | 5 in

Number of Bends, minimum 15 Number of Bends, typical 30

 Tensile Strength
 159 kg | 350.535 lb

 Bending Moment
 19 N-m | 168.164 in lb

 Flat Plate Crush Strength
 1.3 kg/mm | 72.797 lb/in

Environmental Specifications

Installation temperature $-40 \, ^{\circ}\text{C}$ to $+60 \, ^{\circ}\text{C}$ ($-40 \, ^{\circ}\text{F}$ to $+140 \, ^{\circ}\text{F}$)Operating Temperature $-55 \, ^{\circ}\text{C}$ to $+85 \, ^{\circ}\text{C}$ ($-67 \, ^{\circ}\text{F}$ to $+185 \, ^{\circ}\text{F}$)Storage Temperature $-70 \, ^{\circ}\text{C}$ to $+85 \, ^{\circ}\text{C}$ ($-94 \, ^{\circ}\text{F}$ to $+185 \, ^{\circ}\text{F}$)

Attenuation, Ambient Temperature68 °F | 20 °CAverage Power, Ambient Temperature104 °F | 40 °CAverage Power, Inner Conductor Temperature212 °F | 100 °C

Packaging and Weights

Cable weight 0.45 kg/m | 0.302 lb/ft

Regulatory Compliance/Certifications

Agency	Classification
CENELEC	EN 50575 compliant, Declaration of Performance (DoP) available
CHINA-ROHS	Below maximum concentration value
ISO 9001:2015	Designed, manufactured and/or distributed under this quality management system
REACH-SVHC	Compliant as per SVHC revision on www.commscope.com/ProductCompliance
ROHS	Compliant



AVA5-50











AVA7-50, HELIAX® Andrew Virtual Air™ Coaxial Cable, corrugated copper, 1-5/8 in, black PE jacket (Halogen free jacketing non-fire-retardant)

Product Classification

Product Type Coaxial wireless cable

Product Brand HELIAX®
Product Series AVA7-50

Ordering Note CommScope® standard product in Asia Pacific | CommScope® standard

product in Europe, the Middle East, and Africa | CommScope® standard product in Mexico, Central America, and South America | CommScope®

standard product in the United States and Canada

General Specifications

Flexibility Standard

Jacket Color Black

Dimensions

 Diameter Over Dielectric
 44.45 mm | 1.75 in

 Diameter Over Jacket
 51.054 mm | 2.01 in

 Inner Conductor OD
 18.161 mm | 0.715 in

 Outer Conductor OD
 46.355 mm | 1.825 in

Nominal Size 1-5/8 in

Electrical Specifications

Cable Impedance50 ohm ±1 ohm

Capacitance 72.2 pF/m | 22.007 pF/ft

dc Resistance, Inner Conductor1.435 ohms/km0.437 ohms/kftdc Resistance, Outer Conductor0.525 ohms/km0.16 ohms/kft

dc Test Voltage 15000 V

Inductance 0.187 μ H/m | 0.057 μ H/ft

COMMSCOPE®

AVA7-50

Insulation Resistance 100000 Mohms•km

Jacket Spark Test Voltage (rms) 10000 V

Operating Frequency Band 1 – 2700 MHz

 $\begin{tabular}{lll} \begin{tabular}{lll} \begin{$

VSWR/Return Loss

Frequency Band	VSWR	Return Loss (dB)
680-800 MHz	1.13	24.3
806-960 MHz	1.13	24.3
1700-2170 MHz	1.13	24.3

Attenuation

Frequency (MHz)	Attenuation (dB/100 m)	Attenuation (dB/100 ft)	Average Power (kW)
1.0	0.062	0.019	117.56
1.5	0.076	0.023	95.88
2.0	0.088	0.027	82.96
10.0	0.197	0.06	36.78
20.0	0.281	0.086	25.84
30.0	0.346	0.105	21
50.0	0.45	0.137	16.14
85.0	0.593	0.181	12.25
88.0	0.603	0.184	12.03
100.0	0.645	0.197	11.26
108.0	0.672	0.205	10.81
150.0	0.798	0.243	9.09
174.0	0.864	0.263	8.41
200.0	0.93	0.284	7.81
204.0	0.94	0.287	7.72
300.0	1.156	0.352	6.28
400.0	1.351	0.412	5.37
450.0	1.441	0.439	5.04
460.0	1.459	0.445	4.98
500.0	1.527	0.465	4.76
512.0	1.547	0.471	4.69

Page 2 of 4



AVA7-50

600.0	1.689	0.515	4.3
700.0	1.84	0.561	3.95
800.0	1.982	0.604	3.66
824.0	2.016	0.614	3.6
894.0	2.11	0.643	3.44
960.0	2.197	0.67	3.3
1000.0	2.249	0.685	3.23
1218.0	2.517	0.767	2.89
1250.0	2.554	0.779	2.84
1500.0	2.838	0.865	2.56
1700.0	3.053	0.93	2.38
1794.0	3.151	0.96	2.3
1800.0	3.157	0.962	2.3
2000.0	3.359	1.024	2.16
2100.0	3.457	1.054	2.1
2200.0	3.554	1.083	2.04
2300.0	3.649	1.112	1.99
2500.0	3.836	1.169	1.89
2700.0	4.017	1.224	1.81

Material Specifications

Dielectric Material Foam PE

Jacket Material PE

Inner Conductor Material Corrugated copper tube

Outer Conductor Material Corrugated copper

Mechanical Specifications

Minimum Bend Radius, multiple Bends381 mm | 15 inMinimum Bend Radius, single Bend203.2 mm | 8 in

Number of Bends, minimum 15 Number of Bends, typical 50

 Tensile Strength
 181 kg | 399.036 lb

 Bending Moment
 47.5 N-m | 420.41 in lb

 Flat Plate Crush Strength
 1.6 kg/mm | 89.596 lb/in



AVA7-50

Environmental Specifications

Installation temperature $-40 \,^{\circ}\text{C}$ to $+60 \,^{\circ}\text{C}$ ($-40 \,^{\circ}\text{F}$ to $+140 \,^{\circ}\text{F}$)

Operating Temperature $-55 \,^{\circ}\text{C}$ to $+85 \,^{\circ}\text{C}$ ($-67 \,^{\circ}\text{F}$ to $+185 \,^{\circ}\text{F}$)

Storage Temperature $-70 \,^{\circ}\text{C}$ to $+85 \,^{\circ}\text{C}$ ($-94 \,^{\circ}\text{F}$ to $+185 \,^{\circ}\text{F}$)

Attenuation, Ambient Temperature $68 \,^{\circ}\text{F}$ | $20 \,^{\circ}\text{C}$ Average Power, Ambient Temperature $104 \,^{\circ}\text{F}$ | $40 \,^{\circ}\text{C}$ Average Power, Inner Conductor Temperature $212 \,^{\circ}\text{F}$ | $100 \,^{\circ}\text{C}$

Packaging and Weights

Cable weight 1.07 kg/m | 0.719 lb/ft

Regulatory Compliance/Certifications

Agency	Classification

CENELEC EN 50575 compliant, Declaration of Performance (DoP) available

CHINA-ROHS Below maximum concentration value

ISO 9001:2015 Designed, manufactured and/or distributed under this quality management system
REACH-SVHC Compliant as per SVHC revision on www.commscope.com/ProductCompliance

ROHS Compliant





LDF4-50A, HELIAX® Low Density Foam Coaxial Cable, corrugated copper, 1/2 in, black PE jacket (Halogen free jacketing non-fire-retardant)

Product Classification

Product Type Coaxial wireless cable

Product Brand HELIAX®
Product Series LDF4-50A

Ordering Note CommScope® standard product (Global)

General Specifications

Flexibility Standard

Jacket Color Black

Dimensions

 Diameter Over Dielectric
 12.954 mm | 0.51 in

 Diameter Over Jacket
 15.875 mm | 0.625 in

 Inner Conductor OD
 4.826 mm | 0.19 in

 Outer Conductor OD
 13.97 mm | 0.55 in

Nominal Size 1/2 in

Electrical Specifications

Cable Impedance50 ohm ±1 ohm

 $\textbf{Capacitance} \hspace{1.5cm} 75.8 \text{ pF/m} \hspace{0.1cm} | \hspace{0.1cm} 23.104 \text{ pF/ft}$

dc Resistance, Inner Conductor1.48 ohms/km | 0.451 ohms/kftdc Resistance, Outer Conductor2.69 ohms/km | 0.82 ohms/kft

dc Test Voltage 4000 V

 $\label{eq:local_$

Insulation Resistance 100000 Mohms•km

Jacket Spark Test Voltage (rms) 8000 V

Page 1 of 5



Operating Frequency Band 1 – 8800 MHz

 Peak Power
 40 kW

 Velocity
 88 %

VSWR/Return Loss

Frequency Band	VSWR	Return Loss (dB)
680-800 MHz	1.13	24.3
800-960 MHz	1.13	24.3
1700-2200 MHz	1.13	24.3
2300-2700 MHz	1.13	24.3
3400-3800 MHz	1.26	19

Attenuation

Frequency (MHz)	Attenuation (dB/100 m)	Attenuation (dB/100 ft)	Average Power (kW)
1.0	0.211	0.064	36.11
1.5	0.259	0.079	29.46
2.0	0.299	0.091	25.5
10.0	0.672	0.205	11.35
20.0	0.954	0.291	7.99
30.0	1.172	0.357	6.51
50.0	1.521	0.463	5.02
85.0	1.995	0.608	3.82
88.0	2.031	0.619	3.76
100.0	2.169	0.661	3.52
108.0	2.256	0.688	3.38
150.0	2.673	0.815	2.85
174.0	2.887	0.88	2.64
200.0	3.103	0.946	2.46
204.0	3.135	0.956	2.43
300.0	3.835	1.169	1.99
400.0	4.462	1.36	1.71
450.0	4.749	1.447	1.61
460.0	4.804	1.464	1.59
500.0	5.021	1.53	1.52
512.0	5.085	1.55	1.5

Page 2 of 5



600.0	5.533	1.686	1.38
700.0	6.009	1.831	1.27
800.0	6.456	1.968	1.18
824.0	6.56	1.999	1.16
894.0	6.855	2.089	1.11
960.0	7.124	2.171	1.07
1000.0	7.284	2.22	1.05
1218.0	8.11	2.472	0.94
1250.0	8.226	2.507	0.93
1500.0	9.093	2.771	0.84
1700.0	9.744	2.97	0.78
1794.0	10.039	3.06	0.76
1800.0	10.058	3.066	0.76
2000.0	10.666	3.251	0.72
2100.0	10.961	3.341	0.7
2200.0	11.251	3.429	0.68
2300.0	11.535	3.516	0.66
2500.0	12.09	3.685	0.63
2700.0	12.627	3.849	0.6
3000.0	13.407	4.086	0.57
3400.0	14.401	4.389	0.53
3600.0	14.882	4.536	0.51
3700.0	15.118	4.608	0.5
3800.0	15.353	4.679	0.5
3900.0	15.585	4.75	0.49
4000.0	15.815	4.82	0.48
4100.0	16.042	4.889	0.48
4200.0	16.268	4.958	0.47
4300.0	16.492	5.027	0.46
4400.0	16.714	5.094	0.46
4500.0	16.934	5.161	0.45
4600.0	17.153	5.228	0.44
4700.0	17.37	5.294	0.44
4800.0	17.585	5.36	0.43
4900.0	17.798	5.425	0.43

5000.0	18.01	5.489	0.42
6000.0	20.055	6.113	0.38
8000.0	23.826	7.262	0.32
8800.0	25.244	7.694	0.3

Material Specifications

Dielectric Material Foam PE

Jacket Material PE

Inner Conductor Material Copper-clad aluminum wire

Outer Conductor Material Corrugated copper

Mechanical Specifications

Minimum Bend Radius, multiple Bends127 mm | 5 inMinimum Bend Radius, single Bend50.8 mm | 2 in

Number of Bends, minimum15Number of Bends, typical50

 Tensile Strength
 113 kg | 249.122 lb

 Bending Moment
 3.8 N-m | 33.633 in lb

 Flat Plate Crush Strength
 2 kg/mm | 111.995 lb/in

Environmental Specifications

Installation temperature $-40 \,^{\circ}\text{C to} +60 \,^{\circ}\text{C (}-40 \,^{\circ}\text{F to} +140 \,^{\circ}\text{F)}$ Operating Temperature $-55 \,^{\circ}\text{C to} +85 \,^{\circ}\text{C (}-67 \,^{\circ}\text{F to} +185 \,^{\circ}\text{F)}$ Storage Temperature $-70 \,^{\circ}\text{C to} +85 \,^{\circ}\text{C (}-94 \,^{\circ}\text{F to} +185 \,^{\circ}\text{F)}$

Attenuation, Ambient Temperature68 °F | 20 °CAverage Power, Ambient Temperature104 °F | 40 °CAverage Power, Inner Conductor Temperature212 °F | 100 °C

Packaging and Weights

 $\textbf{Cable weight} \hspace{1.5cm} 0.22 \text{ kg/m} \hspace{0.2cm} \mid \hspace{0.2cm} 0.148 \text{ lb/ft}$

Regulatory Compliance/Certifications

Agency Classification

CENELEC EN 50575 compliant, Declaration of Performance (DoP) available

CHINA-ROHS Below maximum concentration value

Page 4 of 5



ISO 9001:2015

Designed, manufactured and/or distributed under this quality management system

REACH-SVHC

Compliant as per SVHC revision on www.commscope.com/ProductCompliance

ROHS Compliant







DAS-OIT223 - BUTLER GUYED TOWER REPLACEMENT SECTION 01 60 00 - FAA LIGHTING SPECIFICATIONS



Vanguard® Medium FTS 372 Lighting System

The Vanguard Medium FTS 372 is a medium intensity lighting system for structures between 200' and 700' AGL. It is configurable for FAA Type E (red/white), D (white) and A (red) applications and uses RS-485 for reliable communication and trouble-free operation.

Designed to be robust and easy to use, the FTS 372 does not require binding operations. The firmware for all components on the tower can be remotely updated, eliminating the cost of site visits. The IP66 rated enclosures house a low voltage environment, making it safer for technicians to service during active operation.

Regulatory Compliance

The Vanguard Medium FTS 372 is certified to FAA AC 150/5345-43J as an L-864/L-865 medium intensity light. It also meets FAA L-885 low intensity catenary requirements and complies with ICAO (Medium Intensity Type A/Type B) and Transport Canada CAR 621 (CL-864/CL-865).



Standard Features

- Infrared (IR) lighting NVG/NVIS compatibility per FAA AC 150/5345-43J
- 7 Industry-leading 25kA surge suppression rating, protecting against 99% of lightning strikes when properly installed and grounded
- Interleaved LEDs and by-pass circuitry provide longer life by compensating for individual LED loss
- 7 Patented Fresnel optics minimizes ground scatter to surrounding community
- RS-485 communication allows for remote firmware upgrades to all tower devices, reducing unnecessary site visits and tower climbs
- Multi-flashhead systems require only two enclosures, reducing the mounting footprint and simplifying installation
- 7 Internal power breaker switch to enhance technician safety
- 4-line OLED backlit display for visibility in any lighting conditions
- 7 Dry contact monitoring (day, night, marker, PHD, GPS, comm alarms and mode status)
- Compliant with FAA AC 70/7460-1M
- 5-year warranty

System Options

- SMART Capability monitor and control the system remotely, and receive full diagnostic information through LTE modem or Ethernet-based connectivity. SNMP, Modbus or Eagle protocols may be used.
- **7** GPS mode change fail-safe protects the community against light pollution, in the event of a photodiode failure
- SMART battery back-up controller to monitor battery health
- → Outdoor Wi-Fi antenna for onsite diagnostics and lighting inspections
- LTE modem for improved communication stability


Vanguard® Medium FTS 372

SPECIFICATIONS	
	FAA AC 150/5345-43J L-864, L-865, L-885
	ICAO Annex 14 Medium Intensity Types A and B
Regulatory Compliance	Transport Canada CAR 621 CL-864, CL-865
	CSA
	CE
Input Voltage	100-240 VAC, 277 VAC
	±48 VDC (optional)
Frequency	50-60 Hz
FH Dimensions	15.8 dia. x 7.3" (401 dia. x 185 mm)
FH Weight	26.3 lbs. (11.9 kg)
FH Aerodynamic Wind Area	0.7 ft ² (0.2 m ²)
Marker Dimensions	9 x 2.8 x 2.1" (228 x 69 x 54 mm)
Marker Weight	1.6 lbs. (0.7 kg)
Controller Dimensions	23.8 x 17.5 x 8.5" (584 x 434 x 162 mm)
Controller Weight	44 lbs. (20 kg)
Protection Rating	IP66

SPECIFICATIONS CONT			
Power Converter Dimensions	23.8 x 17.5 x 8.5" (584 x 434 x 162 mm)		
Power Converter Weight	1 Flashhead	27 lbs.	
	2 Flashhead	37 lbs.	
	3 Flashhead	47 lbs.	
Protection Rating	IP66		

POWER CONSUMPTION				
	Mode	Wattage	Flash Rate*	Flash Intensity
1 065	Day (white)	81	40 fpm	20,000 +/- 25%
L-865	Night (white)	27	40 fpm	2,000 +/- 25%
L-864	Night (red)	36	20/30/40/60 fpm	2,000 +/- 25%
L-810	Night (red)	7.1	Steady	>32
L-010	Night (red)/infrared	1.5	30 fpm	>32

FAA AC 70/7460-1M TOWER LIGHTING



^{*} Only 30 fpm is applicable for FAA-certified applications filed under AC 70/7460-1M.

FLASH TECHNOLOGY 78