



# M Consultants, LLC

26F202 DRC Mansfield Correctional Electrical Upgrades  
1150 N Main St.  
Mansfield, OH 44905

Addendum 1 (04/20/2026)

Due to the issuance of this addendum the Bid date for project number 26F202 will be extended to Thursday 4/30/2026.

Drawing revisions:

**Sheet E101:**

1. Revise coded not 2 to call for directional boring of new feeds.

**Sheet E601:**

1. Revise utility disconnect fuse to 200E.

**Sheet E601A:**

1. Revise utility disconnect fuse to 200E.
2. Revise T-2E transformer to 2000KVA.
3. Revise coded notes 4 and 5 to call for MV105 cables

**Sheet E604:**

1. Add sheets for new fence details.

Specification revisions:

**Spec 26 05 13:**

1. Remove Arc Proofing from specification.
2. Add callout for cold water heat trace in parking level.
3. Add coded note 11.

**Spec 26 12 00:**

1. Add spec section for medium voltage stepdown transformer.

**Spec 26 13 00:**

1. Add ABB and Eaton to spec.
2. Remove reference to spec section 26 23 13
1. Remove wall phone from elevator lobby.
2. Add general note 7.
3. Revise coded note 6.